

PDWP-Camden Co.

Big Island

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

DIVISION OF ENVIRONMENTAL QUALITY

Jefferson City Regional Office

210 Howell Road P.O. Box 176 Jefferson City, MO 65102-0176

(573) 751-2729

FAX (573) 751-2000

FILED²

APR 02 2007

May 25, 1999

**Missouri Public
Service Commission**

**CERTIFIED MAIL # Z 290 136 189
RETURN RECEIPT REQUESTED**

Fulsum Ridgelle dba Big Island
c/o David Lee, Management
HCR 67, Box 680
Roach, MO 65787

Dear Mr. Lee:

Enclosed is a Notice of Violation number 1315 JC being issued to Fulsum Ridgelle dba Big Island for failure to construct water lines and sewer lines in accordance with approved plans. On April 23, 1999, inspection of work being conducted on the water and wastewater lines for the Big Island in Camden County found illegal water and sewer mains being constructed. Instead of constructing individual one-inch PVC service lines for water and wastewater to each home, one inch lines were being placed to serve up to three homes. This would make the lines by definition water and wastewater mains, which have to be at least two-inch PVC and receive prior approval by the Department.

You stated at the time of my inspection that the change from single service lines to lines serving up to three homes was a misunderstanding of the requirements and what was approved. You have since stated to me that all work has been corrected. To resolve this matter, written certification needs to be submitted by your engineer verifying that all water and wastewater construction was corrected /completed in conformance with approved plans. Also, I noted that the water and wastewater service lines were being placed in the same trench. Separation of water and sewer service lines should meet national plumbing code standards.


Dugh Exhibit No. 59
Case No(s) WC-2006-0082 et al
Date 3-01-07 Rptr RP

Mr. David Lee
May 25, 1999
Page Two

I appreciate your cooperation in this matter. If you have any questions regarding this matter, please contact me at (573) 751-2729.

Sincerely,

JEFFERSON CITY REGIONAL OFFICE



Stephen P. Jones, P.E.
Environmental Engineer

SPJ/bg

Enclosure

c: John MacEachen, Public Drinking Water Program
Breck Summerford, Public Drinking Water Program
Jerry Croy, JCRO



MISSOURI DEPARTMENT OF NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL QUALITY
NOTICE OF VIOLATION

P.O. BOX 176
JEFFERSON CITY, MO 65102

VIOLATION NUMBER

1315 JC

DATE AND TIME ISSUED

May 25, 1999

☐ A.M.

☐ P.M.

SOURCE (NAME, ADDRESS, PERMIT NUMBER, LOCATION)

Pulsar Bionelle dba Big Island

MAILING ADDRESS

HCR 67, Box 680

CITY

Roach

STATE

MO

ZIP CODE

65787

NAME OF OWNER OR MANAGER

David Lee

TITLE OF OWNER OR MANAGER

Manager

LAW, REGULATION OR PERMIT VIOLATED

Construction of a sewer main without a permit 10 CSR 20-5.010(1)(A) & (4)(A)

Construction of a water main without a permit 10 CSR 60-3.010(1)(A)

NATURE OF VIOLATION

DATE(S):

April 23, 1999

TIME(S):

Construction of illegal water and wastewater mains.

SIGNATURE (PERSON RECEIVING NOTICE)

SIGNATURE (PERSON ISSUING NOTICE)

TITLE OR POSITION

TITLE OR POSITION/DNR REGION

Environmental Engineer