


FILED 4



Contact Us E-
[Employment](#) [Services](#) [Residents](#) [Visitors](#) [Business](#) [Neighborhoods](#) [Mayor/Council](#) [Home](#)

KCMO - FINISHED WATER 2002

[Home](#) | [Information](#) | [Bottled Water](#) | [Wet Weather Program](#) | [Brookside Improvements](#) | [Catch Basin Replacement](#)

	UNITS	MDL	FED. LIMIT	MAX	MIN	AVG
GENERAL CHEMISTRY						
ALKALINITY, PHENOL	ppm	0		35	4	16
ALKALINITY, TOTAL	ppm	0		80	25	37
ALUMINUM	ppm	0.01		ND	ND	ND
AMMONIA	ppm	0.010		0.501	0.031	0.132
ASBESTOS	mf/L	0.19	7	ND	ND	ND
BROMIDE	ppm	0.03		ND	ND	ND
CALCIUM	ppm			50.7	25.7	33.7
CHLORIDE	ppm	0.04		35	15	24
CHLORINE, FREE	ppm	0.00		0.90	ND	0.24
CHLORINE, TOTAL (CHLORAMINE)	ppm	0.00	MRDL=4	2.76	1.70	2.29
COLOR	su	1		1	1	1
CONDUCTIVITY	umhos/cm			759	391	539
CYANIDE	ppm	0.006	0.2	0.039	ND	0.012
DISSOLVED OXYGEN	su	0.1		14.2	7.3	10.1
FLUORIDE IC	ppm	0.01	4	1.52	0.30	1.06
FLUORIDE, ELEC	ppm	0.05	4	1.40	0.25	1.02
HARDNESS, TOTAL	ppm	1		155	86	109
IRON	ppm	0.006		0.120	ND	BQL
MAGNESIUM	ppm	0.13		32.3	2.61	5.98
NITRATE	ppm	0.03	10	2.87	ND	0.96
NITRITE	ppm	0.010	1	ND	ND	ND
ODOR	ton	1		8	1	3
PERCHLORATE	ppb	4		ND	ND	ND
PH	su			10.5	9.2	9.9
PHENOL	ppm	0.001		0.045	ND	0.004
PHOSPHATE, ORTHO	ppm	0.01		0.52	0.01	0.16
PHOSPHATE, TOTAL	ppm	0.01		0.95	0.18	0.49
SILICA	ppm			5.77	1.70	3.52
SOLIDS, TOTAL	ppm	1		870	150	387

Exhibit No. 27
 Case No(s). EO 2005-0329
 Date 6-03-05 Rptr KF

Exhibit 27
 Case No. EO-2005-0329
 In re Proposed Experimental Regul. Plan of KCPL
 Mo. Public Service Comm'n

SULFATE	ppm	0.10		223	112	175
SURFACTANT	ppm	0.005		0.103	ND	0.011
TASTE		0		3	0	0
TEMPERATURE	deg F			89.3	39.1	59.9
TOC	ppm	0.10	TT	2.95	1.58	2.01
TURBIDITY	ntu	0.01	TT	0.8	0.03	0.13
UV 254	au	0.001		0.065	0.029	0.044

MICROBIOLOGICAL

COLIFORM, TOTAL	cfu/100ml	1		ND	ND	ND
CRYPTOSPORIDIA	/100L	0.3	TT	0.4	ND	ND
FECAL STREP	cfu/100ml	1		ND	ND	ND
GIARDIA	/100L	0.3	TT	ND	ND	ND
PLATE COUNT, HETEROTROPHIC	cfu/ml	1	TT	116	ND	2
ADENOVIRUS	ICC/nPCR					ND
ASTROVIRUS	ICC/nPCR					ND
ENTEROVIRUSES	ICC/nPCR		TT			ND
HEPATITIS A	ICC/nPCR					ND
ROTAVIRUS	ICC/nPCR					ND

VOCs

1,1,1-TRICHLOROETHANE	502.2	ppb	0.5	200	ND	ND	ND
1,1,2-TRICHLOROETHANE	502.2	ppb	0.5	5	ND	ND	ND
1,1-DICHLOROETHENE	502.2	ppb	0.5	7	ND	ND	ND
1,2,4-TRICHLOROBENZENE	502.2	ppb	0.5	70	ND	ND	ND
1,2-DICHLOROETHANE	502.2	ppb	0.5	5	ND	ND	ND
1,2-DICHLOROPROPANE	502.2	ppb	0.5	5	ND	ND	ND
BENZENE	502.2	ppb	0.5	5	ND	ND	ND
BROMODICHLOROMETHANE	502.2	ppb	0.5	**	4.9	ND	BQL
BROMOFORM	502.2	ppb	0.5	**	0.6	ND	ND
CARBON TETRACHLORIDE	502.2	ppb	0.5	5	ND	ND	ND
CHLOROBENZENE	502.2	ppb	0.5	100	ND	ND	ND
CHLOROFORM	502.2	ppb	0.5	**	31.8	ND	6.0
CIS-1,2 DICHLOROETHENE	502.2	ppb	0.5	70	ND	ND	ND
DIBROMOCHLOROMETHANE	502.2	ppb	0.5	**	0.6	ND	ND
DICHLOROMETHANE	502.2	ppb	0.5	5	ND	ND	ND
ETHYLBENZENE	502.2	ppb	0.5	700	ND	ND	ND
ORTHO-DICHLOROBENZENE	502.2	ppb	0.5	600	ND	ND	ND
PARA-DICHLOROBENZENE	502.2	ppb	0.5	75	ND	ND	ND
STYRENE	502.2	ppb	0.5	100	ND	ND	ND
TETRACHLOROETHENE	502.2	ppb	0.5	5	ND	ND	ND
TOLUENE	502.2	ppb	0.5	1000	ND	ND	ND
TRANS-1,2 DICHLOROETHENE	502.2	ppb	0.5	100	ND	ND	ND
TRICHLORETHENE	502.2	ppb	0.5	5	ND	ND	ND
XYLENE, META & PARA	502.2	ppb	0.5		ND	ND	ND

XYLENE, ORTHO	502.2	ppb	0.5		ND	ND	ND
XYLENE, TOTAL	502.2	ppb	0.5	10000	ND	ND	ND
VINYL CHLORIDE	502.2	ppb	0.5	2	ND	ND	ND

* **thm compounds

ORGANICS

1,1,1,2-TETRACHLOROETHANE	524	ppb	0.5		ND	ND	ND
1,1,1-TRICHLOROETHANE	524	ppb	0.5	200	ND	ND	ND
1,1,2,2-TETRACHLOROETHANE	524	ppb	0.5		ND	ND	ND
1,1,2-TRICHLOROETHANE	524	ppb	0.5	5	ND	ND	ND
1,1-DICHLOROETHANE	524	ppb	0.5		ND	ND	ND
1,1-DICHLOROETHENE	524	ppb	0.5	7	ND	ND	ND
1,1-DICHLOROPROPENE	524	ppb	0.5		ND	ND	ND
1,2,3-TRICHLOROBENZENE	524	ppb	0.5		ND	ND	ND
1,2,3-TRICHLOROPROPANE	524	ppb	0.5		ND	ND	ND
1,2,4-TRICHLOROBENZENE	524	ppb	0.5	70	ND	ND	ND
1,2,4-TRIMETHYLBENZENE	524	ppb	0.5		ND	ND	ND
1,2-DIBROMO-3-CHLOROPROPANE	504	ppb	0.0	0.2	ND	ND	ND
1,2-DIBROMO-3-CHLOROPROPANE	524	ppb	0.5	0.2	ND	ND	ND
1,2-DIBROMOMETHANE	524	ppb	0.5		ND	ND	ND
1,2-DICHLOROBENZENE (O)	524	ppb	0.5	600	ND	ND	ND
1,2-DICHLOROETHANE	524	ppb	0.5	5	ND	ND	ND
1,2-DICHLOROPROPANE	524	ppb	0.5	5	ND	ND	ND
1,2-DIPHENYLHYDRAZ	526	ppb	0.12		ND	ND	ND
1,3,5-TRIMETHYLBENZENE	524	ppb	0.5		ND	ND	ND
1,3-DICHLOROBENZENE	524	ppb	0.5		ND	ND	ND
1,3-DICHLOROPROPANE	524	ppb	0.5		ND	ND	ND
1,4-DICHLOROBENZENE (P)	524	ppb	0.5	75	ND	ND	ND
2,2-DICHLOROPROPANE	524	ppb	0.5		ND	ND	ND
2,4,5-T	515	ppb	0.2		ND	ND	ND
2,4,5-TP (SILVEX)	515	ppb	0.35	50	ND	ND	ND
2,4,6-TRICHLOROPHEN	526	ppb	0.14		ND	ND	ND
2,4-D	515	ppb	0.28	70	ND	ND	ND
2,4-DB	515	ppb	1.74		ND	ND	ND
2,4-DICHLOROPHENOL	526	ppb	0.1		ND	ND	ND
2,4-DINITROTOLUENE	525	ppb	0.40		ND	ND	ND
2,6-DINITROTOLUENE	525	ppb	0.21		ND	ND	ND
2-CHLOROTOLUENE	524	ppb	0.5		ND	ND	ND
3,5-DICHLOROBENZOIC ACID	515	ppb	0.24		ND	ND	ND
3-HYDROXYCARBOFURAN	531	ppb	0.5		ND	ND	ND
4-CHLOROTOLUENE	524	ppb	0.5		ND	ND	ND
4-ISOPROPYLTOLUENE	524	ppb	0.5		ND	ND	ND
4-NITROPHENOL	515	ppb	0.26		ND	ND	ND
A-BHC	508	ppb	0.03		ND	ND	ND
ACENAPHTHALENE	525	ppb	0.18		ND	ND	ND
ACETOCHLOR	526	ppb	0.21		1.3	ND	BQL
ACIFLUORFEN	515	ppb	0.26		ND	ND	ND
ALACHLOR (LASSO)	507	ppb	0.06	2	0.2	ND	ND
ALDICARB	531	ppb	0.6		ND	ND	ND

ALDICARB SULFONE	531	ppb	0.6		ND	ND	ND
ALDICARB SULFOXIDE	531	ppb	0.6		ND	ND	ND
ALDRIN	508	ppb	0.054		ND	ND	ND
ALPHA-CHLORDANE	508	ppb	0.019		ND	ND	ND
ANTHRACENE	525	ppb	0.23		ND	ND	ND
ATRAZINE (AATREX)	507	ppb	0.08	3	8.7	ND	0.9
B-BHC	508	ppb	0.028		ND	ND	ND
BENEFIN (BALAN)	507	ppb	0.14		ND	ND	ND
BENTAZON	515	ppb	0.41		ND	ND	ND
BENZ(A)ANTHRACENE	525	ppb	0.14		ND	ND	ND
BENZENE	524	ppb	0.5	5	ND	ND	ND
BENZO (A) PYRENE	525	ppb	0.25	0.2	ND	ND	ND
BENZO (B) FLUORANTHRENE	525	ppb	0.25		ND	ND	ND
BENZO (g,h,i) PERYLENE	525	ppb	0.23		ND	ND	ND
BENZO (K) FLUORANTHRENE	525	ppb	0.08		ND	ND	ND
BIS-(2-ETHYLHEXYL)PHTHALATE	525	ppb	0.21	6	ND	ND	ND
BROMACIL (HYVAR)	507	ppb	0.14		ND	ND	ND
BROMOBENZENE	524	ppb	0.5		ND	ND	ND
BROMOCHLOROMETHANE	524	ppb	0.5		ND	ND	ND
BROMODICHLOROMETHANE	524	ppb	0.5	**	1.3	ND	ND
BROMOFORM	524	ppb	0.5	**	ND	ND	ND
BROMOMETHANE	524	ppb	0.5		ND	ND	ND
BUTACHLOR	507	ppb	0.1		ND	ND	ND
BUTYL BENZYLPHTHALATE	525	ppb	0.13		ND	ND	ND
BUTYLATE (SUTAN)	507	ppb	0.1		ND	ND	ND
CARBARYL	531	ppb	0.6		ND	ND	ND
CARBOFURAN	531	ppb	0.5	40	ND	ND	ND
CARBON TETRACHLORIDE	524	ppb	0.5	5	ND	ND	ND
CHLORAMBEN	515	ppb	0.46		ND	ND	ND
CHLORNEB	508	ppb	0.031		ND	ND	ND
CHLOROBENZENE	524	ppb	0.5	100	ND	ND	ND
CHLOROBENZILATE	508	ppb	0.031		ND	ND	ND
CHLOROETHANE	524	ppb	0.5		ND	ND	ND
CHLOROFORM	524	ppb	0.5	**	11.0	1.8	6.2
CHLOROMETHANE	524	ppb	0.5		ND	ND	ND
CHLOROTHALONIL	508	ppb	0.021		ND	ND	ND
CHRYSENE	525	ppb	0.05		ND	ND	ND
CIS-1,2-DICHLOROETHENE	524	ppb	0.5	70	ND	ND	ND
CIS-1,3-DICHLOROPROPENE	524	ppb	0.5		ND	ND	ND
CIS-PERMETHRIN	508	ppb	0.022		ND	ND	ND
CYANAZINE	526	ppb	0.32		ND	ND	ND
CYCLOATE (RO-NEET)	507	ppb	0.09		ND	ND	ND
DACTHAL	508	ppb	0.025		ND	ND	ND
DACTHAL (DCPA)	515	ppb	1.12		ND	ND	ND
DALAPON	515	ppb	2.15	200	ND	ND	ND
D-BHC	508	ppb	0.051		ND	ND	ND
DI(2-ETHYLHEXYL)ADIPATE	525	ppb	0.09	400	ND	ND	ND
DIAZINON	526	ppb	0.24		ND	ND	ND
DIBENZ (a,h) ANTHRACENE	525	ppb	0.26		ND	ND	ND
DIBROMOCHLOROMETHANE	524	ppb	0.5	**	ND	ND	ND
DIBROMOMETHANE	524	ppb	0.5		ND	ND	ND

DICAMBA	515	ppb	0.15		ND	ND	ND
DICHLORODIFLUOROMETHANE	524	ppb	0.5		ND	ND	ND
DICHLOROPROP	515	ppb	0.39		ND	ND	ND
DIELDRIN	508	ppb	0.037		ND	ND	ND
DIETHYLPHTHALATE	525	ppb	0.15		ND	ND	ND
DIMETHYLPHTHALATE	525	ppb	0.07		ND	ND	ND
DI-N-BUTYLPHTHALATE	525	ppb	1.29		ND	ND	ND
DINOSEB	515	ppb	0.34	7	ND	ND	ND
DISULFOTON	526	ppb	0.14		ND	ND	ND
ENDOSULFAN 2	508	ppb	0.037		ND	ND	ND
ENDOSULFAN I	508	ppb	0.033		ND	ND	ND
ENDOSULFAN SULFATE	508	ppb	0.057		ND	ND	ND
ENDRIN	508	ppb	0.037	2	ND	ND	ND
ENDRIN ALDEHYDE	508	ppb	0.035		ND	ND	ND
EPTC (EPTAM)	507	ppb	0.1		ND	ND	ND
ETHYLBENZENE	524	ppb	0.5	700	ND	ND	ND
ETHYLENE DIBROMIDE (EDB)	504	ppb	0.01	0.05	ND	ND	ND
ETRIDIAZOLE	508	ppb	0.019		ND	ND	ND
FLUORENE	525	ppb	0.07		ND	ND	ND
FONOFOS	526	ppb	0.13		ND	ND	ND
GAMMA-CHLORDANE	508	ppb	0.025		ND	ND	ND
HEPTACHLOR	508	ppb	0.047	0.4	ND	ND	ND
HEPTACHLOR/EPOXIDE	508	ppb	0.039	0.2	ND	ND	ND
HEXACHLOROBENZENE	508	ppb	0.019	1	ND	ND	ND
HEXACHLOROBUTADIENE	524	ppb	0.5		ND	ND	ND
HEXACHLOROCYCLOPENTADIENE	508	ppb	0.057	50	ND	ND	ND
HEXAZINONE (VELPAR)	507	ppb	0.12		ND	ND	ND
INDENO (1,2,3,c,d) PYRENE	525	ppb	0.24		ND	ND	ND
ISOPHORONE	525	ppb			ND	ND	ND
ISOPROPALIN (PAARLAN)	507	ppb	0.12		ND	ND	ND
ISOPROPYLBENZENE	524	ppb	0.5		ND	ND	ND
LINDANE	508	ppb	0.03	0.2	ND	ND	ND
M+P-XYLENE	524	ppb	0.5		ND	ND	ND
METHIOCARB	531	ppb	0.6		ND	ND	ND
METHOMYL	531	ppb	0.5		ND	ND	ND
METHOXYCLOR	508	ppb	0.055	40	ND	ND	ND
METHYLENE CHLORIDE	524	ppb	0.5	5	1.1	ND	BQL
METOLACHLOR (DUAL)	507	ppb	0.1		0.6	ND	0.1
METRIBUZIN (SENCOR)	507	ppb	0.23		ND	ND	ND
MOLINATE (ORDRAM)	507	ppb	0.09		ND	ND	ND
MTBE	524	ppb	0.5		ND	ND	ND
NAPHTHALENE	524	ppb	0.5		ND	ND	ND
NAPHTHALENE	525	ppb	0.04		ND	ND	ND
N-BUTYLBENZENE	524	ppb	0.5		ND	ND	ND
NITROBENZENE	526	ppb	0.15		ND	ND	ND
N-PROPYLBENZENE	524	ppb	0.5		ND	ND	ND
OXADIAZON (RONSTAR)	507	ppb	0.07		ND	ND	ND
OXAMYL	531	ppb	0.6	200	ND	ND	ND
OXYFLUORFEN (GOAL)	507	ppb	0.12		ND	ND	ND
O-XYLENE	524	ppb	0.5		ND	ND	ND
p,p' DDD	508	ppb	0.046		ND	ND	ND

p,p' DDE	508	ppb	0.035		ND	ND	ND
p,p' DDT	508	ppb	0.032		ND	ND	ND
PCB 1221	508	ppb	0.1	0.5	ND	ND	ND
PCB 1232	508	ppb	0.1	0.5	ND	ND	ND
PCB 1242	508	ppb	0.1	0.5	ND	ND	ND
PCB 1248	508	ppb	0.1	0.5	ND	ND	ND
PCB 1254	508	ppb	0.1	0.5	ND	ND	ND
PCB 1260	508	ppb	0.1	0.5	ND	ND	ND
PEBULATE (TILLAM)	507	ppb	0.1		ND	ND	ND
PENDAMETHALIN (PROWL)	507	ppb	0.17		ND	ND	ND
PENTACHLOROPHENOL	515	ppb	0.18	1	ND	ND	ND
PHENANTHRENE	525	ppb	0.04		ND	ND	ND
PICLORAM	515	ppb	0.88	500	ND	ND	ND
PROFLURALIN (TOLBAN)	507	ppb	0.19		ND	ND	ND
PROMETON	526	ppb	0.35		ND	ND	ND
PROPACHLOR	508	ppb	0.036		ND	ND	ND
PROPAZINE (GESOMIL)	507	ppb	0.07		ND	ND	ND
PROPOXUR	531	ppb	0.6		ND	ND	ND
PYRENE	525	ppb	0.06		ND	ND	ND
SEC-BUTYLBENZENE	524	ppb	0.5		ND	ND	ND
SIMAZINE (PRINCEP)	507	ppb	0.08	4	ND	ND	ND
STYRENE	524	ppb	0.5	100	ND	ND	ND
TECHNICAL CHLORDANE	508	ppb	0.1	2	ND	ND	ND
TERBACIL (SINBAR)	507	ppb	0.09		ND	ND	ND
TERBUFOS	526	ppb	0.32		ND	ND	ND
TERT-BUTYLBENZENE	524	ppb	0.5		ND	ND	ND
TETRACHLOROETHENE	524	ppb	0.5	5	ND	ND	ND
TOLUENE	524	ppb	0.5	1000	ND	ND	ND
TOXAPHENE	508	ppb	1	3	ND	ND	ND
TRAN-1,3-DICHLOROPROPENE	524	ppb	0.5		ND	ND	ND
TRANS-1,2-DICHLOROETHENE	524	ppb	0.5	100	ND	ND	ND
TRANS-PERMETHRIN	508	ppb	0.036		ND	ND	ND
TRICHLOROETHENE	524	ppb	0.5	5	ND	ND	ND
TRICHLOROFLUOROMETHANE	524	ppb	0.5		ND	ND	ND
TRIFLURALIN	508	ppb	0.029		ND	ND	ND
VERNOLATE (VERNAM)	507	ppb	0.11		ND	ND	ND
VINYL CHLORIDE	524	ppb	0.5	2	ND	ND	ND
2,3,7,8-TCDD (DIOXIN)		ppq	5	30	ND	ND	ND
DIQUAT		ppb	0.2	20	ND	ND	ND
PARAQUAT		ppb	2.0		ND	ND	ND
ENDOTHALL		ppb	9	100	ND	ND	ND
GLYPHOSATE (RODEO, ROUNDUP)		ppb	6	700	ND	ND	ND
NDMA		ppt	2.0		ND	ND	ND

METALS

ALUMINUM	ppm	0.010		0.082	ND	ND
ANTIMONY	ppm	0.001	0.006	0.001	ND	ND

ARSENIC	ppm	0.001	0.05	ND	ND	ND
BARIUM	ppm	0.001	2	0.015	0.005	0.010
BERYLIUM	ppm	0.001	0.004	ND	ND	ND
BISMUTH	ppm	0.001		ND	ND	ND
BORON	ppm	0.010		0.107	0.046	0.072
CADMIUM	ppm	0.001	0.005	ND	ND	ND
CALCIUM	ppm	0.06		38.3	27.8	32.0
CHROMIUM	ppm	0.001	0.1	ND	ND	ND
COBALT	ppm	0.002		ND	ND	ND
COPPER	ppm	0.001	1.3	ND	ND	ND
IRON	ppm	0.003		0.037	ND	0.013
LEAD	ppm	0.001	0.015	ND	ND	ND
MAGNESIUM	ppm	0.13		8.32	3.40	5.57
MANGANESE	ppm	0.001		ND	ND	ND
MERCURY	ppm	0.0002	0.002	ND	ND	ND
MOLYBDENUM	ppm	0.002		ND	ND	ND
NICKEL	ppm	0.003		ND	ND	ND
POTASSIUM	ppm	0.02		5.95	4.79	5.30
SELENIUM	ppm	0.001	0.05	0.002	ND	ND
SILICON	ppm	0.05		4.82	1.37	2.93
SILVER	ppm	0.002		ND	ND	ND
SODIUM	ppm	0.02		75.7	48.1	59.3
STRONTIUM	ppm	0.001		0.240	0.160	0.200
THALLIUM	ppm	0.001	0.002	ND	ND	ND
TIN	ppm	0.004		ND	ND	ND
TITANIUM	ppm	0.001		ND	ND	ND
VANADIUM	ppm	0.001		ND	ND	ND
ZINC	ppm	0.001		0.019	ND	0.005

RADIOLOGICAL

GROSS ALPHA	pCi/L	1.1	15			1.4
GROSS BETA	pCi/L	0.9	50			6.7
RADIUM 226	pCi/L	0.25	5	BQL	ND	BQL
RADIUM 228	pCi/L	0.98	(combined)	BQL	ND	BQL
RADON 222	pCi/L	50		ND	ND	ND
URANIUM, TOTAL	pCi/L	0.68		BQL	ND	BQL
TRITIUM	pCi/L	200	20000	BQL	ND	BQL
STRONTIUM 90	pCi/L	0.97	8.0	BQL	ND	BQL

DISTRIBUTION SYSTEM TESTING

Lead & Copper Rule Household Testing						90th %
LEAD (90th Percentile) 2001	ppb	1	15			4
COPPER (90th Percentile) 2001	ppb	1	1300			5
Total Coliform Rule:				MAX	MIN	AVG
TURBIDITY (HIGHEST SINGLE TURBIDITY - SEPT. 2002)	ntu	0.01	TT	0.80	0.03	0.08
TURBIDITY - (LOWEST MONTHLY % <0.3)	%		95% <0.3	100	100	100

TOTAL COLIFORM:

HIGHEST MONTHLY % POSITIVE -MARCH
2002

%

<5%
Positive

1.6

ND

0.1

Disinfection By-Product Testing:

TOTAL TRIHALOMETHANES -TTHM	0.5	ppb	80	34.4	0.9	6.2
TOTAL HALOACETIC ACIDS- THAA5	0.5	ppb	60	26.7	10.3	21.1
TOTAL HALOACETONITRILES-THAN	0.5	ppb		0.50	ND	BQL

KEY TO TERMS USED:**MDL** = minimum detection level, the lowest level of a compound that it is possible to detect with method used**FED LIMIT** = maximum contaminant level (MCL) established by federal law and is enforceable, health related standard****** = tthm compounds, limit is for all four compounds added together**AVG** = average value of all tests for this compound conducted this year**MAX** = highest level of this compound detected during the year**MIN** = lowest level of this compound detected during the year**L** = one liter, approximately one quart**ml** = one milliliter = 0.001L, one thousandth of a liter**ppm** = parts per million or milligrams per liter or mg/L**ppb** = parts per billion or micrograms per liter or ug/L (1ppb = 0.001ppm)**ppt** = parts per trillion or nanograms per liter or ng/L (1ppt = 0.001ppb = 0.000001ppm)**ppq** = parts per quadrillion or picograms per liter or pg/L (1ppq = 0.001ppt = 0.000001ppb = 0.00000001ppm)**ND** = not detected**mf/L** = million fibers per liter**su** = standard units**umhos/cm** = micro-mhos per centimeter**cfu/100ml** = colony forming units per 100 milliliters**cfu/ml** = colony forming units per 1 milliliter**Deg F** = degrees Fahrenheit**BQL** = detected, but below quantifiable level**ur** = unregulated compound for which monitoring is required but no limit has been established**ntu** = nephelometric turbidity units**au** = absorbance units**TT** = treatment technique, no actual enforceable limit established, Required to use certain type of treatment**ICC/nPCR** = integrated cell culture/nested Polymerase Chain reaction

Click on a flag below to translate this web page into the language corresponding to the flag. Translated links to external sites may not be functional. This computerized translation is intended to provide only the gist of the original web page and should not be regarded as accurate.



Français



Deutsch



Italiano



Português



Español



Ελληνικά



Nederlands



Русский



简体中文



繁体中文



한국어



日本語

[Contact us](#) | [Employment](#) | [E-Services](#) | [Residents](#) | [Visitors](#) | [Business](#) | [Neighborhoods](#) | [Mayor/Council](#) | [Home](#)
[Search](#) | [Site Directory](#) | [Help](#) | [Calendars](#) | [News](#) | [Departments](#) | [City Services](#) | [Forms](#) | [Maps](#)
[Recreation](#) | [Public Safety](#) | [Ordinances](#) | [Taxes](#) | [Permits & Licenses](#) | [Contracts](#)
[Bids & RFP's](#) | [Transportation](#) | [International](#) | [KC History](#) | [FOCUS](#)
[Housing](#) | [Capital Improvements](#) | [Videos](#) | [Other Agencies](#)

