



Jessica Oakley <jessica.oakley@brightergy.com>

Fwd: FW: Pre Approval- Net Metering App- Two West-Acct 2417997116- MO KCPL

Design Dept <design@brightergy.com>
To: Jessica Oakley <Jessica.Oakley@brightergy.com>

Fri, Aug 16, 2013 at 5:46 PM

This email chain shows an example of requirements that were added after the system was inspected. No where was it identified in the interconnect approval that the systems would need to be labeled according to the apartment numbers, rather than #1 and #2 as we had on our plans.

Amar,

There are two systems on this building, so they are labelled System #1 and System #2, which is how KCP&L Engineering requested they be labelled. The site plaques on the meters show location of equipment for each system, as well having "Caution: Power to this building is also supplied from the following sources:" language on them.

The disconnect may be rated for 225 amps, but it is fused for 80 amps. It was inspected and passed by the city on May 16th (permit # CPEM 201325356).

Please let me know what, if anything, needs to be updated in order to get the net meters installed.

Thanks,
Jessica

On Fri, Jul 19, 2013 at 7:24 AM, Cheema Amarpreet <Amarpreet.Cheema@kcpl.com> wrote:

I am not sure if this information was passed to the installer, but the labels still say "disconnect #1 and disconnect #2" instead of PS and 2W. Also, we need "caution label" (with appropriate wording) next to the meters as well.

Also the other issue noticed was that on Apt 2W, the disconnect has been changed to 225amps!!!

I am not sure if the existing meter bank is rated for 225amp breaker, if city inspection has been received on this, or if the paperwork submitted shows a 225amp service.

Amar Cheema

Kansas City Power & Light

F&M Service Center

4400 Front St, K.C. Missouri 64120

O- 816 245 3942 M- 816 289 5610 F- 816 245 3703

Email- Amarpreet.Cheema@KCPL.com

From: Cheema Amarpreet
Sent: Friday, June 28, 2013 2:47 PM
To: Michael Nathan; Maliwat Roland

Subject: FW: Pre Approval- Net Metering App- Two West-Acct 2417997116- MO KCPL

Here are the pictures you had requested. I could only take pictures of outdoor PV disconnects, as I could not get access to the meter room inside...

Amar Cheema

Kansas City Power & Light

F&M Service Center

4400 Front St, K.C. Missouri 64120

O- 816 245 3942 M- 816 289 5610 F- 816 245 3703

Email- Amarpreet.Cheema@KCPL.com

From: Cheema Amarpreet
Sent: Monday, June 10, 2013 3:39 PM
To: Michael Nathan; Maliwat Roland

Subject: RE: Pre Approval- Net Metering App- Two West-Acct 2417997116- MO KCPL

I had this on the route today, and could not get access. But the outdoor disconnects do not have the correct labels yet- So I did not try to get access inside to complete my inspection.

The meters/disconnect should notify which one is PS and which is apt #2w.

Also the meters need the caution label on meters, notifying that meters are back fed by another source.

Amar Cheema

Kansas City Power & Light

F&M Service Center

4400 Front St, K.C. Missouri 64120

O- 816 245 3942 M- 816 289 5610 F- 816 245 3703

Email- Amarpreet.Cheema@KCPL.com

From: Cheema Amarpreet
Sent: Tuesday, May 21, 2013 7:39 AM
To: Michael Nathan; Maliwat Roland

Subject: RE: Pre Approval- Net Metering App- Two West-Acct 2417997116- MO KCPL

Need the meters and disconnects labeled PS & 2W

Need required "Caution" sticker on the meter

Amar Cheema

Kansas City Power & Light

F&M Service Center

4400 Front St, K.C. Missouri 64120

O- 816 245 3942 M- 816 289 5610 F- 816 245 3703

Email- Amarpreet.Cheema@KCPL.com

From: Michael Nathan

Sent: Wednesday, May 15, 2013 12:00 PM
To: Scheier Jodi
Cc: Burk Tammy; Cheema Amarpreet; Diaz Carlos; White Joey; Wiley Russ
Subject: FW: Pre Approval- Net Metering App- Two West-Acct 2417997116- MO KCPL

For GDT route.

From: Heriford Don
Sent: Wednesday, May 15, 2013 11:04 AM
To: Maliwat Roland; Kerner Lisa; Petersen Dawn; Sowle Elizabeth; Kendrick Suzanne; Graves Mandy; Michael Nathan
Cc: Gaughran Kathy; Graves Susan; Correspondence Desk CCC
Subject: Pre Approval- Net Metering App- Two West-Acct 2417997116- MO KCPL

Attached is a pre approved project. An alteration order will be entered for pre inspection of metering to determine if the customer or vendor should take additional steps to bring it up to specifications prior to the completion of the net metering process.

In some cases the system may appear to be completed. The solar installer has the right to install but not interconnect the system prior to pre-approval. If the system appears to be complete:

1. Ensure that the disconnect is off. The solar array should not be energized prior to a final inspection as requested by the installer/owner.
2. Do not enter an exchange order until prompted by a field inspection request

Customer Information

Two West

514 W 26th St., Suite 2W

Kansas City, MO 64108

816-213-7797

Acct 2417997116

Equipment Specification

1. Single Phase
2. 240 Volt
3. 200 Amp
4. Power Rating –19.14 kW
5. PV

Vendor Information

Gary Freeman

Brightergy

816-866-0555