



**ENGINEERING REPORT
FOR
Lake Region Water and Sewer Company**

**Shawnee Bend/Lake of the Ozarks
Camden County, Missouri**

Water System

**PREPARED BY:
Krehbiel Engineering, Inc.
63 Blair Ave.
Camdenton, MO 65020**

Date Prepared: October 2007



ENGINEERING REPORT

FOR

Lake Region Water and Sewer Company

**Shawnee Bend/Lake of the Ozarks
Camden County, Missouri**

Water System

October 2007



PREPARED FOR:
Lake Region Water and Sewer
Company
802 Bittersweet
Lake Ozark, MO 65049

Krehbiel Engineering, Inc.

63 BLAIR AVENUE POST OFFICE BOX 587 CAMDENTON, MISSOURI 65020
573-346-5316 FAX 573-346-3851 info@krehbielengineering.com www.krehbielengineering.com

TABLE OF CONTENTS

Background

Purpose

Flow Data

Water Supply

Water Storage

Conclusions

Exhibits

1. **PSC Certificated Area**
2. **Flow Data**
3. **WaterCAD Model Pump Curves and Diurnal Flow Pattern**
4. **Calculation of Minimum Water Storage Needed**

**ENGINEERING REPORT
FOR
Lake Region Water and Sewer Company

Shawnee Bend/Lake of the Ozarks
Camden County, Missouri

Water System**

BACKGROUND:

Lake Region Water and Sewer Company is certificated by the Missouri Public Service Commission to serve an area in Shawnee Bend at the Lake of the Ozarks in Camden County, Missouri. The certificated area is shown on the attached Exhibit 1.

The water system is being operated under System ID Number MO3031201.

PURPOSE:

The purpose of this engineering report is provide the information in regard to the transfer of ownership of LRW&S from the previous owner to the present owner. LRW&S, in the order with the Missouri Public Service Commission (PSC), "agreed to conduct an engineering study of the facility improvements that will likely be needed in the long-term,..."

FLOW DATA:

Daily metered well flow measurements were conducted for the last 4 days of June, all of July and August, and the first 26 days of September.

This period was selected as seasonal fluctuations in water demands are anticipated in the Lake of the Ozarks area. Higher flows are anticipated during July and August and on weekends and holidays. The testing period included the entire months of July and August and the July 4th and Labor Day holidays. The data collected is shown in Exhibit 2.

WATER SUPPLY:

Water supply is provided by Well No. 1 and Well No. 2.

Well No. 1 was drilled in 1994 and was reported by consulting engineer Harms to have a yield of approximately 500 gpm.

Well No. 2 was drilled in 1998 and Krehbiel Engineering could find no record of the yield test. Conflicting information was found regarding the depth of this well. The pump installed was tested in 2005 and a yield of 250 gpm was recorded.

Based on a comparison of the records of the two wells, Krehbiel Engineering believes that the yield of Well No. 2 should closely approximate the yield of Well No. 1.

Because of a lack of specific confirmation of the yield of Well No. 2 and for the purposes of this report, Krehbiel Engineering recommends the use of the 250 gpm figure.

Yield

Well No. 1	500 gpm x 1440	=	720,000 gpd
------------	----------------	---	-------------

Well No. 2	250 gpm x 1440	=	360,000 gpd
------------	----------------	---	-------------

In August 2007, the average daily usage was 303,577 gpd. The system has the capacity to supply this demand with what is assumed to be the highest yield well (Well No. 1) out of service.

Based on the Harms' report that Well No. 1 has a yield of approximately 500 gpm, the potential exists for the water supply capacity to be increased by installing larger pumps in one, or both, wells.

In the 2005 Feasibility Study provided to the PSC in Case No. WA-2005-0643, et al., it was projected "that a new well will not be

necessary due to this expansion or internal growth for five years or more”.

Krehbiel Engineering would concur that at the present rate of growth, and with the existing pumps, the supply should be adequate for the 3 years or more. The capacity of the wells could be increased with the installation of larger pumps prior to the drilling of an additional well.

Naturally, growth patterns will affect usage. There is always the potential that some form of major development may be announced at anytime. The utility is constantly monitoring any potential development and would react in accordance with the demand.

WATER STORAGE;

The existing storage capacity consists of a 200,000 gallon elevated storage tank erected in 2003 (Krehbiel Engineering has not been able to confirm a more specific date).

The maximum day's usage was recorded on August 15, 2007 (Exhibit 2) to be 470,300 gallons.

The supply, storage and distribution system has been modeled using WaterCAD. Running the model at the maximum days usage and with both pumps in operation, at the present well yield of 250 gpm each (Exhibit 3), the minimum nominal finished water storage needed to maintain design operating pressure and flow in accordance with the DNR Design Guide is 35,000 gallons (Exhibit 4).


In the absence of documentation of the diurnal flow pattern and the maximum day's usage, DNR suggests that a reasonable default value for minimum storage needed is 25% of design maximum day's usage. For the system, at this time, that would be 25% of 470,300 gallons. That equals 117,575 gallons.

CONCLUSIONS:

It appears that there is adequate supply and storage for the short-term.

For the long-term, assuming that growth will continue in this area, and there is no reason to believe differently, a well and elevated water storage tank will be needed. It is my opinion that it would be premature to determine the location and size of the well and storage tank at this time. Growth and usage patterns need to be monitored and the model needs to be updated and reviewed on a periodic basis.

Respectfully submitted:

A handwritten signature in cursive script, reading "David Krehbiel". The signature is written in black ink and is positioned above a horizontal line.


David Krehbiel, E-11594

P.S.C. MO NO. 1 SECOND REVISED SHEET NO. 3

CANCELLING P.S.C. MO NO. 1 FIRST REVISED SHEET NO. 3

LAKE REGION WATER AND SEWER COMPANY: SHAWNEE BEND SERVICE AREA

FOR WATER SERVICE



R. 16 W
R. 17 W

DATE OF ISSUE 1-4-07 DATE EFFECTIVE 1-3-07

ISSUED BY:

NAME OF OFFICER: John Summers

TITLE: General Manager

ADDRESS: P.O. Box 608 Lake Ozark, Missouri 65049

EXHIBIT 1

LAKE REGION WATER SEWER
SHAWNEE BEND
CAMDEN COUNTY, MO

WASTEWATER (Permit No. MO 0123722)						
Date	Metered Hours			DAILY FLOW		
	Pump #1	Pump #2	Total Hours	Rainfall (Inches)	Flow Pump #1 (Gal.)	Flow Pump #2 (Gal.)
06/27/07	9.98	11.1	21.08		23,952	26,640
06/28/07	4.33	15.1	19.43		10,392	36,240
06/29/07	22.9	16.3	39.2		54,960	39,120
06/30/07	11.5	13.1	24.6		27,600	31,440
TOTALS	48.71	55.6	104.31	0	116,904	133,440
						250,344

WATER (Permit No. MO 3031201)			
DAILY FLOW			
Flow Pump #1 (Gal.)	Flow Pump #2 (Gal.)	Total Flow (Gal.)	
248,000	-	248,000	
54,000	-	54,000	
221,000	-	221,000	
240,000	-	240,000	
763,000	-	763,000	

JUNE 2007

EXHIBIT 2

LAKE REGION WATER SEWER
SHAWNEE BEND
CAMDEN COUNTY, MO


WASTEWATER (Permit No. MO 0123722)							
Date	Metered Hours			Rainfall (Inches)	DAILY FLOW		
	Pump #1	Pump #2	Total Hours		Flow Pump #1 (Gal.)	Flow Pump #2 (Gal.)	Total Flow (Gal.)
07/01/07	17.69	21.10	38.79	-	42,456	50,640	93,096
07/02/07	20.05	18.00	38.05	0.40	48,120	43,200	91,320
07/03/07	13.45	14.40	27.85	-	32,280	34,560	66,840
07/04/07	14.08	15.40	29.48	-	33,792	36,960	70,752
07/05/07	22.64	18.90	41.54	-	54,336	45,360	99,696
07/06/07	11.52	17.90	29.42	Trace	27,648	42,960	70,608
07/07/07	14.36	17.20	31.56	-	34,464	41,280	75,744
07/08/07	16.99	14.90	31.89	-	40,776	35,760	76,536
07/09/07	19.55	13.20	32.75	-	46,920	31,680	78,600
07/10/07	13.00	6.80	19.80	-	31,200	16,320	47,520
07/11/07	13.10	4.40	17.50	-	29,082	9,768	38,850
07/12/07	10.94	4.40	15.34	-	24,287	9,768	34,055
07/13/07	9.08	3.90	12.98	-	20,158	8,658	28,816
07/14/07	14.29	4.90	19.19	-	31,724	10,878	42,602
07/15/07	18.05	19.50	37.55	-	40,071	43,290	83,361
07/16/07	14.09	1.00	15.09	-	31,280	2,220	33,500
07/17/07	17.15	5.40	22.55	-	38,073	11,988	50,061
07/18/07	4.26	7.00	11.26	-	9,457	15,540	24,997
07/19/07	9.40	4.10	13.50	-	20,868	9,102	29,970
07/20/07	12.14	8.00	20.14	0.25	26,951	17,760	44,711
07/21/07	11.43	6.20	17.63	-	25,375	13,764	39,139
07/22/07	15.41	12.30	27.71	-	34,210	27,306	61,516
07/23/07	13.19	12.30	25.49	-	29,282	27,306	56,588
07/24/07	13.19	10.60	23.79	-	29,282	23,532	52,814
07/25/07	8.42	4.60	13.02	-	18,692	10,212	28,904
07/26/07	8.64	5.00	13.64	-	19,181	11,100	30,281
07/27/07	9.97	11.40	21.37	-	22,133	25,308	47,441
07/28/07	10.08	11.40	21.48	-	22,378	25,308	47,686
07/29/07	10.08	15.20	25.28	-	22,378	33,744	56,122
07/30/07	19.06	11.20	30.26	-	42,313	24,864	67,177
07/31/07	12.68	9.30	21.98	-	28,150	20,646	48,796
TOTALS	417.98	329.90	747.88	0.65	957,315	760,782	1,718,097

WATER (Permit No. MO 3031201)				
Flow Pump #1 (Gal.)	Flow Pump #2 (Gal.)	Total Flow (Gal.)	DAILY FLOW	
			Flow Pump #1 (Gal.)	Flow Pump #2 (Gal.)
128,000	-	128,000	128,000	-
318,000	111,600	429,600	318,000	111,600
151,000	111,700	262,700	151,000	111,700
124,000	300,000	424,000	124,000	300,000
-	300,000	300,000	-	300,000
184,000	37,700	221,700	184,000	37,700
141,000	305,200	446,200	141,000	305,200
-	305,200	305,200	-	305,200
142,000	-	142,000	142,000	-
225,000	-	225,000	225,000	-
299,000	-	299,000	299,000	-
124,000	-	124,000	124,000	-
140,000	325,800	465,800	140,000	325,800
212,000	32,100	244,100	212,000	32,100
345,000	32,200	377,200	345,000	32,200
69,000	6,500	75,500	69,000	6,500
186,000	264,400	450,400	186,000	264,400
186,000	-	186,000	186,000	-
199,000	-	199,000	199,000	-
304,000	-	304,000	304,000	-
289,000	-	289,000	289,000	-
290,000	-	290,000	290,000	-
203,000	-	203,000	203,000	-
290,000	-	290,000	290,000	-
254,000	-	254,000	254,000	-
261,000	-	261,000	261,000	-
342,000	-	342,000	342,000	-
364,000	-	364,000	364,000	-
267,000	-	267,000	267,000	-
156,000	-	156,000	156,000	-
6,193,000	2,437,600	8,630,600	6,193,000	2,437,600

WASTEWATER (Permit No. MO 0123722)							
Metered Hours				DAILY FLOW			
Date	Pump #1	Pump #2	Total Hours	Rainfall (Inches)	Flow Pump #1 (Gal.)	Flow Pump #2 (Gal.)	Total Flow (Gal.)
08/01/07	10.41	10.80	21.21		24,984	25,920	50,904
08/02/07	12.79	0.90	13.69		30,696	2,160	32,856
08/03/07	12.84	11.80	24.64		30,816	28,320	59,136
08/04/07	8.29	14.00	22.29		19,896	33,600	53,496
08/05/07	11.37	16.50	27.87		27,288	39,600	66,888
08/06/07	12.93	12.60	25.53		31,032	30,240	61,272
08/07/07	13.34	7.60	20.94		32,016	18,240	50,256
08/08/07	9.68	14.00	23.68		23,232	33,600	56,832
08/09/07	5.15	13.00	18.15		12,360	31,200	43,560
08/10/07	10.03	6.90	16.93		24,072	16,560	40,632
08/11/07	17.52	9.50	27.02		42,048	22,800	64,848
08/12/07	11.45	14.50	25.95		27,480	34,800	62,280
08/13/07	16.10	10.60	26.70		38,640	25,440	64,080
08/14/07	8.32	12.50	20.82		19,968	30,000	49,968
08/15/07	12.06	0.00	12.06		28,944	0	28,944
08/16/07	0.03	11.70	11.73		72	28,080	28,152
08/17/07	11.52	5.10	16.62		27,648	12,240	39,888
08/18/07	14.15	8.60	22.75		33,960	20,640	54,600
08/19/07	15.60	12.10	27.70		37,440	29,040	66,480
08/20/07	13.31	19.50	32.81		31,944	46,800	78,744
08/21/07	3.79	16.20	19.99		9,096	38,880	47,976
08/22/07	16.92	6.50	23.42		40,608	15,600	56,208
08/23/07	9.01	1.60	10.61		21,624	3,840	25,464
08/24/07	13.65	0.00	13.65		32,760	0	32,760
08/25/07	2.94	8.90	11.84		7,056	21,360	28,416
08/26/07	5.88	5.20	11.08		14,112	12,480	26,592
08/27/07	8.52	5.70	14.22		20,448	13,680	34,128
08/28/07	4.24	11.30	15.54		10,176	27,120	37,296
08/29/07	6.15	6.30	12.45		14,760	15,120	29,880
08/30/07	5.09	2.90	7.99		12,216	6,960	19,176
08/31/07	4.50	5.00	9.50		10,800	12,000	22,800
TOTALS	307.58	281.80	589.38	0	738,192	676,320	1,414,512

WATER (Permit No. MO 3031201)				
Flow Pump #1 (Gal.)	Flow Pump #2 (Gal.)	Total Flow (Gal.)	DAILY FLOW	
			Flow Pump #1 (Gal.)	Flow Pump #2 (Gal.)
400,000	-	400,000		
151,000	-	151,000		
218,000	-	218,000		
397,000	57,900	454,900		
330,000	58,000	388,000		
316,000	57,900	373,900		
308,000	58,000	366,000		
126,000	58,000	184,000		
-	247,600	247,600		
234,000	400	234,400		
374,000	400	374,400		
341,000	400	341,400		
274,000	400	274,400		
330,000	400	330,400		
228,000	242,300	470,300		
-	335,100	335,100		
213,000	-	213,000		
329,000	-	329,000		
280,000	-	280,000		
370,000	-	370,000		
216,000	-	216,000		
298,000	-	298,000		
223,000	-	223,000		
320,000	-	320,000		
328,000	-	328,000		
326,000	-	326,000		
295,000	-	295,000		
317,000	-	317,000		
353,000	-	353,000		
282,000	-	282,000		
117,000	100	117,100		
8,294,000	1,116,900	9,410,900		

AUGUST 2007



Title: LRW&S Company

k:\...drawings\050426 watercad model.wcd

10/26/07 10:50:22 AM © Haestad Methods, Inc. 37 Brookside Road Waterbury, CT 06708 USA +1-203-755-1666


krehbiel engineering, inc.

Project Engineer: David Krehbiel

WaterCAD v4.1 [424a]

Page 1 of 1

EXHIBIT 3



Detailed Report for Pattern: max day


Pattern Summary

Pattern	max day	Format	Stepwise
Start Time	0.00 hr	Starting Multiplier	0.21
Duration	24.00 hr		

Pattern

Time from Start (hr)	Multiplier
1.00	0.32
2.00	0.32
3.00	0.22
4.00	0.24
5.00	0.37
6.00	0.49
7.00	0.65
8.00	0.92
9.00	0.94
10.00	0.76
11.00	0.74
12.00	0.79
13.00	0.76
14.00	0.77
15.00	0.83
16.00	0.97
17.00	1.08
18.00	1.17
19.00	0.95
20.00	0.72
21.00	0.49
22.00	0.42
23.00	0.34
24.00	0.21

Stepwise Pattern
max day



KREHBIEL ENGINEERING, INC.

Darren Krehbiel, P.E., P.L.S.

Dave Krehbiel, P.E., P.L.S.

Chris Michaelree, E.I.T.

Vernon Moore, P.L.S.

Ronnie Testerman, Waste Water Specialist

JOB LAKE REGION WATER & SEWERSHEET NO. 1 OF 1CALCULATED BY DAVE KREHBIEL DATE 26 OCT 07

CHECKED BY _____ DATE _____

SCALE _____

CALCULATION OF MINIMUM WATER STORAGE NEEDED:

MODEL WAS RUN AT MAXIMUM DAYS USAGE OF 470,300 GAL.
(LABELED AS "MAX DAY")

ELEVATION IN TOWER FLUCTUATED FROM FULL 928.5'
TO LOW OF 923.9' (SEE ATTACHED TANK HYDRAULIC
GRADE)

$$\text{HEAD RANGE} = 928.5 - 923.9 = 4.6'$$

EXISTING TOWER CAPACITY = 200,000 GALLONS
(DIAMETER = 36', HEAD RANGE = 26.5')
 $18^2 \times 3.14 \times 26.5 \times 7.48 = 200,000 \text{ GAL.}$

$$\text{CAPACITY PER FOOT} = 200,000 / 26.5 = 7547 \text{ GALLONS}$$

MINIMUM NOMINAL FINISHED WATER STORAGE NEEDED:

$$= 4.6' \times 7547 \text{ GALLONS} = 34,716 \text{ GALLONS}$$

EXHIBIT 4

