

EXHIBIT NO.: _____
WITNESS: Robert S. Miller
ISSUE: Termination of Service
TYPE OF EXHIBIT: Surrebuttal Testimony
SPONSORING PARTY: MOPSC Staff
CASE NO.: HO-86-139

MISSOURI PUBLIC SERVICE COMMISSION
UTILITY DIVISION

KANSAS CITY POWER AND LIGHT COMPANY
CASE NO. HO-86-139

Surrebuttal Testimony

of

Robert S. Miller, P.E.

Jefferson City, Missouri

April 6, 1987

Exhibit No. 33
Date 4/8/87 Case No. HO-86-139
Witness Robert S. Miller

BEFORE THE PUBLIC SERVICE COMMISSION
OF THE STATE OF MISSOURI

In the matter of the investigation)
of steam service rendered by)
Kansas City Power & Light Company.)

Case No. HO-86-139

AFFIDAVIT OF ROBERT S. MILLER


STATE OF MINNESOTA)
) ss
COUNTY OF HENNEPIN)

Robert S. Miller, of lawful age, on his oath states: That he has participated in the preparation of the attached written testimony in question and answer form, consisting of 13 pages of testimony to be presented in the above case, that the answers in the attached written testimony were given by him; that he has knowledge of the matters set forth in such answers; and that such matters are true to the best of his knowledge and belief.

Robert S. Miller
Robert S. Miller

Subscribed and sworn to before me this 6th day of April, 1987.

Wanda M. Maricau
Notary Public



My commission expires May 23, 1987

[illegible]

2
3
4
5
6
7
8
9
0
1
2
3
4
5
6
7
8
9
0
1
2
3
4
5
6
7
8

[illegible][illegible][illegible][illegible]

8
9
0
1
2
3
4
5
6
7
8
9
0
1
2
3
4
5
6
7
8
9
0
1
2
3
4
5
6
7
8
9
0

8
9
0
1
2
3
4
5
6
7
8
9
0
1
2
3
4
5
6
7
8
9
0
1
2
3
4
5
6
7
8
9

0
1
2
3
4
5
6
7
8
9
20
21
22
23
24
25
26
27
28

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

2
3
4
5
6
7
8
9
20
21
22
23
24
25
26
27
28

3
4
5
6
7
8
9
20
21
22
23
24
25
26
27
28

- 26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
841
842
843
844
845
846
847
848
849
850
851
852
853
854
855
856
857
858
859

23
24
25
26
27
28

II - Operation and Maintenance Expenses

Q. What is Mr. Levesque's criticism of your operation and maintenance expense?

A. Mr. Levesque stated on page 3 of his rebuttal testimony that I significantly understated the costs to operate and maintain the distribution system. He further stated that with the efficiencies of a rehabilitated distribution system the manpower could be at a level of no fewer than 10 rather than the 3 employees which I estimated.

Q. Did Mr. Levesque provide some operational experience data and estimates of labor requirements?

A. Yes, he did. The data and estimates were prepared by Mr. Gawron and were included with Mr. Levesque's workpapers. I have included Mr. Gawron's analysis in my testimony as Schedule 1.

Q. Do you agree with the Company's estimate?

A. No. There are five problems with the Company's work:

1. System Operation and Maintenance Personnel. The Company summarized the ongoing functions that will be required to maintain the proposed system. Based on those ongoing functions, the Company estimated 3.2 people would be required. This number was rounded up to 4. My estimate of 3 people plus 10% overtime is essentially the same as that prepared by Mr. Gawron.

2. Technician. The Company estimated one technician would be required to maintain steam flow meters, electrical equipment and various control equipment. The Company identified a work task and then claimed an addition to the staff was required. In my estimate of total plant personnel, I included -- besides the 3 outside people -- 3 inplant maintenance people. The inplant maintenance people can maintain

1 both the control equipment associated with the boiler operation as well
2 as the steam meters and other equipment associated with the distribution
3 system. An additional person is not required as the Company claims.

4 3. Heavy Equipment Crew. The Company estimated that
5 0.64 people would be required to fix leaks. This estimate was based on
6 repairing 4 leaks per year in the old pipe and 2 leaks per year in the
7 new pipe. The Company rounded this number up to one and added two more.
8 The justification given is that more people will be required to replace
9 the existing high pressure system, expand the system and add customer
10 services.

11 It appears the Company would maintain a 3-man
12 construction crew to fix 4 to 6 leaks per year, since the condition of
13 the existing high pressure system does not indicate a need for
14 replacement. Furthermore, system expansion and customer addition would
15 be a construction effort chargeable to the customer(s) being served or
16 would be capitalized and not expensed. A more reasonable approach would
17 be to contract out for this work rather than maintain an underutilized
18 construction crew.

19 4. Welder. The Company estimated one welder would be
20 required. As in the case with the technician, the Company identified a
21 work task and then claimed an addition to the staff was required.
22 Again, the inplant maintenance staff can do this work.

23 5. Supervisor. The Company estimated one supervisor
24 was required, apparently to manage the other 7. In fact, only 3 people
25 are required and they can be managed adequately by the plant chief
26 and/or assistant chief.
27
28

1 Q. What are your conclusions regarding the number of people
2 required to operate and maintain the distribution system?

3 A. The Company's estimate of 10 people is overstated. My
4 estimate of 3 people is reasonable and supported by the Company's
5 analysis.

6 III - Auxiliary Electricity

7 Q. Mr. Levesque stated on page 4 of his rebuttal testimony
8 that you underestimated the amount of electricity required to run
9 electric auxiliaries at Grand Avenue Station (Grand Avenue). What is
10 Mr. Levesque's estimated electricity requirement?

11 A. Mr. Levesque stated that the Company estimates 6,027,000
12 Kwh of auxiliary electricity would be consumed compared to my estimated
13 auxiliary electric consumption of 2,892,000 Kwh per year.

14 Q. Do you agree with the Company's estimate?

15 A. No. Mr. Levesque's estimate is flawed in four areas:

- 16 • Use of data from a local major chemical company
17 facility identified as Mobay in Mr. Levesque's
18 workpapers.
19 • Estimate of Grand Avenue lighting.
20 • Estimate of Grand Avenue air conditioning.
21 • Estimate of Grand Avenue miscellaneous.

22 Q. Why do you disagree with the Company's use of the Mobay's
23 actual experience?

24 A. The Mobay plant may not be an appropriate facility to use
25 for estimating electrical consumption at Grand Avenue. Mr. Levesque's
26 workpapers indicate the Mobay plant size is 3,000 square feet and Grand
27 Avenue is 69,000 square feet. We have inspected Grand Avenue but we
28

1 have no information on the Mobay plant. I would be reluctant to use the
2 Mobay data without being able to properly adjust the data to reflect
3 conditions at Grand Avenue.

4 Q. Did the Company properly adjust the Mobay data?

5 A. No. Mr. Levesque's workpapers indicate the Mobay
6 electric auxiliaries include boiler feed pumps, boiler fans, air
7 conditioning, lighting, chemical pumps, and miscellaneous. The Company
8 took the total annual Mobay electric consumption and divided it by the
9 annual steam sendout to get a unit electric consumption rate of 3.41
10 Kwh per Mlb of steam sendout. They applied that unit rate to the
11 sendout from Grand Avenue and then added additional electrical
12 consumption due to air conditioning, lighting, and specific
13 miscellaneous pieces of equipment. It appears that since the Mobay data
14 already included these items, the Company compensated twice for these
15 items.

16 Furthermore, the net sendout that the Company used was
17 incorrect. Mr. Levesque stated he adjusted my sendout number which was
18 970,873 by adding 40,700 (additional losses) and 15,000 Mlb (additional
19 inplant heating). Adding these three numbers, I get 1,026,573 Mlb
20 instead of the 1,065,647 Mlb used in the Company's calculation. Thus
21 the base electric consumption the Company used in their estimate was
22 miscalculated.

23 Q. What would have been a more reasonable approach to using
24 the Mobay data?

25
26
27
28

1 A. A linear regression analysis of the 12 months of Mobay
2 data yields the following relation:

3 $\text{Kwh/month} = 37,840 + 2.4975 * \text{Mlb/month (sendout)}$

4 Correlation = 0.9189

5 This relation shows a constant electric component of 37,840
6 Kwh per month and a variable component of 2.4975 Kwh per Mlb of steam
7 sendout. It may have been appropriate to use the variable component and
8 then add the constant component based on the other electrical
9 consumption specific to Grand Avenue.

10 Q. Why do you disagree with the Company's estimate of
11 lighting?

12 A. The Company based their estimate on lighting the entire
13 Grand Avenue Station. Since only a portion of Grand Avenue will be
14 actively used, it seems logical to take steps to reduce the amount of
15 lighting to a minimum in areas that are not actively used. One obvious
16 area is the turbine room which is not needed to produce steam.

17 Q. Why do you disagree with the Company's estimate of air
18 conditioning?

19 A. The Company used 8 watts per square foot for the 9,000
20 square foot office and foreman's areas. Based on 740 watts per ton of
21 air conditioning this yields 94 square feet per ton of air conditioning.
22 An older office building would normally require 190 to 360 square feet
23 per ton which is 2 to 4 times less than the Company's estimate. Thus I
24 conclude the Company's estimate is too high.

1 Also, it appears to me 9,000 square feet is excessive and is
2 not needed. The air conditioning should be turned off in the areas not
3 used. I conclude, therefore, that the Company's estimate of electrical
4 consumption for air conditioning is overstated.

5 Q. Why do you disagree with the Company's estimate of
6 miscellaneous electric consumption?

7 A. The Company estimates that 82 Kw of air compressors will
8 be continuously required. This value may be reasonable for the old
9 electric facility but is totally inappropriate for the lower compressed
10 air requirements of the packaged gas/oil boilers I propose.

11 The Company estimates a 40 Kw cooling water pump is required.
12 I don't expect any boiler associated equipment will require cooling
13 water, thus this pump is not required.

14 Since the boilers would generate steam at the sendout
15 pressure, no further desuperheating would be required, thus the 50 Kw
16 desuperheating pump included in the Company's estimate would not be
17 required.

18 The Company estimates a 50 Kw drip and drain pump is required.
19 Although the function of the pump isn't clear, this is a large pump. It
20 is comparable to the average electrical draw of the continuously running
21 boiler feed water pumps required for the proposed boiler plant. The
22 Company's estimate is excessive.

23 Q. How would you reconcile the Company's estimate of
24 auxiliary electric consumption with yours?

25 A. If I apply the Mobay data of 2.4975 Kwh per Mlb of
26 sendout to my analysis, I get 2,425,047 Kwh per year. If I add to this
27 the Company's estimate of lighting for the boiler room and office
28

1 (452,016 Kwh) and air conditioning of the 9,000 square foot office area
2 (86,400 Kwh) I get 2,963,463 Kwh per year. The estimate I used in my
3 analysis was 2,892,000 Kwh per year. This alternative calculation is
4 within 2.5% of my previous estimate and confirms my previous estimate.
5 The Company's proposed adjustment is inappropriate.

6
7 IV - Station Heat and Distribution System Losses

8 Q. What is station heat?

9 A. Station heat is the steam used to heat the plant and
10 provide hot water for domestic use. The amount of heat required in a
11 boiler plant is higher than in an office building because of the
12 relatively large amount of outside air drawn into the plant by the
13 boilers for use in combustion.

14 Q. What is Mr. Levesque's criticism of your estimate of
15 station heat?

16 A. Mr. Levesque believes I underestimated the amount of
17 station heat required.

18 Q. What quantity did you use and what quantity does the
19 Company believe should be used?

20 A. The quantity I used was 3,643 Mlb per year as shown on
21 Schedule 1-20 of my prefled direct testimony. The Company states on
22 page 4 of Mr. Levesque's rebuttal testimony that my quantity should be
23 increased by 15,000 Mlb per year.

24 Q. Is the Company's adjustment appropriate?

25 A. No, for four reasons.
26
27
28

1 1. The Company stated in response to Staff Data Request
2 No. 408 that station heat was estimated to be 15,000 Mlb per year.
3 Increasing my estimate as they indicated would raise the station heat
4 requirements to 18,643 Mlb per year.

5 2. The Company's original estimate of 15,000 Mlb per
6 year was based on Grand Avenue data for the year ending December 31,
7 1985. During that year Grand Avenue burned mostly coal. The modern,
8 efficient packaged gas/oil fired boilers I am proposing would require
9 less air for combustion than the inefficient coal fired boilers used in
10 1985.

11 3. Since only a portion of the Grand Avenue plant will
12 be used under my scenario, it seems logical the Company would take steps
13 to reduce the amount of steam used for space heating. For example, the
14 turbine room does not need to be heated to the same temperature as
15 occupied areas of the plant.

16 4. The boilers themselves radiate heat and except for
17 basement areas and office areas, very little space heat is required.

18 Q. Do you see any reason to adjust your estimate?

19 A. No. I calculated space heating based upon heating
20 outside air used by the boilers for combustion. The total space heating
21 requirement of Grand Avenue may be somewhat higher than my estimate.
22 However, it certainly is not as high as the Company claims. At any
23 rate, the effect on the total cost of operating the district heating
24 system will be insignificant.

25 Q. What did Mr. Levesque say about distribution system
26 losses?

1 A. Mr. Levesque testified on page 4 that:

2 "Apparently he (Mr. Miller) failed to realize that the
3 "other than radiation" losses occur mostly on the
4 customers' premises or are steam leaks which will
5 continue to occur even if new distribution is installed.
6 Again, we discussed this with Messrs. Miller and Dahlen
7 and provided actual measurement data."

8 Q. Did Mr. Levesque or anyone else at KCPL provide to you or
9 Mr. Dahlen "actual measurement data" related to "other than radiation"
10 losses?

11 A. No. Neither Mr. Levesque nor anyone else at KCPL
12 provided any "actual measurement data" related to "other than radiation"
13 losses, to losses on customers' premises, or to the amount lost through
14 leaks.

15 The exact distribution between the amount of radiation loss,
16 leak loss and unmetered steam lost in the customers' premises is
17 impossible to determine. The methodology I used and described in my
18 prefiled direct testimony was based on 1985 data, the latest full year
19 available at the time I did the analysis. During 1985, 42 major leaks
20 were repaired. I do not expect anywhere near this number in the future
21 if the system is rehabilitated as I described. The Company did not
22 consider the effect on the "other than radiation" losses caused by the
23 42 major leaks. Thus their adjustment to my estimate is inappropriate.

24 Y - Boiler Size Associated With Short Term Rehabilitation

25 Q. Mr. Levesque stated on page 7 of his rebuttal testimony
26 that a boiler much larger than the one you proposed in your direct
27
28

1 testimony would be required for the short term rehabilitation
2 alternative. What are your comments regarding this?

3 A. If a larger boiler is required then a larger boiler
4 should be installed. The long term rehabilitation program included
5 installing 400,000 lb/hr of new boiler capacity consisting of (1) 70,000
6 lb/hr summer boiler and (2) 165,000 lb/hr boilers. The capital cost of
7 installing (3) 133,000 lb/hr boilers yielding the same plant capacity
8 will essentially be the same.

9 If the summer boiler under the short term rehabilitation
10 program was 133,000 lb/hr instead of 70,000 lb/hr then the capital cost
11 would be higher but the effect on the total cost of service would be
12 small.

13
14 VI - Capital Cost of Individual Gas Fired Boiler

15 Q. Mr. Levesque contends on page 1 of Exhibit 4 to his
16 rebuttal testimony that the cost of a 200 boiler horsepower (bhp) gas
17 boiler should be \$300,000 versus your estimate of \$124,000. What
18 comments do you have regarding this?

19 A. Mr. Levesque does not have a reasoned basis for his cost
20 estimate. On the other hand I developed my cost estimate using standard
21 estimating procedures and the reasonableness of my value (\$620/bhp) is
22 supported by actual contractor proposals (\$748/bhp) as I discussed in my
23 prefled direct testimony.

24 Q. Do you see any reason to adjust your estimate?

25 A. The Company's estimate lacks a reasoned basis so I would
26 have to say no.
27
28

VIII - Capital Cost of Individual Electric Boiler

Q. Mr. Levesque states on page 1 of Exhibit 4 to his rebuttal testimony that the cost of a 200 bhp electric boiler should be \$210,846 versus your estimate of \$340,000. What comments do you have regarding this?

A. Mr. Levesque based his estimate on the Home Savings building test installation. My estimate was based on the average cost of similarly sized installations estimated by the Company, and as such it applies to a broader base than just the Home Savings building.

Q. Do you see any reason to adjust your estimate?

A. No, I continue to believe my estimate is reasonable.

IX - Conservative Analysis

Q. Do you have any reason to expect the estimating procedures you used resulted in a conservatively high estimate for the cost of central district steam?

A. Yes, I do. For example, I used a boiler efficiency of 80% when calculating the fuel consumption at Grand Avenue. This is conservatively low and an efficiency of 85% could have been used for the plant I propose. This would result in the fuel consumption and cost being about 6% lower than I originally estimated.

Also, the cost I used for new pipe was conservatively high. As I stated on page 3 of my rebuttal testimony, the methodology I used results in the estimated cost of installing new pipe being 40% to 70% higher than the estimated cost used by the Company.

1 Finally, as noted by Mr. Levesque on page 4 following his
2 rebuttal testimony, the chemical treatment cost I used was much higher
3 than actually experienced by KCPL.

4 Q. How does the conservatism in your estimates compare to
5 the criticisms by the Company that your estimates are too low?

6 A. To the extent there may be some validity to the Company's
7 arguments, I believe my overestimating exceeds my underestimating.

8 Q. Does this conclude your surrebuttal testimony?

9 A. Yes, it does.

March 30, 1987

Proposed revision to Robert S. Miller's estimate of manpower level for a high pressure distribution system serving all present customers.

System Proposed By: - All Existing high pressure joints replaced.

- R. S. Miller
- Existing low pressure system replaced with a new high pressure system.
 - All abandonment work of low pressure system completed.
 - 100 new PRV stations installed in existing low pressure customers.

The following is a summary of ongoing functions that will be required to be completed to maintain the proposed system:

Trap and Valve inspection and Maintenance -

In manholes -

50 TRAP M.H.

- 10/day-2 men = 10 man-days/month

40 valve M.H.

- 10/day-2 men = 8 man-days/month

Customer service inspections

- 24/day-1 man = 5.3 man-days/month

126 services

Read condensate meters

- 100/day-1 man = 8 man-days/month

About 200

Change 18 flow meter charts each week	- 18/day-1 man = 4 man-days/month
Water changeout on a 2 year cycle 200 meters	- 3/day-2 men = 5.6 man-days/month
Inspect and maintain 126 pressure reducing stations twice annually	- 4/day-2 men = 10.5 man-days/month
Trap Repair and meter overhaul in shop	- 3/days-1 man = 3 man-days/month
Condensate sampling approximately 100 customers twice annually	- 12/day-1 man = 1.4 man-days/month
Trouble calls at 40/month	- 1hr/call-1 man = 5 man-days/month
Trouble tickets 5/month	- 2hr/ticket-2 men=2.4 man-days/month annually
Total	63.3 man-days/month

63.3 man-days/month x 12 months = 759.6 man-days/year.

2080 hours/year = 260 man-days/year

8hrs/man-day

- 10 vacation days
 - 11 holiday
 - 3 sick
- 236 man-days available/person

$$\frac{759.6}{236} = 3.2$$

The above listed functions apply only to regular scheduled maintenance and does not allow for leak repair and miscellaneous work, such as material handling, vehicle maintenance, etc. Therefore, I propose that four (4)

operation and maintenance personnel would be required to maintain a reliable steam delivery system for the long term.

In addition to the above personnel, one (1) technician type person would be required to maintain steam flow meters, electrical equipment and various control equipment beyond the scope and abilities of the 4 operation and maintenance personnel listed above. This individual would also be available for work required in the proposed new boiler plant to maintain the control equipment associated with boiler operation.

The maintenance of steam mains, service lines, manholes, and handling of material installed in the streets will require at minimum a two (2) man heavy equipment crew capable of operating cranes, backhoes, dump trucks, pavement breakers, jackhammers, shoring jacks, etc., for the purpose of excavating and installing equipment in the streets outside the customer's premises.

The proposed plan proposed that all existing expansion joints be replaced on the existing high pressure system and new high pressure piping be installed to replace the low pressure system.

The majority of existing piping on the high pressure system has been in the ground for over 30 years and will have leaks occurring in it. A conservative estimate would be four (4) leaks/year. This existing piping also has insulation containing asbestos which will lengthen the time spent in making an excavation to expose a steam main for repair. An enclosure needs to be placed over the excavation and all work done with protective equipment to eliminate the exposure of the public and workman to this hazardous material

The new Standards for working with asbestos were implemented in January 1987 and the full impact on manpower and length of time required to repair a steam leak is not documented. I estimate at a minimum the handling of asbestos under the new guidelines will double the length of time required to complete a leak repair in the streets.

4 leaks/year x 2 man crew x 5 days x 2 asbestos factor = 80 man-days/year.
(existing system)

2 leaks/year x 2 man crew x 5 days = 20 man-days/year.
(new system)

Adjusting manhole tops for street resurfacing

4/year x 2 men x 2 days = 16 man-days/year.

Operation of crane for handling equipment

in excavations 5 leaks/1 year x 1 man x 1 day = 5 man-days/year.

Operation of crane in handling equipment

in manholes such as valves and blowdown tanks

6/year x 1 man x 1 day = 6 man-days/year.

Maintenance of existing M.H. roofs, floors and
drains of the manholes on the existing high

pressure system 1/month x 2 men x 1 day = 24 man-days/year.

Total 151 man-days/year.

151 man-days/year = .64 persons/year; Therefore 1 man/year
236 man-days available/person


A code welder will be required for work on the majority of equipment, including trap, valves, pipe, expansions joints etc., throughout the year and also would be used in plant maintenance.

1 man/year

Summary from above:

System Operation and Maintenance personnel	4
Technician	1
Heavy Equipment Crew	1
Welder	1
Supervisor	<u>1</u>
	8

This is the minimum manpower level I would consider feasible to operation and maintain the proposed steam distribution system. It does not include personnel for work required to replace the 23,000 foot of existing pipe that presently is 30 years old. It does not include any personnnel for system expansion or addition of customer services. Since the proposed system is a long range rehabilitation program, I judge it reasonable to increase the minimum work force by 2 heavy equipment operators to accomplish this work over 20 years. This brings the total Distribution System manpower to 10.

 3/31/87
Joe Gawron