

**Kansas City Power & Light Company
2013 Annual Missouri Vegetation Management Report
Pursuant to 4 CSR 240-23.030**

**KCP&L Greater Missouri Operations Company
2013 Annual Missouri Vegetation Management Report
Pursuant to 4 CSR 240-23.030**

**TRANSMISSION and DISTRIBUTION RIGHT-OF-WAY
VEGETATION MANAGEMENT PROGRAM**

April 1, 2014

This program document applies to vegetation maintenance of Kansas City Power & Light Company's ("KCP&L") and KCP&L Greater Missouri Operations Company's ("GMO") transmission and distribution power lines. It meets the requirements of the Missouri Public Service Commission Rule 4 CSR 240-23.030 *Electrical Corporation Vegetation Management Standards and Reporting Requirements*. KCP&L, by operating agreement, provides vegetation management services to GMO.

2013 Annual Vegetation Management Report

Table of Contents

2013 Annual Vegetation Management Report	1
Highly Confidential Information and Data	1
1.0 Introduction	1
2.0 Safety and Reliability	1
3.0 Vegetation Manager	2
4.0 Distribution Vegetation Management Program Strategy	2
4.1. Program Objectives	2
4.2. Maintenance Scheduling Strategy	2
Table 1: Missouri Cycle Lengths in Years	2
4.3. Tree Selection Criteria	3
4.4. Contracting Strategy	5
4.5. Customer Relations	5
4.6. Vegetation Management Practices	6
4.7. Reports and Record Keeping	6
APPENDICES	
Appendix A: KCP&L's and GMO's Distribution Line Clearance Guidelines	
Appendix B: 2013 Distribution Vegetation Management Expense and Performance	
Table 2: 2013 Mo Distribution System Vegetation Management Activities	
Table 3: 2013 Missouri Completion Summary	
Table 4: 2013 Missouri Distribution System Miles	
Appendix C: 2014 Distribution Vegetation Management Budget and Scheduled Performance	
Table 5: 2014 Mo Distribution System Vegetation Management Circuits Scheduled for Maintenance	
Table 6: 2014 Summary Mo Distribution System Vegetation Management Circuits Scheduled for Maintenance	
Table 7: 2014 Missouri Distribution System Miles	
Appendix D: 2013 Transmission Vegetation Management Plan	
Appendix E: 2013 Transmission Performance	

Table 8:	2013 Transmission Completed Activities
Appendix F:	2014 Transmission Vegetation Management Budget and Schedule
Table 9:	2014 Missouri Transmission Planned Activities
Table 10:	2014 Missouri Transmission Work Plan Miles
Table 11:	Complete System Transmission Miles
Appendix G:	Transmission Line List
Table 12:	Missouri Transmission Line List
Appendix H:	2013 Third Quarter FERC Report
Appendix H:	2013 Fourth Quarter FERC Report

2013 Annual Vegetation Management Report

Highly Confidential Information and Data

This report contains information that falls under the definitions of Confidential Information, Critical Energy Infrastructure Information, and/or Critical Infrastructure under the *Rules of Procedure of the North American Electric Reliability Corporation*, Section 1500. In light of the requirements to maintain the confidentiality of information and data that falls under Section 1500, portions of this report are marked as Highly Confidential.

1.0 Introduction

Kansas City Power & Light Company (“KCP&L”) and KCP&L Greater Missouri Operations Company’s (“GMO”) Transmission and Distribution Vegetation Management Program (“Program”) report presents the strategy, key processes, and guidelines for orderly, uniform, safe, and efficient management of KCP&L’s and GMO’s overhead delivery systems. The report reflects vegetation management performed in 2013 and planned for 2014; also, the report describes removal, trimming and spraying methods. The Program is dynamic in nature and, at times, requires adjustment to conform to performance as measured by tree-related service reliability; to take advantage of opportunities to gain efficiency; to incorporate customer feedback; to address changes in regulatory initiatives; and to address other program drivers.

2.0 Safety and Reliability

KCP&L and GMOs’ Transmission and Distribution vegetation management program promotes safe and reliable electric service. Beyond compliance and requirements of a robust vegetation maintenance program under 4 CSR 240-23.030 and the National Electric Safety Code Vegetation Management Section 218 (2007), regular vegetation management mitigates service interruptions and reduces potentially dangerous conditions, like downed power lines.

Crews performing vegetation management working on or near KCP&L and GMO facilities, rights-of-way (“ROW”), or easements are required to follow approved safety guidelines and procedures. Contractors performing vegetation management work are contractually required to comply with government safety and health regulations and KCP&L’s own safety and health standards.

Contractors must, prior to work commencing and at all times during the course of their work, have processes and procedures in place to maintain awareness of the nature and characteristics of KCP&L’s and GMOs’ electric facilities. Foundational to safety is the contractors’ understanding that KCP&L’s and GMOs’ electric facilities are energized during the performance of their work unless, prior to the work commencing, arrangements are made with an authorized KCP&L representative to de-energize the facilities.

KCP&L and GMO are pleased to report that in 2013, no incidents occurred resulting in death or life-threatening or serious injury to persons assigned to perform vegetation management activities or to the public.

3.0 Vegetation Manager

KCP&L employs a vegetation manager to oversee KCP&L and GMOs' vegetation management program, ensuring regulatory compliance and implementation of the program described in this report.

4.0 Distribution Vegetation Management Program Strategy

4.1. Program Objectives

The Program's distribution system objectives are: to promote and maintain safe operation of the distribution system; to support system reliability; to ensure optimum use of resources; and to ensure compliance with regulatory requirements. The Program seeks to achieve these objectives, and reduce outage risk, by managing vegetation; trees, and other vegetation, left unmanaged, impact the number of service interruptions and service restoration efficiency. The Program strategy focuses on maintenance activities that reduce outage risks associated with trees growing into distribution lines and risks associated with trees breaking and then falling onto distribution lines.

4.2. Maintenance Scheduling Strategy

The Program's maintenance scheduling strategy considers: time-based maintenance intervals; voltage; historical reliability; potential vegetation interference of energized lines; and a comparison from year-to-year of the impact on safety and service reliability. Maintenance cycles of distribution lines are based on customer density—urban versus rural¹. Mid-cycle line inspections of primary distribution lines are scheduled to identify conditions requiring maintenance in advance of the regular primary cycle.

Table 1: Missouri Cycle Lengths in Years

Circuit Description	Primary Cycle Length (Years)	Mid-cycle Inspection/selective Tree Maintenance (Years)
Urban Circuits	4	2
Rural Circuits	5 to 6	2 to 3

Primary maintenance cycles result in maintenance of 25-percent of total urban distribution miles on an annual basis and 25-percent of rural distribution miles on an 18-month cycle.

¹ Urban circuits are defined as those with customer density equal to or greater than 35 customers per line mile. Rural circuits are defined as those with customer density less than 35 customers per line mile. 4 CSR 240-23.030(1)(G) and (J).

4.3. Tree Selection Criteria

KCP&L uses a strong prescriptive maintenance approach to tree selection. Professional utility arborists are assigned to create work plans designating specific vegetation for pruning, removal, or treatment by contract crews. Trees are selected based on risk factors, avoiding indiscriminate and wholesale maintenance decisions simply based on a fixed-distance-from-conductors criterion. Trees selected for pruning or removal are characterized as exhibiting observable and predictable threats that pose significant threats to service reliability. Also, trees exhibiting only some of the risk factors may be pruned or removed in anticipation of impacting service reliability.

General selection criteria for tree maintenance include:

- Potential to cause service interruption by growth into or across energized conductors prior to the next scheduled inspection or trim cycle;
- Obvious defects that predispose the tree to failure and damage to electrical facilities; and/or,
- Dead or broken branches hanging over electrical facilities.

Selection factors considered include:

- The natural growth rate of the tree;
- The expected re-growth rate following pruning of the tree;
- The relative wood strength of the tree species and potential for breakage;
- Voltage, construction type, conductor spacing, and conductor covering;
- Legal right to access the area;
- Extent of defects (decay, splits, weak branch attachments, etc.), customers served by the line, and potential for tree limbs or trunks to strike primary conductors in the event they break or fall; and/or,
- Sag of conductors at elevated temperatures and under wind and ice loading and combined displacement of vegetation, supporting structures, and conductors under adverse weather or routine wind conditions.

Trees affecting secondary service lines are the property owner's responsibility and not normally maintained. However, as part of the primary scheduled maintenance cycle, trees growing into service lines may be maintained to avoid deflection of secondary voltage conductors by tree limbs.

4.3.1. Tree Removal (trees larger than 4 inches diameter)

Tree removal, together with stump treatment to prevent re-sprouting, provides permanent clearance, eliminates the potential for removed trees to break and cause damage, and reduces future maintenance costs. However, neither is it practical, environmentally desirable, or welcomed by property owners to remove all trees that effect power lines. Consequently, designation of trees selected for removal is based on cost effectiveness, failure risk, and signed permission of the property owner.

Trees may be designated for removal if:

- Pruning will result in a significant adverse impact on the health of the tree;
- The tree is a hazard tree that poses an unacceptable risk to overhead lines; and/or,
- It is economically advantageous to remove rather than periodically prune the tree.

4.3.2. Hazard Trees

Structurally unsound trees, on or off the easement or ROW, that can fall into electrical conductors are evaluated for possible removal. Hazard tree conditions can include, but not limited to, the following symptoms:

- Dead or dying
- Severe lean
- Weak branches
- Root failure
- Cankers
- Conks (fungal fruiting bodies)
- Internal decay

4.3.3. Brush and Vines (trees smaller than 4 inches diameter)

Removal and/or treatment of small-size brush with herbicides is a cost effective method of reducing future maintenance costs before the brush grows large enough to affect power lines. Brush growing below conductors is designated for removal and stump treatment, mowing, foliar treatment, or individual stem treatment prior to growing to wire height and when it can be cost effectively treated. Vines observed growing on poles and guy wires are selected for cutting and treatment with approved herbicides. Pruning brush should be avoided.

4.3.4. Integrated Vegetation Management (IVM)

KCP&L utilizes principles of Integrated Vegetation Management ("IVM") to control brush on distribution ROW. IVM is an approach

that considers the use of mechanical mowing, hand cutting, and herbicide applications, together with the benefits of biological control to manage undesirable woody vegetation on a ROW. The responsible, targeted use of herbicides is an important component of this approach.

Foliar application of herbicides for control of ROW brush on ROW, as well as basal and cut stump methods, will be used when appropriate. Cut stumps should be treated with an effective herbicide mixture to prevent re-sprouting. Small diameter brush stumps should be treated unless a follow-up foliar application is definitely scheduled.

In rural locations, herbicide application may be scheduled to occur 1 to 2 years in advance of tree maintenance. Brush stems missed during herbicide application can be retreated or cut during the tree maintenance cycle. If brush is too tall to control with herbicides and requires hand cutting or mowing, herbicide application should be scheduled approximately one growing season following cutting.

4.4. Contracting Strategy

KCP&L contracts with several utility tree maintenance contractors as opposed to performing vegetation maintenance exclusively with its own personnel. Contracts are written to combine time and equipment with performance-based components.

4.5. Customer Relations

4.5.1. Customer Inquiries

Customer inquiries generated through KCP&L's Customer Care Center, or other channels, are responded to by the appropriate vegetation management individual by personal meeting, telephone, or letter. Requests for tree trimming, removal assistance, or other requests are evaluated by inspection prior to assignment of work to a maintenance crew. Service provided to customers who request assistance with tree removal for the customer's convenience, normally includes removal of overhanging branches and all limbs within ten feet of energized conductors. Any debris is left at the worksite.

Property Owner Notification

KCP&L notifies affected property owners or occupants of pending tree maintenance. Notification is by a combination of personal contact, door hangers, or mailings at least seven, but not more than, ninety days prior to performing scheduled maintenance.

County and Municipal Notification

KCP&L notifies appropriate county and municipal officials in writing at least two months in advance of planned vegetation management work in their respective jurisdictions. The notice includes planned dates and locations of scheduled vegetation maintenance

and other information relevant to the particular municipality or county. The primary contact for each municipality or county is selected by mutual agreement between KCP&L and the highest elected official in the jurisdiction or highest appointed official if there is no elected official.

Public Outreach

KCP&L provides information to the public through its Website, publications, and community events, regarding its vegetation management program and appropriate trees to plant near overhead lines. Also, KCP&L annually mails information to KCP&L and GMO customers regarding vegetation management.

Vegetation Management Practices

Industry Standards

Vegetation management contractors are required to comply with federal, state and local laws and regulations, including those of the U.S. Occupational Safety and Health Administration. Also, vegetation management contractors are required to follow industry safety standards such as, the *American National Standards Institute (ANSI) Z133.1 – 2006, Pruning, Trimming, Repairing, Maintaining, and Removing Trees and Cutting Brush – Safety Requirements, 2006. ANSI A-300 (Part 1) - 2001 Tree, Shrub and Other Woody Plant Maintenance – Standard Practices*—a requirement as it applies to utility tree pruning. Furthermore, contractors are required to implement the pruning concepts presented in the booklet, *Pruning Trees Near Electric Utility Lines*, by Dr. Alex L. Shigo.

KCP&L Vegetation Management Guidelines and Clearance Standards

KCP&L Vegetation Management Guidelines, Appendix A, provide guidance to the performance of work by the vegetation management contractors. Included as part of the guidelines are standards for clearance at the time vegetation is maintained. For conductors energized at 600 to 50,000 volts, the minimum required clearance is ten-feet or clearance to the edge of the ROW, whichever is less. Mature trees, whose trunks or limbs have sufficient strength and rigidity to prevent the trunk or limbs from damaging the conductor under reasonably foreseeable wind and weather conditions, may be retained within ten-feet of conductors.

Post-Work Inspection and Acceptance

KCP&L, as part of its contract management process, inspects work following completion by vegetation maintenance contractors and prior to final acceptance. This inspection/audit process ensures the work performed is of acceptable quality, completeness, and consistent with work plans and specifications.

Reports and Record Keeping

Operational Reporting

Complete records and reporting are important to effective management of vegetation management programs. Records are maintained to identify key aspects of the vegetation management program, to document program performance, and provide information necessary for ongoing program management, including:

Completed work data (substation and circuit designation, date worked, crew size, supervisor and type of work performed);

Cost metrics (cost per mile, cost per circuit, scheduled work, reactive work, etc.);

Contractor performance (man-hours per unit, miles completed, schedule attainment, etc.);

Schedule of future work by substation and circuit; and,

Safety hazards encountered by contractors and OSHA reportable events or accidents.

Regulatory Reporting

KCP&L and GMO submit quarterly and annual reports to the Missouri Public Service Commission ("MPSC"). The quarterly report is submitted approximately six weeks after the quarter ends. It is required under the terms of KCP&L's and GMO's *Non-Unanimous Stipulation and Agreement* (Case Nos. ER-2008-0089, ER-2009-0090, respectively.), and provides data regarding Program expenditure, miles planned, and miles completed on the distribution and transmission systems.

The annual report—the instant report—is filed with the MPSC on or before April 1st of each year pursuant to 4 CSR 240-23.030. It summarizes the vegetation management program success for the previous year, a plan for the current year, and an affidavit, verified by an officer with knowledge of the matters stated therein. Similarly to the quarterly reports, the annual report includes:

vegetation management expenditures for the preceding year;

vegetation management budget for the current year;

circuits, completion dates, and miles trimmed in the preceding year;

circuits, completion dates, and miles scheduled for the current year; and,

total distribution miles for the system and corresponding classification between rural and urban.

The Companies understand material changes contemplated in vegetation management scope, guidelines, or standards are to be filed with the MPSC no later than thirty (30) days prior to implementing the change, and verified by affidavit of an officer with knowledge of the matters stated therein. Additionally, the Companies will report to the MPSC a failure to meet requirements under the *Electrical Corporation Vegetation Management Standards and Reporting Requirements* (4 CSR 240-23.030) within 30 days of discovery and include a mitigation plan for the irregular operation.

AFFIDAVIT OF DUANE D. ANSTAETT


STATE OF MISSOURI)
) ss
COUNTY OF JACKSON)

Duane D. Anstaett, being first duly sworn on his oath, states:

1. My name is Duane D. Anstaett, I work in Kansas City, Missouri, and I am employed by Kansas City Power & Light Company as Vice President, Delivery.
2. I have knowledge of the matters set forth in *KCP&L Greater Missouri Operations Company (GMO) 2013 Annual Missouri Vegetation Management Report Pursuant to 4 CSR 240-23.030*.
3. I hereby swear and affirm that the report is true and accurate to the best of my knowledge, information and belief.



DUANE D. ANSTAETT

Subscribed and sworn before me this 1st day of April, 2014.



Notary Public

My Commission expires: Feb 4 2015



APPENDIX A – KCP&L's and GMO's DISTRIBUTION LINE CLEARANCE GUIDELINES

About This Guideline

KCP&L's and GMO's Distribution Line Clearance Guidelines ("Guidelines") are intended as a contractor's guide to implement KCP&L and GMOs' Distribution Vegetation Management Program. The Guidelines' underlying principle is that each tree, and tree species, has its own unique growth pattern, condition, proximity to conductors, structures and other obstacles, and will require the exercise of professional judgment in implementing the guidelines.

The Guidelines apply to vegetation management of KCP&L's and GMOs' distribution system, including voltages from 600 to 35,000 Volts.

Note: *The Guidelines are not intended as personal safety guidelines¹.*

(1) Introduction

A copy of the Guidelines and the book, *Pruning Trees Near Electric Utility Lines*, by Dr. Alex L. Shigo shall be kept on each crew truck and available at every work location.

The Distribution Vegetation Management Program (hereinafter called the "Program") objective is to help maintain safe, reliable, and least cost electric service, while complying with all regulatory requirements. The Program helps achieve this overall objective by efficiently managing vegetation to reduce outage risk. Left unmanaged, trees and other vegetation can become a leading source of power interruptions during non-storm events and can delay outage restoration associated with major and regular weather events. The Program's strategy focuses on maintenance activities that help reduce tree-caused outage risks associated with trees that grow into lines and risks associated with trees breaking and falling onto lines.

The objectives of the Program are to be achieved within the framework of positive customer relations and using sound environmental practices. The Program also provides incentives to the Contractor to exceed specific production and quality criteria. On the other hand, the Program penalizes Contractors for failing to maintain specific production and quality criteria. KCP&L, and/or its designated representative, is exclusively responsible for program oversight.

(2) Line Clearance Guidelines

(A) Pruning and Removal Guidelines

¹ While the Guidelines may comment on safety issues, Contractors and their crews performing vegetation management work on or near KCP&L and GMO facilities, rights-of-way, or easements are contractually required to follow government safety and health regulations and KCP&L's own safety and health provisions.

All tree pruning shall be governed by approved principles of modern arboriculture and shall adhere to industry standards, including, ANSI A-300 and Z-133 standards and the natural pruning method. KCP&L representatives, in certain cases, can grant exceptions to these pruning standards where mechanical trimming equipment is used. Pruning shall be done in a manner that protects current tree health and with regard for future growth and development.

(B) Voltages

Vegetation management for voltages of (35,000) volts and higher are considered to be Transmission voltages and are deferred to the Transmission Program.

Vegetation management for distribution lines energized at 35 kV and below are maintained by the Program. Primary voltages range from 600 to 34,500 Volts, and are further defined as follows: Backbone consists of (3) energized conductors, and Lateral consists of (1) or (2) energized conductors. Conductors with voltages of less than 600 Volts are considered Secondary voltage. The neutral wire has the potential to carry primary voltage, which CONTRACTOR shall take into consideration when clearing primary lines.

(C) Clearance for Primary voltages

For primary conductors, radial clearance to be achieved at the time of maintenance is 10 feet.

Sub-transmission lines and Backbone lines shall be trimmed vertically to remove overhanging limbs to the widths prescribed in paragraphs (2)(C)1.

Any tree affecting or potentially affecting a primary distribution line shall be trimmed to help maintain reliable service. The following factors are considered during the clearance process: The natural growth rate per species; The re-growth rate of the tree species (how fast the branches grow back after pruning), see Section 9 "Tree Re-growth Rates"; The wood strength of the tree species (what is the chance of the branch breaking under the load of strong wind, snow, ice); the voltage conducted by the line (the risk presented by the branch contacting the line; the higher the voltage, the greater the risk); branches rubbing insulated wires and broken or hanging tree branches.

The radial clearances in subsection (2)(C) are minimum clearances that should be established between the vegetation and the energized conductors and associated live parts where practicable. Vegetation management practices may make it advantageous to obtain greater clearances than those listed. In the event that the specific trimming conflicts with any other materials within this section, the strictest rules shall apply.

Notwithstanding any provision to the contrary in this section (2), mature trees whose trunks or limbs have sufficient strength and rigidity to prevent the trunk or limbs from damaging the conductor under reasonably foreseeable wind and weather conditions are exempt from the minimum clearance requirements in this section (2).

Minimum clearances may be subject to limitations of right-of-way width or legal access. All dead wood shall be removed when it is a risk to conductors or when the KCP&L directs the CONTRACTOR to do so.

(D) Clearance considerations for Secondary Conductors, (600) volts or less

Open Wire secondary shall be cleared to the same standards as lateral primary conductors.

Triplex, street light and service lines shall be cleared only to remove **hard contact**, or deflection of the line's intended path.

All dead wood shall be removed when it is a risk to conductors or when the KCP&L directs the CONTRACTOR to do so.

(E) Clearance considerations for other electrical equipment

The neutral wire has the potential to carry primary voltage, which CONTRACTOR shall take into consideration when clearing primary lines.

Guy Wires and poles shall be cleared on a case by case basis as determined necessary during field inspection, to free them from weight, strain, or displacement caused by contact with trees.

All dead wood shall be removed when it is a risk to conductors or when the KCP&L directs the CONTRACTOR to do so.

(F) Removal Considerations for trees greater than 4" DBH

If the amount of tree crown to be removed in order to obtain adequate clearance will have an adverse impact on the overall long term health of the tree, the tree will be considered for removal.

Tall-growing trees within the width of the right-of-way shall be considered for removal.

Hazard trees that pose a risk to the utilities overhead facilities shall be considered for removal. Hazard tree conditions could include, but are not limited to the following symptoms: Dead or dying, severe lean, weak branches, root failures, cankers, conks or internal decay.

All removed trees should be cut as close to the ground as practical and chemically treated to prevent resprouting.

Trees where the cost of removing is equal to or less than the cost of trimming shall be considered for removal.

(G) Brush considerations

Brush is defined as any tall growing tree that is less than 4" DBH. Brush also includes vines growing on or around KCP&L and GMOs' overhead facilities.

Brush that has been planned to be removed shall be basal treated or cut as close to ground level as practical and chemically treated to prevent resprouting.

Vines shall be cut off approximately one foot above ground level. All vines shall be treated with herbicides below the cut.

Brush (as defined in (2)(G)1) that has been selected for removal and is located within the width of the right-of-way shall be removed and treated.

Second growth from stumps cut on previous pruning cycles shall be removed if it has been planned.

(H) Debris disposal

Unless specified otherwise, CONTRACTOR shall dispose of all debris resulting from scheduled maintenance work. Wood too large to be chipped shall be cut into fireplace lengths (approximately 18" lengths) and stacked on-site unless the homeowner requests the wood to be removed.

CONTRACTOR shall remove all debris produced from scheduled maintenance within 5 business days, unless property owner gives consent to leave debris.

Disposal of chips, wood and brush is the responsibility of the contractor.

Any debris resulting from outages and/or storms will be left on site.

(I) Herbicide treatment

The CONTRACTOR shall provide all necessary herbicide products and comply with applicable Laws regarding the application, storage and handling.

The CONTRACTOR shall use the most effective herbicide available for any given situation to prevent regeneration of vegetation and subject to approval by KCP&L. The applicable MSDS shall be submitted as part of the approval process. Herbicides shall be applied according to manufacturer instructions. Consideration must be given to the surrounding vegetation and soil conditions to prevent damage to other growth or surface water or ground water.

CONTRACTOR shall warranty herbicide treatment for one (1) year after application and remedy any new growth identified.

(3) Maintenance Cycle

(A) Missouri Maintenance Cycle

Urban circuits are defined as circuits with a customer density equal to or greater than 35 customers per line mile.

Rural circuits are defined as circuits with customer density less than 35 customers per line mile.

Urban circuits, both backbone and lateral, shall be maintained on a four (4) year cycle.

Rural circuits, both backbone and lateral, shall be maintained on a five (5) or six (6) year cycle.

Urban circuits shall be inspected every two (2) years. Where needed, vegetation maintenance will occur in a timely manner.

Rural circuits shall be inspected at least every three (3) years. Where needed, vegetation maintenance will occur in a timely manner.

(4) Outage/Storm Response

(A) On-Call/Call Out

In the event of an emergency and when specifically requested by KCP&L, contractors shall provide crews to perform work after hours and on week-ends and holidays, as necessitated by the emergency. Work that is unrelated to the restoration of reliable electric service shall not be performed. On such emergencies, only essential work (i.e. no chipping of brush) shall be done per tree as required to restore electric service rapidly.

If necessary a Vegetation Management Supervisor will report to dispatch headquarters to aid in the dispatching of tree crews.

Improper pruning during outage/storm response work may occur due to unsafe conditions.

Fallen trees, broken limbs and all trimmings and cut vegetation associated with service restoration are left on site. Crews shall not inform customers that KCP&L will return at a later day to clean up the trimmings and cut vegetation.

(5) Customer Request Process

(A) Customer requests

Customer requests generated from KCP&L's call center or other designated source are managed by the vegetation management staff. Customer requests can include but are not limited to: Trim for Line Clearance; Customer Assisted Removal; Check for Drop Service; Pick Up Brush.

Customer requests will be inspected and the customer will be notified with the specific action that will be taken.

Under some circumstances, a customer request may be answered by a standard letter. Response time to customer requests will vary depending on the number of requests in the system and the type of work required.

When necessary and with customer consent, brush will be left on-site.

For customer requested assistance for tree removal, any tree(s) to be removed by customer will have all overhang removed and ten feet (10') of clearance from all energized conductors will be provided.

(6) Notification Process

(A) Landowner Notification

For regularly schedule maintenance, customers will be notified in person or by door card with appropriate contact number, by a KCP&L representative. Questions regarding the scheduled work will be answered at this time. Notice to affected property owners or occupants will occur at least seven (7) days, but not more than ninety (90) days, prior to performing planned vegetation maintenance. Alternative notification methods may include direct mail, postcard or bill insert. KCP&L shall maintain a record of the dates, content, and addresses to which all notices provided were given until the subsequent scheduled vegetation management cycle has occurred for each affected property owner or occupant.

KCP&L and or its representative must secure signed permission to remove any tree equal to or greater than 4" DBH.

If vegetation management is necessary and the landowner refuses permission, the concern will be addressed by KCP&L and or its representative.

(B) Public notification

KCP&L shall provide written notice of any pending vegetation management activities to a primary contact for each county and municipality affected. The primary contact shall be selected by mutual agreement between KCP&L and the highest elected official, or if no elected official, then the highest appointed official, of the county and municipality. Notice shall be made in writing to the primary contact designated under subsection above (6)(B)1, at least two (2) months in advance of the planned vegetation management. This notice shall include the planned dates and locations of the vegetation management and the vegetation manager's name and contact information.

(7) Contractor Guidelines

(A) Appearance and Conduct

All contract line clearance workers shall maintain professional appearance and conduct and shall adhere to the following guidelines. The following guidelines are neither intended to be nor should they be considered to be inclusive. The contractor:

- shall be courteous to customers at all times;
- shall not engage in "horseplay" while on the job;
- shall not use language that is profane, boisterous, derogatory, racial, or of an ethnic nature;
- shall not display sexually suggestive objects or pictures, such as t-shirts, magazines, calendars or posters;
- shall not use customers' property (i.e. patios, picnic tables, etc.) for breaks;
- shall not leave refuse from lunches, etc. on private or public property;
- shall not enter the customer's house;
- shall refrain from climbing over or standing on any fence, garage, tool shed, etc. unless absolutely necessary to access work and only when it can be done safely and without damaging customers' property;
- shall not solicit private work, including tree work, while performing work pursuant to this Contract;
- shall not obligate KCP&L to make any payments to another party, nor make any promises or representations of any nature to another party for or on behalf of KCP&L/GMO;
- shall maintain neat appearance at all times and;
- shall wear clothing and hard hat displaying CONTRACTOR's color and/or emblem.

(B) Supervision

The CONTRACTOR shall ensure that it has adequate supervisory personnel on the property to ensure that all of the CONTRACTOR's crews on the property are properly supervised. CONTRACTOR's personnel shall provide the interaction and communication with KCP&L as required by this Contract. Such supervisory personnel shall be called "General Foremen" in these guidelines.

All contract supervisors and General Foreman will be Certified Arborists through the International Society of Arboriculture (ISA). Employees currently in these positions will have six months to obtain the certification; newly assigned supervisors and general foreman shall obtain their certification within twelve months.

(C) Identification

All General Foreman and Crew Forman shall possess identification stating employee name, employer, as well as documentation stating the contractor is providing vegetation management services for KCP&L.

(D) Employment expectations

CONTRACTOR shall conduct pre-employment and random drug and alcohol screening to detect the presence of amphetamines, cocaine, marijuana, opiates, and phencyclidine, at no additional cost to KCP&L.

CONTRACTOR shall conduct pre-employment background check for felony criminal convictions and motor vehicle violations for all states of residency within the past five (5) years, at no additional cost to KCP&L.

(E) Vehicles

All vehicles and equipment shall be in good working condition, kept clean and organized at all times, maintaining a professional appearance. All trucks shall clearly display CONTRACTOR markings and vehicle numbers. Truck numbering should be visible from both side and the back. Also, the numbering should be large enough to be legible from a distance commonly encountered in traffic, i.e., several car lengths or across a four-lane intersection.

Each General Foreman and Crew shall be equipped with a two-way communication device at no additional cost to KCP&L. If radios are supplied by KCP&L, the contractor will replace all lost or stolen radios.

Cones will be placed at a highly visible area (street intersections, driveways, alleys, etc.) when a crew's work location is not readily detectable, as recommended by Missouri Department of Transportation.

(F) Time Fulfillment

All work shall be performed Monday through Friday, except under special circumstances as agreed by KCP&L. The CONTRACTOR and KCP&L shall mutually agree to the working hours in accordance to IBEW local 53. Any approved overtime shall be paid at the rates set forth in contract, depending on the circumstances, by KCP&L for any work performed in excess of 40 hours per week.

While on **stand-by**, crew(s) shall be dumping chips, fueling trucks, maintaining chainsaws, and engaging in other productive duties. *Crews sitting for the 2-hour show up time shall not charge time towards their perspective equipment.*

Holidays - CONTRACTOR may, upon receipt of permission from KCP&L, work at straight time on any KCP&L-observed holiday.

(G) Certification and permits

The CONTRACTOR shall acquire all certifications and permits required by local, county, municipality, state, tribal and federal agencies in which the CONTRACTOR's crews will be performing work pursuant to this Contract.

(H) Refusal/Access

In the event that the CONTRACTOR encounters conditions prohibiting performance of Work, the crew foreman will make, and document on Work Log, all reasonable efforts to secure access. CONTRACTOR shall notify KCP&L after all reasonable efforts to secure access have failed. A locked gate shall not, in and of itself, constitute "No Access".

CONTRACTOR shall not be entitled to additional compensation for No Access.

In the event that a property owner refuses access to the work scheduled, the crew foreman will notify KCP&L and move on to the next job site. Work will not be performed until KCP&L has notified the CONTRACTOR that access has been granted.

(I) Reporting

The CONTRACTOR shall collect and report key aspects of the vegetation management program to document program performance and provide information necessary for ongoing program management including:

CONTRACTOR Weekly Work Log

Weekly TRES timesheets

Daily Crew Locations

A record of any safety hazards encountered

Any unexpected occurrence or accident resulting in death, life-threatening or serious injury to a person assigned to perform vegetation management activities or the public.

Additional documentation as requested by KCP&L

(J) Contact information

KCP&L and the CONTRACTOR shall provide each other as needed, a list of all Vegetation Management personnel, and the phone numbers where each can be contacted, including pagers/beepers/cell phones.

(K) Communication

During the progress of the work, CONTRACTOR shall provide crew locations to KCP&L staff as requested. In the event the CONTRACTOR plans to deviate from the normal work schedule, e.g. leaving the job site or starting location due to inclement weather or other cause, the foreman shall notify the appropriate personnel immediately.

(L) System Awareness

The CONTRACTOR shall at all times be aware of the nature and characteristics of the electric facilities, including circuit voltage. It is understood that all circuits shall remain energized during the performance of work. Any exceptions must be authorized and scheduled by KCP&L. If in the judgment of the Contractor's general foreman/supervisor, it is hazardous to prune or remove trees with the circuits energized, the Contractor must contact an authorized KCP&L representative. If appropriate, KCP&L will provide the necessary protective materials or de-energize circuits to ensure the safe pruning or removal of the tree(s).

Should the Contractor knock down or come into contact with conductors (power lines), the Contractor shall immediately notify KCP&L and take the necessary protective measures. All Contractor-caused electric service interruptions are subject to repair at the Contractor's expense. This includes any damage to customers' property, including any electrical damage.

In the event a Contractor becomes aware of any broken, damaged, loose or faulty line facilities in the normal course of its line clearance performance, the Contractor shall promptly notify KCP&L as to the exact location(s) and nature of the condition found. The CONTRACTOR's Representative (i.e. Regional Manager or designated representative) and General Foreman shall attend meetings as scheduled by KCP&L to discuss work practices and issues.

(M) Expectations

CONTRACTOR shall insure that crews are being productive at all times.

CONTRACTOR shall perform Work as identified by KCP&L. The CONTRACTOR shall only accept work assignments from KCP&L's designated representative. The CONTRACTOR shall make an attempt to contact the homeowner at each property they have planned work.

(8) Definitions

basal treatment - Herbicide application covering the entire stem to approximately 18 inches above the soil

brush - a woody plant that is less than 4 inches DBH, that is not part of an existing tree, and that may reach the conductor at maturity.

brush work – trimming, clearing brush and applying a herbicide to the cut stems, or only applying herbicide to brush.

clearance - the distance between vegetation and the conductors.

coniferous - any of the cone-bearing trees or shrubs, mostly evergreens.

DBH - "diameter at breast height" – the diameter of individual tree trunks or individual stems of brush measured at a point 4.5 feet above the ground.

deciduous - any perennial plant that sheds its leaves annually at the end of a growing season.

demand tree trimming - trimming or removing trees on a customer requested or emergency basis. Also may include tree work associated with line construction projects. This is typically required when trees have grown into the conductors, or are close to the conductors, and have created a potentially dangerous situation. This may also include special trimming or chipping work when requested by the Utility. Customer requested only Utility authorized representatives may assign demand tree work.

directional pruning - a form of natural pruning used to encourage tree regrowth away from the conductor. It is accomplished by removing limbs growing toward the conductors entirely at the branch collar near the trunk of the tree, or by pruning to lateral branches that are at least one-third the diameter of the limb being cut and are growing away from the conductor.

drop-crotching - is a crown reduction technique in which a tree trimmer makes proper pruning cuts at crotches, removing the larger limb and favoring the smaller. For electric line clearance, the trimmer would remove limbs growing toward the conductors and favor those growing away from the conductors. This usually results in a "V" shaped appearance of the tree crown and is frequently referred to as "V-trimming". See definition of "natural pruning" for further description.

evergreen - any plant that retains its leaves/needles year-round.

foliar herbicide application - the application of a herbicide to the leaves or needles of a target plant.

hazard trees - trees that are located off the right of way, have a high probability for failure and are of sufficient height to contact the conductors and/or structures and guy

wires if they were to fall in that direction, and should be cleared. Conditions could include but are not limited to the following: Dead, dying or diseased, leaning trees, weak branches, shallow root system, root failure, internal decay, canker or canker root.

herbicide - a chemical pesticide used to control, suppress, or kill plants.

natural pruning - a method by which branches are cut to the branch collar at a suitable parent limb, the trunk of the tree, or an appropriately sized lateral branch. This method of pruning is sometimes called "drop-crotching", "proper pruning", the "Shigo method" or "lateral trimming."

preventative maintenance - trimming or removing vegetation on a systematic basis typically by, but not limited to, circuit or grid, and in a manner intended to achieve system reliability.

pruning - the removal of dead, dying, diseased, interfering, objectionable, and/or weak branches of trees or shrubs using proper arboricultural techniques.

removal - completely removing an entire tree as close as practical to ground level and applying herbicide to the cut stump when appropriate.

right-of-way - a transmission or distribution right-of-way, an easement, a utility easement, or any other corridor of land paralleling, on both sides, an overhead transmission or distribution line, and in respect of which the Utility has certain rights.

rounding over - the making of many small cuts so that a tree underneath the conductors is rounded over in a uniform curve. This creates an unhealthy tree condition and results in rapid regrowth directly back toward the electrical conductors. This is not an acceptable practice.

safety zone work – removing all overhang and cutting back limbs to a minimum clearance of 10 feet from the energized conductor.

selective herbicide - a herbicide that, when applied to a mixed population of plants, will control specific species without injury to others.

shearing - the making of many small cuts so that a tree adjacent to the conductors is sheared in a uniform line. This is not a generally acceptable practice.

show-up site – site where CONTRACTOR crews receive work assignments.

side pruning - using natural pruning methods to cut back or removing side branches that are threatening the conductors; required where trees are growing adjacent to conductors.

stump treatment - applying an approved herbicide to the outer ring (cambium) portion of the stump to reduce or eliminate re-growth.


sucker growth - the re-growth within the tree that originates near the cuts made during the previous trimming.

the property - any work site associated with this contract.


topping - cutting back the upper crown of a tree to a uniform horizontal line, leaving multiple stubs. This is an improper and unacceptable trimming technique.

tree - a perennial plant with a woody trunk measuring at least four (4) inches DBH, and having one set of annual rings at ground level or more than one set of annual rings not separated by included bark. Trees that grow adjacent to one another and share an apparent common base completely separated by "included bark" are considered to be distinct trees. "Included bark" is bark that is included within the wood of a tree, or between the woody stems of separate trees, creating a physical separation between the trees.

single tree- a tree that splits above the ground line and has no visible included bark seam down to the ground line.



multiple trees- Any tree that splits at the ground line or any tree that splits above the ground line but has a visible included bark seam down to the ground line.



tree size classifications - tree diameter as measured at breast height (DBH):
4" to 8", 8" to 12", 12" to 24", 24" and greater

tree crown - the upper portion of the tree; the branches or leaf area.

trimming - cutting back tree branches or shrubs to shape or reduce the size of the tree or shrub.

V-trim - using natural pruning methods to cut back large portions of the upper crown of a tree. This is required when trees are located directly beneath a conductor. This is also known as crown reduction pruning or drop-crotching.

vegetation - all the plant (flora) life in a particular region. A plant community, assemblage, or aggregation with distinguishable characteristics

(9) Tree Re-growth Rates

Average Annual Re-growth Rates for Individual Species on the KCP&L and GMO Distribution Systems.

<u>Species</u>	<u>Pruning Type</u>	<u>Inches of Re-growth by Age of Sprout</u>					
		<u>1 Yr.</u>	<u>2 Yr.</u>	<u>3 Yr.</u>	<u>4 Yr.</u>	<u>5 Yr.</u>	<u>6 Yr.</u>
Silver Maple	Side	55	67	84	101	118	135
	Top	71	92	113	134	155	176
Hackberry	Side	36	56	78	87	100	104
	Top	53	81	104	120	140	161
Ash	Side	33	63	84	98	115	132
	Top	26	61	88	118	134	161
Honeylocust	Side	36	68	91	115	135	162
	Top	48	81	115	128	147	173
Black Walnut	Side	43	71	87	103	119	130
	Top	69	103	144	166	183	212
Eastern Redcedar	Side	7	11	17	22	27	34
	Top	17	29	41	53	65	79
Osage-Orange	Side	67	89	111	133	155	177
	Top	81	105	129	153	177	201
Mulberry	Side	28	50	75	86	126	141
	Top	52	96	129	163	202	241
Scotch Pine	Side	12	22	29	37	46	54
	Top	13	25	35	44	53	59
Sycamore	Side	71	112	137	158	176	194
	Top	26	96	132	176	225	275
Eastern Cottonwood	Side	48	80	101	128	160	192
	Top	67	105	147	176	196	209
Shingle Oak	Side	43	57	71	87	94	103
	Top	17	36	54	66	77	88

<u>Species</u>	Pruning <u>Type</u>	<u>Inches of Re-growth by Age of Sprout</u>					
		<u>1 Yr.</u>	<u>2 Yr.</u>	<u>3 Yr.</u>	<u>4 Yr.</u>	<u>5 Yr.</u>	<u>6 Yr.</u>
Pin Oak	Side	27	45	57	68	82	91
	Top	30	59	80	94	106	126
Elm	Side	50	83	111	133	152	203
	Top	53	93	124	158	193	226

APPENDIX B – 2013 Distribution Vegetation Management EXPENSE AND PERFORMANCE

Summary

KCP&L manages vegetation for itself and GMO through an Integrated Vegetation Management (“IVM”) program. The IVM includes, but is not limited to: manual techniques, mechanical techniques, biological, chemical, and cultural control. Standard crew sizes are three workers on a manual crew and two workers on a bucket crew. Safety hazards may be encountered daily thereby requiring the contractor’s certified line clearance trimmer to assess and take proactive measure(s) to safely clear limbs from power lines.

Expenditures – 2013

2013 distribution vegetation management expenditures for Missouri service areas:

KCP&L	\$9,047,511
GMO	\$7,306,736
Total	<u>\$16,354,247</u>

Vegetation Management Activities – 2013

Table 2 summarizes vegetation management activities completed in 2013 on distribution circuits in KCP&L and GMO Missouri service territories.

Table 2: 2013 MO Distribution System Vegetation Management Activities

Company	Circuit	Classification	Miles	Completion Date
KCPL	10411	U	12.83	8/17/2013
KCPL	10421	U	4.35	8/10/2013
KCPL	109	R	0.57	9/21/2013
KCPL	1111	U	3.95	1/19/2013
KCPL	1114	U	4.09	3/2/2013
KCPL	1142	U	6.74	3/2/2013
KCPL	1161	U	3.93	12/28/2013
KCPL	1162	U	1.02	12/28/2013
KCPL	12722	U	31.8	7/13/2013
KCPL	2334	U	12.22	5/11/2013
KCPL	2343	U	21.59	5/4/2013
KCPL	2354	U	17.21	11/9/2013
KCPL	2372	U	16.64	11/2/2013
KCPL	2373	U	8.08	2/2/2013

Company	Circuit	Classification	Miles	Completion Date
KCPL	2374	U	8.44	7/13/2013
KCPL	2442	U	2.35	9/21/2013
KCPL	2473	U	0.09	9/21/2013
KCPL	2511	R	54.3	11/2/2013
KCPL	2611	R	16.76	12/7/2013
KCPL	2712	U	3.96	11/2/2013
KCPL	2714	R	1.68	4/6/2013
KCPL	2721	U	9.17	8/31/2013
KCPL	2743	U	5.62	4/13/2013
KCPL	3011	U	11.2	12/14/2013
KCPL	3022	U	11.34	10/26/2013
KCPL	3142	U	1.02	1/12/2013
KCPL	3144	U	7.62	12/21/2013
KCPL	3513	U	14.61	8/3/2013
KCPL	3542	U	15.02	5/25/2013
KCPL	3543	U	9.25	9/21/2013
KCPL	3553	U	0.38	2/9/2013
KCPL	36	R	0.17	9/7/2013
KCPL	3711	U	7.77	4/6/2013
KCPL	4852	U	3.82	2/2/2013
KCPL	4854	U	2.88	1/26/2013
KCPL	4953	U	8.36	9/7/2013
KCPL	5261	U	14.58	8/24/2013
KCPL	5262	U	3.48	12/28/2013
KCPL	5337	U	9.8	5/18/2013
KCPL	5371	U	18.61	12/21/2013
KCPL	5612	U	8.67	2/9/2013
KCPL	6011	R	89.93	12/7/2013
KCPL	6113	U	18.71	9/28/2013
KCPL	6132	U	11.64	12/21/2013
KCPL	6134	U	6.57	6/8/2013
KCPL	6151	U	9.65	11/16/2013
KCPL	6152	U	5.58	12/28/2013
KCPL	6311	U	7.78	3/16/2013
KCPL	6341	U	16.01	10/26/2013
KCPL	6613	U	5.56	2/16/2013
KCPL	6621	U	7.69	9/14/2013
KCPL	6624	U	1.89	3/23/2013
KCPL	6632	U	3.74	4/13/2013
KCPL	7143	R	0.58	12/14/2013

Company	Circuit	Classification	Miles	Completion Date
KCPL	7401	U	5.06	1/26/2013
KCPL	7404	U	8.15	2/16/2013
KCPL	7413	U	1.59	1/19/2013
KCPL	7453	U	8.61	3/23/2013
KCPL	7491	U	9.36	3/30/2013
KCPL	7522	U	0.03	10/19/2013
KCPL	7542	U	6.03	11/30/2013
KCPL	7561	U	6.62	12/28/2013
KCPL	7571	U	5.82	12/21/2013
KCPL	7573	U	23.05	12/21/2013
KCPL	7582	U	0.38	12/28/2013
KCPL	7584	U	1	12/28/2013
KCPL	7812	U	8.8	7/6/2013
KCPL	7834	U	5.78	8/24/2013
KCPL	7841	U	11.65	12/14/2013
KCPL	7851	U	9.72	9/14/2013
KCPL	7852	U	9.56	10/5/2013
KCPL	7863	U	11.94	12/14/2013
KCPL	7911	U	10.91	11/23/2013
KCPL	7931	R	82.25	9/21/2013
KCPL	8613	U	15.35	9/7/2013
KCPL	9613	R	1.93	10/5/2013
KCPL	9622	R	3.24	10/5/2013
KCPL	9624	R	1.11	9/21/2013
MPS	20408	U	11.96	11/9/2013
MPS	20812	U	2.29	8/10/2013
MPS	21311	U	7.59	12/7/2013
MPS	21312	U	12.41	12/21/2013
MPS	21321	U	10.14	12/28/2013
MPS	21322	U	8.21	12/7/2013
MPS	21323	U	1.89	12/28/2013
MPS	21411	U	3.38	8/10/2013
MPS	21414	U	2.25	8/24/2013
MPS	21421	U	13.23	12/21/2013
MPS	21432	U	3.7	12/28/2013
MPS	21911	R	36	1/26/2013
MPS	22121	U	3.75	12/28/2013
MPS	23812	U	4.22	3/23/2013
MPS	23911	U	5.88	5/11/2013
MPS	24101	U	16.2	5/11/2013

Company	Circuit	Classification	Miles	Completion Date
MPS	24212	U	12.33	4/27/2013
MPS	24511	U	4.83	3/16/2013
MPS	24512	U	42.09	6/15/2013
MPS	247111	R	26.76	12/21/2013
MPS	24814	U	3.52	12/21/2013
MPS	25311	R	45.22	12/14/2013
MPS	26411	U	5.23	4/20/2013
MPS	26421	U	6.65	4/13/2013
MPS	26423	U	18.85	5/4/2013
MPS	27211	R	20.58	11/16/2013
MPS	27212	U	0.45	10/5/2013
MPS	27214	R	61.83	12/7/2013
MPS	27513	U	29.27	4/13/2013
MPS	27712	U	26.86	7/6/2013
MPS	27721	U	4.26	7/6/2013
MPS	27801	U	13.1	11/9/2013
MPS	28211	U	10.96	7/13/2013
MPS	28212	U	5.14	7/27/2013
MPS	28214	U	2.06	7/20/2013
MPS	28221	U	6.9	7/13/2013
MPS	28231	R	7.96	12/28/2013
MPS	28232	U	0.36	10/5/2013
MPS	28311	U	12.56	2/9/2013
MPS	28312	U	11.89	5/18/2013
MPS	29011	U	4.68	1/19/2013
MPS	29022	U	12.74	3/9/2013
MPS	29041	U	1.07	1/12/2013
MPS	29212	U	6.35	4/6/2013
MPS	30711	R	32.32	6/22/2013
MPS	31011	R	16.33	7/27/2013
MPS	31012	U	12.21	8/3/2013
MPS	31311	R	29.64	11/9/2013
MPS	31511	R	18.67	7/13/2013
MPS	31512	R	19.58	9/28/2013
MPS	31513	R	29.84	9/21/2013
MPS	31911	U	163.36	10/5/2013
MPS	32209	U	24.45	2/23/2013
MPS	32210	U	24.25	5/18/2013
MPS	32624	U	6.3	2/16/2013
MPS	32711	U	17.06	8/10/2013

Company	Circuit	Classification	Miles	Completion Date
MPS	32712	U	13.01	9/28/2013
MPS	33111	U	3.58	8/10/2013
MPS	33321	U	18.42	2/2/2013
MPS	33322	R	7.13	12/28/2013
MPS	35112	R	67.19	4/27/2013
MPS	35512	U	19.21	5/18/2013
MPS	35913	U	3.68	2/16/2013
MPS	35922	U	8.12	4/27/2013
MPS	35923	U	2.59	1/12/2013
MPS	36011	R	42.86	4/6/2013
MPS	36012	R	16.68	2/16/2013
MPS	36531	R	23.72	11/16/2013
MPS	36611	U	13.19	4/27/2013
MPS	37013	R	53.5	7/20/2013
MPS	37111	R	10.21	11/16/2013
MPS	37112	R	9.15	11/16/2013
MPS	37614	R	0.95	1/19/2013
MPS	38112	R	48.47	12/21/2013
MPS	WE2	R	4	10/12/2013
SJLP	247511	R	39.49	7/20/2013
SJLP	247821	R	3.01	5/18/2013
SJLP	247822	R	2.81	5/18/2013
SJLP	247921	R	7.28	6/22/2013
SJLP	38221	U	6.44	1/19/2013
SJLP	38311	R	31.66	12/28/2013
SJLP	38521	U	18.46	9/7/2013
SJLP	38531	U	10.86	6/8/2013
SJLP	38712	R	43.22	10/26/2013
SJLP	38833	U	8.28	1/26/2013
SJLP	39031	U	10.04	2/16/2013
SJLP	39032	U	7.51	2/16/2013
SJLP	39033	U	9.64	7/13/2013
SJLP	39611	U	11.37	4/27/2013
SJLP	41411	R	70.68	11/16/2013
SJLP	41511	U	10.33	10/26/2013
SJLP	41611	U	13.2	3/23/2013
SJLP	41621	U	11.61	5/11/2013
SJLP	42212	R	11.65	12/7/2013
SJLP	42213	R	20.05	11/9/2013
SJLP	43031	U	10.53	12/21/2013

Company	Circuit	Classification	Miles	Completion Date
Total 2013 Miles			2,494.63	

Table 3: 2013 Missouri Completion Summary

Territory	Urban Miles	Rural Miles	Total 12 kV (Urban + Rural)	34 kV	Total 12 kV + 34 kV
KCP&L-Missouri	527.74	252.52	780.26	48.98	829.24
GMO	710.69	858.44	1,569.13	96.26	1,665.39
Total	1,238.43	1,110.96	2,349.39	145.24	2,494.63

Table 4: Distribution System MO Mileage Inventory

Territory	Urban Miles	Rural Miles	Total 12 kV (Urban + Rural)	34 kV	12 kV + 34 kV
KCP&L-Missouri	1,999.03	1,794.30	3,793.33	161.73	3,955.06
GMO	3,110.85	4,281.36	7,392.21	484.67	7,876.88
Total	5,109.88	6,075.66	11,185.54	646.40	11,831.94

Note: Minor differences in distribution system miles occur between annual and quarterly reports. The minor differences reflect regular monitoring of the distribution system that identifies retired or new facilities.

APPENDIX C – 2014 DISTRIBUTION VEGETATION MANAGEMENT BUDGET AND SCHEDULED PERFORMANCE

The listed vegetation management work is planned for completion in 2014. The Program is dynamic in nature and, at times, requires adjustment to conform to performance as measured by tree-related service reliability; to take advantage of opportunities to gain efficiency; to incorporate customer feedback; to address changes in regulatory initiatives; and to address other program drivers. In light of the many variables affecting vegetation management activities, including weather, specific schedule dates were excluded from this appendix.

Budget – 2014

2014 distribution vegetation management budget for Missouri service areas:

KCP&L	\$5,650,095
GMO	<u>\$9,824,434</u>
	\$15,474,529

Table 5: 2014 MO Distribution System Vegetation Management Circuits Scheduled for Maintenance

Company	Circuit	Classification	Miles
KCPL	1112	B/L	2.78
KCPL	1162	B/L	14.54
KCPL	12723	34.5kv	22.90
KCPL	13611	B/L	0.07
KCPL	14001	B/L	0.01
KCPL	14002	B/L	0.01
KCPL	1562	B/L	4.09
KCPL	1565	B/L	3.29
KCPL	1576	B/L	2.35
KCPL	2341	B/L	5.71
KCPL	2352	B/L	8.36
KCPL	2412	B/L	4.44
KCPL	2413	B/L	3.48
KCPL	2414	B/L	2.06
KCPL	2433	B/L	0.84
KCPL	2441	B/L	3.83
KCPL	2454	B/L	0.93
KCPL	26	B/L	0.21
KCPL	2613	B/L	22.32
KCPL	2761	B/L	0.47

Company	Circuit	Classification	Miles
KCPL	3012	B/L	13.99
KCPL	3512	B/L	12.04
KCPL	3531	B/L	5.21
KCPL	3551	B/L	6.24
KCPL	3714	B/L	2.01
KCPL	3724	B/L	0.07
KCPL	3732	B/L	1.92
KCPL	3931	B/L	8.44
KCPL	3932	B/L	0.63
KCPL	4221	B/L	137.78
KCPL	4311	B/L	34.48
KCPL	4413	B/L	1.90
KCPL	479	B/L	2.67
KCPL	4811	B/L	8.76
KCPL	4813	B/L	8.34
KCPL	4822	B/L	1.89
KCPL	4823	B/L	7.53
KCPL	4842	B/L	1.05
KCPL	4851	B/L	3.88
KCPL	4951	B/L	9.22
KCPL	5262	B/L	6.21
KCPL	5332	B/L	16.68
KCPL	5333	B/L	2.58
KCPL	5373	B/L	3.27
KCPL	5382	B/L	12.61
KCPL	5621	B/L	10.14
KCPL	5641	B/L	12.20
KCPL	5642	B/L	16.00
KCPL	5661	B/L	10.64
KCPL	568	B/L	4.84
KCPL	5712	B/L	12.31
KCPL	578	B/L	3.59
KCPL	579	B/L	3.43
KCPL	6152	B/L	11.67
KCPL	6162	B/L	10.49
KCPL	6312	B/L	7.93
KCPL	6332	B/L	12.29
KCPL	650	B/L	2.82
KCPL	6634	B/L	5.82
KCPL	7411	B/L	6.56

Company	Circuit	Classification	Miles
KCPL	7412	B/L	5.11
KCPL	7423	B/L	5.51
KCPL	7433	B/L	2.89
KCPL	7452	B/L	2.57
KCPL	7473	B/L	8.90
KCPL	7512	B/L	0.09
KCPL	7541	B/L	0.50
KCPL	7543	B/L	1.20
KCPL	7563	B/L	3.19
KCPL	7564	B/L	0.91
KCPL	7572	B/L	6.08
KCPL	7582	B/L	6.67
KCPL	7822	B/L	8.02
KCPL	7824	B/L	9.63
KCPL	7843	B/L	5.07
KCPL	7844	B/L	9.72
KCPL	7861	B/L	6.64
KCPL	7862	B/L	5.96
KCPL	7932	B/L	0.04
KCPL	9412	B/L	4.59
KCPL	9414	B/L	1.07
KCPL	9512	34.5kv	16.90
KCPL	9513	34.5kv	16.70
KCPL	9614	B/L	3.53
KCPL	9841	B/L	14.80
MPS	11824	B/L	5.89
MPS	11832	B/L	19.27
MPS	20311	B/L	148.03
MPS	20322	B/L	0.06
MPS	20422	B/L	28.61
MPS	21323	B/L	11.84
MPS	21431	B/L	14.54
MPS	21433	B/L	6.85
MPS	21511	B/L	4.75
MPS	21512	B/L	4.23
MPS	21513	B/L	3.28
MPS	22121	B/L	7.48
MPS	22122	B/L	17.03
MPS	22123	B/L	25.20
MPS	22305	34.5kv	12.50

Company	Circuit	Classification	Miles
MPS	22306	34.5kv	29.43
MPS	22311	B/L	15.10
MPS	22312	B/L	17.11
MPS	22601	34.5kv	22.81
MPS	22711	B/L	2.91
MPS	22712	B/L	3.41
MPS	22713	B/L	0.92
MPS	22806	34.5kv	9.00
MPS	23511	B/L	30.63
MPS	23513	B/L	11.30
MPS	24013	B/L	14.15
MPS	24021	B/L	27.74
MPS	24022	B/L	28.58
MPS	24912	B/L	25.64
MPS	25611	B/L	29.29
MPS	25612	B/L	3.13
MPS	26412	B/L	2.80
MPS	27513	B/L	33.19
MPS	27722	B/L	22.28
MPS	28231	B/L	39.79
MPS	28721	B/L	28.63
MPS	29012	B/L	11.29
MPS	29042	B/L	44.33
MPS	29112	B/L	6.87
MPS	29113	B/L	4.17
MPS	29122	B/L	19.44
MPS	29123	B/L	4.31
MPS	29131	B/L	14.60
MPS	29611	B/L	6.88
MPS	30001	34.5kv	28.20
MPS	30111	B/L	8.62
MPS	30312	B/L	3.59
MPS	30313	B/L	11.81
MPS	30614	B/L	12.02
MPS	31112	B/L	10.69
MPS	31912	25kV	27.61
MPS	32513	B/L	9.60
MPS	32612	B/L	4.76
MPS	32622	34.5kv	3.94
MPS	32631	B/L	20.70

Company	Circuit	Classification	Miles
MPS	32721	B/L	4.53
MPS	33312	B/L	4.61
MPS	33322	B/L	104.82
MPS	335111	34.5kv	36.91
MPS	34141	B/L	17.49
MPS	34152	B/L	10.94
MPS	34712	B/L	6.21
MPS	365111	34.5kv	13.16
MPS	36521	B/L	13.84
MPS	37211	B/L	12.32
MPS	37212	B/L	28.10
MPS	37222	B/L	6.59
MPS	37321	B/L	14.38
MPS	37511	B/L	23.69
MPS	37521	B/L	19.17
MPS	37522	B/L	13.78
MPS	WE1	B/L	6.90
SJLP	247512	B/L	0.07
SJLP	38231	B/L	20.12
SJLP	38241	B/L	5.82
SJLP	38311	B/L	78.65
SJLP	38561	B/L	3.93
SJLP	38822	B/L	12.06
SJLP	38823	B/L	22.48
SJLP	38824	B/L	10.87
SJLP	38831	B/L	7.47
SJLP	39043	B/L	10.87
SJLP	39311	B/L	78.53
SJLP	39412	B/L	21.85
SJLP	39421	B/L	0.18
SJLP	39431	B/L	9.08
SJLP	39441	B/L	8.34
SJLP	39442	B/L	0.97
SJLP	39921	34.5kv	4.43
SJLP	39922	34.5kv	12.76
SJLP	40211	B/L	7.77
SJLP	40212	B/L	8.04
SJLP	40411	34.5kv	3.07
SJLP	40413	34.5kv	3.24
SJLP	40422	34.5kv	2.12

Company	Circuit	Classification	Miles
SJLP	40423	34.5kv	1.71
SJLP	40761	B/L	6.97
SJLP	40782	B/L	15.38
SJLP	41641	B/L	7.44
SJLP	41811	B/L	29.91
SJLP	41911	B/L	33.29
SJLP	42612	B/L	31.46
SJLP	42731	B/L	23.74
SJLP	43311	B/L	8.67
SJLP	43312	B/L	28.53
SJLP	43411	B/L	20.30
Total 2014 Miles			2,527.50

Table 6: 2014 Summary MO Distribution System Vegetation Management Circuits Scheduled for Maintenance

Territory	Urban Miles	Rural Miles	Total 12 kV (Urban + Rural)	34 kV	12 kV + 34 kV
KCP&L-Missouri	432.93	199.68	632.61	56.50	689.11
GMO	787.51	867.60	1655.11	183.28	1838.39
Total	1220.44	1067.28	2287.72	239.78	2527.50

Table 7: Distribution System MO Mileage Inventory

Territory	Urban Miles	Rural Miles	Total 12 kV (Urban + Rural)	34 kV	12 kV + 34 kV
KCP&L- Missouri	1,984.98	1,793.72	3,778.70	161.73	3,940.43
GMO	3,102.63	4,315.68	7,418.31	479.98	7,898.29
Total	5,087.61	6,109.40	11,197.01	641.71	11,838.72

**APPENDICES D THROUGH H
HIGHLY CONFIDENTIAL**

These appendices contain information that falls under the definitions of Confidential Information, Critical Energy Infrastructure Information, and/or Critical Infrastructure under *the Rules of Procedure of the North American Electric Reliability Corporation*, Section 1500. In light of the requirements to maintain the confidentiality of information and data that falls under Section 1500, the appendices are marked as Highly Confidential.