

BEFORE THE PUBLIC SERVICE COMMISSION
OF THE STATE OF MISSOURI

In the Matter of the Verified Application of)
Laclede Gas Company for an Order)
Establishing Replacement Requirements for)
the Final Phase of its Soft Copper Service)
Line Replacement Program Previously)
Approved Pursuant to Case No. GO-99-155)

Case No. GS-2008-0038

ERRATA MODIFYING ORDER

Issue Date: October 7, 2008

Effective Date: October 7, 2008

On September 30, 2008, the Commission issued an Order Continuing Requirements. Within the order, under the Bar-hole Leak Surveys section of the portion titled Staff's September 11, 2008 Annual Report, the Commission incorrectly quoted the "leak rate" percentages and the leak rate comparison from the 2007 and 2008 survey.

This errata corrects the percentages and comparisons stated in the Commission's Order Continuing Requirements. Under the section titled Staff's September 11, 2008 Annual Report, Bar-hole Leak Surveys, the last sentence beginning on page four and continuing to page five should have read as follows: "Observations in the eighth year of Laclede's program indicate that this downward trend is continuing with the 0.53 percent (0.53%) leak rate for the 2008 survey, which

is a reduction from the leakage rate of 0.65 percent (0.65%) found during the 2007 leak survey.”

THE COMMISSION ORDERS THAT:

1. This order shall modify the information provided in the Order Continuing Requirements, issued September 30, 2008.
2. This order shall become effective upon issuance.

BY THE COMMISSION

A handwritten signature in black ink, appearing to read 'Colleen M. Dale', written over a horizontal line.

Colleen M. Dale
Secretary

(SEAL)

Colleen M. Dale, Chief Regulatory Law Judge,
by delegation of authority pursuant to
Section 386.240, RSMo 2000

Dated at Jefferson City, Missouri
on this 7th day of October, 2008.