Exhibit No.:

Issue(s): In Service
Witness: J Luebbert
Sponsoring Party: MoPSC Staff

Type of Exhibit: Rebuttal Testimony

Case No.: ER-2021-0240

Date Testimony Prepared: October 15, 2021

MISSOURI PUBLIC SERVICE COMMISSION INDUSTRY ANALYSIS DIVISION ENGINEERING ANALYSIS DEPARTMENT

REBUTTAL TESTIMONY

OF

J LUEBBERT

UNION ELECTRIC COMPANY d/b/a Ameren Missouri

CASE NO. ER-2021-0240

Jefferson City, Missouri October 2021

		REBUTTAL TESTIMONY
		\mathbf{OF}
		J LUEBBERT
		UNION ELECTRIC COMPANY d/b/a Ameren Missouri
		CASE NO. ER-2021-0240
	Q.	Please state your name and business address.
	A.	My name is J Luebbert and my business address is Missouri Public Service
Com	ımission	, P.O. Box 360, Jefferson City, MO 65102.
	Q.	Are you the same J Luebbert that provided sections in Staff's Direct report in
his _]	proceed	ing?
	A.	Yes, I am.
	Q.	What is the purpose of your rebuttal testimony?
	A.	The purpose of my rebuttal testimony is to provide the Commission an update
St	aff's in-	service analysis for the High Prairie Wind Farm.
	Q.	What was Staff's position at direct?

20

1 Q. Why is Staff updating the in-service analysis? 2 A. Staff requested through follow up data requests, and Ameren Missouri provided, 3 additional information and verification from Ameren Missouri regarding the satisfaction of 4 term 2.c. of the jointly submitted in-service criteria. 5 Q. What does term 2.c. of the in-service criteria require? 6 A. Term 2.c. requires each item on the MCC to have been satisfied and proof that 7 the turbine is ready to commence commissioning.¹ 8 Q. What additional information did Ameren Missouri provide? 9 A. Ameren Missouri's response to Staff Data Request No. 0767 included a 10 list of MCC items that either remained open or had been completed and were considered closed. 11 Ameren Missouri's initial response to Staff's follow up Data Request No. 0767.1 indicated that 12 all but one of the MCC items were resolved as of August 30, 2021. The MCC item that 13 remained open as of September 1, 2021 was a damaged switch with an expected resolution date 14 of September 17, 2021. Ameren Missouri provided a supplemental response to Staff Data 15 Request No. 0767.1 on September 20, 2021, which indicated that the final open MCC item was resolved on September 16, 2021. 16 17 Q. What is Staff's updated position regarding Ameren Missouri's fulfillment of the 18 jointly submitted in-service criteria? 19 A. Based on Staff's analysis, High Prairie has met the in-service criteria as of

September 16, 2021. Since Staff initially developed its revenue requirement as though the High

¹ Commissioning is the process by which a developer tests the operability and condition of mechanical, electrical, and safety components for each wind turbine prior to placing the turbine into operation to produce power. The jointly filed in-service criteria requires the completion of a Commissioning Completion Certificate for each turbine.

Prairie project was in-service, an adjustment based upon failure to meet the in-service requirements is unnecessary at this time.

Q. Do any other Staff members intend to file testimony related to the High Prairie Wind Farm?

A. Yes, Staff witnesses Claire Eubanks and Lisa Ferguson will provide testimony regarding the curtailment of the wind turbines.

Q. Does this conclude your rebuttal testimony?

A. Yes, it does.

BEFORE THE PUBLIC SERVICE COMMISSION

OF THE STATE OF MISSOURI

d/b/a Ameren Missouri's T Revenues for Electric Serv	Tariffs to Adjust Its) Case No. ER-2021-0240		
*	AFFIDAVIT O	OF J LUEBBERT		
STATE OF MISSOURI)) ss.	e e e e e e e e e e e e e e e e e e e		
COMES NOW J LUEBB	SERT and on his o	ath declares that he is	of sound mind and	lawful

age; that he contributed to the foregoing *Rebuttal Testimony of J Luebbert*; and that the same is true and correct according to his best knowledge and belief.

Further the Affiant sayeth not.

J LUEBBERT

JURAT

D. SUZIE MANKIN
Notary Public - Notary Seal
State of Missouri
Commissioned for Cole County
My Commission Expires: April 04, 2025
Commission Number: 12412070

Notary Public