

Exhibit No.:
Issue: Greenwood Solar; Fuel Adjustment
Clause; Lake Road Allocations;
Electric Vehicle Charging Station
Income Eligible Weatherization;
Crossroads Energy Center, Economic
Relief Pilot Program
Witness: Tim M. Rush
Type of Exhibit: Rebuttal Testimony
Sponsoring Party: Kansas City Power & Light Company
and KCP&L Greater Missouri
Operations Company
Case Nos.: ER-2018-0145 and ER-2018-0146
Date Testimony Prepared: July 27, 2018

MISSOURI PUBLIC SERVICE COMMISSION

CASE NOS.: ER-2018-0145 and ER-2018-0146

REBUTTAL TESTIMONY

OF

TIM M. RUSH

ON BEHALF OF

**KANSAS CITY POWER & LIGHT COMPANY and
KCP&L GREATER MISSOURI OPERATIONS COMPANY**

**Kansas City, Missouri
July 2018**

REBUTTAL TESTIMONY

OF

TIM M. RUSH

Case Nos. ER-2018-0145 and ER-2018-0146

1 **Q: Please state your name and business address.**

2 A: My name is Tim M. Rush. My business address is 1200 Main Street, Kansas City,
3 Missouri 64105.

4 **Q: By whom and in what capacity are you employed?**

5 A: I am employed by Kansas City Power & Light Company (“KCP&L”) as Director,
6 Regulatory Affairs.

7 **Q: On whose behalf are you testifying?**

8 A: I am testifying on behalf of KCP&L (“KCP&L”) and KCP&L Greater Missouri
9 Operations Company (“GMO”) (collectively, the “Company”).

10 **Q: Are you the same Tim M. Rush who filed Direct Testimony in both ER-2018-0145**
11 **and ER-2018-0146?**

12 A: Yes, I am.

13 **Q: What is the purpose of your testimony?**

14 A: The purpose of my testimony is to address the following issues:

15 I. Greenwood Solar

16 II. Fuel Adjustment Clause

17 III. Lake Road Allocations

18 IV. Electric Vehicle Charging Stations

19 V. Income Eligible Weatherization

1 VI. Crossroads Energy Center

2 VII. Economic Relief Pilot Program “ERPP”

3 **I. GREENWOOD SOLAR**

4 **Q: What has Staff recommended regarding the Greenwood solar station?**

5 A: In Staff’s Cost of Service Report, beginning on page 27, Staff recommends a
6 methodology for the Greenwood solar station which allocates cost and any related
7 revenues based on numbers of KCP&L and GMO customers. Staff further allocates
8 these costs to the KCP&L Kansas jurisdiction based on its demand allocator to allocate
9 production plant and reserve costs between Kansas and Missouri. Staff believes that an
10 allocation is needed due to the conditions contained in the Commission’s order granting
11 the certificate for the solar station (EA-2015-0256).

12 **Q Do you agree with Staff’s allocation proposal?**

13 A: No. The investment in the solar project at GMO does not benefit KCP&L and does not
14 warrant an allocation of any costs of the facility, whether direct or indirect, to KCP&L
15 because not a single electron produced by the Greenwood solar station will ever reach the
16 KCP&L system. The Greenwood Solar facility is interconnected to GMO’s distribution
17 system and as such all energy from the system is produced for the benefit and use of
18 GMO’s customers. As a corporation with multiple operating utilities, many projects,
19 both generation and distribution, are often done at one utility subsidiary and may result in
20 benefits of an intangible nature to the other. One of the benefits identified during the
21 acquisition of GMO by Great Plains Energy was the expertise that GMO had in
22 maintenance of its natural gas plants. That expertise was shared with KCP&L. Likewise,
23 KCP&L had substantial expertise in maintenance of its coal fleet and that was then

1 shared with GMO, without compensation through allocation of costs. KCP&L was one
2 of the first utilities in the nation to implement an automated meter reading system many
3 years ago. Both KCP&L and GMO are now in the process of deploying next generation
4 automated metering (AMI) and GMO is receiving the benefit of KCP&L's expertise,
5 without any transfer of costs to GMO for that knowledge. The Company believes it is
6 not appropriate to transfer any of the costs of the Greenwood solar station to KCP&L.

7 The Greenwood Solar Project was constructed at a site, the Greenwood Energy
8 Center, already owned by GMO and located within GMO's service territory. The 300-
9 acre Greenwood site includes four combustion turbines that were constructed and in
10 service prior to the solar facility. This site was selected for the solar project in part to
11 minimize the cost of the solar installation based on the availability of land and existing
12 electrical infrastructure. Furthermore, due to additional land availability at the site, it
13 could allow for future expansion of solar as the company gains experience operating a
14 solar facility and as the anticipated cost declines for the technology materialize.

15 In addition to the installation cost benefits associated with the Greenwood site,
16 GMO customers receive a direct benefit from the solar energy produced at the site. The
17 solar plant is connected to a single circuit at the distribution level of GMO's electrical
18 system and can serve the load of customers on that circuit. This energy reduces GMO's
19 load purchase requirement from the Southwest Power Pool ("SPP") and reduces SPP load
20 expense for the benefit of all GMO customers. As a result, the FAC charged or credited
21 to GMO customers is lower because of the solar system.

1 **Q: If the Commission required GMO to transfer some dollar amount of the Greenwood**
2 **solar station to KCP&L, have you given any thought as to how much might be**
3 **appropriate and how it could be done?**

4 A: Yes. I would reiterate that the Company is opposed to any allocation and want to make it
5 clear that the combination of the customer and demand-based allocator proposed by Staff
6 which would allocate more than 63% of the plant and expenses associated with the
7 Greenwood Solar facility away from GMO to be paid by KCP&L customers is clearly
8 unjustified and inappropriate. Particularly when the Staff recommends that the energy
9 produced from the solar goes 100% to the benefit of GMO customers. However, the
10 Company understands that this pilot project was built and operated to gain experience
11 with a utility scale solar project.

12 I had recommended in the previous case (Case No. ER-2016-0156) in rebuttal
13 testimony an alternative allocation. I used a methodology based on comparing an
14 alternative renewable energy resource to the solar facility. Using that methodology
15 resulted in roughly \$1 million in capital cost allocated to KCP&L. However, because of
16 all the other impacts on the investment such as specific tax benefits, REC's, the energy
17 from the facility, and operating costs which would remain with GMO, using a plant
18 investment allocation was not practical. If the Commission ordered the Company to
19 make an allocation, my recommendation in the last case, and would be that today, is to
20 allocate no more than \$100,000 to KCP&L in expenses to be reflected in KCP&L cost of
21 service and subtract a like amount from GMO's cost of service. I would further
22 recommend that the \$100,000 be assigned to Missouri only, as this is more an issue with
23 Missouri than it is with Kansas.

1 **Q: Do you think that an allocation like the one you described is appropriate?**

2 A: No. While less impactful to KCP&L, I still disagree with any allocation. However, if the
3 Commission deems that an allocation is necessary, then the one I have described is more
4 appropriate.

5 **II. FUEL ADJUSTMENT CLAUSE (“FAC”)**

6 **Q: OPC witness Mantle alleges at p. 8 of her testimony that the Company has not**
7 **provided sufficient information for OPC to take a position on the FAC. How do you**
8 **respond?**

9 A: This does not make sense. The Company has responded timely to all OPC data requests
10 and OPC, like every other party, has the obligation to present its case in chief in its Direct
11 Testimony.

12 **Q: Ms. Mantle also alleges that because fuel costs are falling that the Company’s FAC**
13 **costs should also be falling. How do you respond?**

14 A: The Company’s request to increase FAC base rates is appropriate; there is nothing
15 mysterious or counter-intuitive about it. The reason for KCP&L increase is related to
16 falling natural gas prices. This situation has led to a large decrease in off system sales
17 and the off-system sales are made are at lower margins. The loss of off system sales
18 revenue means that KCP&L no longer has large offsets to fuel costs in the FAC.
19 Additionally, Ms. Mantle fails to recognize that transmission costs are increasing and are
20 at least partially recovered in the FAC.

1 **Q: Ms. Mantle makes the unsupported allegation on p. 5 of her Direct testimony that**
2 **the Company no longer considers its generation resources as resources to meet**
3 **customer needs but rather they are resources to generate revenue from the**
4 **Southwest Power Pool (“SPP”). Is this claim accurate?**

5 A: Not at all. The SPP Integrated Marketplace does not supersede the Company’s
6 responsibilities with regard to capacity adequacy and reserves. All revenue from SPP is
7 used to reduce the cost to energy used by the Company’s customers so customers see the
8 benefits of sales. The Company is required, as part of its Southwest Power Pool (SPP)
9 requirement to support its customers’ generation loads through its own generation or
10 purchases and the Company takes care to meet their requirements.

11 **III. LAKE ROAD ALLOCATIONS (GMO ONLY)**

12 **Q: Please summarize the issue related to the allocation factors for Lake Road.**

13 A: The Lake Road plant in St. Joseph, MO produces steam for industrial customers and
14 electricity for GMO retail customers. In its previous rate case, Case No. ER-2016-0156,
15 GMO proposed a modification to the existing allocation methodology.

16 The overall case was ultimately settled and allocation factors were agreed to
17 without a decision on the proposed modifications to the methodology. Staff witness Alan
18 Bax addressed the issue and recommended a review of all allocations attributable to Lake
19 Road steam and electric operations once more operational data was available.

20 The Company has performed a review and is recommending an allocation
21 methodology in this case. The methodology and resulting allocation factors recognize
22 changes in the operating characteristics of the plant and market dynamics.

1 **Q: Has Staff reviewed your proposed allocation methodology?**

2 A: Yes, Staff Witness Chuck Poston has been the primary Staff reviewer, and we have spent
3 considerable time discussing the methodology of the allocations proposed by the
4 Company, as well as the Allocation Manual submitted by me in my direct testimony. Mr.
5 Poston was very helpful in reviewing the manual in detail and made several
6 recommendations, both in correcting errors and suggestions for the overall manual.
7 While I provided a revised Allocations Manual in DR 0386, I am also attaching it to this
8 rebuttal testimony as Schedule TMR-6 which reflects the corrections and suggestions by
9 Mr. Poston.

10 **Q: What does Staff recommend on the Lake Road allocation factors?**

11 A: At this time, Staff recommends that the allocation factors agreed to in the Stipulation and
12 Agreement in Case No. ER-2016-0156 be left in place. Staff is not opposed to a revision
13 of the Lake Road allocation procedures that would account for the changes in fuel use
14 and market conditions that have occurred in the past several years. However, Staff
15 indicates that the review of this issue is ongoing due to delays in receiving GMO's
16 revision to the allocation procedures originally proposed in this case. This
17 recommendation may be subject to modification depending on the results of Staff's final
18 review of GMO's proposed revisions to the allocations procedures.

19 **Q: What is GMO's recommendation for allocation of Lake Road costs between steam
20 and electric customers?**

21 A: Based on the operational and market changes discussed in my direct testimony, GMO
22 believes its allocation proposed by the Company in this case as shown in Schedule TMR
23 -6 should be approved by the Commission.

1 **Q: Since the Company filed its case, have any other facts come up that add importance**
2 **to a decision regarding the allocations procedures?**

3 A: Yes. As a result of the Tax reform that took place on January 1, 2018, the Commission
4 has initiated a “Show Cause” Case (Case No. HR-2018-0231) for the GMO steam
5 business. It appears that a steam rate case may be warranted in the near future. This is
6 because the steam business is currently under-earning its authorized return. GMO has not
7 sought to increase rates to the steam business for a number of reasons, but one of the
8 primary reasons is the potential impact a rate change would have on these customers,
9 particularly without clear direction on the allocations that would be used in developing
10 steam rates. While the GMO steam business only has five customers, they represent
11 nearly 5,000 employees in St. Joseph, MO. Our hope in this case is to establish an
12 allocations procedure that can withstand the test of time and be more representative of the
13 operations of the Lake Road Plant and the Electric/Steam businesses.

14 **IV. ELECTRIC VEHICLE CHARGING STATIONS**

15 **Q: What does Staff recommend regarding the electric vehicle (“EV”) charging**
16 **stations?**

17 A: Staff has removed the O&M expense, plant in service and accumulated depreciation
18 reserve related to the EV charging stations from the cost of service. Staff’s position is
19 based on the Commission’s determination in ER-2016-0285 that the charging stations are
20 not “electric plant” under Missouri law. KCP&L has appealed the Commission’s Report
21 and Order to the Missouri Court of Appeals and a decision will likely occur during the
22 pendency of this rate case. The Company believes that the charging service it provides
23 must be recognized as a regulated service under Missouri law.

1 **V. INCOME ELIGIBLE WEATHERIZATION**

2 **Q: Please summarize Staff’s recommendations regarding the Income Eligible**
3 **Weatherization program (“IEW”).**

4 A: Staff witness Kory Boustead recommends:

5 1.) The Commission approve the continuation of GMO’s IEW Program at the
6 annual funding level of \$400,000 to be included in base rates.

7 2.) The Commission approve the continuation of the KCP&L IEW Program at
8 the current annual funding level of \$573,888; authorizing an annual
9 amount of \$258,914 to be included in base rates, and the unspent funds to
10 be amortized over four years to reach IEW yearly funding amount of
11 \$573,888.

12 3.) KCP&L and GMO work closely with the Community Action Agencies
13 (“CAAs”) to address any process barriers to getting the funds fully
14 expended within the IEW program year.

15 **Q: Does the Company agree with Staff’s proposal?**

16 A: Yes. The Company acknowledges that there has been an accumulation of unused
17 program funds associated with IEW. Staff is misinterpreting the appropriate way to
18 address these prior unspent funds, however. In Case No. ER-2016-0285 a liability of
19 \$1,259,897 was established as a rate base offset and approved for a 4-year amortization.
20 This does leave \$258,914 to be collected in base rates. However, the Company’s forward
21 spend is to be at the \$573,888 level. Future over/under spend is to be based upon this
22 level, and the amortization of the prior underspend should continue for the four years.

1 **Q: Please explain the issues associated with how Staff Witness Michael Jason Taylor**
2 **has included the impact of Income Eligible Weatherization costs in this Case.**

3 A: For KCP&L in Case No. ER-2016-0285, the Company agreed to include accumulated
4 unspent funds as a rate base offset. In addition, a Regulatory Liability was established on
5 the books for the underspent total at the true-up date of December 31, 2016. The amount
6 included as a rate base offset was the underspent funds calculated by comparing the level
7 set and collected in rates to the amount spent. These two levels included program costs,
8 marketing costs and Throughput Disincentive (“TD”) sometimes referred to as lost
9 margins revenues. This regulatory liability has been tracked as Vintage 1 and is being
10 amortized to expense over four years as established in Case No. ER-2016-0285. The
11 Company has continued to record unspent/over-collected funds from January 2017,
12 through June 2018, the true-up date in this case, as Vintage 2. Consistent with the 2016
13 case, the Company has included the total unspent balance in the account as of June 2018,
14 as an offset to the rate base in this case. Staff misstated the unspent funds balance in the
15 liability account for both Vintages 1 and 2. In Vintage 1, Staff did not include the
16 amortization which should have begun in July 2017, and would have decreased the
17 balance of unspent funds over time. Additionally, Staff re-amortized the under-spent
18 balance over 4 years while the Company kept Vintage 1 and 2 separate in its amortization
19 calculation. In Vintage 2, Staff’s over/under calculation incorrectly excluded TD- from
20 the 2017 expense level used to calculate its over/under. As the original underspend
21 amount included lost margins revenues, the actual spend should continue to include lost
22 margins revenues. The Company is agreeable to the re-amortization but not to the
23 exclusion of lost margins revenues.

1 For GMO, The Company agrees to include the balance of unspent IEW program
2 funding as an offset to rate base in this case. This is consistent with the KCP&L rate case
3 filing. The balance is adjusted to include interest accrued at the AFUDC rate for unspent
4 funds as agreed to in Case No. ER-2016-0156. As stated above for KCP&L, the
5 company disagreed with Staff's exclusion of lost margins revenues in the over/under
6 calculation.

7 **Q: Was there an additional proposal regarding IEW?**

8 A: Yes. Missouri Department of Economic Development – Division of Energy (“DE”) witness Sharlet E. Kroll, supports IEW and recommends that the Commission: (1)
9 continue the IEW programs at a funding level of \$573,888 for KCP&L and \$500,000 for
10 GMO with any unspent annual funds rolling forward into future program years, (2)
11 convene a joint advisory group of interested stakeholders which would meet biannually to
12 consider weatherization policy and program improvements for both companies and (3)
13 order the new advisory group to consider the policy of voluntary customer contributions
14 to IEW through a check off box on customer bills and the on-line payment system.
15

16 **Q: Does the Company agree with DE's proposal?**

17 A: The Company is not in agreement with increasing the funding level for GMO by 25%,
18 from \$400,000 to \$500,000. The Company is not opposed to a joint advisory group but
19 believes that there is already adequate coordination in place between the stakeholders.

1 **VI. CROSSROADS ENERGY CENTER**

2 **Q: Staff recommends that GMO not be allowed any recovery of transmission costs**
3 **associated with Crossroads either in base rates or through the fuel adjustment**
4 **clause. Staff has gone beyond exclusions made in prior rate cases and excluded**
5 **other costs that may have some association with the Crossroads facility. This**
6 **includes MISO administrative fees, Mississippi state franchise taxes, and travel**
7 **expenses to and from the facility. How do you respond?**

8 A: The Staff position is new and goes beyond the Commission rulings in the prior cases
9 dealing with Crossroads, the Report and Order of May 4, 2011 in Case No. ER-2010-
10 0356 and the Report and Order of January 9, 2013 in Case No. ER-2012-0175. The
11 Staff's new position treats the Crossroads facility as if it is excluded from any recovery
12 except for the plant value that the Commission previously allowed in rate base. This
13 position is inconsistent with prior cases which allowed recovery of MISO administrative
14 fees, travel costs by employees and other costs related to Crossroads. Staff's new position
15 goes well beyond any prior decision of this Commission. The Company disagrees with
16 the position taken by Staff as it attempts to treat all costs for Crossroads as imprudent and
17 goes well beyond Commission reasoning for its adjustments to the plant.

18 **Q: MECG supports the Commission's prior decisions to disallow all Crossroads**
19 **transmission cost from customer rates. How do you respond to the MECG**
20 **position?**

21 A: While I agree that MECG states that it supports prior decisions, I believe that the position
22 the Company is presenting is consistent with prior Commission rulings. As indicated in
23 my direct testimony, the Company is not asking the Commission to reverse its prior

1 decisions on rate base or transmission costs. However, GMO proposes to include in rates
2 the increase in transmission cost above the \$4.9 million which was disallowed in the prior
3 two cases, ER-2010-0356 and ER-2012-0175.

4 **Q: In light of the denial of transmission costs historically, how does GMO justify**
5 **inclusion in rates of the increase in costs?**

6 A: The Company's position on the reasonableness of the cost of the Crossroads facility is
7 well documented and is described in the rebuttal testimony of Company witness
8 Crawford. Regardless of the location, the facility remains a low-cost option for providing
9 GMO customers with generation capacity. This would be true even if full recovery was
10 allowed for rate base and transmission costs. Even with the disallowances for rate base
11 and transmission costs ordered in the prior cases, Crossroads continues to provide value
12 to customers. Prior to the increase in transmission costs precipitated by Entergy's entry
13 into MISO, the Company estimates that GMO customers were paying about \$5 million
14 annually for 300 MW of reliable peaking capacity from a diverse source, while GMO
15 shareholders were losing \$10 million annually.

16 If the Commission accepts the GMO position in this case, the Company will lose
17 about \$10 million annually and customers will pay about \$12 million annually. This
18 equitable allocation of costs provides customers with energy from a reasonably priced
19 asset whose capacity is fully accredited capacity and with firm transmission to supply
20 energy to GMO customers. As shown in the Rebuttal Testimony of Company witness
21 Crawford, Crossroads is much more economical than all options, including new
22 construction.

1 **Q: Please summarize your position on what has occurred with Crossroads over the**
2 **years and your recommendation to the Commission?**

3 A: The regulatory treatment of Crossroads has been quite adverse to the Company. The
4 decision to place it in rate base was the **absolute right** thing to do for both the Customer
5 and Company at the time it was done. The Company and customers needed the capacity
6 that Crossroads provided. Its original cost and the potential transmission costs still made
7 Crossroads the lowest cost of all the alternatives evaluated. However, the Commission
8 determined that the plant's fair market value should be less than the original cost by over
9 half (allowing \$61.8 million into rate base compared to the original cost of \$132 million)
10 and that the transmission costs at the levels in the prior cases should be excluded from
11 recovery. Transmission costs that have gone unrecovered will be over \$80 million by the
12 time this case becomes effective. In all, the Company has lost over \$100 million in rate
13 recovery while customers have paid approximately \$40 million. If the Company had
14 selected the second lowest cost option when it initially evaluated the Crossroads plant,
15 customers would have paid over \$140 million over the same period (e.g. the sum of the
16 \$100 million shareholder loss and \$40 million customer paid).

17 That is why the Company's proposal is to continue with the lower plant value and
18 set the transmission loss at the \$4.9 million established in the last Crossroads
19 Commission order. While we cannot undo the past, the Company recommends that the
20 Commission establish a fair balance between the costs that GMO continues to absorb and
21 the value that customers pay for.

1 **VII. ECONOMIC RELIEF PILOT PROGRAM (“ERPP”)**

2 **Q: Staff recommends that the ERPP continue at its current funding level, that unspent**
3 **funds collected from customers be made available for future ERPP funding and that**
4 **a third-party evaluator reviews the program before the next rate case. What is your**
5 **response?**

6 **A:** The Company agrees with Staff that ERPP should continue at its current funding level
7 and that unspent funds be used for future funding. The Company agrees that a
8 comprehensive assessment of ERPP by a third-party evaluator, paid with ERPP funds and
9 selected by the Company, Staff and OPC makes sense in order to ensure that costs are
10 minimized and the maximum amount of ERPP funds are used to assist participants in the
11 program. The Company also agrees to remove the “three-year pilot” reference in GMO’s
12 tariff.

13 **Q: Does that conclude your testimony?**

14 **A:** Yes, it does.

**BEFORE THE PUBLIC SERVICE COMMISSION
OF THE STATE OF MISSOURI**

In the Matter of Kansas City Power & Light)
Company's Request for Authority to Implement)
A General Rate Increase for Electric Service)

Case No. ER-2018-0145

In the Matter of KCP&L Greater Missouri)
Operations Company's Request for Authority to)
Implement A General Rate Increase for Electric)
Service)

Case No. ER-2018-0146

AFFIDAVIT OF TIM M. RUSH


STATE OF MISSOURI)
) ss
COUNTY OF JACKSON)

Tim M. Rush, being first duly sworn on his oath, states:

1. My name is Tim M. Rush. I work in Kansas City, Missouri, and I am employed by Kansas City Power & Light Company as Director, Regulatory Affairs.


2. Attached hereto and made a part hereof for all purposes is my Rebuttal Testimony on behalf of Kansas City Power & Light Company and KCP&L Greater Missouri Operations Company consisting of fifteen (15) pages, having been prepared in written form for introduction into evidence in the above-captioned docket.

3. I have knowledge of the matters set forth therein. I hereby swear and affirm that my answers contained in the attached testimony to the questions therein propounded, including any attachments thereto, are true and accurate to the best of my knowledge, information and belief.




Tim M. Rush

Subscribed and sworn before me this 27th day of July 2018.



Notary Public

My commission expires: 4/26/2021



**KCP&L GREATER MISSOURI
OPERATIONS ELECTRIC/STEAM
ALLOCATION PROCEDURES
CASE NO. ER-2018-0146**

Contents

| | | |
|-------|--|---|
| I. | CAPITAL PLANT ALLOCATION – Lake Road..... | 3 |
| A. | Lake Road Capital Plant Assigned 100% to Electric..... | 3 |
| B. | Lake Road Capital Plant 100% Assigned to Industrial Steam..... | 3 |
| C. | Lake Road Capital Plant Common to Electric and Industrial Steam..... | 3 |
| D. | Reserve for Depreciation Allocation – Lake Road..... | 4 |
| II. | INVENTORY – Fuel - Lake Road..... | 4 |
| III. | INVENTORY – Materials and Supplies - Lake Road..... | 5 |
| IV. | OTHER RATE BASE ITEMS – Lake Road..... | 5 |
| A. | Prepayments..... | 5 |
| B. | Regulatory Assets and Liabilities..... | 5 |
| C. | Deferred Taxes..... | 5 |
| D. | Customer Advances and Deposits..... | 5 |
| V. | EXPENSE – FUEL..... | 6 |
| A. | Fuel Expense Allocation..... | 6 |
| B. | Lake Road Daily Ash Removal Expense Allocation..... | 6 |
| C. | Auxiliary Electric Power Allocation..... | 7 |
| VI. | EXPENSES – Non-Fuel O&M Expense Allocation..... | 8 |
| VII. | EXPENSES – A&G Expense Allocation..... | 8 |
| VIII. | EXPENSES – Property Taxes..... | 9 |

I. CAPITAL PLANT ALLOCATION – Lake Road

A. Lake Road Capital Plant Assigned 100% to Electric

The following Lake Road capital plant is to be allocated 100% to Electric, with the noted exceptions:

- Lake Road Unit 1 through 4 turbines (Account 310-316). Does not include the Boilers which are allocated or steam specific utility accounts ending in xxx09 listed in subsection B below.
- All combustion turbine generators and associated equipment (Account 342-346).
- Turbine building and other buildings and structures housing and/or associated with the 100% electric generation facilities (Account 311 & 341). Does not include steam specific utility accounts ending in xxx09 listed in subsection B below.

B. Lake Road Capital Plant 100% Assigned to Industrial Steam

The following Lake Road Capital plant is to be allocated 100% to Industrial Steam:

- All steam specific plant utility accounts ending in xxx09 such as 31009, 31109, 31209, 31509, 37509, 37609, 37909, 38009 and 38109

C. Lake Road Capital Plant Common to Electric and Industrial Steam

The following Lake Road capital plant is to be allocated between Electric and Industrial Steam, using the allocation methods specified and applied to any balance to be allocated after allocations in subsections A and B above.

1. All Boilers and Turbines in account 312, 314 and 316

Allocation – Property remaining to be allocated for account 312, 314 and 316 will be allocated first by applying the 900lb Steam Demand Allocation Factor as described below. Then each individual plant account, 312, 314 or 316, will be allocated based on the ratio derived from the total allocated to steam or electric over the sum total plant cost of each individual plant account 312, 314 or 316.

The 900lb Steam Demand Allocation Factor is determined using the average maximum hourly coincident peak for steam for each month over a 36-month period divided by the maximum capability of turbines 1-3 and the average maximum hourly coincident peak for steam. (See attached Schedule TMR-5, Wkpr 1).

2. Structures, Accessory Equipment, Software and General Plant (Account 303, 311, 315 and 391 through 398).

Allocation - Allocate based on the ratio derived from the total plant allocated to industrial steam and electric as calculated in subsections A, B and C above for Accounts 312, 314, 316 and 341 through 346 combined.

D. Reserve for Depreciation Allocation – Lake Road

The following Lake Road reserve for depreciation will be allocated between Electric and Industrial Steam, using the allocation methods specified:

1. Structures, Accessory Equipment, Software and General Plant (Account 303, 311, 315 and 391 through 398). Does not include steam specific utility accounts ending in xxx09.

Allocation – Allocate based on the ratio derived from the total plant cost allocated to industrial steam and electric as calculated in subsections A, B and C above for Accounts 312, 314, 316, 341 through 346 combined.

2. Boiler Plant (Account 312). Does not include steam specific utility accounts ending in xxx09.

Allocation – Allocate based on the ratio derived from the total plant cost allocated to industrial steam and electric for 312 Accounts only. See subsection C (1) Allocation above.

3. Turbogenerator Plant (Account 314)

Allocation – Allocate based on the ratio derived from the total plant cost allocated to industrial steam and electric for 314 Accounts only. See subsection C (1) Allocation above.

4. Miscellaneous Plant Equipment (Account 316)

Allocation – Allocate based on the ratio derived from the total plant cost allocated to industrial steam and electric for 316 Accounts only. See subsection C (1) Allocation above.

5. Combustion turbine generators and associated structures and equipment (Accounts 341-346)

Allocation – Allocate 100% to Electric

6. Steam specific plant utility accounts ending in xxx09 such as 31009, 31109, 31209, 31509, 37509, 37609, 37909, 38009 and 38109.

Allocation – Allocate 100% to Industrial Steam

II. INVENTORY – Fuel - Lake Road

The fuel inventory will be allocated based on the minimum fuel inventory levels required for each operation, recognizing the fact that the LR electrical load is not predictable and a larger fuel inventory is required to sustain system reliability during extended periods of abnormally high electrical generation at LR. The Coal fuel inventory quantities above and beyond the minimum coal inventory levels will be allocated based on a 50/50 split between electric and steam. This split is premised on the need to maintain a 60-day average burn on coal inventory, while electric

load is totally unpredictable. (See attached Schedule TMR-5, Wkpr 3 for fuel inventory analysis dated 11/1/2017)

Oil inventory is primarily a reserve fuel for both electric and steam load. Oil for electric generation covers each generating unit at the Lake Road Plant. As such, the allocation of oil should be based on the overall Fuel Oil Demand Allocation Factor, which looks at electric capability of the entire plant and steam load. (See attached Schedule TMR-5, Wkpr 3 for fuel inventory analysis dated 11/1/2017). The Fuel Oil Demand Allocation factor is calculated consistent with the 900lb steam demand allocation factor, but considers all turbines and boilers capable of burning oil. (See attached Schedule TMR-5, Wkpr 1 for the Fuel Oil Demand Factor calculation).

III. INVENTORY – Materials and Supplies - Lake Road

Materials and Supplies Inventory for Lake Road will be allocated based on the Electric/Steam Plant Factor.

IV. OTHER RATE BASE ITEMS – Lake Road

A. Prepayments

Prepayments for Lake Road are allocated 100% to Electric.

B. Regulatory Assets and Liabilities

Regulatory Assets and Liabilities will be allocated on the unique circumstance of each asset or liability.

1. Missouri DSM Programs, Iatan 1 and Common, and Iatan 2 are allocated 100% to Electric.
2. ERISA Steam Tracker is allocated 100% to Steam.
3. FAS87 Pension Tracker and OPEB Tracker are allocated based on Electric After Steam Allocation (A&G) factor. The A&G factor is based on a 50/50 weighting between the Allocated Plant Base factor and Allocated O&M factor described below in Section V11.

C. Deferred Taxes

Deferred taxes for Lake Road will be allocated based the Allocated Plant Base Factor. This factor is the Ratio of Total GMO Plant per the most current Form 1 filed excluding Asset Retirement plant accounts 317, 347 and 399. The adjusted Total will be reduced by the total Steam Allocated plant amount allocated in Section 1, subsections A, B and C above.

D. Customer Advances and Deposits

Customer Advances and Deposits for Lake Road will be allocated 100% to Electric.

V. EXPENSE – FUEL

A. Fuel Expense Allocation

The procedure outlined in the January 1995, paper entitled “Exergy-Based Electric and Steam Allocation Procedure for Lake Road 900# Plant Fuel and Auxiliary Power” (hereinafter referred to as the “Exergy Approach”) should be used for the basis of allocations. (See Attached Report Page 10-13 below).

B. Lake Road Daily Ash Removal Expenses

Expenses to be allocated with these factors include the removal cost of all ash material sent to the ash tank; it does not include cost associated with cleaning of temporarily stored material on the concrete pad in the coal yard.

It is assumed that the amount of removal cost incurred is directly proportional to the amount of ash material sent to the ash tank, on a moisture-free, carbon-free basis. This material includes all coal ash from Boiler 5.

The total amount of ash material produced in Boilers 5 is directly proportional to the amount of coal burned. This allows a steam/electric allocation factor for ash to be calculated using coal burn (mmBtu) data currently available in the Lake Road Monthly Results Summary. The factors are based on a three-year rolling average.

The calculations are as follows:

AAFS = ASH ALLOCATION FACTOR FOR STEAM
AAFE = ASH ALLOCATION FACTOR FOR ELECTRIC

$$AAFS = \frac{\text{Total Coal mmBtu to Steam}}{\text{Boiler 5 Coal mmBtu}}$$

$$AAFE = 1 - AAFS$$

3-Year Coal Burn (mmBtu) Data from Results Summary

| Year | Boiler 5 Coal Burn (mmBtu) | Coal Btu To Steam (mmBtu) |
|-------|-------------------------------|------------------------------|
| 2015 | 1,373,065 | 1,353,435 |
| 2016 | 1,853,331 | 1,805,706 |
| 2017 | 1,750,216 | 1,737,075 |
| TOTAL | 4,976,612 | 4,896,216 |

$$AAFS = 4,896,216 / 4,976,612 = 0.9838$$

$$AAFE = 1 - AAFS = 0.0162$$

Material Cleaned from Coal Yard Runoff Ditches

The Coal Yard at Lake Road Plant has a ditch system surrounding it to collect rain-water runoff material and to prevent it from encroaching on neighboring property. The layout of the ditch system directs all flow to the south side of the coal yard where it is eventually pumped into settling ponds. Through the course of a year, some material settles out in the ditches and must be cleaned out.

The total annual weight (including coal, moisture, and some dirt) of this material which is cleaned out is estimated to be approximately 100 tons. This coal is spread out over the coal pile during the dry months and reclaimed for use in Boiler 5. Costs for this work is minimal and part of the plant coal handler activities.

Since the activity associated with accumulating this material is related to the coal pile itself, the allocation will follow the procedures above outlined for the Lake Road Daily Ash Removal Expenses.

Boiler 5 Coal Mill Reject Material

A small amount of material is rejected from coal mills during the grinding process and placed into a special chamber in the mill for periodic emptying. At Lake road, operators empty these chambers on the coal mills for Boiler 5 and haul the material by wheelbarrow to a collecting point outside the plant between 5 & 6 Boilers.

Every 3-4 weeks, coal handlers load this material on concrete pad and is mixed with other temporarily stored material. Typically, they fill a dump truck during each of these cleanings. Based on this, the total annual weight of this material placed on the concrete pad area is estimated to be approximately 150 tons.

The allocation for this material will follow the procedures outlined above for the Lake Road Daily Ash Removal Expenses

C. Auxiliary Electric Power Allocation

The method of determining the amount of auxiliary electric power to be allocated to industrial steam and to electric users will be that method presented in the January 1995, paper on the "Exergy Approach" (See attached Report Page 13 below). The auxiliary electric power will be priced using the average system energy cost (\$/MWH) for each month, which includes all GMO fuel related generation costs, fuel handing expenses and net purchased power expenses. Additionally, the Company's average purchased capacity cost (\$/MW) will be used to price the demand. An average monthly demand of 2 MW will be used. Billing considerations and accounting for the auxiliary electric power charges will be treated through "steam transfer credits", rather than direct billings.

VI. EXPENSES – Non-Fuel O&M Expense Allocation

Operation and Maintenance (O&M) expenses refer to expenses associated with the production, transmission and distribution functions. O&M expenses are classified in FERC accounts 500-514 and 546-598. The allocations of O&M Expense Accounts are listed in Schedule TMR-5, Wkpr 2.

Non-Fuel O&M Accounts 500-514, the allocation is primarily based on the ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M for the most recent full calendar year referred to as the “Electric After Steam Allocation (O&M) factor. The allocated Steam Payroll is derived by multiplying the total non-fuel production Lake Road Payroll charged to O&M for the most recent full calendar year by the Equivalent Employment Factor.

The Equivalent Employment Factor is the fraction of time spent by a typical Lake Road Plant operating crew on the operation of the industrial steam system, based upon a breakdown of each operator’s time. See Schedule TMR-5, Wkpr 4.

VII. EXPENSES – A&G Expense Allocation

Administrative and General (A&G) expenses refer to expenses associated with administrative and general functions of the company, as contrasted with expenses directly associated with the production and transmission and distribution functions. A&G expenses include salaries and wages, outside services, injuries and damages, employee benefits, regulatory commission expenses, advertising, rents and maintenance. A&G expenses are classified in FERC accounts 901 through 935. The allocations of A&G Expense Accounts are listed in Schedule TMR-5, Wkpr 2.

Not all charges to A&G FERC accounts are allocable. Costs incurred which benefit only a particular utility’s operations are directly charged to that utility’s operations. Also, Customer Accounts, Customer Service and Sales Expenses are allocated 100% to Electric.

However, the majority of A&G expenses accounts 920-935 are allocated between electric and industrial steam operations based on the Electric After Steam Allocation (A&G) Factor which is two allocation factors that are given 50/50 weighting described below:

1. Allocated Plant Base Factor - Ratio of Total GMO Plant per the most current Form 1 filed excluding Asset Retirement plant accounts 317, 347 and 399. The adjusted Total is reduced by the total Steam Allocated plant amount allocated in Section I, subsections A, B and C above.
2. Allocated O&M Factor - The most current Annual Surveillance filed is updated for the “Electric After Steam Allocation (O&M) factor” described in Section VI above.

There should be reasonable correlation between the factor(s) used and the A&G costs incurred. The two factors selected include that correlation as A&G expenses primarily represent costs incurred in managing the Company’s personnel and operating and maintenance activities and controlling the Company’s investment in plant.

VIII. EXPENSES – Property Taxes

Property Tax Expense is allocated based on the Allocated Plant Base Factor - Ratio of Total GMO Plant per the most current Form 1 filed excluding Asset Retirement plant accounts 317, 347 and 399. The adjusted Total is reduced by the total Steam Allocated plant amount allocated in Section I, subsection A, B and C above.

Exergy-Based Electric and Steam Allocation Procedure for Lake Road 900# Plant Fuel and Auxiliary Power

January 1995

The Lake Road 900# Plant fuel allocation is performed between steam electric constituencies based upon the amount of fuel energy required to supply each on a daily basis. To determine this allocation, the fuel energy is tracked on an exergy¹ basis through the 900# plant. The fuel “cost” per unit of exergy of flow streams within the plant are determined by the “cost” of input streams and second law efficiencies of plant equipment. The use of this method is strongly supported in technical literature dealing with the allocation of costs in cogeneration facilities.²

Fuel energy is based upon the “higher heating value” of the fuels and is considered to be 100% available to the boilers. That is, the exergy content and heating value of the fuels are assumed to be equal. One mmBtu³ of fuel is defined as one cost unit. By tracking the exergy flow and its “cost” through the plant, the quantity of fuel energy required to supply a given flow stream is simply the exergy flow of the stream multiplied by the unit cost of that stream. Exergy is measured relative to the reference state of water at 14.3 psia (corresponding to the plant evaluation of 812 feet above sea level) and the plant well water temperature, typically 60° F.

The procedure begins with the total daily fuel, steam, water, and electricity flows to, from and within the 900# plant, along with the average thermodynamic conditions. Using heat and mass balance equations, an approximate daily 900# plant heat balance is determined. The major components in the heat balance are: 900# boilers (1-5), 900# turbines and condensers (1-3), industrial steam system (high pressure and low pressure), pressure reducing valves, attemperating equipment, flash tanks, water treatment plant, general plant (pumps, feedwater heaters, 900# auxiliary steam loads), and Unit 4/6 (auxiliary steam). The daily total mass and exergy flows in and out of the above components are determined. After these quantities are known, a set of simultaneous equations is solved to determine the cost of the various flow streams. These equations are determined by equating the total costs in and cost of the individual components. That is the following equation is solved for each component.

$$\sum (E_i c_i) = \sum (E_e c_e) \quad (1)$$

The above equation states that the sum of the products of incoming exergy flows (E_i) and their respective unit costs (c_i) is equal to the sum of the products of the exiting exergy flows (E_e) and their respective unit costs (c_e). Generally, the equation (1) has the following form.

$$\sum (M_i E_i c_i) = \sum (M_e E_e c_e) + W_e c_e$$

In equation (2), the M 's represents flow in pounds per day, E 's represent exergy content of the fluid in Btu per pound, the W represents work generated by the device in Btu/day (i.e. turbine shaft work to a generator) and the c 's represent the unit cost in Btu's of fuel per Btu of exergy.

As an example, consider a boiler consuming 100 mmBtu of fuel per hour at a cost of 1 (fuel Btu per exergy Btu), with a feedwater flow and exergy content of 100,000 lb/hr and 75 Btu/lb at a cost of 5, and

¹ See “Definition of Exergy” on page 12.

² See Reference List on page 12.

³ mmBtu = one million British thermal units = 10^6 Btu.

delivering 100,000 lb/hr of steam with an exergy content of 600 Btu/lb. The cost of the steam would be determined from the following equation.

$$\begin{aligned} & \left[100(10^6) \frac{\text{Btu}}{\text{hr}} \times 1 \frac{\text{fuel Btu}}{\text{exergy Btu}} \right] \text{fuel} + \\ & \left[100(10^3) \frac{\text{lb}}{\text{hr}} \times 75 \frac{\text{Btu}}{\text{lb}} \times 5 \frac{\text{fuel Btu}}{\text{exergy Btu}} \right] \text{feedwater} \\ & = 100 (10^3) \frac{\text{lb}}{\text{hr}} \times 600 \frac{\text{Btu}}{\text{lb}} \times c_{\text{stm}} \end{aligned} \quad (3)$$

Solving for c_{stm} , the steam cost is 2.29 fuel Btu per exergy Btu. The total cost of the steam is 137 mmBtu of fuel per hour (100,000 lb/hr x 600 Btu/lb x 2.29 Btu fuel/Btu exergy).

In the case of multiple outputs from a plant component, it is necessary to establish one or more auxiliary equations which relate to the costs of the exergy flows. Usually, this consists of simply equating the exiting costs ($c_{e1} = c_{e2} = c_{e3} \dots$). That is, the output streams all share the incoming costs in proportion to their exergy contents. This approach is used for Lake Road Turbine 1: the cost per unit of exergy of the extraction steam is set equal to the cost of the shaft work developed in the high pressure turbine section (shaft work is considered 100% available to the generator).

In some cases it is necessary to apply different costs to the output flows. This is true with a low pressure turbine and condenser combination. The two outputs are the shaft work to the generator and the condensate returning to the plant. If these two outputs were assigned the same cost, the condensate would become quite expensive as it would be charged with much of the exergy destruction and rejection in the condenser and cooling tower. However, these losses were incurred so that electric generation could take place, not for production of condensate. Therefore, the cost of the condensate should not reflect these losses. Generally in this situation the condensate “by-product” is priced at zero or is assigned a cost per unit of exergy equal to that of the steam to the turbine. This shifts the cost of losses to the electric generation function, where it belongs. In the Lake Road Plant, fuel allocation calculations, condensate is priced at the same cost per unit of exergy as the incoming steam.

Exergy flows which are consumed in the general plant for the benefit of both steam and electric (e.g. 900# auxiliary steam) are assigned a cost of zero. This effectively “raises the price” of those exergy flows which are ultimately delivered to the steam or electric consumers and forces all fuel costs to be charged to these consumers in proportion to the exergy used by them.

Fuel Energy Charged to Electric

The daily fuel energy charged to electric is the total cost (mmBtu of fuel) or the turbine shaft work which drives the 900# plant generators plus the total cost of steam and condensates transferred to Unit 4/6.

Fuel Energy Charged to Industrial Steam

The daily fuel energy charged to industrial steam is the total cost (mmBtu of fuel) delivered to the industrial steam system. This includes the steam supplied through the 12”, 14” and 16” header meters, the attemperating water supplied to the customer steam lines, and the steam delivered to the high pressure steam customer plus the cost of exergy losses between plant and the high pressure customer meter.

The daily steam fuel allocation factor, X_s , is determined by dividing the mmBtu's of fuel charged to industrial steam from the above procedure by the total 900# boiler fuel mmBtu's consumed. This factor is used in the allocation of auxiliary power, described later.

FUEL ALLOCATION PROCEDURE REFERENCE LIST

- Gaggioli, R. A., and El-Sayed, Y. M., "A Critical Review of Second Law Costing Methods" present at the Forth International Symposium of on Second Law Analysis of Thermal Systems; Rome, Italy; May 25 – 29, 1987
- Gaggioli, R. A., "Proper Evaluation and Pricing of 'Energy'"
- Gaggioli, R. A., El-Sayed, Y. M., El-Nahsar, A.M., Kamaluddin, B., "Second Law Efficiency and Costing Analysis of a Combined Power and Desalination Plant"; Journal of Energy Resources Technology, Vol. 110, pp 114-118, June 1988.
- Lang, Fred D., Horn, Ken F., "Make Fuel-Consumption Index Basis of Performance Monitoring" Power, Vol. 134, No.10, pp 19-22, October 1990.
- Moran, M. J., Availability Analysis, pp 206-210, ASME Press, 1989
- Reistad, G. M., and Gangglioli, R. A., "Available-Energy Costing", October 30, 1979.
- Sandage, P. E., "Turbine By-pass System Evaluation & Costing", Sega, Inc., October 18, 1990.
- "Exergy Costing in Multi-Product Plants"

DEFINITION OF EXERGY

Exergy is the thermodynamic quantity representing the maximum work than can be extracted from a given system or flow in an ideal, reversible process. It is calculated as $E = H - H_0 - T_0(S - S_0)$ (neglecting kinetic and potential energy terms), in which H represents total enthalpy, S represents total entropy, and T represents absolute temperature. The subscript "0" indicates the property is at a reference states representative of ambient conditions or a "zero-energy level". Total exergy is measured in Btu and is often called "availability" or "available energy." (note that these terms are easily confused with other plant performance and thermodynamic quantities; "exergy" is more specific.) The term "exergy" often refers to specific exergy, which is the amount of exergy per unit of mass in a system or flow. Specific Exergy has units of Btu/lb and is calculated as $E = h - h_0 - T_0(s - s_0)$ in which total enthalpy and entropy values are replaced with the corresponding specific enthalpy (h) and entropy (s). In practice, total exergy, E, of a fluid stream is usually calculated as the total mass flow, M, times specific exergy, or $E = Me$.

AUXILIARY POWER ALLOCATION

The allocation of auxiliary power is performed in the following manner. First, the auxiliary power can be attributed directly to industrial steam or electric is subtracted from the total 900 psi plant metered auxiliary power, leaving an allocable quantity. Auxiliary power which is metered elsewhere in the plant, but benefits the 900 psi plant is added to the allocable amount. This result is then allocated by the fuel allocation factor (x, see the fuel allocation procedure). Auxiliary power which is directly attributed to each demand is then added to the allocated quantities.

Included in the auxiliary power attributed directly to each constituency is a daily base power consumption. The base usage for the total 900 psi plant is approximately 7.5 MWhr per day. This corresponds to an idle but ready plant (no industrial steam sales and no electric generation). The 7.5 MWhr is allocated between steam and electric using the 900 lb. Steam Demand Allocation Factor, which is defined in Section I, Subsection C.

The process is summarized in the following steps.

1. Meter the daily auxiliary power (kwhr) used by the 900 psi plant via house service transformers #1 and #2, and #3 standby transformer, call this P_{900} .
2. Determine the 900 psi auxiliary power which is 100% electric (e.g. condensate and circulating water pump motors, cooling tower fans, substation power, and base station power for electric), call this P_{e1} . These auxiliaries are estimated from hourly motor current readings, test data, and the allocation of the total base station power.
3. Determine the 900 psi auxiliary power which is chargeable directly to the industrial steam system, P_{s1} . The quantity is the sum of the base station power for steam and the power consumed by various pumps for the benefit of industrial steam. The pump power consumption is that required for well water pumps, softener booster pumps, treated water make-up pumps, and tempering water pumps. The total pumping energy quantities are calculated from water flows, pressures, and appropriate test data. Pumping energy for the water treatment function is allocated 96% to the industrial steam, based on the 1994 plant water use study for the MPSC Case EO-94-36.
4. Determine the portion of P_{900} which can be allocated,
 $P'_{900} = P_{900} - P_{e1} - P_{s1}$
5. Determine the auxiliary power consumed by Boiler 5 precipitator (supplied from the Unit 5 auxiliary transformer), $P_{5p} = K1 \times \text{number hours Boiler 5 is on burning coal}$, where K1 is the average kilowatt load drawn by the Boiler 5 precipitator.
6. Estimate the power consumed by #3 and #8 coal belts to deliver coal to the Boiler 5 coal bunkers, $P_{38} = K2 \times \text{number of tons of coal delivered to Boiler 5 bunkers}$. K2 is the average kwh required to transport one ton of coal from the reclaim pit to the Boiler 5 bunkers.
7. Meter the daily auxiliary power used by the rotary dumper, #6 and #7 coal belts, and related equipment supplied by #7 auxiliary transformer. Determine the amount allocated to steam by multiplying by the Plant Coal Burn Allocation Factor, Schedule TMR-5, Wkpr 3. Designate this power as **PSC**.
8. Total auxiliary power charged to steam is calculated as
 $P_S = X_S(P'_{900} + P_{5p} + P_{38}) + P_{s1} + P_{SC}$ where X_S is the fuel allocation factor for steam.
9. Total auxiliary power charged to electric is the difference between the total plant auxiliary power and P_S .

**KCP&L Greater Missouri Operations
Electric / Steam Allocation Factors**

L&P - Combined

12 Months Ended December 2016

| | 2016 | | Notes |
|--|-----------------------------------|-----------|------------------------------|
| | Electric | Steam | |
| <u>Electric/Steam Allocation Factors</u> | | | |
| 1 | Electric - 100% | 0.0000 % | 100.000 % |
| 2 | Steam - 100% | 0.0000 % | 100.000 % |
| 4 | Land Factor | 82.5407 % | 100.000 % Tab A, Factor D |
| 5 | Structures Factor | 82.5407 % | 100.000 % Tab A, Factor D |
| 6 | Boiler Plant Factor | 74.5543 % | 100.000 % Tab A, Factor A |
| 7 | Turbogenerators Factor | 97.9069 % | 100.000 % Tab A, Factor B |
| 8 | Access Elec Eqpt & General Factor | 82.5407 % | 100.000 % Tab A, Factor D |
| 9 | Misc Steam GEN Eqpt Factor | 67.8573 % | 100.000 % Tab B, Factor A |
| 10 | Electric/Steam Plant Factor | 82.4161 % | 100.000 % Tab A, Factor E |
| <u>Income Statement Allocation Factors (Elec/Steam)</u> | | | |
| 13 | Electric After Steam Alloc (O&M) | 93.1605 % | 100.000% Tab D, Factor A |
| 14 | Electric After Steam Alloc (A&G) | 98.9907 % | 100.000% Tab C, Factor A |
| <u>Factors Used to Calculate Other Factors</u> | | | |
| 3 | Allocated Plant Base Factor | 99.1377 % | 100.000 % Tab C, Factor B |
| 11 | 900 lb Steam Demand Factor | 67.3379 % | 100.000 % Tab B, Factor A |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

| KCP&L Greater Missouri Operations | IND Steam | | 9008 Steam Demand Factor | | TOTAL PLANT AFTER ALLOCATIONS: | | Plant Acct | Total | Factor |
|---|---|--------------------|----------------------------|--------------------------|--|---|--------------------|-------------------|--------------------|
| | Electric Plant | Steam Plant | Electric | Steam | Electric | Steam | | | |
| STEAM PLANT ALLOCATION FACTOR | | | | | | | | | |
| Lake Road & IND Steam Plant-In-Service | | | | | | | | | |
| Plant Account | IND Steam | Steam Plant | Less: LR Unit 1-4 | Equals: Remaining | 9008 Steam Demand Factor | Plant Account | Electric | Steam | Total |
| | Electric Plant | Steam Plant | 100% Electric | Allocable Elec Pk | 34.8627% | | | | |
| | | | See notes | | | | | | |
| GENERATION - Allocated based on 9008 Steam Demand Factor | | | | | | | | | |
| 31200 - Boiler Plant Equipment | 84,999,345 | | 22,814,659 | 62,184,687 | 41,873,309 | 31200 - Boiler Plant Equipment | 84,999,345 | 20,310,567 | 84,999,345 |
| 31201 - Boiler Pollution Equipment | 5,638,497 | | 1,178,649 | 4,459,847 | 3,003,032 | 31201 - Boiler Pollution Equipment | 5,638,497 | 1,486,615 | 5,638,497 |
| 31202 - India Sim-Baker Plant Exp | 1,738,366 | | | | | 31202 - India Sim-Baker Plant Exp | 1,738,366 | 1,738,366 | 1,738,366 |
| 31400 - Turbogun Units | 21,583,861 | | 20,200,076 | 1,383,785 | 931,408 | 31400 - Turbogun Units | 21,583,861 | 451,777 | 21,583,861 |
| 31600 - Miscellaneous Plant Equipment | 1,348,489 | | 21,443 | 1,327,046 | 893,611 | 31600 - Miscellaneous Plant Equipment | 1,348,489 | 433,444 | 1,348,489 |
| 34100 - Other Steam & Improvements | 1,623,428 | | 1,923,428 | 0 | 0 | 34100 - Other Steam & Improvements | 1,623,428 | 0 | 1,623,428 |
| 34200 - Fuel Holders & Accessories | 620,559 | | 620,559 | 0 | 0 | 34200 - Fuel Holders & Accessories | 620,559 | 0 | 620,559 |
| 34300 - Prime Movers | 17,004,988 | | 17,004,988 | 0 | 0 | 34300 - Prime Movers | 17,004,988 | 0 | 17,004,988 |
| 34400 - Generators | 2,688,016 | | 2,688,016 | 0 | 0 | 34400 - Generators | 2,688,016 | 0 | 2,688,016 |
| 34500 - Accessory Elec Equipment | 2,458,159 | | 2,458,159 | 0 | 0 | 34500 - Accessory Elec Equipment | 2,458,159 | 0 | 2,458,159 |
| 34600 - Misc Power Plant Equipment | 137,962,354 | | 89,698,989 | 68,353,795 | 48,761,360 | 34600 - Misc Power Plant Equipment | 137,962,354 | 22,852,494 | 137,962,354 |
| | | | | | | | | | |
| GENERATION - Allocated based on Total Avg Alloc Calc Above | | | | | | | | | |
| 3100X - Land & Lease Rights | 11,450 | | | | | 3100X - Land & Lease Rights | 11,450 | 11,450 | 11,450 |
| 3100Y - Road & Improvements | 21,819,410 | | 5,118,517 | 16,700,893 | 13,967,364 | 3100Y - Road & Improvements | 21,819,410 | 2,857,671 | 21,819,410 |
| 3100Z - Accessory Electric Equipment | 48,649 | | 5,607,648 | 5,715,134 | 4,717,311 | 3100Z - Accessory Electric Equipment | 48,649 | 10,523,859 | 10,523,859 |
| | 90,457 | | 10,954,633 | 21,910,210 | 18,084,675 | | 29,048,814 | 3,915,732 | 32,964,546 |
| | | | | | | | | | |
| GENERAL PLANT | Electric Plant | Steam Plant | Less: 100% Electric | Equals: Remaining | Allocation Based on Plant Ratios Above: | Plant Account | Electric | Steam | Total |
| | | | | | | | | | |
| 30300 - Misc Intangible Software - 5 year | 350,000 | | 288,602 | 61,398 | 61,398 | 30300 - Misc Intangible Software - 5 year | 288,602 | 61,398 | 350,000 |
| 30100 - Office Furniture and Equipment | 361,273 | | 298,197 | 63,076 | 63,076 | 30100 - Office Furniture and Equipment | 298,197 | 63,076 | 361,273 |
| 30102 - Computer Hardware | 116,827 | | 96,430 | 20,397 | 20,397 | 30102 - Computer Hardware | 96,430 | 20,397 | 116,827 |
| 30104 - Computer Software | 81,387 | | 67,177 | 14,210 | 14,210 | 30104 - Computer Software | 67,177 | 14,210 | 81,387 |
| 3020X - Transportation | 341,948 | | 282,244 | 59,704 | 59,704 | 3020X - Transportation | 282,244 | 59,704 | 341,948 |
| 30300 - Heavy Equipment | 13,024 | | 11,081 | 1,943 | 1,943 | 30300 - Heavy Equipment | 11,081 | 1,943 | 13,024 |
| 30400 - Tools | 287,089 | | 236,865 | 50,224 | 50,224 | 30400 - Tools | 236,865 | 50,224 | 287,089 |
| 30500 - Lin Equipment | 438,654 | | 362,085 | 76,569 | 76,569 | 30500 - Lin Equipment | 362,085 | 76,569 | 438,654 |
| 30600 - Power Oper Equipment | 933,854 | | 792,031 | 141,823 | 141,823 | 30600 - Power Oper Equipment | 792,031 | 141,823 | 933,854 |
| 30700 - Communication Equipment | 671,317 | | 572,629 | 98,688 | 98,688 | 30700 - Communication Equipment | 572,629 | 98,688 | 671,317 |
| 30800 - Miscellaneous Equipment | 3,560,009 | | 2,954,956 | 605,053 | 605,053 | 30800 - Miscellaneous Equipment | 2,954,956 | 605,053 | 3,560,009 |
| | | | | | | | | | |
| INDUSTRIAL STEAM | | | | | | | | | |
| 37500 - Ind Steam Dist Steam and Improvements | 132,825 | | 100% Steam | | | 37500 - Ind Steam Dist Steam and Improvements | 132,825 | 132,825 | 132,825 |
| 37600 - Ind Steam Dist Meas | 1,420,926 | | 100% Steam | | | 37600 - Ind Steam Dist Meas | 1,420,926 | 1,420,926 | 1,420,926 |
| 37900 - Ind Steam City Gate Meas and Reg | 480,205 | | 100% Steam | | | 37900 - Ind Steam City Gate Meas and Reg | 480,205 | 480,205 | 480,205 |
| 38000 - Ind Steam Servics | 100,842 | | 100% Steam | | | 38000 - Ind Steam Servics | 100,842 | 100,842 | 100,842 |
| 38100 - Ind Steam Meas | 363,650 | | 100% Steam | | | 38100 - Ind Steam Meas | 363,650 | 363,650 | 363,650 |
| | 2,488,648 | | | | | | 2,488,648 | 2,488,648 | 2,488,648 |
| Total Plant Before Allocations: | 174,473,312 | 4,327,471 | | | | Total Plant Before Allocations: | 147,314,928 | 31,430,235 | 178,744,764 |
| Percentage Breakdown: | 97.6% | 2.4% | | | | Percentage Breakdown: | 82.4619% | 17.53809% | 100.0% |
| Notes: | Plant Data provided by property accounting - Powerplant Query - See Excel file "Steam & Lake Road PP Query" | | | | | | | | |
| | For purposes of reporting, the S.U.P. Lake Road Allocation Schedule - Accounts 310 Dbn 316 are placed in two categories as follows: | | | | | | | | |
| | 1) 100% Electric and 2) Allocated to Electric Plant | | | | | | | | |
| | Lake Road Unit 1 thru Unit 4 amounts are included in the "100% Electric" category. This does not include the Boilers which are Allocated. | | | | | | | | |
| | Lake Road Common-RC-1090 and 31000 Land only is included in the "100% Electric" category. | | | | | | | | |
| | Lake Road 340-346 show production in the "100% Electric" category. | | | | | | | | |
| | All other asset locations are included in the "Allocated to Electric Plant" category. | | | | | | | | |
| | Lake Road Intangible plant, Industrial steam plant, Other production plant and General plant are not included in either category. | | | | | | | | |

| | | | | | | | | |
|--|--|-------------------------------|---|--|---------|-------|----------|---|
| KCP&L Greater Missouri Operations | | | | | | | | |
| 900 lb STEAM DEMAND ALLOCATION FACTOR | | | | | | | | |
| | | | | | | | | |
| Demand and Utilization Factors | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | 471.8 | | |
| | | Calculated fuel for max sales | | | | | | |
| | | Fuel Energy for Generation | = | | 1,444.5 | | 32.6621% | A |
| | | | | | | | | |
| | | | | | | | | |

| KCP&L Greater Missouri Operations Industrial Steam Allocation 900 lb Steam Demand Detail | 2015 | | | | | | | | | | | | 2016 | | | | | | | | | | | |
|--|--|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|--|--|--|--|
| | Jan | Feb | Mar | Apr | May | June | July | Aug | Sept | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | June | July | Aug | | | | |
| Maximum hourly 155# steam sales | 404.1 | 400.4 | 409.5 | 359.1 | 357.0 | 375.9 | 333.9 | 355.1 | 396.7 | 336.5 | 388.2 | 355.3 | 380.7 | 391.3 | 367.4 | 351.0 | 353.0 | 327.1 | 314.6 | 316.0 | | | | |
| Maximum hourly 155# steam sales | 313.4 | 311.4 | 318.2 | 278.7 | 276.0 | 292.1 | 260.1 | 275.7 | 323.9 | 261.2 | 289.8 | 271.9 | 251.3 | 305.0 | 286.1 | 280.1 | 272.8 | 253.2 | 244.0 | 247.3 | | | | |
| Day | 74 | 71 | 72 | 6 | 12 | 4 | 10 | 10 | 3 | 3 | 19 | 11 | 19 | 20 | 11 | 18 | 18 | 10 | 7 | 6 | | | | |
| Time | 19:42 | 19:45 | 23:22 | 17:47 | 18:58 | 22:27 | 11:59 | 18:04 | 20:08 | 19:58 | 19:51 | 11:11 | 18:47 | 19:43 | 3:49 | 4:40 | 1:55 | 5:02 | 11:05 | 1:58 | | | | |
| Maximum hourly Total steam sales (155# + 850#) | 431.1 | 439.4 | 439.4 | 387.6 | 390.6 | 409.5 | 361.7 | 382.2 | 370.8 | 384.7 | 388.8 | 384.2 | 409.8 | 424.1 | 398.2 | 392.4 | 365.7 | 358.7 | 344.3 | 350.7 | | | | |
| Maximum hourly Total steam sales (155# + 850#) | 335.2 | 336.9 | 337.5 | 301.8 | 304.6 | 318.4 | 292.7 | 287.6 | 343.3 | 287.6 | 299.5 | 286.3 | 320.9 | 330.6 | 310.3 | 305.5 | 300.0 | 278.7 | 267.9 | 343.5 | | | | |
| Day | 6 | 23 | 2 | 8 | 12 | 4 | 10 | 17 | 3 | 9 | 23 | 1 | 20 | 22 | 3 | 7 | 14 | 8 | 6 | 6 | | | | |
| Time | 23:35 | 20:55 | 23:22 | 17:47 | 18:58 | 22:26 | 11:39 | 18:04 | 20:09 | 15:33 | 19:31 | 132 | 1947 | 900 | 1314 | 214 | 210 | 508 | 947 | 1:58 | | | | |
| Note: | The MMBtu/Hr values listed above are the energy in the steam, not the energy in the fuel. The fuel energy value can be found by dividing by 81.5%, the weighted average boiler efficiency. | | | | | | | | | | | | | | | | | | | | | | | |
| Note: | The MMBtu/Hr values listed above are the energy in the steam, not the energy in the fuel. The fuel energy value can be found by dividing by 81.5%, the weighted average boiler efficiency. | | | | | | | | | | | | | | | | | | | | | | | |
| Per 2010 SPP Capability Test | Calculated fuel for max sales | | | | | | | | | | | | | | | | | | | | | | | |
| Per PSC Heat Rate Tests | Fuel Energy for Generation | | | | | | | | | | | | | | | | | | | | | | | |
| Net MW Rating | 81.5% Weighted Average Btu/EH | | | | | | | | | | | | | | | | | | | | | | | |
| Gross MW | 81.5% Weighted Average Btu/EH | | | | | | | | | | | | | | | | | | | | | | | |
| GTHR | 81.5% Weighted Average Btu/EH | | | | | | | | | | | | | | | | | | | | | | | |
| Steam Energy For Turbine For Generation | 972.7 | | | | | | | | | | | | | | | | | | | | | | | |
| Steam Energy For Generation | 972.7 | | | | | | | | | | | | | | | | | | | | | | | |
| 900lb Steam Demand Factor = | 972.7 | | | | | | | | | | | | | | | | | | | | | | | |

| KCP&L Greater Missouri Operations | | | | | | | | | | | | | | | | |
|--|---|---------|----------|----------|---------|----------|-------|-------|-------|-------|-------|--------|-----------|---------|----------|----------|
| Industrial Steam Allocation | | | | | | | | | | | | | | | | |
| 900 lb Steam Demand Detail | | | | | | | | | | | | | | | | |
| | September | October | November | December | January | February | March | April | May | June | July | August | September | October | November | December |
| Maximum hourly 155# steam sales | 347.9 | 346.4 | 337.5 | 374.3 | 378.3 | 374.4 | 356.0 | 350.4 | 351.6 | 317.2 | 340.0 | 302.8 | 306.5 | 306.5 | 283.4 | 307.9 |
| Minimum hourly 155# steam sales | 287.2 | 283.8 | 251.5 | 219.3 | 212.2 | 206.2 | 219.5 | 273.0 | 283.9 | 246.9 | 283.7 | 239.1 | 216.8 | 202.7 | 207.0 | 209.3 |
| Day | 26 | 27 | 15 | 16 | 12 | 28 | 28 | 11 | 11 | 8 | 21 | 8 | 8 | 8 | 30 | 30 |
| Time | 2102 | 1031 | 1759 | 1707 | 1012 | 227 | 1235 | 451 | 1452 | 945 | 1303 | 839 | 2729 | 954 | 1020 | 566 |
| Maximum hourly Total steam sales (155# + 850#) | 377.8 | 377.0 | 365.1 | 403.8 | 412.4 | 406.6 | 382.1 | 357.1 | 388.2 | 351.6 | 333.9 | 333.0 | 338.9 | 357.8 | 394.9 | 423.5 |
| Minimum hourly Total steam sales (155# + 850#) | 293.7 | 293.6 | 284.8 | 314.9 | 319.8 | 315.5 | 301.2 | 302.6 | 304.9 | 274.2 | 280.6 | 259.2 | 264.4 | 268.3 | 308.0 | 330.6 |
| Day | 23 | 27 | 16 | 16 | 12 | 28 | 15 | 11 | 9 | 1 | 21 | 28 | 8 | 23 | 30 | 30 |
| Time | 2102 | 1844 | 331 | 1707 | 1012 | 227 | 1235 | 451 | 1452 | 945 | 1303 | 935 | 2729 | 954 | 1020 | 558 |
| Note: | The MMBtu/Hr values listed above are the energy in the steam, not the steam itself. | | | | | | | | | | | | | | | |
| Note: | Per 2010 SPP Capability Test: | | | | | | | | | | | | | | | |
| Per FSC Heat Rate Tests | 471.8 | | | | | | | | | | | | | | | |
| Per FSC Heat Rate Tests | 1444.5 | | | | | | | | | | | | | | | |
| Per FSC Heat Rate Tests | 32.6621% | | | | | | | | | | | | | | | |
| Net MW Rating | 21.7 | | | | | | | | | | | | | | | |
| | 28.4 | | | | | | | | | | | | | | | |
| | 31 | | | | | | | | | | | | | | | |
| | 56.1 | | | | | | | | | | | | | | | |

| | 2015 | | | | | | | | | | | | 2016 | | | | | | | | | | | |
|---|--|-------|-------|-------|-------|-------|-------|-------|-------|---------|----------|----------|-------|-------|-------|-------|-------|-------|-------|-------|-------|---------|----------|----------|
| | Jan | Feb | Mar | Apr | May | June | July | Aug | Sept | October | November | December | Jan | Feb | Mar | Apr | May | June | July | Aug | Sept | October | November | December |
| KCR&L Greater Missouri Operations | Maximum consistent demand for steam customers in 2015, 2016 and 2017 (mmBtu/hr) | | | | | | | | | | | | | | | | | | | | | | | |
| Fuel Oil Demand Allocation Factor Allocation of Fuel Inventory | | | | | | | | | | | | | | | | | | | | | | | | |
| Minimum hourly 1554 steam sales | 404.1 | 402.4 | 408.5 | 408.5 | 359.1 | 357.0 | 375.9 | 333.9 | 355.1 | 338.7 | 336.5 | 346.2 | 358.3 | 360.7 | 391.3 | 384.4 | 361.0 | 353.0 | 327.1 | 314.8 | 319.9 | 347.9 | 347.9 | |
| Maximum hourly 1554 steam sales | 313.4 | 311.4 | 318.2 | 318.2 | 278.7 | 279.0 | 262.1 | 280.1 | 275.7 | 323.9 | 261.2 | 269.8 | 277.5 | 297.3 | 303.9 | 282.8 | 280.0 | 272.8 | 253.2 | 244.0 | 321.3 | 269.4 | 269.4 | |
| Minimum hourly 1558 steam sales | 14 | 27 | 27 | 2 | 8 | 12 | 4 | 10 | 17 | 3 | 10 | 23 | 31 | 20 | 10 | 31 | 3 | 3 | 8 | 7 | 6 | 29 | 29 | |
| Maximum hourly 1558 steam sales | 1842 | 1845 | 2322 | 2322 | 1747 | 1835 | 2227 | 1136 | 1804 | 2088 | 1808 | 931 | 111 | 1947 | 304 | 346 | 440 | 156 | 508 | 1105 | 158 | 2102 | 2102 | |
| Minimum hourly Total steam sales (1554 + 1558) | 431.1 | 430.4 | 434.4 | 434.4 | 367.6 | 369.6 | 408.6 | 363.7 | 382.2 | 370.8 | 363.8 | 384.7 | 384.2 | 408.8 | 424.1 | 388.2 | 382.4 | 365.7 | 338.7 | 344.3 | 350.7 | 377.8 | 377.8 | |
| Maximum hourly Total steam sales (1554 + 1558) | 332.2 | 332.9 | 337.5 | 337.5 | 301.6 | 304.0 | 318.4 | 282.7 | 297.5 | 340.3 | 267.8 | 289.5 | 299.5 | 379.9 | 350.6 | 319.3 | 305.5 | 309.0 | 278.7 | 287.9 | 343.5 | 293.7 | 293.7 | |
| Day | 5 | 23 | 2 | 2 | 8 | 12 | 4 | 10 | 17 | 3 | 8 | 23 | 31 | 20 | 10 | 31 | 7 | 7 | 14 | 8 | 6 | 29 | 29 | |
| Time | 2336 | 2095 | 2322 | 2322 | 1747 | 1936 | 2228 | 1139 | 1804 | 2088 | 1533 | 931 | 132 | 1947 | 909 | 1314 | 214 | 210 | 508 | 947 | 158 | 2102 | 2102 | |
| Notes: | The MMBohr values listed above are the energy in the steam, not the energy in the fuel. The fuel energy value can be found by dividing by 81.5%, the weighted average boiler efficiency. Generator 2 and Boiler 5 are not included in the calculation since Boiler 5 is not capable of burning fuel oil. Boiler 5 and Turbine 2 were installed together and stand accordingly. | | | | | | | | | | | | | | | | | | | | | | | |
| Per 2010 SPP Capability Test | | | | | | | | | | | | | | | | | | | | | | | | |
| Per PSC Heat Rate Tests | | | | | | | | | | | | | | | | | | | | | | | | |
| Oil Demand Factor | | | | | | | | | | | | | | | | | | | | | | | | |
| Net MW Rating | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 | 21.7 |
| Gross MWh | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 | 26.4 |
| HR | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 | 9.4 |
| Fuel Energy For Generation MMBohr | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 |
| Steam Energy For Turbine MMBohr | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 | 218 |
| Site notes | See notes | | | | | | | | | | | | | | | | | | | | | | | |
| Generator 1 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 |
| Generator 2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 | 12.2 |
| Generator 3 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 | 9.981 |
| Generator 4 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 |
| Generator 5 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 |
| Generator 6 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 |
| Generator 7 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 |
| Total | 260.6 | 274.4 | | | | | | | | | | | | | | | | | | | | | | |
| Calculated Fuel Oil for Max Sales | 471.9 | | | | | | | | | | | | | | | | | | | | | | | |
| Fuel Oil for Generation and Max Steam Sales | 3567.4 | | | | | | | | | | | | | | | | | | | | | | | |
| Calculated Fuel Oil for 81.5% efficiency | 471.9 | | | | | | | | | | | | | | | | | | | | | | | |
| Fuel Oil for Generation and Max Steam Sales | 3567.4 | | | | | | | | | | | | | | | | | | | | | | | |
| Calculated Fuel Oil for 81.5% efficiency | 471.9 | | | | | | | | | | | | | | | | | | | | | | | |

| | October | November | December | January | February | March | April | May | June | July | August | September | October | November | December |
|--|---------|----------|----------|---------|----------|-------|-------|-------|-------|-------|--------|-----------|---------|----------|----------|
| 2017 | | | | | | | | | | | | | | | |
| KCP&L Greater Missouri Operations | | | | | | | | | | | | | | | |
| Fuel Oil Demand Allocation Factor | | | | | | | | | | | | | | | |
| Allocation of Fuel Inventory | | | | | | | | | | | | | | | |
| Maximum hourly 155# steam sales | 346.4 | 337.5 | 374.3 | 378.3 | 372.4 | 366.0 | 366.0 | 361.9 | 361.9 | 317.4 | 340.0 | 306.6 | 306.5 | 338.2 | 388.4 |
| Minimum hourly 155# steam sales | 289.7 | 281.8 | 281.0 | 292.3 | 288.1 | 276.6 | 276.6 | 273.0 | 283.5 | 246.5 | 236.7 | 237.6 | 238.1 | 260.7 | 287.0 |
| Day | 27 | 15 | 16 | 12 | 28 | 15 | 15 | 9 | 9 | 1 | 21 | 28 | 8 | 23 | 30 |
| Time | 1031 | 1759 | 1707 | 1912 | 227 | 1253 | 1253 | 451 | 1452 | 945 | 1303 | 835 | 2229 | 954 | 1070 |
| Maximum hourly Total steam sales (155# + 850#) | 377.0 | 366.1 | 403.6 | 412.4 | 405.6 | 392.1 | 387.1 | 388.2 | 388.2 | 351.6 | 333.9 | 333.0 | 338.9 | 367.8 | 384.0 |
| Minimum hourly Total steam sales (155# + 850#) | 293.8 | 284.6 | 314.9 | 319.6 | 315.5 | 307.2 | 302.6 | 304.6 | 304.6 | 274.2 | 260.9 | 259.2 | 264.4 | 295.3 | 308.0 |
| Day | 27 | 16 | 16 | 12 | 28 | 15 | 15 | 9 | 9 | 1 | 21 | 28 | 8 | 23 | 30 |
| Time | 1644 | 331 | 1727 | 1012 | 227 | 1259 | 1259 | 481 | 1452 | 945 | 1303 | 835 | 2229 | 954 | 1020 |
| Net MW Rating | | | | | | | | | | | | | | | |
| Generator 1 | | | | | | | | | | | | | | | |
| Generator 2 | | | | | | | | | | | | | | | |
| Generator 3 | | | | | | | | | | | | | | | |
| Generator 4 | | | | | | | | | | | | | | | |
| Generator 5 | | | | | | | | | | | | | | | |
| Generator 6 | | | | | | | | | | | | | | | |
| Generator 7 | | | | | | | | | | | | | | | |
| Total | | | | | | | | | | | | | | | |

Note:
The MW/BtuHr values listed above are the energy in the steam, not
Generator 2 and Boiler 5 are not included in the calculation since B
Per 2010 SPP Capability Test
Per PSC Heat Rate Tests

| KCP&L Greater Missouri Operations | | | | |
|--|--|---------------|--------|--------------|
| O&M FACTOR | | | | |
| Industrial Steam Allocation | | | | |
| Source: Amy Murray - Regulatory Affairs | | | | |
| 1. Payroll Allocation Factors - Steam v Electric | | | | |
| Annual S.J.P. Iatan Payroll for O&M - 2016 Actual | | \$ 2,485,259 | (B) | |
| Annual S.J.P. Lake Road Payroll for O&M - 2016 Actual | | 5,915,992 | (A) | |
| Annual MOPUB Sibley Iatan, JEC for O&M - 2016 Actual | | 13,223,137 | (C) | |
| Total GMO 2016 Payroll charged to O&M | | \$ 21,624,389 | | |
| LR Payroll for Steam Business | | \$ 1,478,998 | | |
| Payroll Percentage for O&M Allocation | | 6.8395% | A | #13 |
| 2. Payroll Applicable to Steam Business: | | | | |
| Lake Road Production Payroll by Account: | | 2016 Payroll | | |
| 500000 | | 301,186 | | |
| 502000 | | 383,788 | | |
| 502001 | | 1,323,956 | | |
| 502004 | | 54,825 | | |
| 502005 | | 5,524 | | |
| 502012 | | 212,290 | | |
| 502015 | | 309 | | |
| 505000 | | 3,165 | | |
| 505007 | | 4,912 | | |
| 505010 | | 957,206 | | |
| 505011 | | 2 | | |
| 506000 | | 836,774 | | |
| 510000 | | 702,420 | | |
| 511000 | | 131,489 | | |
| 511002 | | 11,534 | | |
| 512000 | | 124,732 | | |
| 512001 | | 26,453 | | |
| 512002 | | 9,855 | | |
| 512004 | | 30,540 | | |
| 512005 | | 10,956 | | |
| 512006 | | 79,740 | | |
| 512007 | | 39,274 | | |
| 512008 | | 186,366 | | |
| 512010 | | 126,737 | | |
| 512011 | | 149,707 | | |
| 512012 | | 15,992 | | |
| 513000 | | 190 | | |
| 513001 | | 107,161 | | |
| 513003 | | 16,673 | | |
| 513006 | | 50,452 | | |
| 514000 | | 11,784 | | |
| Allocated | | \$ 5,915,992 | 25.00% | \$ 1,478,998 |
| Industrial Steam Distrib Accounts (588730 & 598730) | | | | |
| Total Steam | | | | |
| Note: Used the Total Plant Coal Burn Allocation Factor to determine the Steam % above. | | | | |
| (A) LR payroll to accounts 500, 502-507, 510-514 only | | | | |
| (B) S.J.P. Iatan payroll (dept 1115) to accounts 500, 502-507, 510-514 only | | | | |
| (C) M.P.S. Iatan and Sibley payroll to accounts 500, 502-507, 510-514 only | | | | |

KCP&L Greater Missouri Operations

O&M, A&G, Other Taxes

Revenue Requirements Model Schedule 2

| Account No. | Description | Juris Factor No. | Allocator Factor | Allocation based on |
|-----------------------------------|---------------------------------------|------------------|---------------------------------------|--|
| Operating Expenses | | | | |
| <i>Electric Operating Expense</i> | | | | |
| 500000 | Prod-Steam Oper-Supv & Enginr | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 500000E | Prod-Steam Oper-Supv & Enginr-Elec | 1,1 | 100% Electric | |
| 501000 | Fuel Exp-Deliv Cost Coal Burn | 4,1 | 100% Electric | |
| 501020 | Fuel on System Steam | 4,1 | 100% Electric | |
| 501030 | Fuel Off-System Steam (bk20) | 4,1 | 100% Electric | |
| 501033 | FuelSteamInterUN/IntraST(bk11) | 4,1 | 100% Electric | |
| 501300 | Fuel Exp-Additives - Limestone | 4,1 | 100% Electric | |
| 501400 | Fuel Exp-Residuals | 4,1 | 100% Electric | |
| 501420 | Fuel Exp-Residuals Non FAC | 4,1 | 100% Electric | |
| 501450 | Fuel Exp-Residuals-Landfills | 4,1 | 100% Electric | |
| 501500 | Fuel Handling Costs | 4,1 | 100% Electric | |
| 501501 | Fuel Hndlg-Oil Purch Exp-Start | 4,1 | 100% Electric | |
| 501502 | Fuel Hndlg-Coal Pile Mgmt-Pwr | 4,1 | 100% Electric | |
| 501503 | Fuel Handling Negot Transp Cnt | 4,1 | 100% Electric | |
| 501504 | Fuel Hndlg-Plan Fuel Req-Pwr P | 4,1 | 100% Electric | |
| 501506 | Fuel Hndlg-Receive Coal | 4,1 | 100% Electric | |
| 501507 | Fuel Hndlg-Fossil Fuel Unload | 4,1 | 100% Electric | |
| 501508 | Fuel Handling - Slacker | 4,1 | 100% Electric | |
| 501509 | Fuel Handling - Coal Pile | 4,1 | 100% Electric | |
| 501510 | Fuel Handling - Conveyor | 4,1 | 100% Electric | |
| 501700 | Fuel Expense Industrial Steam | 2,2 | 100% Steam | |
| 502000 | Steam Oper-City Water | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 502001 | Steam Oper-Boiler | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 502002 | Steam Oper-Nitrogen | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 502004 | Steam Oper-Water | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 502005 | Steam Oper-Condensate | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 502012 | Steam Oper- Ash | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 502014 | Steam Oper-Air Pollution Contr | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 502015 | Steam Oper-Water Pollution Con | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 502020 | Steam Ops Apx Precipitator | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 502021 | Steam Ops ACQ Baghouse | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 502022 | Steam Ops Wet Gas Scrubber | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 502024 | Steam Ops AQC Scr | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 502025 | Steam Ops Activated CO2 Inject | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 504100 | Steam Transfer Exp | 2,2 | 100% Steam | |
| 505000 | Steam Ops Elec Exp Other | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 505004 | Steam Op Ele Exp Comp Air Sys | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 505005 | Steam Ops Ele Exp Cooling Sys | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 505007 | Steam Ops Ele Exp Facilities | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 505010 | Steam Ops Ele Exp Turbine Gen | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 505011 | Steam Ops Ele Exp Aux System | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 508000A | Misc Steam Power Operations | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 506000E | Steam Ops Misc Steam Power Exp -Elec | 1,1 | 100% Electric | |
| 506000S | Steam Ops Misc Steam Power Exp -Steam | 2,2 | 100% Steam | |
| 507000 | Steam Power Operations - Rents | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 509000A | EI Op Exp-Allowances | 4,1 | 100% Electric | |
| 509000E | EI Op Exp-Allowances-Elec | 1,1 | 100% Electric | |
| 546000 | Prod-Turbine Oper-Supv & Engnr | 3,1 | 100% Electric | |
| 547000 | Oth Prod Fuel | 4,1 | 100% Electric | |
| 547020 | Fuel On-System Other Prod | 4,1 | 100% Electric | |
| 547027 | Fuel OnSys Oth Prod-Demand | 4,1 | 100% Electric | |
| 547030 | Fuel Off-Sys Other Prod (bk20) | 4,1 | 100% Electric | |
| 547033 | FuelOtherInterUN/IntraST(bk11) | 4,1 | 100% Electric | |
| 547100 | Oth Prod Fuel Handling | 4,1 | 100% Electric | |
| 547102 | Comb Turbine-Gas Purch Exp | 4,1 | 100% Electric | |
| 548000 | Comb Turbine-City Water | 3,1 | 100% Electric | |
| 548002 | Comb Turbine-AQC- | 3,1 | 100% Electric | |
| 548003 | Comb Turbine-Turb/Genr-CT | 3,1 | 100% Electric | |
| 549000 | CombTurbine Oper-Misc Other | 3,1 | 100% Electric | |
| 549001 | Comb Turbine - Facilities | 3,1 | 100% Electric | |
| 555000 | Purch Pwr-Enrgy & Cpcty Pur-Al | 4,1 | 100% Electric | |
| 555005 | Purch Pwr-Capacity Purch-Gardn | 3,1 | 100% Electric | |
| 555021 | Base Pwr On-Sys Interco (bk10) | 4,1 | 100% Electric | |
| 555030 | Purchased Power Off-Sys Sales | 4,1 | 100% Electric | |
| 555031 | Purch Pwr Off-System Interunit | 4,1 | 100% Electric | |
| 555032 | PurchasePower IntraState(bk11) | 4,1 | 100% Electric | |
| 555035 | Purchased Power Off-Sys-WAPA | 4,1 | 100% Electric | |
| 555000 | System Control and Load Dispath | 4,1 | 100% Electric | |
| 557000 | Prod-Other-Other Expenses | 4,1 | 100% Electric | |
| 557100 | Other Production Exp Riders | 1,1 | 100% Electric | |
| 560000 | Transm Oper-Superv & Engineering | 8,1 | 100% Electric | |
| 561000 | Transm Oper-Load Dispatching | 8,1 | 100% Electric | |
| 561200 | Trans Op-Ld Disptch-Mon&Oper | 8,1 | 100% Electric | |
| 561300 | Trans Op-Ld Disptch-Serv&Sched | 8,1 | 100% Electric | |
| 561400 | Trans Op-Schd,Contr & Dis Serv | 8,1 | 100% Electric | |
| 561600 | Trans Op-Service Studies | 8,1 | 100% Electric | |
| 561800 | Trans Op-Relt Plan&Std Dv-RTO | 8,1 | 100% Electric | |
| 562000 | Transm Oper-Station Exp | 8,1 | 100% Electric | |
| 563000 | Transm Oper-Overhead Line Oper | 8,1 | 100% Electric | |
| 563002 | Transm Oper-Inspect OH Lines-G | 8,1 | 100% Electric | |
| 563010 | Transm Oper-Lost & Standby Tim | 8,1 | 100% Electric | |
| 564000 | Trans Op Ug Lines | 8,1 | 100% Electric | |
| 565000 | Transm Oper-Elec Tr-By Others | 8,1 | 100% Electric | |

KCP&L Greater Missouri Operations

O&M, A&G, Other Taxes

Revenue Requirements Model Schedule 2

| Account No. | Description | Juris Factor No. | Allocator Factor | Allocation based on |
|----------------------------------|---|------------------|---------------------------------------|---|
| 565020 | Transm Op Trans Res Load Chg | 8,1 | 100% Electric | |
| 565027 | Transm Oper-Elec Tr-Demand | 8,1 | 100% Electric | |
| 565030 | Transm Oper-Elec Tr-OffSys | 8,1 | 100% Electric | |
| 565000 | Transm Oper-Misc Expense | 8,1 | 100% Electric | |
| 567000 | Transm Oper-Rents | 8,1 | 100% Electric | |
| 575700 | Trans Op-Mkt Mon&Comp Ser-RTD | 8,1 | 100% Electric | |
| 580000 | Distr Oper-Superv & Engring | 5,1 | 100% Electric | |
| 581000 | Distr Oper-Load Dispatching | 5,1 | 100% Electric | |
| 582000 | Distr Oper-Station Expense | 5,1 | 100% Electric | |
| 583000 | Distr Oper-Overhead Lines | 5,1 | 100% Electric | |
| 583001 | Distr Oper-OH Transformer | 5,1 | 100% Electric | |
| 583002 | Distr Oper-OH Trsfmr Cptzd | 5,1 | 100% Electric | |
| 584000 | Distr Oper-Underground Lines | 5,1 | 100% Electric | |
| 584001 | Distr Oper-UG Transformer | 5,1 | 100% Electric | |
| 584002 | Distr Oper-UG Trsfmr Cptzd | 5,1 | 100% Electric | |
| 585001 | Distr Oper-Operate St Light Sy | 5,1 | 100% Electric | |
| 585002 | Distr Oper-Traffic Signals | 5,1 | 100% Electric | |
| 586000 | Distr Oper-Meter Exp-Con/Disco | 5,1 | 100% Electric | |
| 586001 | Distr Oper-Meter Expenses | 5,1 | 100% Electric | |
| 586002 | Distr Oper-Meter Cptzd | 5,1 | 100% Electric | |
| 587000 | Distr Oper-Customer Inst | 5,1 | 100% Electric | |
| 588000 | Distr Oper-Misc Distr Expense | 5,1 | 100% Electric | |
| 588730 | Dist Ops Ind Steam | 2,2 | 100% Steam | |
| 589000 | Distr Oper-Rents | 5,1 | 100% Electric | |
| A&G Operating Expense | | | | |
| 901000 | Customer Acct Supervision Exp | 1,1 | 100% Electric | |
| 902000 | Meter Reading Expense | 1,1 | 100% Electric | |
| 903000 | Customer Record/Collection Exp | 1,1 | 100% Electric | |
| 903300 | Cust Accts-Dollar-Aide Match | 1,1 | 100% Electric | |
| 904000 | Uncollectible Accounts Exp | 1,1 | 100% Electric | |
| 905000 | Miscellaneous Customer Acct Ex | 1,1 | 100% Electric | |
| 907000 | Customer Svc Supervision Exp | 1,1 | 100% Electric | |
| 908000 | Customer Assistance Expense | 1,1 | 100% Electric | |
| 908100 | Customer Assistance Expense RIDER | 1,1 | 100% Electric | |
| 908500 | Cust Assistance Expense EEIA Program Cost | 1,1 | 100% Electric | |
| 909000 | Info/Instruct Advertising Exp | 1,1 | 100% Electric | |
| 910000 | Miscellaneous Cust Svc Exp | 1,1 | 100% Electric | |
| 911000 | Sales Supervision Expense | 1,1 | 100% Electric | |
| 912000 | Sales Expense | 1,1 | 100% Electric | |
| 913000 | Sales Exp-Oper-Advertising | 1,1 | 100% Electric | |
| 916000 | Sales Exp-Oper-Misc Expense | 1,1 | 100% Electric | |
| 920000A | A&G Labor Expense | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 920000E | A&G Labor Expense-100% Retail | 1,1 | 100% Electric | |
| 920000S | A&G Labor - Amort of Merger Trans Steam | 2,2 | 100% Steam | |
| 921000 | A&G Exp-Oper-Office Exp | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 921202 | A&G Allocn-to JO Partners | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 921999 | Misc Issue Settlements | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 922000 | A&G Expenses Transferred | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 922050 | KCP&L Bill of Common Use Plant | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 923000A | Outside Services Employed | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 923000E | Outside Services Employed-Retail | 1,1 | 100% Electric | |
| 923000S | Outside Services-Amort of Merger Transition - Steam | 2,2 | 100% Steam | |
| 923100 | GP&S A&G Trnsf-Depr Int Tax | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 924000 | Property Insurance | 7,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 925000 | Injuries and Damages | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 925050 | Injuries & Damages xfer Constr | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 928000A | Employee Pensions & Benefits | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 926000E | Employee Pensions & Benefits-Retail | 1,1 | 100% Electric | |
| 926000S | Employee Pensions & Benefits - Steam | 2,2 | 100% Steam | |
| 926500 | Empl Pens and Bens Loadings | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 926510 | Benefits on Construct | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 926511 | PR Tax, Pens & Bnfita on O&M | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 926730 | Empl Pens and Bens Ind Steam | 2,2 | 100% Steam | |
| 928000A | Regulatory Commission Expense - Allocated | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 928000E | Regulatory Commission Expense - All Electric | 1,1 | 100% Electric | |
| 928001A | Reg Comm Exp-MPSC Assessment | | | |
| 928001E | Reg Comm Exp-MPSC Assessment - Elec | | | |
| 928001S | Reg Comm Exp-MPSC Assessment - Steam | | | |
| 928003 | Reg Comm Exp-FERC Assessment | | | |
| 928011A | Reg Comm Exp-Mo Proceeding Exp | | | |
| 928011E | Reg Comm Exp-Mo Proceeding Exp - Elec | | | |
| 928011S | Reg Comm Exp-Mo Proceeding Exp - Steam | | | |
| 928012 | Reg Comm Exp-Ks Proceeding Exp | | | |
| 928023 | Reg Comm Exp-FERC Proceedings | | | |
| 928030 | Reg Comm Exp-Load Research Pgm | | | |
| 928040 | Reg Comm Exp-Misc Tariff Filing | | | |
| 929000 | Duplicate Charges-Credit | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 930100 | General Advertising Expense | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 930200 | Miscellaneous General Expense | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 930201 | Misc A&G-Board of Dir Fees | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 930220 | Environ Remed-MO Electric | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 930230 | Misc A&G-Company Assoc Dues | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 930231 | Misc A&G-Edison Elect Inst Dues | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 930232 | Misc A&G-EPRI Research Subscri | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 930242 | Misc A&G-Bond Expense | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |

KCP&L Greater Missouri Operations

O&M, A&G, Other Taxes

Revenue Requirements Model Schedule 2

| Account No. | Description | Juris Factor No. | Allocator Factor | Allocation based on |
|-----------------------------|--------------------------------------|------------------|---------------------------------------|--|
| 930250 | Miscellaneous A&G | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 931000A | A&G Rent Exp | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 931000E | A&G Rent Expense - Elec | 1,1 | 100% Electric | |
| 931002 | Rent of Equipment | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 933000 | Transportation Expense | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 933100 | Transportation & O Series Allo | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 935000 | A&G Mtce of General Plant | 6,14 | Electric After Steam Allocation (A&G) | 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| Maintenance Expenses | | | | |
| 510000 | Steam Power Maint-Supv & Engrn | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 511000 | Steam Power Maint-Structure | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 511002 | Steam Power Maint-Struct-Fac-F | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512000 | Boiler Pit Maint - | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512000E | Boiler Pit Maint - Electric | 1,1 | 100% Electric | |
| 512001 | Boiler Pit Maint - FF Unload | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512002 | Boiler Pit Maint - Stackers | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512003 | Boiler Pit Maint - Coal Pile | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512004 | Boiler Pit Maint - Ash | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512005 | Boiler Pit Maint - Conveyor | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512006 | Boiler Pit Maint - Fuel | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512007 | Boiler Pit Maint - Air | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512008 | Boiler Pit Maint - Water | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512010 | Boiler Pit Maint - Cond Sys | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512011 | Boiler Pit Maint - Furnace | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512012 | Boiler Pit Maint - Aux Steam | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512020 | Boiler Pit Maint-Default Proc | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512021 | Maint Botl Pit Baghouse | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512022 | Maint Boiler Plant Wet Gas Scr | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512024 | Maint Boiler Plant Scr | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 512025 | Maint Boiler Plant Activated CO2 Inj | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 513000 | Elec Pit Maint - | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 513001A | Elec Pit Maint - FF Turb/Gen | 1,1 | 100% Electric | |
| 513001E | Elec Pit Maint - FF Turb/Gen | 2,2 | 100% Steam | |
| 513001S | Elec Pit Maint - FF Turb/Gen | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 513002 | Elec Pit Maint - Transfer FF | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 513003 | Elec Pit Maint - Aux Elec | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 513006 | Elec Pit Maint - Cooling | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 514000 | Misc Steam Pit - | 3,13 | Electric After Steam Allocation (O&M) | Ratio of the allocated Steam Payroll to total non-fuel production GMO Payroll charged to O&M |
| 551000 | Comb Turbine Mtce-Supv & Engrn | 3,1 | 100% Electric | |
| 552000 | Oth Gen Maint of Structures | 3,1 | 100% Electric | |
| 552001 | CT Mtce Structure-Facilities | 3,1 | 100% Electric | |
| 552002 | Comb Turbine Mtce - Bulk Oil F | 3,1 | 100% Electric | |
| 552003 | Comb Turbine Mtce - Fire CT | 3,1 | 100% Electric | |
| 553000 | Comb Turbine Maint - | 3,1 | 100% Electric | |
| 553001 | Comb Turbine Maint - Comb Turb | 3,1 | 100% Electric | |
| 553100 | Oth Pwr Gen Maint Turb Gen | 3,1 | 100% Electric | |
| 554000 | Comb Turbine Maint- Comp Air | 3,1 | 100% Electric | |
| 568000 | Transm Mtce-Suprv & Engineering | 8,1 | 100% Electric | |
| 569000 | Transm Mtce-Subst Bldg/Grounds | 8,1 | 100% Electric | |
| 570000 | Transm Mtce-Subst Equip | 8,1 | 100% Electric | |
| 570001 | Transm Mtce-Subst Teleco/SCADA | 8,1 | 100% Electric | |
| 570002 | Transm Mtce-Subst Breakers | 8,1 | 100% Electric | |
| 570003 | Transm Mtce-Subst Xfrms/Regltr | 8,1 | 100% Electric | |
| 570004 | Transm Mtce-Subst Bus/Groundin | 8,1 | 100% Electric | |
| 570005 | Transm Mtce-Subst Relay Panels | 8,1 | 100% Electric | |
| 570006 | Trans Maint Subst Capacitr Brk | 8,1 | 100% Electric | |
| 570007 | Trans Maint Subst Eqp Bat Bkup | 8,1 | 100% Electric | |
| 571000 | Transm Mtce-Overhead Lines | 8,1 | 100% Electric | |
| 571002 | Trans Maint Oh Lines Twr Lghtg | 8,1 | 100% Electric | |
| 571003 | Transm Mtce-Overhead Structure | 8,1 | 100% Electric | |
| 571004 | Transm Mtce-Cndctrs/Devices | 8,1 | 100% Electric | |
| 571005 | Transm Mtce-Tree-Hand Cutting | 8,1 | 100% Electric | |
| 571006 | Transm Mtce-Tree-Mech Cut | 8,1 | 100% Electric | |
| 572000 | Transm Mtce-Underground Lines | 8,1 | 100% Electric | |
| 573000 | Trans Maint of Misc Trans Plan | 8,1 | 100% Electric | |
| 590000 | Distr Mtce-Suprv & Engineering | 5,1 | 100% Electric | |
| 591000 | Distr Mtce-Structures | 5,1 | 100% Electric | |
| 592000 | Distr Mtce-Station Equip | 5,1 | 100% Electric | |
| 592001 | Distr Mtce-Subst Welding | 5,1 | 100% Electric | |
| 592002 | Distr Mtce-Tele/SCADA | 5,1 | 100% Electric | |
| 592003 | Distr Mtce-Subst Breakers | 5,1 | 100% Electric | |
| 592004 | Distr Mtce-Subst Transformers | 5,1 | 100% Electric | |
| 592005 | Distr Mtce-Subst Line/Bus | 5,1 | 100% Electric | |
| 592006 | Distr Mtce-Subst Relay | 5,1 | 100% Electric | |
| 592007 | Distr Mtce Sub Capacitor | 5,1 | 100% Electric | |
| 592008 | Distr Mtce-Sub Battery Bkup | 5,1 | 100% Electric | |
| 593000 | Distr Mtce-OH-Perform Line Cle | 5,1 | 100% Electric | |
| 593001 | Distr Mtce-OH- Wood Poles | 5,1 | 100% Electric | |
| 593002 | Distr Mtce-OH-Poles/Fixtures | 5,1 | 100% Electric | |
| 593003 | Distr Mtce-OH-Conductors/Devic | 5,1 | 100% Electric | |
| 593004 | Distr Mtce-OH-Prop Dmg Uncolle | 5,1 | 100% Electric | |
| 594000 | Distr Mtce-UG-Dist | 5,1 | 100% Electric | |
| 594001 | Distr Mtce-UG-Dist Conduits | 5,1 | 100% Electric | |
| 594002 | Distr Mtce-UG-Conductors/Devic | 5,1 | 100% Electric | |
| 594003 | Distr Mtce-UG Prop Dmg Uncoll | 5,1 | 100% Electric | |
| 595000 | Distr Mtce-Transformers | 5,1 | 100% Electric | |

KCP&L Greater Missouri Operations

O&M, A&G, OtherTaxes

Revenue Requirements Model Schedule 2

| Account No. | Description | Juris Factor No. | Allocator Factor | Allocation based on |
|--------------------|--------------------------------|------------------|---------------------------------------|--|
| 595001 | Distr Mlce-Transfm-Rep Dist Po | 5,1 | 100% Electric | Ratio of Total GMO Plant excluding ARO's adjusted for the total Steam Allocated Plant 50/50 weighting of the Allocated Plant Base Factor and the Allocated O&M Factor |
| 595002 | Distr Mlce-Transfm0Rep Dist Pa | 5,1 | 100% Electric | |
| 595003 | Distr Mlce-Transfm-Repair | 5,1 | 100% Electric | |
| 596000 | Distr Mlce-Street Ltg & Signls | 5,1 | 100% Electric | |
| 596001 | Distr Mlce-St Ltg & Sig-Rpr OH | 5,1 | 100% Electric | |
| 596002 | Distr Mlce-St Ltg & Sig-Rpr UG | 5,1 | 100% Electric | |
| 596003 | Distr Mlce-St Ltg & Sig-Prop D | 5,1 | 100% Electric | |
| 597000 | Distr Mlce-Meters | 5,1 | 100% Electric | |
| 598000 | Distr Mlce-Misc Dist Pll | 6,1 | 100% Electric | |
| 598730 | Dist Mlce Ind Steam | 2,2 | 100% Steam | |
| OTHER TAXES | | | | |
| 408101 | State Cap Stk Tax Elec | 7,1 | 100% Electric | |
| 408110 | Earnings Tax Electric | 6,1 | 100% Electric | |
| 408112 | Totlt Elec | 6,1 | 100% Electric | |
| 408120 | Property Taxes - Elec | 7,3 | Allocated Plant Base | |
| 408140 | TOTIT FICA FLTA SUTA | 6,14 | Electric After Steam Allocation (A&G) | |

KCP&L Greater Missouri Operations

Lake Road Fuel Inventory Analysis 11/1/17

| | | COAL | | OIL | |
|------------|-------------|-------------------------------------|-----------------------------------|--------------------|--|
| Burn | Jan17-Oct17 | Electric | mmbtus | Electric | mmbtus |
| | | Steam | 11,954 | Steam | 6,462 |
| | | Total | 1,427,761 | Total | 54 |
| | | | 1,439,715 | | 6,516 |
| | | | | | 99.17% |
| | | | | | 0.83% |
| Inventory | | Available | Tons | Available | Barrels |
| | | Basemat | 22,000 | Unavailable | 21,194 |
| | | Total | 13,736 | Total | 234 |
| | | | 35,736 | | 21,428 |
| | | | \$1,235,394 | | \$1,725,424 |
| | | mmbtu's per ton | 17.6 (8800 Btu's per lb. of coal) | mmbtu's per barrel | 5.801 (138,139 Btu's per gallon, 42 gal per barrel)) |
| | | Total mmbtu's | 628,954 | Total mmbtu's | 124,304 |
| Allocation | | Steam 60 Day Average burn on Coal | 287,943 | | |
| | | Recommendation based on 35,736 tons | | | |
| | | Electric | 50.00% | | |
| | | Steam | 50.00% | | |

Oil is primarily a reserve fuel for Electricity and Steam. While use of oil for electricity covers generators beyond the 900 lb. system, the allocation should be based on overall capability of the plant to use oil.

**KCP&L Greater Missouri Operations
Steam Equivalent Employment Factor**

From: John Janorschke
Sent: Friday, January 26, 2018 8:38 AM
To: Tim Rush <Tim.Rush@kcpl.com>
Cc: Aron Branson <Aron.Branson@kcpl.com>; Linda Nunn <Linda.Nunn@kcpl.com>
Subject: FW: Steam Equivalent Employment Factor

This documents the calculation for the Equivalent Employment Factor used in our Steam/Electric allocation procedures. Based on a review of each shift, time worked on steam sales for the 8 hour shift are as follows:

| | |
|---|-------------------|
| Control Operator Hi Side, 4/6 and combustion turbines | 0.5 hours |
| Control Operator Rover, red holds, switching, plant rounds and misc. work | 1.0 Hours |
| Control Operator Low Side, 900# boilers, 900# turbines and steam sales | 4.5 Hours |
| Plant Equipment Operator, outside operator for 4/6, 900# steam turbines and misc. | 1.5 Hours |
| Plant Equipment Operator, 900# boilers, CTs, water system and steam sales | 2.5 Hours |
| Total time to steam sales for each 8 hour shift | 10.0 Hours |

Equivalent Employment Factors are as follows:

Steam: Equivalent Employment Factor = 10 Hrs. / 40 Hrs. = 0.25
 Electric: Equivalent Employment Factor = 1 - 0.25 = 0.75

John Janorschke
Operations Superintendent
 Kansas City Power and Light
 Lake Mead Generation Station
 St. Joseph, MO 64504
 P | 816.387.6431 C | 816.361.7725