

**BEFORE THE PUBLIC SERVICE COMMISSION  
OF THE STATE OF MISSOURI**

In the Matter of the Application of	)	
Osage Utility Operating Company, Inc.	)	
to Acquire Certain Water and Sewer	)	Case No.: WA-2019-0185
Assets and for a Certificate of	)	
Convenience and Necessity	)	

**GREAT SOUTHERN BANK'S  
RESPONSE TO STAFF RECOMMENDATION AND MEMORANDUM**

Great Southern Bank (“**Great Southern**”) responds to the Staff Recommendation and Staff Memorandum, dated May 24, 2019 (collectively, the “**Staff Response**”) as follows:

1. On page 17 of the Staff Memorandum, the Staff states that certain PVC piping and valving does not meet the requirements of the Department of Natural Resources (“**DNR**”) and that the above-ground section of the potable water distribution system needs a heat source.
2. Attached hereto as **Exhibit A** is a letter from DNR dated May 21, 2018. In this letter, DNR approved an engineering report prepared by Michael Stalzer, P.E. dated April 9, 2018 regarding the Reflections’ water system, which report only recommended the addition of three (3) hydropneumatic tanks and a new chlorination system.
3. The report of Michael Stalzer, P.E. dated April 9, 2018 regarding the Reflections’ water system is attached hereto as **Exhibit B** (the “**Stalzer Report**”).
4. Great Southern believes that the two improvements discussed in the Stalzer Report are the only repairs/improvements that need to be made to the potable water system at Reflections to satisfy DNR.
5. Great Southern notes that while the improvements proposed by the Applicant and referenced in the Staff Response greatly exceed those in the Stalzer Report, in both scope and cost, there is no reference to installation of a chlorination system.
6. To the extent chlorination would become necessary to provide adequate water quality, Great Southern requests that the Applicant be directed to include chlorination in its improvements.
7. As Great Southern intends to offer the remaining ground it owns at the Reflections subdivision for development of additional residential and/or commercial uses, Great Southern requests the Commission’s order in this matter reflect that new connections to the Reflections’ systems will not incur a tap-on fee; provided that should additional back-bone facilities (e.g. significant additional storage) be required to serve any new development that would connect to the systems at Reflections, such new development may be required to contribute to the cost of such back-bone facilities.

8. Great Southern requests that the Commission's order in this matter direct that any tax on any future contributions in aid of construction at Reflections be deferred; and that the Applicant include a tariff substantially similar to Missouri American Water Company's P.S.C. Mo. No. 13, 2<sup>nd</sup> Revised Tariff Sheet No. R. 65, a copy of which is attached hereto as **Exhibit 3**, in its tariff's for Reflections, whereby any income tax amounts associated with a contribution in aid of construction will be deferred.

9. Should the other intervenors in this proceeding raise issues with the systems other than Reflections that require additional consideration by the parties and/or Commission that do not involve Reflections, Great Southern respectfully requests that the proceeding regarding Reflections be separated from the further proceedings for such other system(s), so that approval of the Applicant's acquisition of the Reflections' systems is not unnecessarily delayed.

Respectfully submitted,

SANDBERG, PHOENIX & VON  
GONTARD, P.C.

By: /s/ Sue A. Schultz

Sue A. Schultz MO #37219  
475 Regency Park, Suite 175  
O'Fallon, IL 62269  
Phone: (618) 624-3478  
Fax: (314) 241-7604  
sschultz@sandbergphoenix.com

ATTORNEYS FOR GREAT  
SOUTHERN BANK

### **CERTIFICATE OF SERVICE**

I hereby certify that a true and correct copy of the foregoing was served, either electronically or by hand-delivery or by First Class United States Mail, postage prepaid, on this 3<sup>rd</sup> day of June, 2019, with notice of the same being sent to all counsel of record.

/s/Sharon Ludwig

**EXHIBIT 1**

RECEIVED MAY 23 2018



**Missouri Department of** dnr.mo.gov  
**NATURAL RESOURCES**

Eric R. Greitens, Governor

Carol S. Comer, Director

May 21, 2018

Mr. John Wright, President  
Reflections Condominiums  
Owners Association, Inc.  
P.O. Box 2409  
Lake Ozark, MO 65049

RE: Reflections Condos, MO3071337, Camden County, Review No. 5000063-18

Dear Mr. Wright:

The Missouri Department of Natural Resources' Public Drinking Water Permits and Engineering Section has reviewed the Engineering Report for the Reflections Condos, in Camden County, Missouri. The report was examined as to sanitary features which may affect the operation of the system, including size, capacities, of units, and factors which may affect efficiency and ease of operation. Approval of the Engineering Report as regards to these points is hereby given. This approval is valid for two years.

It is suggested that you proceed to make arrangements for financing the proposed projects and instruct your engineer to prepare the necessary detailed plans and specifications for the proposed improvements.

Regulations require written approval of detailed plans and specifications before awarding the contract or initiating construction. Upon receipt of the detailed plans and specifications, we will proceed with our review and advise you by written report of our approval. An updated Engineering Report must be submitted with the detailed plans and specifications if there is a change in the scope of the project or if the original report is more than two years old.

If you have any questions concerning this letter or if you need any further assistance, please contact Ms. Diane Muenks by phone at 573-751-5924, or contact the engineer by email at [brandon.bach@dnr.mo.gov](mailto:brandon.bach@dnr.mo.gov), or email me at [maher.jaafari@dnr.mo.gov](mailto:maher.jaafari@dnr.mo.gov). Thank you

Sincerely,

WATER PROTECTION PROGRAM

Maher Jaafari, Ph.D., P.E., Chief  
Drinking Water Permits and Engineering Section

MJ:bbm

Enclosure

c: Mr. Michael Stalzer, P.E.  
Southwest Regional Office



**DEPARTMENT OF NATURAL RESOURCES OF MISSOURI**  
**ENGINEERING EVALUATION FOR APPROVAL OF ENGINEERING**  
**REPORT**

Reflections Condos  
Camden County, Missouri  
May 21, 2018

**INTRODUCTION**

Review Number 5000063-18

An Engineering Report dated April 9, 2018, for Reflections Condos, in Camden County, Missouri were submitted for review and approval by Michael Stalzer, P.E., of Tampa, Florida.

**BRIEF DESCRIPTION**

An Engineering Report for Reflections Condos has been reviewed. The report was examined as to sanitary features which may affect the operation of the project, including size, capacities of units, and factors which may affect efficiency and ease of operation.

The Engineering Report consists of the following:

- Description of the existing water.
  - The water system currently consists of 50 condominiums. Twelve of these are occupied year round.
  - The system is supplied by one well equipped with a 125 gallon per minute (gpm) submersible pump
  - Storage is provided by seven 119 gallon hydropneumatic tanks.
- A brief description of the exposed water main is included that indicates the water main currently has no leaks and is acceptable as constructed.

The Engineer Report recommends the following

- Based on an average daily flow of 3,700 gpm and a population equivalent of 74 people. The Engineering Report recommends the addition of three additional 119 gallon hydropneumatic tanks.
- New chlorination system at the well including solution tank, metering pump, and injection tap at the well house.

**NOTE**

- Should the exposed water main develop issues it needs to be properly installed and bedded below ground.
- Before the installation of the new hydropneumatic tanks a construction permit along with plans and specifications must be submitted to the Department for review and approval.

**STAFF RECOMMENDATION**

On the basis of the review in accordance with Missouri Drinking Water Regulation 10 CSR 60-10.010(1), I recommend this Engineering Report be granted approval.



\_\_\_\_\_  
Brandon Bach, E.I.  
Drinking Water Permits and Engineering Section

Reflections Condos, Approval  
Page 2

**APPROVAL TO CONSTRUCT**

The engineering plans and specifications described above were examined as to sanitary features of design which may affect the operation of the sanitary works, including size, capacities of the units, and factors which may affect the efficiency and ease of operation. Approval as regards these points is hereby given.

Approval is given with the understanding that final inspection and approval of the completed work shall be made by the Department of Natural Resources before same is accepted and placed in operation. If construction is not commenced two (2) years after the date of issue or there is a halt in construction of more than two years, the approval to construct will be void unless an extension of time has been granted by the department.

In the examination of plans and specifications, the Department of Natural Resources, Public Drinking Water Program does not examine the structural features of design or efficiency of mechanical equipment. This approval does not include approval of these features.

The Department of Natural Resources, Public Drinking Water Program reserves the right to withdraw the approval of plans and specifications at any time it is found that additional treatment or alterations are necessary to assure reasonable operating efficiency and to afford adequate protection to public health.

**EXHIBIT 2**

**ENGINEERING REPORT**

**WATER SYSTEM IMPROVEMENT  
REFLECTIONS CONDOMINIUM  
CAMDEN COUNTY, MISSOURI**

**OWNER:  
REFLECTIONS CONDOMINIUM OWNERS'  
ASSOCIATION, INC  
HCR 82, BOX 5040  
CAMDENTON, MO 65020**

April 9, 2018



*MS 4/9/18*  
MICHAEL STALZER, P.E.  
CPWG  
3918 N. Highland Ave  
Tampa, FL 33603  
417-860-9697



## Table of Contents

---

1	Introduction.....	2
2	Description.....	2
3	Operation and Maintenance .....	2
4	Drinking Water Facility Description .....	3
4.1	<i>Disinfection</i> .....	3

## Appendices

---

- A. Location Map
- B. Pressure Tank Specification
- C. Chlorination System Specification
- D. MDNR – High Yield and Public Well Record



## 1 Introduction

This report is for the purpose of obtaining the approval from the State of Missouri for the addition of new bladder tanks to the water system serving Reflections Condominium, Camdenton, Missouri. This improvement will bring the system into compliance based on the number of units served. The site location in Section 8, Township 39 North, Range 17 West, Camden County, Missouri.

## 2 Description

Currently, the distribution system serves fifty condominium units, of which twelve are occupied year round. The metered water usage from 2016 resulted in an average demand of 3,700 gallons per day, and a peak daily demand of 7,400 gallons.

According to the MDNR High Yield and Public Well Record and Pump Information Data report #A072734, the state approved deep well has a pump rate of 125 gallons per minute (gpm) and a well yield of 193 gpm. The well is controlled by 7 - 119 gallon bladder tanks and a 20/40 pounds per square inch (psi) pressure switch. The water storage for the system is provided by the 7 bladder tanks. At an operating pressure range of 20/40 psi, the usable tank volume is 47.8 gallons or a combined total of 334.6 gallons.

The system does not provide a minimum fire hydrant flow rate of 250 gpm as required by MDNR, however, under NFPA 13-R the water system does provide adequate flow and pressure for a fire sprinkler system. The required fire flow is 0.05 gpm per square feet of area sprinkled.

Based on a well production rate of 125 gallons per minute, a sprinkled system can serve a floor area of:

Well pumping rate = 125 gpm  
Domestic demand = 10.27 gpm

Flow available for fire suppression =  $(125 - 10.27) = 114.73$  gpm

Floor area served =  $114.73 \text{ gpm} / 0.05 \text{ gpm/sf} = 2,294$  sf

With the existing maximum unit size at approximately 1,100 sf, the system as constructed is adequate to serve both the needed domestic flow and the needed flow for the fire suppression system.

## 3 Operation and Maintenance

Great Southern Bank currently owns the land and improvements where the water system is located; and Reflections Condominium Owners' Association operates and maintains the system. Both such entities intend to turn the system over to Ozarks Clean Water Company to own, operate, and maintain.

The exposed water main has been inspected, and there are no issues or leaks. The main, as constructed, is acceptable.

#### **4 Drinking Water Facility Description**

Based on available metered flow data from 2016, the average daily flow was 3,700 gpd. Given an average flow of 3,700 gpd, the maximum daily demand would be 7,400 gpd. At twice the maximum day demand, the maximum hour demand would be 14,800 gallon per day or 10.27 gallons per minute.

Based on metered usage, the population served by the system is:

$$3,700 \text{ gpd} / 50 \text{ gpd/person} = 74 \text{ people}$$

For this population equivalent, the required number of bladder tanks is:

$$74 \text{ people} \times 6.25 \text{ gallons/person served} = 462.5 \text{ gallons}$$

$$\text{Usable tank volume per bladder tank at 20/40 psi} = 47.8 \text{ gal}$$

$$\text{Required number of tanks} = 462.5/47.8 \text{ gal} = 9.67 \text{ use } 10$$

With seven bladder tanks currently installed, three additional tanks are needed. After approval of the engineering report, a construction permit application will be submitted for the installation of the additional bladder tanks and chlorination system.

#### **4.1 Disinfection**

A review of the water quality reports indicates that the water system is in compliance with the applicable water quality standards. Although the system does not have the needed water storage capacity for the required 30 minutes of chlorine contact time, a tap for a chlorine injection pump has been included. If water quality deteriorates prior to the addition of a ground level storage tank, an LMI model P122-352S1 metering pump with a 35 gallon T40-0003 solution tank may be used as a chlorination system. The system operator will need to meter the pump in a manner necessary to meet the allowable chlorine level.

## Appendix A

SECTION 8, T39N, R17W  
CAMDEN COUNTY, MISSOURI



SITE LOCATION

# Appendix B



WELL-X-TROL PROFESSIONAL  
Pre-Pressurized  
**Water System  
Tanks**





# WELL-X-TROL® Professional revolutionizes the industry

WELL-X-TROL® Professional redefined the industry with its advanced engineering and innovative product design including the pre-pressurized well tank, sealed-in air charge, and unique water chamber design. With proven performance since 1963, WELL-X-TROL Professional continues to deliver unparalleled results making it **the most trusted choice of professionals** in today's market. WELL-X-TROL Professional offers many unique features that result in consistent, reliable performance, including design elements that prevent tank corrosion and reduce wear and tear on the well pump.

## Features and Benefits

Exclusive butyl diaphragm, along with the 100% corrosion resistant virgin polypropylene liner, are secured by a positive hoop ring seal for added strength and reliability. This totally integrated system outperforms other types of water chamber designs.

The stainless steel air valve is welded rather than threaded to prevent loss of air pressure.

The finest quality, custom mill steel is used in the deep drawn dome for extra strength while keeping tank weight to a minimum.

## More choices mean more flexibility


WELL-X-TROL Professional offers more options and sizes than any other well tank manufacturer, including both vertical and horizontal designs, and sizes ranging from 2 gallons to 119 gallons so you can configure a system that's right for any application.

## First on Industry Safety Standards

WELL-X-TROL Professional tanks were the first to meet all industry standards for quality and safety. The butyl diaphragm in all models meets EPA requirements for potable water as defined in the Safe Drinking Water Act of 1986. The entire tank which includes the virgin polypropylene liner, butyl diaphragm, and acceptance fittings for a 100% corrosion resistant water reservoir is listed by NSF International Standard 61.

# Advanced design features continue to set industry standards

- Stainless steel air valve is welded in position rather than mechanically threaded to prevent loss of air pressure and to minimize stress on the well's pump system. It also carries a tamper-evident warning label.
- Deep-drawn steel domes offer twice the strength of rolled steel while minimizing weight.
- Unique positive hoop ring seal secures diaphragm and liner for added strength and reliability.
- Heavy duty butyl diaphragm features seamless construction for uniform strength and flexibility. It conforms exactly to the shell configuration without stretching, creasing, or forming bubbles or corners that could trap water or sediment. Butyl is the best known elastomer to prevent air loss.
- Heavy duty butyl diaphragm is extremely resistant to bacterial growth and meets FDA requirements for potable water supply.
- Virgin polypropylene liner provides a 100% corrosion resistant, non-metallic rigid water reservoir that is listed by NSF International Standard 61.
- Stainless-steel system connection withstands aggressive water.
- Exclusive welding process eliminates interior rough spots and sharp edges which prevent damage to the diaphragm and liner.
- Each finished tank is pressure tested for safety.
- Each finished tank is pre-pressurized to the most common pump cut-in pressure.
- Exterior appliance-like finish looks attractive while protecting the tank from the elements.







**esp**

**(Effective System Protection):**

# maximum system output with minimal pump starts

The ESP sizing procedure covers modern residential water-use habits, increased off-peak demands and the general increase in water use that have occurred over the past twenty-five years.

ESP sizing is designed to reduce pump wear and tear, and reduce energy consumption by keeping pump starts to a minimum.

## Choose the amount of protection you need.

**ESP I:** Tank selection is based on approximately one minute minimum pump running time. This is recommended for pumps up to 3/4 H.P.

**ESP II:** Tank selection is based on approximately two minute minimum pump running time. This is recommended for 3/4 H.P. or larger pumps.

### ESP Sizing Table


PUMP DISCHARGE RATE GPM (Approx.)	OPERATING PRESSURE - PSIG						
	20/40	ESP I 30/50		40/60	ESP II 30/50		40/60
5	WX-202	WX-202	WX-202	WX-202XL	WX-205	WX-205	
7	WX-202	WX-202	WX-202XL	WX-205	WX-250	WX-251	
10	WX-202XL	WX-205	WX-205	WX-251	WX-251	WX-255	
12	WX-205	WX-250	WX-250	WX-251	WX-255	WX-255	
15	WX-250	WX-250	WX-251	WX-255	WX-302	WX-350	
20	WX-251	WX-251	WX-255	WX-350	WX-350	(2) WX-255	
25	WX-251	WX-255	WX-302	(2) WX-251	(2) WX-255	(2) WX-302	
30	WX-255	WX-302	WX-350	(2) WX-255	(2) WX-302	(2) WX-350	
35	WX-302	WX-350	WX-350	(2) WX-302	(2) WX-350	(2) WX-350	
40	WX-350	WX-350	(2) WX-255	(2) WX-350	(2) WX-350	(3) WX-302	




# WELL-X-TROL Professional tank operation time-tested design



1  
WELL-X-TROL Professional has a sealed in air chamber that is pre-pressurized before it leaves our factory. Air and water do not mix.



2  
When the pump starts, water enters the WELL-X-TROL Professional. Only usable water is stored.



3  
When the pressure in the chamber reaches cut-out pressure, the pump stops. The WELL-X-TROL Professional is filled.




4  
When water is demanded, pressure in the air chamber forces water into the system. Since WELL-X-TROL Professional consistently delivers the maximum usable water, minimum pump starts are assured.



# WELL-X-TROL Professional

## residential models


### In-Line Models



Model No.	Dimensions		Total Volume (gals)	Max. Accept. Factor	System Drawdown			Shipping Wt. (Vol.) lbs (cu ft)
	Diameter (ins)	Height (ins)			20/40 (gals)	30/50 (gals)	40/60 (gals)	
WX-101	8	12 5/8	2.0	0.45	.8	.7	.6	5 (0.6)
WX-102	11	15	4.4	0.55	1.8	1.5	1.3	9 (1.2)
WX-103	11	22 1/4	7.6	0.42	3.1	2.6	2.2	15 (1.8)
WX-104	15 3/8	17 3/4	10.3	1.00	4.1	3.5	3.0	20 (2.6)
WX-200	15 3/8	22	14.0	0.81	5.6	4.8	4.1	22 (3.3)

Precharge Pressure for WX-101 & WX-102 is 20 PSIG and Sys. Conn. is 3/4" NPTM.  
 Precharge Pressure for WX-103 is 30 PSIG and Sys. Conn. is 3/4" NPTM.  
 Precharge Pressure for WX-104 and WX-200 is 30 PSIG and Sys. Conn. is 1" NPTM.  
 Maximum Working Pressure is 125 PSIG and Maximum Working Temperature is 200° F.  
 WX-101 and WX-102 models available with Ultra TUF-KOTE™ exterior coating option.

### Stand Models



Model No.	Dimensions		Total Volume (gals)	Max. Accept. Factor	System Drawdown			Shipping Wt. (Vol.) lbs (cu ft)
	Diameter (ins)	Height (ins)			20/40 (gals)	30/50 (gals)	40/60 (gals)	
WX-104-S	15 3/8	19 1/4	10.3	1.00	4.1	3.5	3.0	23
WX-201	15 3/8	23 7/8	14.0	0.81	5.6	4.8	4.1	25
WX-202	15 3/8	31 5/8	20.0	0.57	8.0	6.8	5.9	33
WX-202XL	15 3/8	38 1/4	26.0	0.44	10.5	8.8	7.6	36
WX-203	15 3/8	46 1/2	32.0	0.35	—	10.9	9.4	43
WX-205	22	29 5/8	34.0	1.00	13.7	11.6	10.0	61
WX-250	22	36	44.0	0.77	17.7	15.0	12.9	69
WX-251	22	46 3/4	62.0	0.55	24.9	21.1	18.2	92
WX-255	22	56 3/8	81.0	0.41	32.6	27.5	23.8	103
WX-252	22	62 1/4	86.0	0.39	34.6	29.2	25.3	114
WX-302	26	47 1/4	86.0	0.54	34.6	29.2	25.3	123
WX-350	26	61 7/8	119.0	0.39	47.8	40.5	35	166

Tank Specified

Precharge Pressure for WX-104-S thru WX-203 is 30 PSIG and Sys. Conn. is 1" NPTF.  
 Precharge Pressure for WX-205 thru WX-350 is 38 PSIG and Sys. Conn. is 1 1/4" NPTF.  
 Maximum Working Temperature is 200° F. Maximum Working Pressure for all models except WX-252 is 125 PSIG.  
 Maximum Working Pressure for WX-252 is 100 PSIG.  
 All models available with Ultra TUF-KOTE™ except WX-104-S, WX-201, and WX-252.  
 All models except, WX-104S, WX-201, WX-252 are available with Pro-Access.

### Underground Models



Model No.	Dimensions		Total Volume (gals)	Max. Accept. Factor	System Drawdown			Shipping Wt. (Vol.) lbs (cu ft)
	Diameter (ins)	Height (ins)			20/40 (gals)	30/50 (gals)	40/60 (gals)	
WX-200-UG	15 3/8	22	14.0	0.81	5.6	4.8	4.1	22
WX-202-UG	15 3/8	30	20.0	0.57	8.0	6.8	5.9	30 (4.9)
WX-250-UG	22	33 3/8	44.0	0.77	17.7	15.0	13.0	60 (9.8)
WX-251-UG	22	44 1/8	62.0	0.55	24.9	21.1	15.3	83 (13.9)

Precharge Pressure for WX-202-UG is 30 PSIG and Sys. Conn. is 1" NPTF Coupling.  
 Precharge Pressure for WX-205-UG and WX-251-UG is 38 PSIG and Sys. Conn. is 1 1/4" NPTF Coupling.  
 Maximum Working Pressure is 125 PSIG and Maximum Working Temperature is 200° F.



# WELL-X-TROL Professional

## specialty residential models

### Pump Stand Models

Model No.	Height (ins)	Dimensions		Total Volume (gals)	Max. Accept. Factor	System Drawdown			Shipping Wt. (Vol.) lbs (cu ft)
		Width (ins)	Length (ins)			20/40 (gals)	30/50 (gals)	40/60 (gals)	
WX-105-PS	11	10 9/16	18 1/4	5.3	0.80	2.1	1.8	1.6	13
WX-200-PS	16	15 3/8	20 7/8	14.0	0.81	5.6	4.8	4.1	29

Precharge Pressure is 30 PSIG and Sys. Conn. is 3/4" NPTM Fitting for 103-PS and 105-PS; and 1" NPTF Coupling for 200-PS. Maximum Working Pressure is 125 PSIG and Maximum Working Temperature is 200° F.



### Offset Connector Models

Model No.	Diameter (ins)	Height (ins)	Total Volume (gals)	Max. Accept. Factor	System Drawdown			Shipping Wt. (Vol.) lbs (cu ft)
					20/40 (gals)	30/50 (gals)	40/60 (gals)	
WX-202-OC	15 3/8	29	20.0	.57	8.0	6.8	5.9	32 (5.0)

1" Barb Connection. 30 PSIG Precharge Pressure. 100 PSI Maximum Working Pressure. 200° (F) Maximum Working Temperature



### Space Saver Model

Model No.	Height (ins)	Dimensions		Total Volume (gals)	Max. Accept. Factor	System Drawdown			Shipping Wt. (Vol.) lbs (cu ft)
		Width (ins)	Length (ins)			20/40 (gals)	30/50 (gals)	40/60 (gals)	
WX-202-H	28 5/8	15 3/8	15 1/4	20.0	0.57	8.0	6.8	5.9	33 (4.9)

Precharge Pressure is 30 PSIG. System connection is 1" NPTF (straight coupling connection). Maximum Working Pressure is 125 PSIG. Maximum Working Temperature is 200° F.



### Specialty Options

#### Ultra TUF-KOTE™

A new improved paint finish available only on WELL-X-TROL tanks. This new paint has been re-formulated for outdoor applications where acids, salts and moisture can harm regular paint. It is crack proof and impermeable to moisture.

#### PRO Access™

PRO Access Stainless Steel System Connection piped through the stand is available on most WELL-X-TROL models. Indicate PRO Access when ordering.





# AMTROL has innovative ways to help you grow your business



## Water Treatment Technologies



Hydrogen Sulfide Removal System



Arsenic Removal System



Iron Removal System



Water Softening and Filtration



## Hydronic Technologies



Boiler Expansion Tanks



Water Heater Expansion Tanks



Indirect-Fired Water Heaters

Ask for Quality. Ask for AMTROL®.

**Corporate Headquarters**  
1400 Division Road  
West Warwick, RI 02893  
Telephone: 401-884-6300  
Fax: 401-884-5276

**AMTROL Canada, Ltd.**  
275 Shoemaker Street  
Kitchener, Ontario N2E 3B3  
Telephone: 519-748-1138  
Fax: 519-748-4231

Part# 9015-516 MC# 4380 (7/04) © 2004 AMTROL Inc.

WELL-X-TROL is a registered trademark of AMTROL Inc.

## Appendix C

# CHLORINATION SYSTEMS: LIQUID SODIUM HYPOCHLORITE INJECTION



**Household Bleach** is 5 1/4% Sodium Hypochlorite

**Liquid Pool Chlorine** is 12 1/2% Sodium Hypochlorite

For best results use 12 1/2% NSF certified chlorine designed for potable water; or use fresh pool chlorine, and size of system and injection rate so that you make up fresh solution once a month.

**LMI Metering Pumps:** The standard for excellence in electronic diaphragm metering pumps. Unlike cheaper pumps made from pvc or polypropylene, these units use heavy-duty, chemically resistant PVDF pump heads for very long usage between replacement. Pump 12% sodium hypochlorite with no failures. All pumps come standard with the LMI Four Function Valve for safety and ease-of-use.

Part #	LMI Model	GPD	PSI	VOLT	Price Each
P5001030	P121-352SI	5	150	120	\$424
P5001110	P122-352SI	5	150	240	\$424
P5001020	P131-392SI	10	110	120	\$431
P5001140	P132-392SI	10	110	240	\$431
P5001040	P141-352SI	14	250	120	\$441
P5001150	P142-352SI	14	250	240	\$441
P5000810	P151-392SI	24	110	120	\$450
P5000820	P152-392SI	24	110	240	\$450
P5000830	P161-362SI	48	50	120	\$467
P5000840	P162-362SI	48	50	240	\$467

## Three Sizes of Solution Tanks to Choose From:

### 10-Gallon

Pump Installs on Top



T40-0004 \$119.00

### 35-Gallon

Pump Installs on Tank Shelf for Flooded Suction



T40-0003 \$289.00

### 50-Gallon

Pump Installs on Top




T40-0006 \$209.00

## Hundreds of Metering Pumps and Accessories For Practically Any Flow Rate Available Including:

- Proportionally Fed Systems
- Electronic Flow Meters
- Flow Computers
- Check Valves, Anti-Syphon Valves
- Static Mixers
- Electrical Mixers

## Typical Installation of Metering Pumps for Chlorination:



## How To Figure out What Size Pump to Use, and How To Set the Speed and the Stroke To Achieve Proper Dosage:

Step One : Determine Flow Rate of the water stream you are injecting into, in Gallons Per Minute (GPM)

Step Two : Determine the parts per million of chlorine you are trying to achieve (PPM).

Step Three : Use the formula below to compute the gallons per day and select the pump.

Step Four : Adjust the output of the metering pump to achieve proper dosage.

Multiply the FLOW RATE (GPM) times the Applied Dosage in Parts Per Million Desired times 1440. Then Divide by the Solution Strength being used. Household bleach is 5 1/4%, Pool Chlorine is 12%. You can vary the applied dosage of chlorine by adjusting the solution strength and by adjusting the speed knob and/or the stroke knob of the metering pump. If both the speed and stroke knobs are set to 100%, then the metering pump will deliver 100% of its rated output in gallons per day. After you use the formula below to compute the gallons per day adjust the knobs to end up with the desired dosage.

$$\frac{12 \text{ GPM} \times 1.5 \text{ PPM} \times 1440}{1,000,000 \times 5 \frac{1}{4}\%} = 0.49 \text{ Gallons Per Day}$$

Divide the Gallons Per Day figure by the Rated Maximum Output of the Metering Pump: For Instance: Using Model P50-0005 which has a maximum output of 10 Gallons Per day: 0.49 divided by 10 = .049 or 5% SO! You could set the metering for 5% of its rated output by adjusting the Speed Knob to 10 and the Stroke Knob to 50, since 10% x 50% = 5%.



743 41<sup>st</sup> Ave. Santa Cruz, California 95062  
Tel: 831.462.8359 Fax: 831.476.0832

<http://www.advancedh2o.com> E-mail: [info@advancedh2o.com](mailto:info@advancedh2o.com)




Dedicated to Safe Drinking Water  
American Water Works Assoc.  
Proud Members for 10 Years



PACIFIC WATER  
QUALITY ASSOCIATION



## Appendix D

 <b>MISSOURI DEPARTMENT OF NATURAL RESOURCES</b> <b>DIVISION OF GEOLOGY AND LAND SURVEY</b> (573) 368-2165	REF NO 00252901	DATE RECEIVED 11/01/2001																								
	CR NO																									
<b>HIGH YIELD AND PUBLIC WELL RECORD AND PUMP INFORMATION DATA</b>	STATE CERT NO APPROVED DATE A072734 11/30/2001	CHECK NO. 2485																								
	DATE ENTERED PHASE 1 PHASE 2 PHASE 3 11/01/2001 11/13/2001 11/13/2001	ROUTE PCD	REVENUE NO. 110101																							
INFORMATION SUPPLIED BY WELL OR PUMP INSTALLATION CONTRACTOR		DNR VARIANCE NUMBER _____																								
OWNER NAME REFLECTIONS CONDOMINIUMS	TELEPHONE (OPTIONAL)	CASING DEPTH NUMBER _____ Applicable only if casing depth or variance were obtained from DNR																								
OWNER ADDRESS HCR 76 BOX 733	CITY CAMDENTON	STATE MO ZIP 65020																								
ADDRESS OF WELL (IF DIFFERENT THAN ABOVE)	CITY	STATE MO ZIP																								
<b>PROPOSED USE OF WELL SEE BACK OF FORM FOR WELL CLASSIFICATIONS</b> <input type="checkbox"/> Water Supply for Irrigation (capable of producing more than 70 gpm to surface) Unconsolidated Material Well <input type="checkbox"/> Bedrock Well <input type="checkbox"/> <input type="checkbox"/> Water Supply for a High-Capacity Well capable of producing more than 70 gpm to surface - get casing depth from GSRAD before start <input type="checkbox"/> Open Loop Heat Pump Supply Well <input type="checkbox"/> Return Well <input type="checkbox"/> <input checked="" type="checkbox"/> Water Supply to a Public Facility (convenience store, restaurant, church, business, condo, mobile home park, rural or urban water supply) <b>CONTACT THE DNR REGIONAL OFFICE to get instructions for water supply to a PUBLIC FACILITY</b>																										
<b>CASING DETAILS</b> CASING LENGTH O.D. OF CASING DIAMETER OF DRILL HOLE 440.0 FT. 6.62 IN. 10.0 IN. CASING MATERIAL <input checked="" type="checkbox"/> STEEL <input type="checkbox"/> PLASTIC <input type="checkbox"/> CONCRETE POSITION OF GROUT SEAL <input type="checkbox"/> BOTTOM <input checked="" type="checkbox"/> FULL LENGTH <input type="checkbox"/> TOP																										
CASING GROUT MATERIAL <input checked="" type="checkbox"/> CEMENT TYPE 1 <input type="checkbox"/> BENTONITE SLURRY <input type="checkbox"/> GRANULAR PELLETS <input type="checkbox"/> GRAVITY OPEN HOLE <input type="checkbox"/> POS. DISPLACEMENT TREMIE <input type="checkbox"/> HI-EARLY <input type="checkbox"/> CHIPS <input type="checkbox"/> CHIPS <input type="checkbox"/> OPEN HOLE <input type="checkbox"/> TREMIE NO. OF SACKS USED 230.0 POUNDS PER SACK _____ PRESSURE GROUT <input type="checkbox"/> THROUGH CASING <input type="checkbox"/> THROUGH TREMIE DRILLING SUSPENDED <input type="checkbox"/> NO <input checked="" type="checkbox"/> YES 72 HRS																										
<b>LINER DETAILS</b> LENGTH O.D. OF LINER LINER MATERIAL POSITION OF SEAL FT. IN. <input type="checkbox"/> STEEL <input type="checkbox"/> PLASTIC <input type="checkbox"/> FULL LENGTH <input type="checkbox"/> BOTTOM <input type="checkbox"/> TOP LINER GROUT MATERIAL <input type="checkbox"/> CEMENT TYPE 1 <input type="checkbox"/> BENTONITE SLURRY <input type="checkbox"/> GRANULAR PELLETS <input type="checkbox"/> GRAVITY OPEN HOLE <input type="checkbox"/> POS. DISPLACEMENT TREMIE <input type="checkbox"/> HI-EARLY <input type="checkbox"/> CHIPS <input type="checkbox"/> CHIPS <input type="checkbox"/> OPEN HOLE <input type="checkbox"/> TREMIE NO. OF SACKS USED _____ POUNDS PER SACK 94 LINER USED TO: <input type="checkbox"/> HOLD BACK FORMATION <input type="checkbox"/> SEAL OUT UNDESIRABLE AQUIFER CONDITIONS <input type="checkbox"/> PREVENT RUST ABANDONED WELL ON SITE? <input type="checkbox"/> YES <input type="checkbox"/> PLUGGED? <input type="checkbox"/> YES																										
<b>LOCATION OF WELL</b> LAT. 38° 7' 53.2" LONG. 92° 49' 12.6" COUNTY CAMDEN Please be aware that we do not guarantee the accuracy of the data. It is submitted to us by a third party and has not been field verified.																										
DEPTH TO FIRST GROUNDWATER FEET WELL YIELD 193.0 GPM STATIC WATER LEVEL 131.0 FEET WELL COMPLETION DATE 10/12/2001 PUMP RATE 125.0 GPM PUMP SET DEPTH 367.0 FEET PUMP INSTALLATION DATE pump info required this record or on pump card		AREA 1B _____ C DATA REQ'D <input type="checkbox"/>																								
<table border="1"> <thead> <tr> <th>DEPTH FROM</th> <th>DEPTH TO</th> <th>FORMATION DESCRIPTION</th> </tr> </thead> <tbody> <tr><td>0.0</td><td>220.0</td><td>WT LS</td></tr> <tr><td>220.0</td><td>225.0</td><td>OPEN BRKN</td></tr> <tr><td>225.0</td><td>305.0</td><td>LS</td></tr> <tr><td>305.0</td><td>325.0</td><td>WT SS</td></tr> <tr><td>325.0</td><td>430.0</td><td>WT LS</td></tr> <tr><td>430.0</td><td>432.0</td><td>BLK SHELL</td></tr> <tr><td>432.0</td><td>900.0</td><td>GRY LS</td></tr> </tbody> </table>		DEPTH FROM	DEPTH TO	FORMATION DESCRIPTION	0.0	220.0	WT LS	220.0	225.0	OPEN BRKN	225.0	305.0	LS	305.0	325.0	WT SS	325.0	430.0	WT LS	430.0	432.0	BLK SHELL	432.0	900.0	GRY LS	(OPTIONAL) ELEVATION _____ LEGAL LOCATION (OPTIONAL) NE 1/4 SW 1/4 SW 1/4 787 FT. SEC. 8 TWN. 39 RNG. 17 W OTHER INFORMATION OR LOCATION DATA (OPTIONAL)
DEPTH FROM	DEPTH TO	FORMATION DESCRIPTION																								
0.0	220.0	WT LS																								
220.0	225.0	OPEN BRKN																								
225.0	305.0	LS																								
305.0	325.0	WT SS																								
325.0	430.0	WT LS																								
430.0	432.0	BLK SHELL																								
432.0	900.0	GRY LS																								
<b>I HEREBY CERTIFY THE WELL/PUMP INFORMATION DESCRIBED HEREIN IS TRUE AND ACCURATE</b>																										
PRIMARY CONTRACTOR SIGNATURE LLOYD MORELAND		PERMIT NUMBER 002450 DATE _____																								
WELL DRILLER SIGNATURE LLOYD MORELAND		PERMIT NUMBER 002450 DATE _____																								
PUMP INSTALLER SIGNATURE LLOYD MORELAND		PERMIT NUMBER 002450 DATE _____																								
APPRENTICE DRILLER SIGNATURE		PERMIT NUMBER _____ DATE _____																								
APPRENTICE PUMP SIGNATURE		PERMIT NUMBER _____ DATE _____																								
DEPTH TO BEDROCK FEET TOTAL DEPTH 900.0 FEET																										

### EXHIBIT 3

FORM NO. 13

P.S.C MO NO. 13

2<sup>nd</sup> Revised Sheet No. R 65  
 Cancelling 1<sup>st</sup> Revised Sheet No. R 65

Missouri-American Water Company  
 Name of Issuing Corporation

For

All Missouri Service Areas  
 Community, Town or City

<b>Rules and Regulations Governing the Rendering of Water Service</b>	
<p><b><u>Taxable Advances and Contributions in Aid of Construction</u></b></p> <p>Any Federal, State or Local income tax incurred by the Company due to the receipt of taxable Advances or Contributions in Aid of Construction, as defined by the Internal Revenue Service, the State of Missouri, or other taxing authority, and not otherwise paid by a third party, will be paid by the Company. Such income taxes shall be segregated in a deferred account for inclusion in rate base in the Company's next general rate proceeding.</p>	<p>*</p> <p>*</p> <p>*</p> <p>*</p> <p>*</p>

- \* Indicates new rate or text
- + Indicates change

Date of Issue: August 21, 2018

Effective Date: ~~September 20, 2018~~ December 7, 2018

Issued By: Cheryl Norton, President  
727 Craig Road, St. Louis, MO 63141

FILED  
 Missouri Public  
 Service Commission  
 WT-2019-0054; JW-2019-0019