

FILED³

JUN 19 2003

Walter L. Mulvania

ATTORNEY AT LAW
213 SOUTH MAIN ST.
Rock Port, Missouri
64482-1531

Missouri Public
Service Commission

AREA CODE 660
PHONES: OFFICE 744-2576
HOME 744-2936

April 30, 2003

Aquila
Att: Ron Vandiver
Operations Manager Electric
1824 E First St.
Maryville, MO 64468

Re: Request for Release of Grain Bin Service By Aquila

Dear Mr. Vandiver:

Chad Ottmann of Ottmann Electric was in my office yesterday giving me the information needed to draw up the enclosed release on the Julia J. Bennington bin site on her land.

If I need to do anything further in this regard, please let me know.

Very truly yours,

Walter L. Mulvania

Walter L. Mulvania

WLM:rf
Enclosure

FILED³

JUN 19 2003

BEFORE THE PUBLIC SERVICE COMMISSION
OF THE STATE OF MISSOURI

Missouri Public
Service Commission

In the matter of the application of)

Julia Bennington)

(Name of Applicant))

Case No. _____

for change of electric supplier.)

APPLICATION FOR CHANGE OF ELECTRIC SERVICE PROVIDER

1. Applicant's address is: 116237 State Highway E

Rock Port MO. 64482

2. The name of Applicant's current electric service provider is: Aquila

3. Applicant requests the Missouri Public Service Commission to order a change of electric supplier to the address indicated above.

4. Applicant requested the Commission to order a change of electric supplier
from Aquila (Current)
to Atchison-Holt Electric (REA) (Requested)

5. Applicant requests the Missouri Public Service Commission to order a change of electric provider for the following reasons.* _____

Enclosed is a letter of change of
Electric provider.

6. Applicant has taken the following steps in an attempt to work out electric service problems with the electric service provider: _____

WHEREFORE, Applicant requests the Missouri Public Service Commission to issue an Order which changes the current electric service provider.

June 17, 2003
(Date)

Julia J. Bennett
(Signature of Applicant)
660-744-2378
(Phone Number)

*If reason for change is poor service, outages, low voltage, etc., applicant should submit a record of service problems covering at least 90 days, including dates and times of problems to the extent possible. Applicant should also attempt to determine reasons for any service problems. For instance, if electric service was out or you are experiencing blinking lights, you should contact the supplier of electric service to determine the problem, and include this information with the application. (If the reasons from the supplier was a storm, car hitting pole, trees in line, conductor fell down, or whatever the supplier states for the problem, this should be noted.)

STATE OF MISSOURI

COUNTY OF

Atchison

)
)
)
SS.

VERIFICATION

Jula J. Bennett, on oath, states that he/she has read the foregoing application and is familiar with its contents and the matters set forth therein are true to the best of his/her knowledge, information and belief.

Jula J. Bennett
(Signature of Applicant)

SWORN TO BEFORE ME, the undersigned Notary Public on this the

17

day of

June

2003

Celia Sue Dalrymple
Notary Public

My Commission Expires:

CELIA SUE DALRYMPLE
Notary Public - Notary Seal
STATE OF MISSOURI
Atchison County
My Commission Expires: Jan. 31, 2005

TO: Aquila
Att: Ron Vandiver
Operations Manager Electric
1824 E First St.
Maryville, MO 64468

FROM: Julia J. Bennington, 16237 State Hwy E, Rock Port, MO 64482 -- Landowner, and
Gary Bennington, 610 S Market St., Rock Port, MO 64482 ----- Tenant.

REQUEST FOR RELEASE OF GRAIN BIN SERVICE BY AQUILA

Re: Electrical service to grain bins located on real estate of Julia J. Bennington at 16237 State Hwy E, Rock Port, Missouri 64482, southwest of Rock Port, Missouri, which is 2 miles West of Exit 107, I-29, on North side of Route E, said real estate located in the Northwest Quarter of Section 17, Township 64, Range 41, in Atchison County, Missouri.

REASONS FOR REQUEST:


1. Insufficient power to grain bins. There are ten government grain bins, approximately 3500 bushels each, with 3/4 hp. fan motors on each for a total of 7½ hp. fan load presently with Aquila.
2. There is only one Aquila meter to supply power for both the residence and the grain bins - a distance of 800+ feet from primary service (Aquila) to bins.
3. There is low voltage in the dwelling when the tenant runs two or more bin fan motors at one time.
4. There being only one meter, the homeowner is and has been paying the total utility bill, for the reason the tenant has no way of knowing what the grain bin utility might be.
5. Tenant cannot run auger to remove grain from the bins because of lack of power.
6. It has been determined by Chad Ottmann of Ottmann Electric, 25137 State Hwy 111, Rock Port, MO 64482 that the underground wiring is defective and not usable.
7. Atchison-Holt Electric Cooperative, 18585 Industrial Road, Rock Port, Missouri 64482, has primary service available within 50 feet of bin site, and is willing to provide such service to said bin site.


REASONS FOR RELEASE OF GRAIN BIN UTILITY SERVICE ONLY:

1. It would not be cost effective for Aquila to run 800+ feet of primary underground wire to the grain bin site from the meter.
2. There are no plans to build additional bins on the property.
3. Aquila service to the dwelling would remain as it now stands.
4. A release is being requested only for the grain bin service.
5. Power for the grain bin site can be provided by Atchison-Holt Electric Cooperative, Rock Port, Missouri since it has primary service available within 50 feet of the bin site.

The undersigned request that Aquila release the grain bins only from electrical service at said bin site.

In Witness Whereof, the undersigned have executed this document this 30th day of April, 2003.


Julia J. Bennington, Landowner


Gary Bennington, Tenant