

REMOVED METER#	DATE	TESTED BY
84255800	9/23/20	3056
END READ	ADJ START READ	SIZE: 5/8"
2516	2516.5709	%FLOW
		SHOP / SAP
CF @ 5 10 GPM	2516.6211	100.4,
CF @ 2 2 GPM	2516.6413	101.0,
CF @ 0.1 1/8 GPM	2516.6423	100.0,

Head 1K
 UML 9/21/21 5/8 2516
 R S
 9/21/20
 DATE REMOVED
 TEST HIGH LOW
 1004 MIN 101.0 LOW 100.0 %
 MILEAGE
 84255800
 METER NUMBER

Removed Meter No. 84255800 Set Meter No.
 MTU # 220007086
 Address
 Make NCF Size 5/8 Reading 2516
 Remove Reason Customer Request Date 9/21/20
 Test Data 10 High Flow GPM 100.4 % Min. Flow GPM 101.0 % 1/8 Low Flow GPM 100.0
 Comments 6001317936 Hold for Testing / Customer Witnessed
 3056
 TESTED BY 9/23/20
 DATE
 Gears R S
 CHARGE FOR REPAIR REM. BY TRUCK # EMP # 2991