

DIVISION OF HEALTH
OF THE DEPARTMENT OF PUBLIC HEALTH AND WELFARE
STATE OF MISSOURI



Application Exhibit No. *WA-7470*
Date *8-28-78* Case No. *WE-7431*
Reporter *jj* *WF-78-72*

PERMIT OF APPROVAL
FOR SUPPLYING WATER TO THE PUBLIC

PERMIT NO. 6162

GRANTED TO

LAKE SIDE INVESTMENT COMPANY, INC. (TOMAHAWK & LAKE SIDE SUBDIVISION) STONE COUNTY, MISSOURI

(Name of Municipality, Corporation, Company, Person or Institution)

ISSUED IN ACCORDANCE WITH SECTION 192.200
MISSOURI REVISED STATUTES AND RULES AND REGULATIONS
PROMULGATED UNDER SECTION 192.180.

By *Harold R. W. W. W. W.*
Director of Division of Health

Date *January 15, 1973*

**THE DIVISION OF HEALTH
OF MISSOURI**

**REPORT OF FINAL INSPECTION AND APPROVAL
TOMAHAWK AND LAKESIDE SUBDIVISIONS
STONE COUNTY, VIOLA, MISSOURI
December 14, 1972**

INTRODUCTION

A final inspection was made of the completed water supply facilities to serve Tomahawk and Lakeside Subdivisions near Viola, Missouri by a representative of the Division of Health on December 5, 1972. The following is a brief description and final approval of these facilities.

DESCRIPTION

The completed facilities include a drilled well, pumping equipment, storage and distribution systems.

The well is drilled to a total depth of 404 feet and cased to a depth of 279 feet with six inch steel casing. The casing is satisfactorily sealed its entire length with neat cement grout.

A submersible pump of 50 gallons per minute capacity is installed in the well. This installation is equipped with a master flow meter, water level depth gauge, breather pipe, and automatic electrical controls.

Pressure and storage is provided by two pressure tanks with a total capacity of 500 gallons each. This installation is provided with an air compressor and sight glass.

The distribution system is being installed essentially as per plans and specifications as development warrants.

FINAL APPROVAL

The completed sanitary works described above were examined as to features of construction which may affect the operation of such systems, including size, capacities of various units, and features which may affect the efficiency and ease of operation. The completed works, so far as could be determined, are constructed essentially in accordance with the approved plans, and final approval of the completed works is hereby granted.

In the final inspection of the works, the Division of Health does not examine into structural features or the efficiency of mechanical equipment. This final approval does not include approval of these features.

The Division of Health reserves the right to withdraw the approval of the sanitary works at any time it is found to be operating unsatisfactorily, and to require alterations, additional treatment or changed methods of operation as deemed necessary to place the works in satisfactory condition.

APPROVED:

Glen A. Harwell
Glen A. Harwell, Supervisor of

John R. Nixon
John R. Nixon
Sanitary Engineer