

# Technical Resource Manual

Table of Abbreviations .....	ii
Introduction .....	3
Protocol for Deeming New Measures Not Found Within the TRM .....	5
Residential Energy Efficiency Program Measures .....	6
Residential Lighting Program Measures .....	6
Residential HVAC Program Measures .....	9
Efficient Products Program Measures .....	20
Low Income Program Measures .....	24
Energy Efficiency Kit Program Measures .....	32
Home Energy Report Program Measures .....	37
Business Energy Efficiency Program Measures .....	39
Business Standard Program Measures: .....	119
Small Business Direct Install Program Measures: .....	119
Custom, Retro-commissioning and New Construction Program Measure Analysis Methodology .....	119
Custom Program Measures .....	123
Retro-commissioning Program Measures .....	125
New Construction Program Measures .....	127

**Effective June 1, 2017**

**Table of Abbreviations**

<u>Term</u>	<u>Abbrev</u>	<u>Term</u>	<u>Abbrev</u>
Air Source Heat Pump	ASHP	Building Automation System	BAS
Central Air Conditioner	CAC		
Demand Side Management	DSM	Energy Efficiency Ratio	EER
Electronically Commutated Motors	ECM	Energy Management System	EMS
Energy Independence & Security Act	EISA	Equivalent Full Load Hours	EFLH
Evaluation Measurement & Verification	EM&V	Integrated Part Load Value	IPLV
On-line iEnergy Technical Reference Library	iTRL	High Intensity Discharge	HID
Hours of Use	HOU	Heating Ventilation & Air Conditioning	HVAC
Kilowatt per Hour	kWh	Kilowatt	kW
Missouri Energy Efficiency Investment Act	MEEIA	Net Present Value	NPV
National Electrical Manufacturers Association	NEMA	Packaged Terminal Heat Pump	PTHP
Packaged Terminal Air Conditioner	PTAC	Remaining Efficient Life	REL
Real Discount Rate	RDR	Seasonal Energy Efficiency Ratio	SEER
Remaining Useful Life	RUL	Technical Analysis Study	TAS
Solar Heat Gain Coefficient	SHGC	Thermostatic Expansion Valves	TXV
Technical Resource Manual	TRM	Utility Discount Rate	UDR
Typical Meteorological Year	TMY	Variable Air Volume	VAV
Unit Energy Consumption	UEC	Variable Speed Drive	VSD
Variable Frequency Drive	VFD		

## Introduction

The Ameren Missouri Technical Resource Manual (TRM) was developed to establish deemed measure level savings values with associated attributes and supporting documentation. For measures which cannot be deemed, the relevant protocols to determine the measure savings values are described. These savings values and protocols will be used prospectively and updated annually.

This TRM appendix was developed using the iEnergy Technical Reference Library (iTRL) as a web-based platform. This web-based interface gives Ameren Missouri the ability to consolidate and organize efficiency measures and measure parameters to update measure savings as new information becomes available from EM&V data and other sources. Data referenced in the TRM are also dynamically linked such that a user will always know what parameters were used to establish measure level savings.

The application delivers improved transparency and consistency by enabling utility program administrators, evaluators and regulators to calculate, verify and audit TRM savings for all DSM programs. The TRM is organized by customer program type: residential and business. Within each section is a listing of energy efficiency measures broken down by programs:

- Residential Programs
  - Lighting
  - HVAC
  - Efficient Products
  - Low Income
  - Energy Efficiency Kits
  - Home Energy Reports
  
- Business Programs
  - Standard
  - Small Business Direct Install
  - Custom
  - Retro-Commissioning
  - New Construction

A measure level table of efficiency measures is provided for each program. The measure level table contains:

- Measure Reference Number,

- Measure Name,
- Effective Start Date of the savings values,
- Effective End Date of the savings values,
- Incremental Cost of the measure
- Cost Unit of the measure,
- Gross Annual Demand Reduction (kW),
- Gross Incremental Annual Electric Savings (kWh)
- Savings Unit of the measure, and
- Measure Life.

The measure level table displays basic information about the energy efficiency measure while additional savings attributes associated with the measure gross energy and demand savings and supporting documentation is available from the online TRM by using the Measure Reference number.

Accuracy, transparency, and ease of updating measure savings is the overarching reason for converting the TRM to its electronic counterpart, iTRL. Since calculations for similar measures are performed electronically using the same formula, transcription error is eliminated. Within iTRL, the formulas used to calculate savings are displayed, or in the case of deemed values, the reference source for the deemed value is included, increasing transparency. Finally, when better data is available, through EM&V results, for instance, parameters such as Hours of Use (HOU) or Equivalent Full Load Hours (EFLH) can be updated and all affected measures are easily updated.

To arrive at the individual measure level assumptions, Ameren Missouri consulted multiple databases, Ameren Missouri 2013 and 2014 Evaluation Measurement & Verification (EM&V) Reports, and other TRMs. Missouri specific data, where available, took precedence over all other data available. Measure level values were given primary precedence if they came from Ameren Missouri EM&V reports. For measures not contained in the EM&V reports, Ameren Missouri consulted its internal database developed by Morgan Marketing Partners which utilizes Missouri specific weather, building vintages, and home sizes. Finally, other state and utility TRMs were consulted. These other TRMs were mainly used to derive engineering equations for estimating energy savings and other formatting ideas and practices.

The measure level gross annual demand reduction (kW) identified in the TRM is determined by applying the end-use category energy to coincident peak demand factors found in Appendix E of this Stipulation.

The TRM values will be updated annually as better data becomes available. New measure level data savings values will be applied prospectively for the next program year.

The Ameren Missouri web-based TRM can be accessed by Ameren Missouri Energy Efficiency Regulatory Stakeholder Advisory Team member at: <https://ameren.dsmcentral.com>.

Please contact [Laureen Welikson at LWelikson@ameren.com](mailto:LWelikson@ameren.com) to request a password to access the site.

The following program measure sections identify various energy efficiency measures for both residential and business customers. The values expressed represent Ameren Missouri's best effort to utilize recent Missouri specific data and, where this type of data was not readily available, national best practices.

### **Protocol for Deeming New Measures Not Found Within the TRM**

A measure or technology maybe discovered to yield cost effective energy and demand savings and is not included within this TRM. The 11 Step Review Process, referenced in Chapter 4 and described in detail in the MEEIA program tariff, will be followed to deem measure level energy and demand savings, incremental costs, effective useful life and other appropriate attributes and supporting documentation.

After the 11 Step Review Process is completed, the TRM will be updated with the new measure savings value and the new measure will be used prospectively.

## Residential Energy Efficiency Program Measures

The individual measures included in the specific Residential Programs may be applied to other Residential Programs as long as the attributes associated with the energy and demand savings are constant.

## Residential Lighting Program Measures

The Lighting Program provides upstream incentives for replacing lights with high efficiency bulbs and fixtures.

One aspect of the Lighting Program that merits additional discussion is the calculation of incremental costs associated with lighting measures in cases where the efficient technology has a longer life than the baseline measure being replaced. An example of this is an LED bulb. An LED lasts 25 years, while a halogen bulb only lasts 2 years and a compact fluorescent lasts 9 years. This differential in lifetimes indicates that the baseline bulb would actually need to be replaced multiple times over the life of the LED. As a result, the incremental cost of an LED is set to zero even though the initial cost of the LED is greater than a single baseline bulb.

The following is a listing of all the Residential Lighting Measures extracted from iTRL.

## Ameren Missouri Residential Lighting Measures for MEEIA Cycle 2016-18

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>LED - 10.5W Downlight E26: Lighting</b>								
962	Jan 1, 2017		0	per bulb	0.006	40.8	per bulb	25
<b>LED - 10W: Lighting</b>								
1204	Jan 1, 2017		0	per bulb	0.006	38.2	per bulb	25
<b>LED - 12W Dimmable Light Bulb : Lighting</b>								
963	Jan 1, 2017		0	per bulb	0.012	77.7	per bulb	25
<b>LED - 15W: Lighting</b>								
1205	Jan 1, 2017		0	per bulb	0.007	50.0	per bulb	25
<b>LED - 15W Flood Light PAR30 Bulb: Lighting</b>								
964	Jan 1, 2017		0	per bulb	0.009	60.1	per bulb	25
<b>LED - 18W Flood Light PAR38 Bulb: Lighting</b>								
965	Jan 1, 2017		0	per bulb	0.013	88.2	per bulb	25
<b>LED - 20W: Lighting</b>								
1206	Jan 1, 2017		0	per bulb	0.013	66.5	per bulb	25

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>LED - 4W Candelabra: Lighting</b>								
1231	Jan 1, 2017		0	per bulb	0.006	42.0	per bulb	25
<b>LED - 8W Globe Light G25 Bulb: Lighting</b>								
966	Jan 1, 2017		0	per bulb	0.006	42.8	per bulb	25



## Residential HVAC Program Measures

The HVAC program provides incentives for replacement of HVAC units with energy efficient models. It also provides incentives for HVAC tune-ups and duct sealing.

The replacement of HVAC systems can either be applied as an “early replacement” or as a “replace on fail”. An “early replacement” analysis uses the existing equipment as the baseline for energy and demand savings while “replace on fail” uses the baseline efficiency for a new Standard/Code measure when determining energy and demand savings.

The incremental cost for an “early replacement” is calculated as the difference between the full cost of the efficient measure and the Net Present Value of the Standard/Code baseline equipment assuming the Standard/Code measure will be installed at the expiration of the remaining useful life of the existing equipment, typically after one third of the useful life of the new measure. For “replace on fail”, the incremental cost is the cost of the efficient measure less the cost of the Standard/Code measure.

Some equipment has multiple measures listed based upon what it is replacing. For example, an efficient ASHP can either replace an existing ASHP or a CAC with an electric resistance furnace.

The following is a listing of all the Residential HVAC Measures extracted from iTRL.

Ameren Missouri Residential HVAC Measures for MEEIA Cycle 2016-18

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>ASHP - SEER 15 ER Elec Resist Furnace: HVAC</b>								
919	Jan 1, 2017		1607	per measure	6.480	13903	per measure	18
<b>ASHP - SEER 15 ER with ASHP: HVAC</b>								
920	Jan 1, 2017		1184	per measure	2.266	4862	per measure	18
<b>ASHP SEER 15 MF ER Replace ASHP: HVAC</b>								
1239	Jan 1, 2017		592	per measure	1.115	2392.5	per measure	12
<b>ASHP SEER 15 MF ER Replace Elec Resist Furnace: HVAC</b>								
1266	Jan 1, 2017		803	per measure	3.366	7222.5	per measure	12
<b>ASHP SEER 15 MF Replace at Fail ASHP: HVAC</b>								
1267	Jan 1, 2017		261	per measure	0.343	735.0	per measure	12
<b>ASHP SEER 15 MF Replace at Fail Elec Resist Furnace: HVAC</b>								
1268	Jan 1, 2017		537	per measure	3.153	6764.0	per measure	12
<b>ASHP- SEER 15 Replace at Fail Elec Resist Furnace: HVAC</b>								
921	Jan 1, 2017		1074	per measure	5.389	11562	per measure	18

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>ASHP - SEER 15 Replace at Fail with ASHP: HVAC</b>								
922	Jan 1, 2017		522	per measure	0.401	860	per measure	18
<b>ASHP - SEER 16+ ER Elec Resist Furnace: HVAC</b>								
923	Jan 1, 2017		2018	per measure	7.666	16448	per measure	18
<b>ASHP - SEER 16+ ER with ASHP: HVAC</b>								
924	Jan 1, 2017		1595	per measure	3.023	6487	per measure	18
<b>ASHP- SEER 16+ Replace at Fail Elec Resist Furnace: HVAC</b>								
925	Jan 1, 2017		1485	per measure	6.134	13160	per measure	18
<b>ASHP - SEER 16+ Replace at Fail with ASHP: HVAC</b>								
926	Jan 1, 2017		522	per measure	0.825	1770	per measure	18
<b>ASHP SEER 16 MF ER Replace ASHP: HVAC</b>								
1240	Jan 1, 2017		797	per measure	1.473	3161.0	per measure	12
<b>ASHP SEER 16 MF ER Replace Elec Resist Furnace: HVAC</b>								
1269	Jan 1, 2017		1009	per measure	3.535	7584.5	per measure	12
<b>ASHP SEER 16 MF Replace at Fail ASHP: HVAC</b>								
1270	Jan 1, 2017		467	per measure	0.440	944	per measure	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>ASHP SEER 16 MF Replace at Fail Elec Resist Furnace: HVAC</b>								
1271	Jan 1, 2017		743	per measure	3.057	6560	per measure	12
<b>CAC - SEER 14 ER: HVAC</b>								
945	Jan 1, 2017		890	per measure	1.550	1636	per measure	18
<b>CAC - SEER 14 Replace at Fail: HVAC</b>								
944	Jan 1, 2017		357	per measure	0.306	323	per measure	18
<b>CAC - SEER 15 ER: HVAC</b>								
947	Jan 1, 2017		1247	per measure	1.826	1927	per measure	18
<b>CAC - SEER 15 Replace at Fail: HVAC</b>								
946	Jan 1, 2017		714	per measure	0.357	377	per measure	18
<b>CAC - SEER 16+ ER: HVAC</b>								
949	Jan 1, 2017		1304	per measure	1.828	1929	per measure	18

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>CAC - SEER 16+ Replace at Fail: HVAC</b>								
948	Jan 1, 2017		771	per measure	0.333	351	per measure	18
<b>DFHP SEER 15_MF: HVAC</b>								
1241	Jan 1, 2017		254	per measure	0.086	185	per measure	12
<b>DFHP - SEER 15_SF: HVAC</b>								
928	Jan 1, 2017		508	per measure	0.172	370	per measure	12
<b>DFHP SEER 16_MF: HVAC</b>								
1242	Jan 1, 2017		382	per measure	0.335	271	per measure	12
<b>DFHP - SEER 16_SF: HVAC</b>								
929	Jan 1, 2017		763	per measure	0.253	542	per measure	12
<b>DFHP - SEER 17_SF: HVAC</b>								
930	Jan 1, 2017		1017	per measure	0.483	1037	per measure	12
<b>DFHP SEER 17+_MF: HVAC</b>								
1243	Jan 1, 2017		509	per measure	0.242	518.5	per measure	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>DFHP - SEER 18_SF: HVAC</b>								
931	Jan 1, 2017		1342	per measure	0.503	1079	per measure	12
<b>Ductless ASHP ER: HVAC</b>								
1250	Jan 1, 2017		1982	per measure	2.141	4594	per measure	18
<b>Ductless ASHP Replace Electric Resistance ER: HVAC</b>								
1252	Jan 1, 2017		2108	per measure	30479	7465	per measure	18
<b>Ductless ASHP Replace Electric Resistance ROF: HVAC</b>								
1253	Jan 1, 2017		1051	per measure	3.685	7906	per measure	18
<b>Ductless ASHP ROF: HVAC</b>								
1251	Jan 1, 2017		888	per measure	0.814	1746	per measure	18
<b>Duct Sealing Level 1: HVAC</b>								
905	Jan 1, 2016		325	per home	0.299	641.1	per home	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Duct Sealing Level 2: HVAC</b>								
906	Jan 1, 2016		325	per home	0.519	1113.1	per home	20
<b>ECM Auto Fan Early Replacement: HVAC</b>								
908	Jan 1, 2017		168	per measure	0.370	794	per measure	15
<b>ECM Auto Fan MF: HVAC</b>								
1257	Jan 1, 2017		263	per measure	0.183	392.5	per measure	15
<b>ECM Auto Fan Replace at Fail: HVAC</b>								
907	Jan 1, 2017		263	per measure	0.366	785	per measure	15
<b>ECM Continuous Fan Early Replacement: HVAC</b>								
911	Jan 1, 2017		168	per measure	1.533	3289	per measure	15
<b>ECM Continuous Fan MF: HVAC</b>								
1244	Jan 1, 2017		263	per measure	0.766	1644.5	per measure	15
<b>ECM Continuous Fan Replace at Fail: HVAC</b>								
910	Jan 1, 2017		125	per measure	1.533	3289	per measure	15

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Geothermal HP Desuperheater: HVAC</b>								
932	Jan 1, 2016		239	per measure	0.065	730.5	per measure	10
<b>GSHP - 23 EER ER: HVAC</b>								
1248	Jan 1, 2017		4859	per measure	4.012	8607	per measure	18
<b>GSHP - 23 EER Replace at Fail</b>								
1249	Jan 1, 2017		3200	per measure	1.681	3607	per measure	18
<b>GSHP SEER 14+ ER ASHP with GSHP ER: HVAC</b>								
1247	Jan 1, 2017		5250	per measure	5.904	12667	per measure	18
<b>GSHP - SEER 14+ ER Elec Resist Furnace: HVAC</b>								
934	Jan 1, 2017		5250	per measure	12.678	27201	per measure	18
<b>GSHP - SEER 14+ Replace Elec Resist Furnace: HVAC</b>								
935	Jan 1, 2017		4717	per measure	10.645	22840	per measure	18
<b>Heat Pump Strip Installed: HVAC</b>								
913	Jan 1, 2016		154	per measure	0.621	1332.0	per measure	15
<b>Heat Pump Strip Reset: HVAC</b>								
914	Jan 1, 2016		25	per measure	0.621	1332.0	per measure	15



Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Heat Pump Water Heater: HVAC</b>								
1232	Jan 1, 2017		1480	per measure	0.254	2865	per measure	15
<b>HVAC Maintenance and Tune-up_MF: HVAC</b>								
1245	Jan 1, 2016		70	per measure	0.165	174	per measure	10
<b>HVAC Maintenance and Tune-up_SF: HVAC</b>								
943	Jan 1, 2017		70	per measure	0.0165	174	per measure	10
<b>Indoor Coil Cleaning: HVAC</b>								
941	Jan 1, 2017		63	per cleaning	0.055	117	per measure	5
<b>Learning Thermostat: HVAC</b>								
1222	Jan 1, 2016		224	per measure	0.438	462	per measure	10
<b>Outdoor Coil Cleaning: HVAC</b>								
942	Jan 1, 2017		31	per cleaning	0.120	258	per measure	5
<b>PTAC 10.3 EER_SF: HVAC</b>								
950	Jan 2, 2013		124	per measure	0.126	133.0	per measure	15

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>PTAC 10 EER_MF: HVAC</b>								
1233	Jan 1, 2016		124	per measure	0.126	133	per measure	15
<b>PTAC 9.3 EER_SF: HVAC</b>								
951	Jan 2, 2013		136	per measure	0.201	212.5	per measure	15
<b>PTAC 9 EER_MF: HVAC</b>								
1234	Jan 1, 2016		136	per measure	0.201	212.5	per measure	15
<b>PTHP 10.9 EER_SF: HVAC</b>								
936	Jan 2, 2013		155	per measure	0.114	244.3	per measure	15
<b>PTHP 10 EER_MF: HVAC</b>								
1235	Jan 1, 2016		155	per measure	0.114	244.3	per measure	15
<b>PTHP 9.1 EER_SF: HVAC</b>								
937	Jan 2, 2013		169	per measure	0.157	336.2	per measure	15
<b>PTHP 9 EER_MF: HVAC</b>								
1236	Jan 1, 2016		169	per measure	0.157	336.2	per measure	15

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>RCA 10% improvement_MF: HVAC</b>								
1246	Jan 1, 2016		70	per measure	0.346	365	per measure	10
<b>RCA 10% improvement_SF: HVAC</b>								
940	Jan 1, 2017		127	per measure	0.399	856	per measure	10
<b>SEER 14 MF ER: HVAC</b>								
1275	Jan 1, 2017		445	per measure	0.773	815.5	per measure	12
<b>SEER 14 MF Replace on Fail: HVAC</b>								
1237	Jan 1, 2017		178.5	per measure	0.155	163.8	per measure	12
<b>SEER 15 MF ER: HVAC</b>								
1276	Jan 1, 2017		623.5	per measure	0.903	953.5	per measure	12
<b>SEER 15 MF Replace on Fail: HVAC</b>								
1238	Jan 1, 2017		357	per measure	0.180	190	per measure	12

## Efficient Products Program Measures

The Efficient Products Program provides mail-in and online rebates for retail products and the sale of products at a discounted price through an online store. Various end-use cost-effective measures included consist of qualified energy star appliances, power management, water heaters, window air conditioning units, pool pumps, and various building shell measures.

The following is a listing of all the Residential Efficient Products Measures extracted from iTRL.

Ameren Missouri Residential Efficient Products Measures for MEEIA Cycle 2016-18

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>AC - Energy Star Room: Efficient Products</b>								
857	Jan 1, 2016		50	per measure	0.047	49.6	per measure	12
<b>Air Sealing (Infiltration reduction) - 50%_SF: Efficient Products</b>								
874	Jan 1, 2016		264	per home	0.345	739.8	per home	13
<b>Ceiling Insulation R5-R30 All Electric: Efficient Products</b>								
875	Jan 1, 2016		.46	per sq ft	2.0E-4	0.46	per sq ft	25
<b>Ceiling Insulation R5-R38 All Electric: Efficient Products</b>								
876	Jan 1, 2016		0.58	per sq ft	2.0E-4	0.48	per sq ft	25
<b>Ceiling Insulation R5-R49 All Electric: Efficient Products</b>								
881	Jan 1, 2016		0.70	per sq ft	2.0E-4	0.49	per sq ft	25
<b>Energy Star Air Purifier:Efficient Products</b>								
1177	Jan 1, 2017		70	per measure	0.240	515	per measure	9
<b>Energy Star Water Cooler - Cold Only: Efficient Products</b>								
1180	Jan 2, 2013		17	per measure	0.006	47.4	per measure	10

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Energy Star Water Cooler - Hot and Cold: Efficient Products</b>								
1181	Jan 1, 2017		17	per measure	0.018	140	per measure	10
<b>Heat Pump Water Heaters: Efficient Products</b>								
872	Jan 1, 2017		1480	per measure	0.254	2865	per measure	15
<b>Learning Thermostat: Efficient Products</b>								
1230	Jan 1, 2016		224	per measure	0.438	462	per unit	10
<b>Pool Pump and Motor Single Speed: Efficient Products</b>								
860	Jan 2, 2013		85	per measure	0.0957	694.0	per measure	10
<b>Pool Pump and motor w auto controls - multi speed: Efficient Products</b>								
859	Jan 1, 2016		579	per measure	0.2483	1799.7	per measure	10
<b>Smart Strip - Motion Sensing: Efficient Products</b>								
1258	Jan 1, 2017		8.96	per measure	0.007	64.	per measure	5
<b>Smart Strip plug outlet_Load Sensing: Efficient Products</b>								
1031	Jan 1, 2017		4	per measure	0.007	59	per measure	5

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>VFDs on Residential Swimming Pool Pumps: Efficient Products</b>								
861	Jan 1, 2017		425	per measure	0.283	2052.8	per measure	10
<b>Window Replacement_SF: Efficient Products</b>								
882	Jan 1, 2016		4.33	per sq ft	0.0021	4.41	per sq ft	20

### **Low Income Program Measures**

The Low Income Program provides the direct installation of energy efficient lighting and hot water measures into low income single family homes and multi-tenant properties. The program can also include the replacement and tune-up of HVAC systems, the replacement of appliances, and the installation of building shell measures.

The following is a listing of all the Residential Low Income Measures extracted from iTRL.



Ameren Missouri Low Income Measures for MEEIA Cycle 2016-18

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>AC - Energy Star Room_MF: Low Income</b>								
974	Jan 1, 2017		442	per measure	0.473	499	per measure	12
<b>AC - Energy Star Room_SF: Low Income</b>								
975	Jan 1, 2016		445	per measure	0.259	273	per measure	12
<b>AC - Energy Star Room - Thru-Wall_MF: Low Income</b>								
972	Jan 1, 2017		637	per measure	0.473	499	per measure	12
<b>AC - Energy Star Room - Thru-Wall_SF: Low Income</b>								
973	Jan 1, 2016		641	per measure	0.259	273	per measure	12
<b>Air Sealing (Infiltration reduction) - 50%_MF: Low Income</b>								
1220	Jan 1, 2016		400	per home	0.1864	400	per home	13
<b>Air Sealing (Infiltration reduction) - 50%_SF: Low Income</b>								
1207	Jan 1, 2016		500	per home	0.233	500	per home	10
<b>Ceiling Insulation R5-R30 All Electric_MF: Low Income</b>								
1209	Jan 1, 2016		1.37	per sq ft	2.0E-4	0.46	per sq ft	25

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Ceiling Insulation R5-R30 All Electric_SF: Low Income</b>								
1208	Jan 1, 2016		1.47	per sq ft	2.0E-4	0.46	per sq ft	10
<b>Dirty Filter Alarm_MF: Low Income</b>								
1260	Jan 1, 2016		5	per measure	0.051	110	per measure	14
<b>Dirty Filter Alarm_SF: Low Income</b>								
1259	Jan 1, 2016		5	per measure	0.051	110	per measure	14
<b>Energy Star Refrigerator_MF: Low Income</b>								
968	Jan 1, 2017		750	per measure	0.114	888	per measure	10
<b>Energy Star Refrigerator_SF: Low Income</b>								
1221	Jan 1, 2016		750	per measure	0.104	807	per measure	10
<b>HVAC Maintenance and Tune-up_MF: Low Income</b>								
999	Jan 1, 2017		90	per measure	0.067	143	per measure	10
<b>HVAC Maintenance and Tune-up_SF: Low Income</b>								
1000	Jan 1, 2016		100	per measure	0.081	174	per measure	10

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>LED - 10.5W Downlight E26 Light Bulb_MF: Low Income</b>								
1018	Jan 1, 2017		0	per bulb	0.003	21.3	per bulb	25
<b>LED - 10.5W Downlight E26 Light Bulb_SF: Low Income</b>								
1019	Jan 1, 2016		0	per bulb	0.004	28	per bulb	25
<b>LED - 12W Dimmable Light Bulb_MF: Low Income</b>								
1021	Jan 1, 2017		0	per bulb	0.003	22.8	per bulb	25
<b>LED - 12W Dimmable Light Bulb_SF: Low Income</b>								
1020	Jan 1, 2016		0	per bulb	0.004	28	per bulb	25
<b>LED - 15W Flood Light PAR30 Bulb_MF: Low Income</b>								
1022	Jan 1, 2017		0	per bulb	0.005	31.5	per bulb	25
<b>LED - 15W Flood Light PAR30 Bulb_SF: Low Income</b>								
1023	Jan 1, 2016		0	per bulb	0.005	33.5	per bulb	25
<b>LED - 18W Flood Light PAR38 Bulb_MF: Low Income</b>								
1024	Jan 1, 2017		0	per bulb	0.004	29.8	per bulb	25

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>LED - 18W Flood Light PAR38 Bulb_SF: Low Income</b>								
1025	Jan 1, 2016		0	per bulb	0.005	33.5	per bulb	25
<b>LED - 8W Globe Light G25 Bulb_MF: Low Income</b>								
1026	Jan 1, 2017		0	per bulb	0.002	12.8	per bulb	25
<b>LED - 8W Globe Light G25 Bulb_SF: Low Income</b>								
1027	Jan 1, 2016		0	per bulb	0.005	33.5	per bulb	25
<b>Low Flow Faucet Aerator _MF: Low Income</b>								
1033	Jan 1, 2017		14	per measure	0.004	42	per measure	12
<b>Low Flow Faucet Aerator _SF: Low Income</b>								
1034	Jan 1, 2016		16	per measure	0.005	57	per measure	12
<b>Low Flow Showerhead_MF: Low Income</b>								
1035	Jan 1, 2017		42	per measure	0.018	202.4	per measure	12
<b>Low Flow Showerhead_SF: Low Income</b>								
1036	Jan 1, 2016		42	per measure	0.032	361	per measure	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Pipe Insulation_MF: Low Income</b>								
1037	Jan 1, 2017		1.5	per ft	0.002	22	per ft	6
<b>Pipe Insulation_SF: Low Income</b>								
1038	Jan 1, 2016		1.6	per ft	0.002	25.7	per ft	6
<b>PTAC 10.3 EER_MF: Low Income</b>								
1005	Jan 1, 2016		124	per measure	0.126	133.0	per measure	15
<b>PTAC 9.3 EER_MF: Low Income</b>								
1006	Jan 1, 2016		136	per measure	0.201	212.5	per measure	15
<b>PTHP 10.9 EER_MF: Low Income</b>								
991	Jan 1, 2016		155	per measure	0.114	244.3	per measure	15
<b>PTHP 9.1 EER_MF: Low Income</b>								
992	Jan 1, 2016		169	per measure	0.157	336.2	per measure	15
<b>RCA 10% improvement_MF: Low Income</b>								
995	Jan 1, 2017		75	per measure	0.239	512	per measure	10

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>RCA 10% improvement_SF: Low Income</b>								
996	Jan 1, 2016		80	per measure	0.089	191	per measure	10
<b>Refrigerator Coil Cleaning Brush_SF: Low Income</b>								
1172	Jan 2, 2013		8.5	per measure	0.002	16.5	per measure	2
<b>Setback thermostat - full setback_MF: Low Income</b>								
993	Jan 1, 2016		75	per measure	0.109	234	per measure	9
<b>Setback thermostat - full setback_SF: Low Income</b>								
994	Jan 1, 2016		75	per measure	0.109	234	per measure	15
<b>Smart Strip plug outlet_MF: Low Income</b>								
1030	Jan 1, 2017		40	per measure	0.011	70	per measure	5
<b>Water Heater, Tank Blanket-Insulation - Electric_MF: Low Income</b>								
1039	Jan 1, 2016		18	per measure	0.004	41	per measure	15
<b>Water Heater, Tank Blanket-Insulation - Electric_SF: Low Income</b>								
1041	Jan 1, 2016		58.81	per measure	0.016	180.0	per measure	15

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Window Film_MF: Low Income</b>								
970	Jan 1, 2016		538	per measure	0.1515	325	per measure	10
<b>Window Replacement_SF: Low Income</b>								
1211	Jan 1, 2016		14	per sq ft	0.0012	2.53	per sq ft	20

### **Energy Efficiency Kit Program Measures**

The Kit Program offers free home energy kits to customers and may include lighting and hot water measures for customers with electric water heaters. The kits may be distributed through schools, directly installed into multifamily properties, or distributed to targeted customers that request them.

The following is a listing of all the Kit Measures extracted from iTRL.



Ameren Missouri Kit Measures for MEEIA Cycle 2016-18

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Dirty filter alarm_LI: Kits</b>								
1264	Jan 1, 2016		5	per measure	0.051	110	per measure	14
<b>Dirty filter alarm_MF: Kits</b>								
1225	Jan 1, 2017		5	per measure	0.091	195.8	per measure	14
<b>Dirty filter alarm_SF: Kits</b>								
1224	Jan 1, 2016		5	per measure	0.051	110	per measure	14
<b>Dirty filter alarm_SK: Kits</b>								
1226	Jan 1, 2017		5	per measure	0.091	195.8	per measure	14
<b>LED - 12 W_LI: Kits</b>								
1263	Jan 1, 2016		0	per measure	0.004	25.8	per measure	25
<b>LED - 12 W_MF: Kits</b>								
1203	Jan 1, 2017		0	per bulb	0.006	37.7	per bulb	25
<b>LED - 12 W_SF: Kits</b>								
1202	Jan 1, 2017		0	per bulb	0.004	23.9	per bulb	25

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>LED - 12 W_SK: Kits</b>								
1227	Jan 1, 2017		0	per bulb	0.006	37.7	per bulb	25
<b>Low Flow Faucet Aerator_LI: Kits</b>								
1262	Jan 1, 2016		3	per measure	0.003	39	per measure	12
<b>Low Flow Faucet Aerator - Bathroom_MF: Kits</b>								
865	Jan 1, 2017		2.5	per measure	0.003	38	per measure	12
<b>Low Flow Faucet Aerator - Bathroom_SK: Kits</b>								
1228	Jan 1, 2017		2.5	per measure	0.002	22.1	per measure	12
<b>Low Flow Faucet Aerator - Electric water heater_SF: Kits</b>								
864	Jan 1, 2017		2.5	per measure	0.002	20.3	per measure	12
<b>Low Flow Faucet Aerator - Kitchen_MF: Kits</b>								
1273	Jan 1, 2017		2.5	per measure	0.007	78.3	per measure	12
<b>Low Flow Faucet Aerator - Kitchen_SK: Kits</b>								
1274	Jan 1, 2017		2.5	per measure	0.007	79.7	per measure	12
<b>Low Flow Showerhead - Electric water heater_LI: Kits</b>								
1261	Jan 1, 2016		9	per measure	0.019	218	per measure	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Low Flow Showerhead - Electric water heater_MF: Kits</b>								
867	Jan 1, 2017		9	per measure	0.018	206.2	per measure	12
<b>Low Flow Showerhead - Electric water heater_SF: Kits</b>								
866	Jan 1, 2017		9	per measure	0.009	104.3	per measure	12
<b>Low Flow Showerhead - Electric water heater_SK: Kits</b>								
1229	Jan 1, 2017		9	per measure	0.016	181.6	per measure	12
<b>Pipe Insulation_MF: Kits</b>								
868	Jan 1, 2017		0.42	per ft	0.002	22.7	per ft	6
<b>Pipe Insulation_SF: Kits</b>								
1167	Jan 1, 2017		0.42	per ft	0.001	10.7	per ft	6
<b>Pipe Insulation_SK: Kits</b>								
1272	Jan 1, 2017		0.42	per ft	0.002	26.0	per ft	6
<b>Refrigerator Coil Cleaning Brush_LI: Kits</b>								
1265	Jan 1, 2016		3	per measure	0.002	16.5	per measure	2

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Refrigerator Coil Cleaning Brush_MF: Kits</b>								
1255	Jan 1, 2016		3	per measure	0.002	16.5	per measure	2
<b>Refrigerator Coil Cleaning Brush_SF: Kits</b>								
1256	Jan 1, 2016		3	per measure	0.002	16.5	per measure	2
<b>Refrigerator Coil Cleaning Brush_SK: Kits</b>								
1254	Jan 1, 2016		3	per measure	0.002	16.5	per measure	2

### **Home Energy Report Program Measures**

The Home Energy Report Program encourages energy consumption behavior changes of participating residential customers by mailing Home Energy Reports to targeted residential customers on an established frequency for the duration of the program.

The following is a listing of all the Home Energy Report Measures extracted from iTRL.

Ameren Missouri Behavior Measures for MEEIA Cycle 2016-18

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Home Energy Report: Behavior</b>								
1223	Jan 1, 2016		0	per home	.07	150	per home	1

## Business Energy Efficiency Program Measures

The Business Energy Efficiency Prescriptive measures are listed below primarily for the Standard program. The Small Business Direct Install (SBDI) Program can share most of these measures when appropriate for small businesses. The Custom, Retro-Commissioning (RCx) program and New Construction program measures are similar in that they require calculation of the savings by the methodology outlined in the Custom Section. Where they differ is RCx only applies to Compressed Air, Building Automation System (BAS), and Lighting. The New Construction program can include both Custom measures and those listed in the Prescriptive measure list. The individual measures included in the Prescriptive measure list may be applied to other Business Programs as long as the attributes associated with the energy and demand savings are consistent with the deemed values.

The following is a listing of all the Business Prescriptive Measures extracted from iTRL, Ameren Missouri's online database for maintaining information on energy saving measures.

### Ameren Missouri Prescriptive Measures Listing for MEEIA Cycle 2016-18

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>4L T9: Biz Prescriptive</b>								
3059	Jan 1, 2016		219.50	per measure	0.2216	1166.29	per measure	11
<b>6L T8: Biz Prescriptive</b>								
3060	Jan 1, 2016		208	per measure	0.1579	830.97	per measure	11
<b>AC 135,000 - 240,000: Biz Prescriptive</b>								
726	Jan 2, 2013		110.89	per ton	0.1084	119.0	per ton	15
<b>AC 240,000 - 760,000: Biz Prescriptive</b>								
726-1	Jan 2, 2016		115.13	per ton	0.0568	62.4	per ton	15
<b>AC greater than 760,000: Biz Prescriptive</b>								
727	Jan 2, 2013		98.38	per ton	0.0839	92.1	per ton	15
<b>AC less than 65,000 1 Ph: Biz Prescriptive</b>								
728	Jan 2, 2013		55.57	per ton	0.0594	65.2	per ton	15
<b>Air-Cooled Recip Chiller COP = 2.8, IPLV = 3.41: Biz Prescriptive</b>								
2800	Jan 1, 2016		45.07	per ton	0.02	126.5	per ton	20



Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Air-Cooled Recip Chiller COP = 2.8, IPLV = 3.89: Biz Prescriptive</b>								
2801	Jan 1, 2016		92.04	per ton	0.041	268.7	per ton	20
<b>Air-Cooled Recip Chiller COP = 2.8, IPLV = 4.24: Biz Prescriptive</b>								
2802	Jan 1, 2016		119.59	per ton	0.053	338.6	per ton	20
<b>Air-Cooled Recip Chiller COP = 3.08, IPLV = 3.36: Biz Prescriptive</b>								
2803	Jan 1, 2016		58.58	per ton	0.104	222.9	per ton	20
<b>Air-Cooled Recip Chiller COP = 3.08, IPLV = 3.76: Biz Prescriptive</b>								
2804	Jan 1, 2016		99.68	per ton	0.123	338	per ton	20
<b>Air-Cooled Recip Chiller COP = 3.08, IPLV = 4.28: Biz Prescriptive</b>								
2805	Jan 1, 2016		141.63	per ton	0.142	467.5	per ton	20
<b>Air-Cooled Recip Chiller COP = 3.08, IPLV = 4.67: Biz Prescriptive</b>								
2806	Jan 1, 2016		166.96	per ton	0.152	531.2	per ton	20
<b>Air-Cooled Recip Chiller COP = 3.36, IPLV = 3.66: Biz Prescriptive</b>								
2807	Jan 1, 2016		106.23	per ton	0.192	410.9	per ton	20
<b>Air-Cooled Recip Chiller COP = 3.36, IPLV = 4.10: Biz Prescriptive</b>								
2808	Jan 1, 2016		144.29	per ton	0.209	516.5	per ton	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Air-Cooled Recip Chiller COP = 3.36, IPLV = 4.67: Biz Prescriptive</b>								
2809	Jan 1, 2016		182.94	per ton	0.227	635.2	per ton	20
<b>Air-Cooled Recip Chiller COP = 3.36, IPLV = 5.09: Biz Prescriptive</b>								
2810	Jan 1, 2016		205.88	per ton	0.236	693.6	per ton	20
<b>Air-Cooled Screw Chiller COP = 2.8, IPLV = 3.46: Biz Prescriptive</b>								
2811	Jan 1, 2016		50.57	per ton	0.024	142.4	per ton	20
<b>Air-Cooled Screw Chiller COP = 2.8, IPLV = 3.64: Biz Prescriptive</b>								
2812	Jan 1, 2016		69.12	per ton	0.044	204.6	per ton	20
<b>Air-Cooled Screw Chiller COP = 2.8, IPLV = 4.75: Biz Prescriptive</b>								
2813	Jan 1, 2016		152.46	per ton	0.065	380.3	per ton	20
<b>Air-Cooled Screw Chiller COP = 3.08, IPLV = 3.36: Biz Prescriptive</b>								
2814	Jan 1, 2016		58.58	per ton	0.106	223.5	per ton	20
<b>Air-Cooled Screw Chiller COP = 3.08, IPLV = 3.80: Biz Prescriptive</b>								
2815	Jan 1, 2016		103.31	per ton	0.128	353.2	per ton	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Air-Cooled Screw Chiller COP = 3.08, IPLV = 4.00: Biz Prescriptive</b>								
2816	Jan 1, 2016		120.4	per ton	0.146	409.8	per ton	20
<b>Air-Cooled Screw Chiller COP = 3.08, IPLV = 5.22: Biz Prescriptive</b>								
2817	Jan 1, 2016		196.24	per ton	0.166	569.8	per ton	20
<b>Air-Cooled Screw Chiller COP = 3.36, IPLV = 3.66: Biz Prescriptive</b>								
2818	Jan 1, 2016		106.23	per ton	0.196	412.2	per ton	20
<b>Air-Cooled Screw Chiller COP = 3.36, IPLV = 4.15: Biz Prescriptive</b>								
2819	Jan 1, 2016		148.11	per ton	0.216	531	per ton	20
<b>Air-Cooled Screw Chiller COP = 3.36, IPLV = 4.42: Biz Prescriptive</b>								
2820	Jan 1, 2016		167.22	per ton	0.233	583	per ton	20
<b>Air-Cooled Screw Chiller COP = 3.36, IPLV = 5.69: Biz Prescriptive</b>								
2821	Jan 1, 2016		232.77	per ton	0.251	729.6	per ton	20
<b>Anti-Sweat Heater Controls -- Cooler: Biz Prescriptive</b>								
838	Jan 2, 2013		151	per measure	0.1855	1366.9	per measure	12
<b>Beverage Vending Machine Control: Biz Prescriptive</b>								
839	Jan 1, 2016		216	per measure	0.1086	800	per measure	5

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Built-in to individual fixtures: Biz Prescriptive</b>								
3061	Jan 1, 2016		1	per measure	0.0735	387	per measure	11
<b>Central Lighting Control: College/University: Biz Prescriptive</b>								
776-1	Jan 1, 2016		3700	per 10,000 square feet	3.6517	19223.2	per 10,000 square feet	12
<b>Central Lighting Control: Elementary School: Biz Prescriptive</b>								
776-10	Jan 1, 2016		3700	per 10,000 square feet	1.4378	7568.8	per 10,000 square feet	12
<b>Central Lighting Control: Exterior: Biz Prescriptive</b>								
776-15	Jan 1, 2016		3700	per 10,000 square feet	2.6001	13687.5	per 10,000 square feet	12
<b>Central Lighting Control: Garage, 24/7 lighting: Biz Prescriptive</b>								
776-19	Jan 1, 2016		3700	per 10,000 square feet	5.2003	27375.0	per 10,000 square feet	12
<b>Central Lighting Control: Garage: Biz Prescriptive</b>								
776-4	Jan 1, 2016		3700	per 10,000 square feet	2.1015	11062.5	per 10,000 square feet	12
<b>Central Lighting Control: Grocery: Biz Prescriptive</b>								
776-5	Jan 1, 2016		3700	per 10,000 square feet	3.8611	20325.5	per 10,000 square feet	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Central Lighting Control: Heavy Industry: Biz Prescriptive</b>								
776-11	Jan 1, 2016		3700	per 10,000 square feet	3.6497	19212.4	per 10,000 square feet	12
<b>Central Lighting Control: High School/Middle School: Biz Prescriptive</b>								
776-12	Jan 1, 2016		3700	per 10,000 square feet	2.5592	13471.9	per 10,000 square feet	12
<b>Central Lighting Control: Hospital: Biz Prescriptive</b>								
776-6	Jan 1, 2016		3700	per 10,000 square feet	3.1195	16421.4	per 10,000 square feet	12
<b>Central Lighting Control: Hotel/Motel Common Areas: Biz Prescriptive</b>								
776-7	Jan 1, 2016		3700	per 10,000 square feet	4.5893	24158.7	per 10,000 square feet	12
<b>Central Lighting Control: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
776-13	Jan 1, 2016		3700	per 10,000 square feet	0.4613	2428.1	per 10,000 square feet	12
<b>Central Lighting Control: Light Industry: Biz Prescriptive</b>								
776-9	Jan 1, 2016		3700	per 10,000 square feet	3.4421	18119.8	per 10,000 square feet	12
<b>Central Lighting Control: Miscellaneous: Biz Prescriptive</b>								
776-14	Jan 1, 2016		3700	per 10,000 square feet	3.2901	17319.9	per 10,000 square feet	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Central Lighting Control: Multifamily Common Areas: Biz Prescriptive</b>								
776-16	Jan 1, 2016		3700	per 10,000 square feet	3.5321	18593.8	per 10,000 square feet	12
<b>Central Lighting Control: Office: Biz Prescriptive</b>								
776-8	Jan 1, 2016		3700	per 10,000 square feet	2.764	14549.9	per 10,000 square feet	12
<b>Central Lighting Control: Religious Worship/Church: Biz Prescriptive</b>								
776-18	Jan 1, 2016		3700	per 10,000 square feet	0.9878	5200.0	per 10,000 square feet	12
<b>Central Lighting Control: Restaurant: Biz Prescriptive</b>								
776-3	Jan 1, 2016		3700	per 10,000 square feet	3.4119	17960.9	per 10,000 square feet	12
<b>Central Lighting Control: Retail/Service: Biz Prescriptive</b>								
776-2	Jan 1, 2016		3700	per 10,000 square feet	3.0003	15793.9	per 10,000 square feet	12
<b>Central Lighting Control: Warehouse: Biz Prescriptive</b>								
776-20	Jan 1, 2016		3700	per 10,000 square feet	2.9961	15771.8	per 10,000 square feet	12
<b>Ceramic Metal Halide 20-100W: College/University: Biz Prescriptive</b>								
731-1	Jan 1, 2016		225	per measure	0.1414	744.3	per measure	16

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Ceramic Metal Halide 20-100W: Elementary School: Biz Prescriptive</b>								
731-10	Jan 1, 2016		225	per measure	0.0557	293.1	per measure	16
<b>Ceramic Metal Halide 20-100W: Exterior: Biz Prescriptive</b>								
731-15	Jan 1, 2016		225	per measure	0.1007	530.0	per measure	16
<b>Ceramic Metal Halide 20-100W: Garage, 24/7 lighting: Biz Prescriptive</b>								
731-19	Jan 1, 2016		225	per measure	0.2014	1060.0	per measure	16
<b>Ceramic Metal Halide 20-100W: Garage: Biz Prescriptive</b>								
731-4	Jan 1, 2016		225	per measure	0.0814	428.3	per measure	16
<b>Ceramic Metal Halide 20-100W: Grocery: Biz Prescriptive</b>								
731-5	Jan 1, 2016		225	per measure	0.1495	787.0	per measure	16
<b>Ceramic Metal Halide 20-100W: Heavy Industry: Biz Prescriptive</b>								
731-11	Jan 1, 2016		225	per measure	0.1413	743.9	per measure	16
<b>Ceramic Metal Halide 20-100W: High School/Middle School: Biz Prescriptive</b>								
731-12	Jan 1, 2016		225	per measure	0.0991	521.6	per measure	16

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Ceramic Metal Halide 20-100W: Hospital: Biz Prescriptive</b>								
731-6	Jan 1, 2016		225	per measure	0.1208	635.8	per measure	16
<b>Ceramic Metal Halide 20-100W: Hotel/Motel Common Areas: Biz Prescriptive</b>								
731-7	Jan 1, 2016		225	per measure	0.1777	935.4	per measure	16
<b>Ceramic Metal Halide 20-100W: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
731-13	Jan 1, 2016		225	per measure	0.0179	94.0	per measure	16
<b>Ceramic Metal Halide 20-100W: Light Industry: Biz Prescriptive</b>								
731-9	Jan 1, 2016		225	per measure	0.1333	701.6	per measure	16
<b>Ceramic Metal Halide 20-100W: Miscellaneous: Biz Prescriptive</b>								
731-14	Jan 1, 2016		225	per measure	0.1274	670.6	per measure	16
<b>Ceramic Metal Halide 20-100W: Multifamily Common Areas: Biz Prescriptive</b>								
731-16	Jan 1, 2016		225	per measure	0.1368	720.0	per measure	16
<b>Ceramic Metal Halide 20-100W: Office: Biz Prescriptive</b>								
731-8	Jan 1, 2016		225	per measure	0.107	563.4	per measure	16
<b>Ceramic Metal Halide 20-100W: Religious Worship/Church: Biz Prescriptive</b>								
731-18	Jan 1, 2016		225	per measure	0.0382	201.3	per measure	16



Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Ceramic Metal Halide 20-100W: Restaurant: Biz Prescriptive</b>								
731-3	Jan 1, 2016		225	per measure	0.1321	695.4	per measure	16
<b>Ceramic Metal Halide 20-100W: Retail/Service: Biz Prescriptive</b>								
731-2	Jan 1, 2016		225	per measure	0.1162	611.5	per measure	16
<b>Ceramic Metal Halide 20-100W: Warehouse: Biz Prescriptive</b>								
731-20	Jan 1, 2016		225	per measure	0.116	610.7	per measure	16
<b>Delamping: Biz Prescriptive</b>								
3084	Jan 1, 2017		1.5	per foot	0.0058	30.4	per ft	15
<b>Electronics - Monitor Power Management: Biz Prescriptive</b>								
3065	Jan 1, 2016		6.03	per building	0.2438	1,767.47	per building	5
<b>ENERGY STAR Commercial Glass Door Freezers 15 to 30 ft3: Biz Prescriptive</b>								
827	Jan 2, 2013		950	per measure	0.272	2004.0	per measure	12
<b>ENERGY STAR Commercial Glass Door Freezers 30 to 50ft3: Biz Prescriptive</b>								
828	Jan 2, 2013		1307	per measure	0.5252	3869.0	per measure	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>ENERGY STAR Commercial Glass Door Freezers less than 15ft3: Biz Prescriptive</b>								
826	Jan 2, 2013		220	per measure	0.2298	1693	per measure	12
<b>ENERGY STAR Commercial Glass Door Freezers more than 50ft3: Biz Prescriptive</b>								
829	Jan 2, 2013		2300	per measure	0.9662	7118.0	per measure	12
<b>ENERGY STAR Commercial Glass Door Refrigerators 15 to 30 ft3: Biz Prescriptive</b>								
843	Jan 1, 2016		500	per measure	0.0907	668	per measure	12
<b>ENERGY STAR Commercial Glass Door Refrigerators less than 15ft3: Biz Prescriptive</b>								
842	Jan 1, 2016		250	per measure	0.098	722	per measure	12
<b>ENERGY STAR Commercial Solid Door Freezers 15 to 30 ft3: Biz Prescriptive</b>								
831	Jan 2, 2013		400	per measure	0.118	869.0	per measure	12
<b>ENERGY STAR Commercial Solid Door Freezers 30 to 50ft3: Biz Prescriptive</b>								
832	Jan 2, 2013		550	per measure	0.2346	1728.0	per measure	12
<b>ENERGY STAR Commercial Solid Door Freezers less than 15ft3: Biz Prescriptive</b>								
830	Jan 2, 2013		150	per measure	0.0808	595.0	per measure	12
<b>ENERGY STAR Commercial Solid Door Freezers more than 50ft3: Biz Prescriptive</b>								
833	Jan 2, 2013		700	per measure	0.51	3757.0	per measure	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>ENERGY STAR Hot Holding Cabinets Full Size - Electric: Biz Prescriptive</b>								
679	Jan 1, 2016		1783	per measure	1.3241	6624	per measure	12
<b>ENERGY STAR Ice Machines 500 to 1000 lbs: Biz Prescriptive</b>								
835	Jan 1, 2016		1500	per measure	0.1211	892	per measure	12
<b>ENERGY STAR Ice Machines less than 500 lbs: Biz Prescriptive</b>								
834	Jan 1, 2016		600	per measure	0.0813	599	per measure	12
<b>ENERGY STAR Ice Machines more than 1000 lbs: Biz Prescriptive</b>								
836	Jan 1, 2016		2000	per measure	0.1746	1286	per measure	12
<b>Energy Star Laptop: Biz Prescriptive</b>								
3066	Jan 1, 2016		0.51	per building	0.1035	750.40	per building	4
<b>Energy Star POS Terminal: Biz Prescriptive</b>								
3067	Jan 1, 2016		292.72	per building	0.3046	2,208.48	per building	4
<b>Energy Star Server: Biz Prescriptive</b>								
3068	Jan 1, 2016		0.04	per building	0.3472	2,516.82	per building	3

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>ENERGY STAR Steam Cookers 3 Pan - Electric: Biz Prescriptive</b>								
675	Jan 2, 2013		4150	per measure	2.2364	11188.0	per measure	12
<b>ENERGY STAR Steam Cookers 4 Pan - Electric: Biz Prescriptive</b>								
676	Jan 2, 2013		4150	per measure	2.4306	12159.2	per measure	12
<b>ENERGY STAR Steam Cookers 5 Pan - Electric: Biz Prescriptive</b>								
677	Jan 2, 2013		4150	per measure	2.6264	13138.9	per measure	12
<b>ENERGY STAR Steam Cookers 6 Pan - Electric: Biz Prescriptive</b>								
678	Jan 2, 2013		4150	per measure	3.0323	15169.4	per measure	12
<b>ENERGY STAR Vending Machine: Biz Prescriptive</b>								
846	Jan 1, 2016		140	per measure	0.1362	1003.35	per measure	10
<b>Garage HID replacement above 175W to 250W HID retrofit: College/University: Biz Prescriptive</b>								
738-1	Jan 1, 2017		500	per measure	0.0030	525.9	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Elementary School: Biz Prescriptive</b>								
738-10	Jan 1, 2017		500	per measure	0.0012	207.1	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Exterior: Biz Prescriptive</b>								
738-15	Jan 1, 2017		500	per measure	0.0021	374.5	per measure	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Garage HID replacement above 175W to 250W HID retrofit: Garage, 24/7 lighting: Biz Prescriptive</b>								
738-19	Jan 1, 2017		500	per measure	0.0042	749.0	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Garage: Biz Prescriptive</b>								
738-4	Jan 1, 2017		500	per measure	0.0017	302.7	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Grocery: Biz Prescriptive</b>								
738-5	Jan 1, 2017		500	per measure	0.0031	556.1	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Heavy Industry: Biz Prescriptive</b>								
738-11	Jan 1, 2017		500	per measure	0.0030	525.7	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: High School/Middle School: Biz Prescriptive</b>								
738-12	Jan 1, 2017		500	per measure	0.0021	368.6	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Hospital: Biz Prescriptive</b>								
738-6	Jan 1, 2017		500	per measure	0.0025	449.3	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Hotel/Motel Common Areas: Biz Prescriptive</b>								
738-7	Jan 1, 2017		500	per measure	0.0037	661.0	per measure	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Garage HID replacement above 175W to 250W HID retrofit: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
738-13	Jan 1, 2017		500	per measure	.0004	66.4	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Light Industry: Biz Prescriptive</b>								
738-9	Jan 1, 2017		500	per measure	0.0028	495.8	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Miscellaneous: Biz Prescriptive</b>								
738-14	Jan 1, 2017		500	per measure	0.0027	473.9	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Multifamily Common Areas: Biz Prescriptive</b>								
738-16	Jan 1, 2017		500	per measure	0.0029	508.7	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Office: Biz Prescriptive</b>								
738-8	Jan 1, 2017		500	per measure	0.0022	398.1	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Religious Worship/Church: Biz Prescriptive</b>								
738-18	Jan 1, 2017		500	per measure	0.0008	142.3	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Restaurant: Biz Prescriptive</b>								
738-3	Jan 1, 2017		500	per measure	0.0028	491.4	per measure	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Garage HID replacement above 175W to 250W HID retrofit: Retail/Service: Biz Prescriptive</b>								
738-2	Jan 1, 2017		500	per measure	0.0024	432.1	per measure	12
<b>Garage HID replacement above 175W to 250W HID retrofit: Warehouse: Biz Prescriptive</b>								
738-20	Jan 1, 2017		500	per measure	0.0024	431.5	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: College/University: Biz Prescriptive</b>								
739-1	Jan 1, 2017		800	per measure	0.0074	1326.2	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Elementary School: Biz Prescriptive</b>								
739-10	Jan 1, 2017		800	per measure	0.0029	522.2	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Exterior: Biz Prescriptive</b>								
739-15	Jan 1, 2017		800	per measure	0.0053	944.3	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Garage, 24/7 lighting: Biz Prescriptive</b>								
739-19	Jan 1, 2017		800	per measure	0.0106	1888.6	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Garage: Biz Prescriptive</b>								
739-4	Jan 1, 2017		800	per measure	0.0043	763.2	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Grocery: Biz Prescriptive</b>								
739-5	Jan 1, 2017		800	per measure	0.0079	1402.2	per measure	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Garage HID replacement above 250W to 400W HID retrofit: Heavy Industry: Biz Prescriptive</b>								
739-11	Jan 1, 2017		800	per measure	0.0074	1325.5	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: High School/Middle School: Biz Prescriptive</b>								
739-12	Jan 1, 2017		800	per measure	0.0052	929.4	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Hospital: Biz Prescriptive</b>								
739-6	Jan 1, 2017		800	per measure	0.0064	1132.9	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Hotel/Motel Common Areas: Biz Prescriptive</b>								
739-7	Jan 1, 2017		800	per measure	0.0094	1666.7	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
739-13	Jan 1, 2017		800	per measure	0.0009	167.5	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Light Industry: Biz Prescriptive</b>								
739-9	Jan 1, 2017		800	per measure	0.0070	1250.1	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Miscellaneous: Biz Prescriptive</b>								
739-14	Jan 1, 2017		800	per measure	0.0067	1194.9	per measure	12



Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Garage HID replacement above 250W to 400W HID retrofit: Multifamily Common Areas: Biz Prescriptive</b>								
739-16	Jan 1, 2017		800	per measure	0.0072	1282.8	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Office: Biz Prescriptive</b>								
739-8	Jan 1, 2017		800	per measure	0.0056	1003.8	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Religious Worship/Church: Biz Prescriptive</b>								
739-18	Jan 1, 2017		800	per measure	0.0020	358.7	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Restaurant: Biz Prescriptive</b>								
739-3	Jan 1, 2017		800	per measure	0.0070	1239.1	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Retail/Service: Biz Prescriptive</b>								
739-2	Jan 1, 2017		800	per measure	0.0061	1089.6	per measure	12
<b>Garage HID replacement above 250W to 400W HID retrofit: Warehouse: Biz Prescriptive</b>								
739-20	Jan 1, 2017		800	per measure	0.0061	1088.1	per measure	12
<b>Garage HID replacement to 175W HID retrofit: Biz Prescriptive</b>								
3075	Jan 1, 2016		400	per measure	0.1161	611.0	per measure	12
<b>GSHP under 135,000 17EER: Biz Prescriptive</b>								
686	Jan 2, 2013		180	per ton	0.1066	240.1	per ton	15

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>GSHP under 135,000 19EER: Biz Prescriptive</b>								
687	Jan 2, 2013		180	per ton	0.1356	305.4	per ton	15
<b>High Bay 3L T5HO Replacing 250W HID: College/University: Biz Prescriptive</b>								
757-1	Jan 1, 2016		180	per fixture	0.1356	713.6	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Elementary School: Biz Prescriptive</b>								
757-10	Jan 1, 2016		180	per fixture	0.0534	281.0	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Exterior: Biz Prescriptive</b>								
757-15	Jan 1, 2016		180	per fixture	0.0965	508.1	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Garage, 24/7 lighting: Biz Prescriptive</b>								
757-19	Jan 1, 2016		180	per fixture	0.193	1016.2	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Garage: Biz Prescriptive</b>								
757-4	Jan 1, 2016		180	per fixture	0.078	410.6	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Grocery: Biz Prescriptive</b>								
757-5	Jan 1, 2016		180	per fixture	0.1433	754.5	per fixture	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay 3L T5HO Replacing 250W HID: Heavy Industry: Biz Prescriptive</b>								
757-11	Jan 1, 2016		180	per fixture	0.1355	713.2	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: High School/Middle School: Biz Prescriptive</b>								
757-12	Jan 1, 2016		180	per fixture	0.095	500.1	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Hospital: Biz Prescriptive</b>								
757-6	Jan 1, 2016		180	per fixture	0.1158	609.6	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Hotel/Motel Common Areas: Biz Prescriptive</b>								
757-7	Jan 1, 2016		180	per fixture	0.1704	896.8	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
757-13	Jan 1, 2016		180	per fixture	0.0171	90.1	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Light Industry: Biz Prescriptive</b>								
757-9	Jan 1, 2016		180	per fixture	0.1278	672.6	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Miscellaneous: Biz Prescriptive</b>								
757-14	Jan 1, 2016		180	per fixture	0.1221	642.9	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Multifamily Common Areas: Biz Prescriptive</b>								
757-16	Jan 1, 2016		180	per fixture	0.1311	690.2	per fixture	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay 3L T5HO Replacing 250W HID: Office: Biz Prescriptive</b>								
757-8	Jan 1, 2016		180	per fixture	0.1026	540.1	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Religious Worship/Church: Biz Prescriptive</b>								
757-18	Jan 1, 2016		180	per fixture	0.0367	193.0	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Restaurant: Biz Prescriptive</b>								
757-3	Jan 1, 2016		180	per fixture	0.1266	666.7	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Retail/Service: Biz Prescriptive</b>								
757-2	Jan 1, 2016		180	per fixture	0.1114	586.3	per fixture	12
<b>High Bay 3L T5HO Replacing 250W HID: Warehouse: Biz Prescriptive</b>								
757-20	Jan 1, 2016		180	per fixture	0.1112	585.4	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: College/University: Biz Prescriptive</b>								
758-1	Jan 1, 2016		700	per fixture	0.409	2153.0	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Elementary School: Biz Prescriptive</b>								
758-10	Jan 1, 2016		700	per fixture	0.161	847.7	per fixture	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Exterior: Biz Prescriptive</b>								
758-15	Jan 1, 2016		700	per fixture	0.2912	1533.0	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Garage, 24/7 lighting: Biz Prescriptive</b>								
758-19	Jan 1, 2016		700	per fixture	0.5824	3066.0	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Garage: Biz Prescriptive</b>								
758-4	Jan 1, 2016		700	per fixture	0.2354	1239.0	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Grocery: Biz Prescriptive</b>								
758-5	Jan 1, 2016		700	per fixture	0.4325	2276.5	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Heavy Industry: Biz Prescriptive</b>								
758-11	Jan 1, 2016		700	per fixture	0.4088	2151.8	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: High School/Middle School: Biz Prescriptive</b>								
758-12	Jan 1, 2016		700	per fixture	0.2866	1508.9	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Hospital: Biz Prescriptive</b>								
758-6	Jan 1, 2016		700	per fixture	0.3494	1839.2	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Hotel/Motel Common Areas: Biz Prescriptive</b>								
758-7	Jan 1, 2016		700	per fixture	0.514	2705.8	per fixture	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
758-13	Jan 1, 2016		700	per fixture	0.0517	272.0	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Light Industry: Biz Prescriptive</b>								
758-9	Jan 1, 2016		700	per fixture	0.3855	2029.4	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Miscellaneous: Biz Prescriptive</b>								
758-14	Jan 1, 2016		700	per fixture	0.3685	1939.8	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Multifamily Common Areas: Biz Prescriptive</b>								
758-16	Jan 1, 2016		700	per fixture	0.3956	2082.5	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Office: Biz Prescriptive</b>								
758-8	Jan 1, 2016		700	per fixture	0.3096	1629.6	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Religious Worship/Church: Biz Prescriptive</b>								
758-18	Jan 1, 2016		700	per fixture	0.1106	582.4	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Restaurant: Biz Prescriptive</b>								
758-3	Jan 1, 2016		700	per fixture	0.3821	2011.6	per fixture	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Retail/Service: Biz Prescriptive</b>								
758-2	Jan 1, 2016		700	per fixture	0.336	1768.9	per fixture	12
<b>High Bay 6L T5HO Double fixture replace 1000W HID: Warehouse: Biz Prescriptive</b>								
758-20	Jan 1, 2016		700	per fixture	0.3356	1766.4	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: College/University: Biz Prescriptive</b>								
759-1	Jan 1, 2016		160	per fixture	0.2248	1183.5	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Elementary School: Biz Prescriptive</b>								
759-10	Jan 1, 2016		160	per fixture	0.0885	466.0	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Exterior: Biz Prescriptive</b>								
759-15	Jan 1, 2016		160	per fixture	0.1601	842.7	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Garage, 24/7 lighting: Biz Prescriptive</b>								
759-19	Jan 1, 2016		160	per fixture	0.3201	1685.3	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Garage: Biz Prescriptive</b>								
759-4	Jan 1, 2016		160	per fixture	0.1294	681.1	per fixture	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Grocery: Biz Prescriptive</b>								
759-5	Jan 1, 2016		160	per fixture	0.2377	1251.3	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Heavy Industry: Biz Prescriptive</b>								
759-11	Jan 1, 2016		160	per fixture	0.2247	1182.8	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: High School/Middle School: Biz Prescriptive</b>								
759-12	Jan 1, 2016		160	per fixture	0.1576	829.4	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Hospital: Biz Prescriptive</b>								
759-6	Jan 1, 2016		160	per fixture	0.1921	1011.0	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Hotel/Motel Common Areas: Biz Prescriptive</b>								
759-7	Jan 1, 2016		160	per fixture	0.2825	1487.3	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
759-13	Jan 1, 2016		160	per fixture	0.0284	149.5	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Light Industry: Biz Prescriptive</b>								
759-9	Jan 1, 2016		160	per fixture	0.2119	1115.5	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Miscellaneous: Biz Prescriptive</b>								
759-14	Jan 1, 2016		160	per fixture	0.2026	1066.3	per fixture	12



Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Multifamily Common Areas: Biz Prescriptive</b>								
759-16	Jan 1, 2016		160	per fixture	0.2175	1144.7	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Office: Biz Prescriptive</b>								
759-8	Jan 1, 2016		160	per fixture	0.1702	895.8	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Religious Worship/Church: Biz Prescriptive</b>								
759-18	Jan 1, 2016		160	per fixture	0.0608	320.1	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Restaurant: Biz Prescriptive</b>								
759-3	Jan 1, 2016		160	per fixture	0.2101	1105.8	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Retail/Service: Biz Prescriptive</b>								
759-2	Jan 1, 2016		160	per fixture	0.1847	972.3	per fixture	12
<b>High Bay Fluorescent 4LF32T8 Replacing 250W HID: Warehouse: Biz Prescriptive</b>								
759-20	Jan 1, 2016		160	per fixture	0.1845	971.0	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: College/University: Biz Prescriptive</b>								
760-1	Jan 1, 2016		160	per fixture	0.2884	1518.3	per fixture	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Elementary School: Biz Prescriptive</b>								
760-10	Jan 1, 2016		160	per fixture	0.1136	597.8	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Exterior: Biz Prescriptive</b>								
760-15	Jan 1, 2016		160	per fixture	0.2054	1081.1	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Garage, 24/7 lighting: Biz Prescriptive</b>								
760-19	Jan 1, 2016		160	per fixture	0.4107	2162.2	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Garage: Biz Prescriptive</b>								
760-4	Jan 1, 2016		160	per fixture	0.166	873.8	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Grocery: Biz Prescriptive</b>								
760-5	Jan 1, 2016		160	per fixture	0.305	1605.4	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Heavy Industry: Biz Prescriptive</b>								
760-11	Jan 1, 2016		160	per fixture	0.2883	1517.5	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: High School/Middle School: Biz Prescriptive</b>								
760-12	Jan 1, 2016		160	per fixture	0.2021	1064.1	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Hospital: Biz Prescriptive</b>								
760-6	Jan 1, 2016		160	per fixture	0.2464	1297.0	per fixture	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Hotel/Motel Common Areas: Biz Prescriptive</b>								
760-7	Jan 1, 2016		160	per fixture	0.3625	1908.1	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
760-13	Jan 1, 2016		160	per fixture	0.0364	191.8	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Light Industry: Biz Prescriptive</b>								
760-9	Jan 1, 2016		160	per fixture	0.2719	1431.2	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Miscellaneous: Biz Prescriptive</b>								
760-14	Jan 1, 2016		160	per fixture	0.2599	1368.0	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Multifamily Common Areas: Biz Prescriptive</b>								
760-16	Jan 1, 2016		160	per fixture	0.279	1468.6	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Office: Biz Prescriptive</b>								
760-8	Jan 1, 2016		160	per fixture	0.2183	1149.2	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Religious Worship/Church: Biz Prescriptive</b>								
760-18	Jan 1, 2016		160	per fixture	0.078	410.7	per fixture	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Restaurant: Biz Prescriptive</b>								
760-3	Jan 1, 2016		160	per fixture	0.2695	1418.6	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Retail/Service: Biz Prescriptive</b>								
760-2	Jan 1, 2016		160	per fixture	0.237	1247.4	per fixture	12
<b>High Bay Fluorescent 6LF32T8 Replacing 400W HID: Warehouse: Biz Prescriptive</b>								
760-20	Jan 1, 2016		160	per fixture	0.2366	1245.7	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: College/University: Biz Prescriptive</b>								
761-1	Jan 1, 2016		400	per fixture	0.5632	2965.0	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Elementary School: Biz Prescriptive</b>								
761-10	Jan 1, 2016		400	per fixture	0.2218	1167.4	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Exterior: Biz Prescriptive</b>								
761-15	Jan 1, 2016		400	per fixture	0.4011	2111.2	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Garage, 24/7 lighting: Biz Prescriptive</b>								
761-19	Jan 1, 2016		400	per fixture	0.8021	4222.3	per fixture	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Garage: Biz Prescriptive</b>								
761-4	Jan 1, 2016		400	per fixture	0.3241	1706.3	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Grocery: Biz Prescriptive</b>								
761-5	Jan 1, 2016		400	per fixture	0.5955	3135.0	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Heavy Industry: Biz Prescriptive</b>								
761-11	Jan 1, 2016		400	per fixture	0.5629	2963.3	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: High School/Middle School: Biz Prescriptive</b>								
761-12	Jan 1, 2016		400	per fixture	0.3947	2077.9	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Hospital: Biz Prescriptive</b>								
761-6	Jan 1, 2016		400	per fixture	0.4811	2532.8	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Hotel/Motel Common Areas: Biz Prescriptive</b>								
761-7	Jan 1, 2016		400	per fixture	0.7078	3726.2	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
761-13	Jan 1, 2016		400	per fixture	0.0711	374.5	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Light Industry: Biz Prescriptive</b>								
761-9	Jan 1, 2016		400	per fixture	0.5309	2794.8	per fixture	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Miscellaneous: Biz Prescriptive</b>								
761-14	Jan 1, 2016		400	per fixture	0.5075	2671.4	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Multifamily Common Areas: Biz Prescriptive</b>								
761-16	Jan 1, 2016		400	per fixture	0.5448	2867.9	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Office: Biz Prescriptive</b>								
761-8	Jan 1, 2016		400	per fixture	0.4263	2244.2	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Religious Worship/Church: Biz Prescriptive</b>								
761-18	Jan 1, 2016		400	per fixture	0.1524	802.0	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Restaurant: Biz Prescriptive</b>								
761-3	Jan 1, 2016		400	per fixture	0.5263	2770.3	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Retail/Service: Biz Prescriptive</b>								
761-2	Jan 1, 2016		400	per fixture	0.4628	2436.0	per fixture	12
<b>High Bay Fluorescent 8LF32T8 Double fixture replace 1000W HID: Warehouse: Biz Prescriptive</b>								
761-20	Jan 1, 2016		400	per fixture	0.4621	2432.6	per fixture	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: College/University: Biz Prescriptive</b>								
762-1	Jan 1, 2017		414	per fixture	0.1871	984.9	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Elementary School: Biz Prescriptive</b>								
762-10	Jan 1, 2017		414	per fixture	0.0737	387.8	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Exterior: Biz Prescriptive</b>								
762-15	Jan 1, 2017		414	per fixture	0.1332	701.3	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Garage, 24/7 lighting: Biz Prescriptive</b>								
762-19	Jan 1, 2017		414	per fixture	0.2664	1402.5	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Garage: Biz Prescriptive</b>								
762-4	Jan 1, 2017		414	per fixture	0.1077	566.8	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Grocery: Biz Prescriptive</b>								
762-5	Jan 1, 2017		414	per fixture	0.1978	1041.4	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Heavy Industry: Biz Prescriptive</b>								
762-11	Jan 1, 2017		414	per fixture	0.1870	984.3	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: High School/Middle School: Biz Prescriptive</b>								
762-12	Jan 1, 2017		414	per fixture	0.1311	690.2	per fixture	11

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Hospital: Biz Prescriptive</b>								
762-6	Jan 1, 2017		414	per fixture	0.1598	841.3	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Hotel/Motel Common Areas: Biz Prescriptive</b>								
762-7	Jan 1, 2017		414	per fixture	0.2351	1237.7	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
762-13	Jan 1, 2017		414	per fixture	0.0236	124.4	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Light Industry: Biz Prescriptive</b>								
762-9	Jan 1, 2017		414	per fixture	0.1763	928.3	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Miscellaneous: Biz Prescriptive</b>								
762-14	Jan 1, 2017		414	per fixture	0.1686	887.4	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Multifamily Common Areas: Biz Prescriptive</b>								
762-16	Jan 1, 2017		414	per fixture	0.1810	952.6	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Office: Biz Prescriptive</b>								
762-8	Jan 1, 2017		414	per fixture	0.1416	745.5	per fixture	11



Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Religious Worship/Church: Biz Prescriptive</b>								
762-18	Jan 1, 2017		414	per fixture	0.0506	266.4	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Restaurant: Biz Prescriptive</b>								
762-3	Jan 1, 2017		414	per fixture	0.1748	920.2	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Retail/Service: Biz Prescriptive</b>								
762-2	Jan 1, 2017		414	per fixture	0.1537	809.2	per fixture	11
<b>High Bay Fluorescent 8LF32T8 Replacing 400W HID: Warehouse: Biz Prescriptive</b>								
762-20	Jan 1, 2017		414	per fixture	0.1535	808.0	per fixture	11
<b>HP 135,000 - 240,000: Biz Prescriptive</b>								
683	Jan 2, 2013		125	per ton	0.0635	143.0	per ton	15
<b>HP over 240,000: Biz Prescriptive</b>								
684	Jan 2, 2013		130	per ton	0.0777	175.1	per ton	15
<b>HP under 65,000 1 Ph: Biz Prescriptive</b>								
685	Jan 2, 2013		73.5	per ton	0.0507	114.1	per ton	15

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>HP Water Heater 100 to 300 MBH: Biz Prescriptive</b>								
851	Jan 2, 2013		25000	per measure	25.5502	141041.0	per measure	15
<b>HP Water Heater 10 to 50 MBH: Biz Prescriptive</b>								
850	Jan 2, 2013		6000	per measure	3.8325	21156.0	per measure	15
<b>HP Water Heater 300 to 500 MBH: Biz Prescriptive</b>								
852	Jan 2, 2013		42000	per measure	51.1002	282081.0	per measure	15
<b>HP Water Heater 50 to 100 MBH: Biz Prescriptive</b>								
853	Jan 2, 2013		14000	per measure	9.5813	52890.0	per measure	15
<b>HP Water Heater above 500 MBH: Biz Prescriptive</b>								
854	Jan 2, 2013		63000	per measure	76.6505	423122.0	per measure	15
<b>HVAC - Occupancy Sensors: Biz Prescriptive</b>								
3058	Jan 1, 2016		6002	per building	5.7347	12916.48	per building	8
<b>Induction Street Lighting: Biz Prescriptive</b>								
3003	Jan 1, 2016		0	per fixture	0.0011	192	per fixture	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Interior Ceiling (6 fixtures controlled): Biz Prescriptive</b>								
3062	Jan 1, 2016		161	per measure	0.1804	949.8	per measure	11
<b>Interior High-Bay T5 (3 fix. Controlled): Biz Prescriptive</b>								
3063	Jan 1, 2016		25	per measure	0.0361	190.2	per measure	15
<b>Interior Wall (3 fixtures controlled): College/University: Biz Prescriptive</b>								
779-1	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Elementary School: Biz Prescriptive</b>								
779-10	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Exterior: Biz Prescriptive</b>								
779-15	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Garage, 24/7 lighting: Biz Prescriptive</b>								
779-19	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Garage: Biz Prescriptive</b>								
779-4	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Grocery: Biz Prescriptive</b>								
779-5	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Interior Wall (3 fixtures controlled): Heavy Industry: Biz Prescriptive</b>								
779-11	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): High School/Middle School: Biz Prescriptive</b>								
779-12	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Hospital: Biz Prescriptive</b>								
779-6	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Hotel/Motel Common Areas: Biz Prescriptive</b>								
779-7	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
779-13	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Light Industry: Biz Prescriptive</b>								
779-9	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Miscellaneous: Biz Prescriptive</b>								
779-14	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Interior Wall (3 fixtures controlled): Multifamily Common Areas: Biz Prescriptive</b>								
779-16	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Office: Biz Prescriptive</b>								
779-8	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Religious Worship/Church: Biz Prescriptive</b>								
779-18	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Restaurant: Biz Prescriptive</b>								
779-3	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Retail/Service: Biz Prescriptive</b>								
779-2	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>Interior Wall (3 fixtures controlled): Warehouse: Biz Prescriptive</b>								
779-20	Jan 2, 2013		91	per 3 fixtures	0.060	620.9	per 3 fixtures	11
<b>LED (BAR/R) Reflector Lamp EISA Compliant: Biz Prescriptive</b>								
3007	Jan 1, 2017		48.27		0.0344	181.3	per lamp	9

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>LED (BAR/R) Reflector Lamp EISA Exempt: Biz Prescriptive</b>								
3007-1	Jan 1, 2017		48.27		0.0467	246.0	per lamp	9
<b>LED (PAR) Reflector Lamp: Biz Prescriptive</b>								
3008	Jan 1, 2017		74.64		0.0398	209.5	per lamp	9
<b>LED 100 Watt Lamp (12 hrs/day): Biz Prescriptive</b>								
3004-1	Jan 1, 2017		233.64		0.0052	924.2	per lamp	12
<b>LED 100 Watt Lamp (24 hrs/day): Biz Prescriptive</b>								
3004-2	Jan 1, 2017		233.64		0.0104	1848.4	per lamp	9
<b>LED 120 Watt Lamp (12 hrs/day): Biz Prescriptive</b>								
3005-1	Jan 1, 2017		361.64		0.2147	1130.0	per lamp	12
<b>LED 120 Watt Lamp (24 hrs/day): Biz Prescriptive</b>								
3005-2	Jan 1, 2017		361.64		0.0127	2260.1	per lamp	9
<b>LED 12-20 Watt A-Line Lamp: Biz Prescriptive</b>								
3009	Jan 1, 2016		19.64		0.0283	148.8	per lamp	9
<b>LED 1-8 Watt Decorative Lamp: Biz Prescriptive</b>								
3010	Jan 1, 2017		22.64		0.0454	239.1	per lamp	5

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>LED 5-11 Watt A-Line Lamp: Biz Prescriptive</b>								
3011	Jan 1, 2016		15.64		0.0161	85.0	per lamp	9
<b>LED 52 Watt Lamp (12 hrs/day): Biz Prescriptive</b>								
3006-1	Jan 1, 2016		191.39		0.003	538.7	per lamp	12
<b>LED 52 Watt Lamp (24 hrs/day): Biz Prescriptive</b>								
3006-2	Jan 1, 2016		191.39		0.0061	1077.5	per lamp	9
<b>LED Exit Sign - 3_0 W_CF 18 base</b>								
8001	Jan 1, 2016		91.68	per fixture	0.0425	223.8	per fixture	16
<b>LED Exit Sign - 3_0 W_CF 9 base</b>								
8000	Jan 1, 2016		45.45	per fixture	0.0462	243.1	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: College/University: Biz Prescriptive</b>								
793-1	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Elementary School: Biz Prescriptive</b>								
793-10	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>LED Exit Sign - 3_0 W_Inc30 base: Exterior: Biz Prescriptive</b>								
793-15	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Garage, 24/7 lighting: Biz Prescriptive</b>								
793-19	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Garage: Biz Prescriptive</b>								
793-4	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Grocery: Biz Prescriptive</b>								
793-5	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Heavy Industry: Biz Prescriptive</b>								
793-11	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: High School/Middle School: Biz Prescriptive</b>								
793-12	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Hospital: Biz Prescriptive</b>								
793-6	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Hotel/Motel Common Areas: Biz Prescriptive</b>								
793-7	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16



Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>LED Exit Sign - 3_0 W_Inc30 base: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
793-13	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Light Industry: Biz Prescriptive</b>								
793-9	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Miscellaneous: Biz Prescriptive</b>								
793-14	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Multifamily Common Areas: Biz Prescriptive</b>								
793-16	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Office: Biz Prescriptive</b>								
793-8	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Religious Worship/Church: Biz Prescriptive</b>								
793-18	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Restaurant: Biz Prescriptive</b>								
793-3	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>LED Exit Sign - 3_0 W_Inc30 base: Retail/Service: Biz Prescriptive</b>								
793-2	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED Exit Sign - 3_0 W_Inc30 base: Warehouse: Biz Prescriptive</b>								
793-20	Jan 1, 2016		63	per fixture	0.0425	223.81	per fixture	16
<b>LED MR16 (12 Watt) Lamp: Biz Prescriptive</b>								
3012	Jan 1, 2016		39.64		0.0329	173.1	per lamp	9
<b>LED MR16 (8 Watt) Lamp: Biz Prescriptive</b>								
3013	Jan 1, 2017		36.64		0.0580	305.2	per lamp	9
<b>Lighted Snack Dispensing Machine: Biz Prescriptive</b>								
847	Jan 1, 2016		47	per measure	0.0445	328	per measure	4
<b>Linear Tube LED 4ft Efficient Lamp Upgrade - 25W T8 Base: Biz Prescriptive</b>								
3023	Jan 1, 2016		29.64		0.0063	33.4	per lamp	17
<b>Linear Tube LED 4ft Efficient Lamp Upgrade - 28W T8 Base</b>								
3024	Jan 1, 2016		29.64		0.0081	42.5	per lamp	17
<b>Linear Tube LED 4ft Efficient Lamp Upgrade - 32W T8 Base: Biz Prescriptive</b>								
3025	Jan 1, 2017		29.64		0.0104	54.7	per lamp	17

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Linear Tube LED 4ft Efficient Lamp Upgrade - T12 Base: Biz Prescriptive</b>								
3026	Jan 1, 2017		29.64		0.0104	54.7	per lamp	17
<b>Linear Tube T8 4ft Efficient Lamp Upgrade - T12 Base: Biz Prescriptive</b>								
3019	Jan 1, 2016		10.49		0.0035	18.2	per lamp	10
<b>Linear Tube T8 4ft Efficient Lamp Upgrade - T8 Base: Biz Prescriptive</b>								
3020			10.49		0.0035	18.2	per lamp	10
<b>Linear Tube T8 4ft High Efficient Lamp Upgrade - T12 Base: Biz Prescriptive</b>								
3021	Jan 1, 2016		11.69		0.0061	31.9	per lamp	12
<b>Linear Tube T8 4ft High Efficient Lamp Upgrade - T8 Base: Biz Prescriptive</b>								
3022	Jan 1, 2016		11.69		0.0061	31.9	per lamp	12
<b>Low Flow Faucet Aerator - Electric water heater: Biz Prescriptive</b>								
848	Jan 2, 2013		31.10	per building	0.0315	173.9	per building	9
<b>Low Flow Showerhead_MF: Biz Prescriptive</b>								
3074	Jan 1, 2016		42.00	per measure	0.0380	210.00	per measure	12

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>LW HPT8 4 ft 1 lamp: Biz Prescriptive</b>								
3081	Jan 1, 2016		25.29	per measure	0.0055	29.00	per measure	12
<b>LW HPT8 4 ft 2 lamp: Biz Prescriptive</b>								
3082	Jan 1, 2016		30.49	per measure	0.0091	48.00	per measure	12
<b>LW HPT8 4 ft 3 lamp: Biz Prescriptive</b>								
3083	Jan 1, 2016		31.56	per measure	0.0118	62.00	per measure	12
<b>LW HPT8 4 ft 4 lamp: Biz Prescriptive</b>								
3076	Jan 1, 2016		60.00	per measure	0.0175	92.00	per measure	12
<b>Occupancy Sensor (Dual Technology) - Controlling Lighting Circuit &gt; 150 watts</b>								
3016	Jan 1, 2016		128.08	per sensor	0.1463	770.4	per sensor	8
<b>Occupancy Sensor (Single Technology) - Controlling Lighting Circuit &gt; 120 watts</b>								
3079	Jan 1, 2016		119.56	per sensor	0.0874	460.0	per sensor	11
<b>Occupancy Sensor (Single Technology) - Controlling Lighting Circuit GT 50 watts and LTEQ 120 Watts</b>								
3080	Jan 1, 2016		42.35	per sensor	0.0237	125.0	per sensor	11
<b>Occupancy Sensor - Controlling Fixture GT 200 watts and LTEQ 500 watts</b>								
3077	Jan 1, 2016		116.33	per sensor	0.0570	300.0	per sensor	10

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Occupancy Sensors over 500 W: College/University: Biz Prescriptive</b>								
786-1	Jan 1, 2016		311	per 750 square feet	0.3155	1660.9	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Elementary School: Biz Prescriptive</b>								
786-10	Jan 1, 2016		311	per 750 square feet	0.1242	653.9	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Exterior: Biz Prescriptive</b>								
786-15	Jan 1, 2016		311	per 750 square feet	0.2247	1182.6	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Garage, 24/7 lighting: Biz Prescriptive</b>								
786-19	Jan 1, 2016		311	per 750 square feet	0.4493	2365.2	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Garage: Biz Prescriptive</b>								
786-4	Jan 1, 2016		311	per 750 square feet	0.1816	955.8	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Grocery: Biz Prescriptive</b>								
786-5	Jan 1, 2016		311	per 750 square feet	0.3336	1756.1	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Heavy Industry: Biz Prescriptive</b>								
786-11	Jan 1, 2016		311	per 750 square feet	0.3153	1660.0	per 750 square feet	10

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Occupancy Sensors over 500 W: High School/Middle School: Biz Prescriptive</b>								
786-12	Jan 1, 2016		311	per 750 square feet	0.2211	1164.0	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Hospital: Biz Prescriptive</b>								
786-6	Jan 1, 2016		311	per 750 square feet	0.2695	1418.8	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Hotel/Motel Common Areas: Biz Prescriptive</b>								
786-7	Jan 1, 2016		311	per 750 square feet	0.3965	2087.3	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
786-13	Jan 1, 2016		311	per 750 square feet	0.0399	209.8	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Light Industry: Biz Prescriptive</b>								
786-9	Jan 1, 2016		311	per 750 square feet	0.2974	1565.6	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Miscellaneous: Biz Prescriptive</b>								
786-14	Jan 1, 2016		311	per 750 square feet	0.2843	1496.4	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Multifamily Common Areas: Biz Prescriptive</b>								
786-16	Jan 1, 2016		311	per 750 square feet	0.3052	1606.5	per 750 square feet	10

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Occupancy Sensors over 500 W: Office: Biz Prescriptive</b>								
786-8	Jan 1, 2016		311	per 750 square feet	0.2388	1257.1	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Religious Worship/Church: Biz Prescriptive</b>								
786-18	Jan 1, 2016		311	per 750 square feet	0.0854	449.3	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Restaurant: Biz Prescriptive</b>								
786-3	Jan 1, 2016		311	per 750 square feet	0.2948	1551.8	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Retail/Service: Biz Prescriptive</b>								
786-2	Jan 1, 2016		311	per 750 square feet	0.2592	1364.6	per 750 square feet	10
<b>Occupancy Sensors over 500 W: Warehouse: Biz Prescriptive</b>								
786-20	Jan 1, 2016		311	per 750 square feet	0.2589	1362.7	per 750 square feet	10
<b>Occupancy Sensors under 500 W: College/University: Biz Prescriptive</b>								
787-1	Jan 1, 2016		144	per 300 square feet	0.1262	664.4	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Elementary School: Biz Prescriptive</b>								
787-10	Jan 1, 2016		144	per 300 square feet	0.0497	261.6	per 300 square feet	10

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Occupancy Sensors under 500 W: Exterior: Biz Prescriptive</b>								
787-15	Jan 1, 2016		144	per 300 square feet	0.0899	473.0	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Garage, 24/7 lighting: Biz Prescriptive</b>								
787-19	Jan 1, 2016		144	per 300 square feet	0.1797	946.1	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Garage: Biz Prescriptive</b>								
787-4	Jan 1, 2016		144	per 300 square feet	0.0726	382.3	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Grocery: Biz Prescriptive</b>								
787-5	Jan 1, 2016		144	per 300 square feet	0.1334	702.4	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Heavy Industry: Biz Prescriptive</b>								
787-11	Jan 1, 2016		144	per 300 square feet	0.1261	664.0	per 300 square feet	10
<b>Occupancy Sensors under 500 W: High School/Middle School: Biz Prescriptive</b>								
787-12	Jan 1, 2016		144	per 300 square feet	0.0884	465.6	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Hospital: Biz Prescriptive</b>								
787-6	Jan 1, 2016		144	per 300 square feet	0.1078	567.5	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Hotel/Motel Common Areas: Biz Prescriptive</b>								
787-7	Jan 1, 2016		144	per 300 square feet	0.1586	834.9	per 300 square feet	10



Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Occupancy Sensors under 500 W: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
787-13	Jan 1, 2016		144	per 300 square feet	0.0159	83.9	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Light Industry: Biz Prescriptive</b>								
787-9	Jan 1, 2016		144	per 300 square feet	0.119	626.2	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Miscellaneous: Biz Prescriptive</b>								
787-14	Jan 1, 2016		144	per 300 square feet	0.1137	598.6	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Multifamily Common Areas: Biz Prescriptive</b>								
787-16	Jan 1, 2016		144	per 300 square feet	0.1221	642.6	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Office: Biz Prescriptive</b>								
787-8	Jan 1, 2016		144	per 300 square feet	0.0955	502.8	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Religious Worship/Church: Biz Prescriptive</b>								
787-18	Jan 1, 2016		144	per 300 square feet	0.0341	179.7	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Restaurant: Biz Prescriptive</b>								
787-3	Jan 1, 2016		144	per 300 square feet	0.1179	620.7	per 300 square feet	10

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Occupancy Sensors under 500 W: Retail/Service: Biz Prescriptive</b>								
787-2	Jan 1, 2016		144	per 300 square feet	0.1037	545.8	per 300 square feet	10
<b>Occupancy Sensors under 500 W: Warehouse: Biz Prescriptive</b>								
787-20	Jan 1, 2016		144	per 300 square feet	0.1035	545.1	per 300 square feet	10
<b>Office Electronics - Monitor, Max Efficiency: Biz Prescriptive</b>								
3064	Jan 1, 2016		136.99	per measure	0.1894	1,372.98	per measure	4
<b>Office Equipment - Plug Load Occupancy Sensors: Biz Prescriptive</b>								
3069	Jan 1, 2016		256.82	per building	0.9260	6,712.97	per building	5
<b>Passive Infrared or Ultrasonic_2: College/University: Biz Prescriptive</b>								
781-1	Jan 2, 2013		92	per measure	0.023	616.3		11
<b>Passive Infrared or Ultrasonic_2: Elementary School: Biz Prescriptive</b>								
781-10	Jan 2, 2013		92	per measure	0.023	616.3		11
<b>Passive Infrared or Ultrasonic_2: Exterior: Biz Prescriptive</b>								
781-15	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic_2: Garage, 24/7 lighting: Biz Prescriptive</b>								
781-19	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Passive Infrared or Ultrasonic_2: Garage: Biz Prescriptive</b>								
781-4	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic_2: Grocery: Biz Prescriptive</b>								
781-5	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic_2: Heavy Industry: Biz Prescriptive</b>								
781-11	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic_2: High School/Middle School: Biz Prescriptive</b>								
781-12	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic_2: Hospital: Biz Prescriptive</b>								
781-6	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic_2: Hotel/Motel Common Areas: Biz Prescriptive</b>								
781-7	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic_2: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
781-13	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Passive Infrared or Ultrasonic_2: Light Industry: Biz Prescriptive</b>								
781-9	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic_2: Miscellaneous: Biz Prescriptive</b>								
781-14	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic_2: Multifamily Common Areas: Biz Prescriptive</b>								
781-16	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic_2: Office: Biz Prescriptive</b>								
781-8	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic_2: Religious Worship/Church: Biz Prescriptive</b>								
781-18	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic_2: Restaurant: Biz Prescriptive</b>								
781-3	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic_2: Retail/Service: Biz Prescriptive</b>								
781-2	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Passive Infrared or Ultrasonic_2: Warehouse: Biz Prescriptive</b>								
781-20	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: College/University: Biz Prescriptive</b>								
780-1	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Elementary School: Biz Prescriptive</b>								
780-10	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Exterior: Biz Prescriptive</b>								
780-15	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Garage, 24/7 lighting: Biz Prescriptive</b>								
780-19	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Garage: Biz Prescriptive</b>								
780-4	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Grocery: Biz Prescriptive</b>								
780-5	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Heavy Industry: Biz Prescriptive</b>								
780-11	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Passive Infrared or Ultrasonic: High School/Middle School: Biz Prescriptive</b>								
780-12	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Hospital: Biz Prescriptive</b>								
780-6	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Hotel/Motel Common Areas: Biz Prescriptive</b>								
780-7	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
780-13	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Light Industry: Biz Prescriptive</b>								
780-9	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Miscellaneous: Biz Prescriptive</b>								
780-14	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Multifamily Common Areas: Biz Prescriptive</b>								
780-16	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Passive Infrared or Ultrasonic: Office: Biz Prescriptive</b>								
780-8	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Religious Worship/Church: Biz Prescriptive</b>								
780-18	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Restaurant: Biz Prescriptive</b>								
780-3	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Retail/Service: Biz Prescriptive</b>								
780-2	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>Passive Infrared or Ultrasonic: Warehouse: Biz Prescriptive</b>								
780-20	Jan 2, 2013		92	per measure	0.023	616.3	per measure	11
<b>PC Power Management Software: Biz Prescriptive</b>								
1178	Jan 2, 2013		20	per unit	0.0276	200.0	per unit	4
<b>Pool Heater Heat Pump: Biz Prescriptive</b>								
3071	Jan 1, 2016		199.14	per measure	0.2497	1,810.39	per measure	15
<b>Pool Pump - Timer: Biz Prescriptive</b>								
3072	Jan 1, 2016		100	per measure	0.0830	601.89	per measure	10

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Pumps HP 10: Biz Prescriptive</b>								
2795	Jan 1, 2016		332	per measure	0.2778	2014	per measure	15
<b>Pre Rinse Sprayers - Electric water heater: Biz Prescriptive</b>								
849	Jan 2, 2013		85.8	per measure	1.0201	5631.1	per measure	5
<b>Pumps HP 15 (Eff increase 16.09): Biz Prescriptive</b>								
796	Jan 1, 2016		585	per measure	0.4167	3021	per measure	15
<b>Pumps HP 20: Biz Prescriptive</b>								
2797	Jan 1, 2016		850	per measure	0.5556	4028	per measure	15
<b>Pumps HP 3 (Eff increase 7.19): Biz Prescriptive</b>								
798	Jan 1, 2016		350	per measure	0.0833	604	per measure	15
<b>Pumps HP 5: Biz Prescriptive</b>								
2799	Jan 1, 2016		341	per measure	0.1389	1007	per measure	15
<b>Pumps HP 7.5: Biz Prescriptive</b>								
2794	Jan 1, 2016		498	per measure	0.2084	1511	per measure	15



Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Pumps HP 7.5 (Eff Increase: 6.05): Biz Prescriptive</b>								
1137	Jan 2, 2013		498	per measure	0.2372	1719.9	per measure	15
<b>Pumps HP 7.5 (Eff Increase: 7.48): Biz Prescriptive</b>								
800	Jan 2, 2013		498	per measure	0.2538	1840.2	per measure	15
<b>Refrigerated Display Case Lighting 5ft T8 to 5ft LED - cooler: Biz Prescriptive</b>								
3035	Jan 1, 2016		250		0.0416	219	per measure	8
<b>Refrigerated Display Case Lighting 5ft T8 to 5ft LED - freezer: Biz Prescriptive</b>								
3036	Jan 1, 2016		250		0.0448	236	per measure	8
<b>Refrigerated Display Case Lighting 6ft T8 to 6ft LED - cooler: Biz Prescriptive</b>								
3037	Jan 1, 2016		250		0.0498	262	per measure	8
<b>Refrigerated Display Case Lighting 6ft T8 to 6ft LED - freezer: Biz Prescriptive</b>								
3038	Jan 1, 2016		250		0.0538	283	per measure	8
<b>Refrigerator - Door Gasket Replacemen: Biz Prescriptivet</b>								
3073	Jan 1, 2016		2,653.75	per measure	3.2747	24,124.99	per measure	8

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Smart Thermostat: Biz Prescriptive</b>								
3085	June 1, 2017		224	per measure	0.1867	205	per measure	10
<b>Strip Curtain for Walk-in Cooler: Biz Prescriptive</b>								
845	Jan 1, 2016		286.16	per measure	0.0573	422	per measure	4
<b>Strip Curtain - Walk In Freezer: Biz Prescriptive</b>								
3034	Jan 1, 2016		286.16		4.0686	29974	per measure	6
<b>T5 High-Bay 4L-F54HO: College/University: Biz Prescriptive</b>								
1102-1	Jan 1, 2017		339	per fixture	0.2466	1298.0	per fixture	11
<b>T5 High-Bay 4L-F54HO: Elementary School: Biz Prescriptive</b>								
1102-10	Jan 1, 2017		339	per fixture	0.0971	511.0	per fixture	11
<b>T5 High-Bay 4L-F54HO: Exterior: Biz Prescriptive</b>								
1102-15	Jan 1, 2017		339	per fixture	0.1756	924.2	per fixture	11
<b>T5 High-Bay 4L-F54HO: Garage, 24/7 lighting: Biz Prescriptive</b>								
1102-4	Jan 1, 2017		339	per fixture	0.1419	746.9	per fixture	11

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>T5 High-Bay 4L-F54HO: Garage: Biz Prescriptive</b>								
1102-19	Jan 1, 2017		339	per fixture	0.3511	1848.4	per fixture	11
<b>T5 High-Bay 4L-F54HO: Grocery: Biz Prescriptive</b>								
1102-5	Jan 1, 2017		339	per fixture	0.2607	1372.4	per fixture	11
<b>T5 High-Bay 4L-F54HO: Heavy Industry: Biz Prescriptive</b>								
1102-11	Jan 1, 2017		339	per fixture	0.2464	1297.2	per fixture	11
<b>T5 High-Bay 4L-F54HO: High School/Middle School: Biz Prescriptive</b>								
1102-12	Jan 1, 2017		339	per fixture	0.1728	909.6	per fixture	11
<b>T5 High-Bay 4L-F54HO: Hospital: Biz Prescriptive</b>								
1102-6	Jan 1, 2017		339	per fixture	0.2106	1108.8	per fixture	11
<b>T5 High-Bay 4L-F54HO: Hotel/Motel Common Areas: Biz Prescriptive</b>								
1102-7	Jan 1, 2017		339	per fixture	0.3099	1631.2	per fixture	11
<b>T5 High-Bay 4L-F54HO: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
1102-13	Jan 1, 2017		339	per fixture	0.0311	163.9	per fixture	11
<b>T5 High-Bay 4L-F54HO: Light Industry: Biz Prescriptive</b>								
1102-9	Jan 1, 2017		339	per fixture	0.2324	1223.5	per fixture	11

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>T5 High-Bay 4L-F54HO: Miscellaneous: Biz Prescriptive</b>								
1102-14	Jan 1, 2017		339	per fixture	0.2221	1169.4	per fixture	11
<b>T5 High-Bay 4L-F54HO: Multifamily Common Areas: Biz Prescriptive</b>								
1102-16	Jan 1, 2017		339	per fixture	0.2385	1255.5	per fixture	11
<b>T5 High-Bay 4L-F54HO: Office: Biz Prescriptive</b>								
1102-8	Jan 1, 2017		339	per fixture	0.1866	982.4	per fixture	11
<b>T5 High-Bay 4L-F54HO: Religious Worship/Church: Biz Prescriptive</b>								
1102-18	Jan 1, 2017		339	per fixture	0.0667	351.1	per fixture	11
<b>T5 High-Bay 4L-F54HO: Restaurant: Biz Prescriptive</b>								
1102-3	Jan 1, 2017		339	per fixture	0.2304	1212.7	per fixture	11
<b>T5 High-Bay 4L-F54HO: Retail/Service: Biz Prescriptive</b>								
1102-2	Jan 1, 2017		339	per fixture	0.2026	1066.4	per fixture	11
<b>T5 High-Bay 4L-F54HO: Warehouse: Biz Prescriptive</b>								
1102-20	Jan 1, 2017		339	per fixture	0.2023	1064.9	per fixture	11

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>T5 High-Bay 6L-F54HO: College/University: Biz Prescriptive</b>								
1106-1	Jan 1, 2017		256	per fixture	0.1040	547.5	per fixture	11
<b>T5 High-Bay 6L-F54HO: Elementary School: Biz Prescriptive</b>								
1106-10	Jan 1, 2017		256	per fixture	0.0410	215.6	per fixture	11
<b>T5 High-Bay 6L-F54HO: Exterior: Biz Prescriptive</b>								
1106-15	Jan 1, 2017		256	per fixture	0.0740	389.8	per fixture	11
<b>T5 High-Bay 6L-F54HO: Garage, 24/7 lighting: Biz Prescriptive</b>								
1106-19	Jan 1, 2017		256	per fixture	0.1481	779.6	per fixture	11
<b>T5 High-Bay 6L-F54HO: Garage: Biz Prescriptive</b>								
1106-4	Jan 1, 2017		256	per fixture	0.0599	315.1	per fixture	11
<b>T5 High-Bay 6L-F54HO: Grocery: Biz Prescriptive</b>								
1106-5	Jan 1, 2017		256	per fixture	0.1100	578.9	per fixture	11
<b>T5 High-Bay 6L-F54HO: Heavy Industry: Biz Prescriptive</b>								
1106-11	Jan 1, 2017		256	per fixture	0.1039	547.2	per fixture	11
<b>T5 High-Bay 6L-F54HO: High School/Middle School: Biz Prescriptive</b>								
1106-12	Jan 1, 2017		256	per fixture	0.0729	383.7	per fixture	11

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>T5 High-Bay 6L-F54HO: Hospital: Biz Prescriptive</b>								
1106-6	Jan 1, 2017		256	per fixture	0.0888	467.7	per fixture	11
<b>T5 High-Bay 6L-F54HO: Hotel/Motel Common Areas: Biz Prescriptive</b>								
1106-7	Jan 1, 2017		256	per fixture	0.1307	688.0	per fixture	11
<b>T5 High-Bay 6L-F54HO: Hotel/Motel Guest Rooms: Biz Prescriptive</b>								
1106-13	Jan 1, 2017		256	per fixture	0.0131	69.2	per fixture	11
<b>T5 High-Bay 6L-F54HO: Light Industry: Biz Prescriptive</b>								
1106-9	Jan 1, 2017		256	per fixture	0.0980	516.1	per fixture	11
<b>T5 High-Bay 6L-F54HO: Miscellaneous: Biz Prescriptive</b>								
1106-14	Jan 1, 2017		256	per fixture	0.0937	493.3	per fixture	11
<b>T5 High-Bay 6L-F54HO: Multifamily Common Areas: Biz Prescriptive</b>								
1106-16	Jan 1, 2017		256	per fixture	0.1006	529.6	per fixture	11
<b>T5 High-Bay 6L-F54HO: Office: Biz Prescriptive</b>								
1106-8	Jan 1, 2017		256	per fixture	0.0787	414.4	per fixture	11

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>T5 High-Bay 6L-F54HO: Religious Worship/Church: Biz Prescriptive</b>								
1106-18	Jan 1, 2017		256	per fixture	0.0281	148.1	per fixture	11
<b>T5 High-Bay 6L-F54HO: Restaurant: Biz Prescriptive</b>								
1106-3	Jan 1, 2017		256	per fixture	0.0972	511.5	per fixture	11
<b>T5 High-Bay 6L-F54HO: Retail/Service: Biz Prescriptive</b>								
1106-2	Jan 1, 2017		256	per fixture	0.0854	449.8	per fixture	11
<b>T5 High-Bay 6L-F54HO: Warehouse: Biz Prescriptive</b>								
1106-20	Jan 1, 2017		256	per fixture	0.0853	449.2	per fixture	11
<b>T5 (Standard Output) Delamping</b>								
3086	June 1, 2017		12	per measure	0.0171	89.9	per measure	17
<b>T5 (Standard Output) to LED Retrofit</b>								
3088	June 1, 2017		24	per measure	0.0098	51.4	per measure	17
<b>T5HO (High Output) Delamping</b>								
3087	June 1, 2017		25	per measure	0.0439	231.1	per measure	17
<b>T5HO (High Output) to LED Retrofit</b>								
3089	June 1, 2017		35	per measure	0.0236	124.1	per measure	17

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Tractor Heater Timers: Biz Prescriptive</b>								
681	Jan 2, 2013		35	per measure	0.0	576.0	per measure	10
<b>Vending Equipment Controller: Biz Prescriptive</b>								
794	Jan 2, 2013		141	per measure	0.2271	1646.0	per measure	5
<b>VFD CHW Pump CV reheat econ: Biz Prescriptive</b>								
3046	Jan 1, 2016		198		2.4845	5596	per measure	15
<b>VFD HP 10 Process Pumping: Biz Prescriptive</b>								
801	Jan 2, 2013		2860	per measure	1.4778	10713.4	per measure	15
<b>VFD HP 15 Process Pumping: Biz Prescriptive</b>								
802	Jan 2, 2013		3265	per measure	2.2391	16232.3	per measure	15
<b>VFD HP 20 Process Pumping: Biz Prescriptive</b>								
803	Jan 2, 2013		4515	per measure	2.9856	21643.7	per measure	15
<b>VFD HP 25 Process Pumping: Biz Prescriptive</b>								
804	Jan 2, 2013		5120	per measure	3.7319	27054.1	per measure	15



Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>VFD HP 30 Process Pumping: Biz Prescriptive</b>								
806	Jan 2, 2013		5770	per measure	4.4783	32464.6	per measure	15
<b>VFD HP 3 Process Pumping: Biz Prescriptive</b>								
805	Jan 2, 2013		1845	per measure	0.4478	3246.3	per measure	15
<b>VFD HP 40 Process Pumping: Biz Prescriptive</b>								
807	Jan 2, 2013		8095	per measure	5.971	43285.5	per measure	15
<b>VFD HP 50 Process Pumping: Biz Prescriptive</b>								
809	Jan 2, 2013		8950	per measure	7.4639	54108.2	per measure	15
<b>VFD HP 5 Process Pumping: Biz Prescriptive</b>								
808	Jan 2, 2013		2070	per measure	0.7389	5356.5	per measure	15
<b>VFD HP 7.5 Process Pumping: Biz Prescriptive</b>								
810	Jan 2, 2013		2860	per measure	1.1196	8116.6	per measure	15
<b>VFDs on Commercial Swimming Pool Pumps: Biz Prescriptive</b>								
3070	Jan 1, 2016		286	per measure	0.3464	2,511.00	per measure	15

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Window replacement: Biz Prescriptive</b>								
671	Jan 2, 2013		7994.87	per building	12.5684	28308.24	per building	20
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.51 kWperTon with 0.36 kWperTon IPLV: Biz Prescriptive</b>								
2733	Jan 1, 2016		149.24	per ton	0.131	359.1	per ton	20
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.51 kWperTon with 0.39 kWperTon IPLV: Biz Prescriptive</b>								
705	Jan 1, 2016		143.51	per ton	0.128	336.6	per ton	20
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.51 kWperTon with 0.3 kWperTon IPLV: Biz Prescriptive</b>								
2732	Jan 1, 2016		161.85	per ton	0.137	402.8	per ton	20
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.51 kWperTon with 0.41 kWperTon IPLV: Biz Prescriptive</b>								
2734	Jan 1, 2016		137.78	per ton	0.125	316.2	per ton	20
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.51 kWperTon with 0.48 kWperTon IPLV: Biz Prescriptive</b>								
2735	Jan 1, 2016		122.87	per ton	0.116	256.4	per ton	20
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.57 kWperTon with 0.34 kWperTon IPLV: Biz Prescriptive</b>								
2736	Jan 1, 2016		105.29	per ton	0.082	292.5	per ton	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.57 kWperTon with 0.43 kWperTon IPLV: Biz Prescriptive</b>								
706	Jan 1, 2016		84.65	per ton	0.071	218.2	per ton	20
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.57 kWperTon with 0.46 kWperTon IPLV: Biz Prescriptive</b>								
2738	Jan 1, 2016		78.2	per ton	0.068	195.4	per ton	20
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.57 kWperTon with 0.4 kWperTon IPLV: Biz Prescriptive</b>								
2737	Jan 1, 2016		91.1	per ton	0.075	243.4	per ton	20
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.57 kWperTon with 0.54 kWperTon IPLV: Biz Prescriptive</b>								
2739	Jan 1, 2016		61.44	per ton	0.058	128.2	per ton	20
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.63 kWperTon with 0.38 kWperTon IPLV: Biz Prescriptive</b>								
2740	Jan 1, 2016		48.73	per ton	0.026	182.4	per ton	20
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.63 kWperTon with 0.45 kWperTon IPLV: Biz Prescriptive</b>								
707	Jan 1, 2016		32.96	per ton	0.018	127.9	per ton	20
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.63 kWperTon with 0.48 kWperTon IPLV: Biz Prescriptive</b>								
2741	Jan 1, 2016		25.8	per ton	0.014	100.0	per ton	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Wtr-Cool cent Chiller 150 - 300 ton 0.63 kWperTon with 0.51 kWperTon IPLV: Biz Prescriptive</b>								
2742	Jan 1, 2016		18.63	per ton	0.011	74.6	per ton	20
<b>Wtr-Cool cent Chiller over 300 ton 0.46 kWperTon with 0.28 kWperTon IPLV: Biz Prescriptive</b>								
2721	Jan 1, 2016		130.19	per ton	0.125	371.0	per ton	20
<b>Wtr-Cool cent Chiller over 300 ton 0.46 kWperTon with 0.33 kWperTon IPLV: Biz Prescriptive</b>								
2722	Jan 1, 2016		118.26	per ton	0.120	331.2	per ton	20
<b>Wtr-Cool cent Chiller over 300 ton 0.46 kWperTon with 0.35 kWperTon IPLV: Biz Prescriptive</b>								
708	Jan 1, 2016		112.83	per ton	0.117	310.8	per ton	20
<b>Wtr-Cool cent Chiller over 300 ton 0.46 kWperTon with 0.37 kWperTon IPLV: Biz Prescriptive</b>								
2723	Jan 1, 2016		107.41	per ton	0.114	292.2	per ton	20
<b>Wtr-Cool cent Chiller over 300 ton 0.46 kWperTon with 0.44 kWperTon IPLV: Biz Prescriptive</b>								
2724	Jan 1, 2016		92.22	per ton	0.106	234.2	per ton	20
<b>Wtr-Cool cent Chiller over 300 ton 0.52 kWperTon with 0.31 kWperTon IPLV: Biz Prescriptive</b>								
2725	Jan 1, 2016		88.82	per ton	0.075	270.8	per ton	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Wtr-Cool cent Chiller over 300 ton 0.52 kWperTon with 0.37 kWperTon IPLV: Biz Prescriptive</b>								
2726	Jan 1, 2016		75.40	per ton	0.069	226.0	per ton	20
<b>Wtr-Cool cent Chiller over 300 ton 0.52 kWperTon with 0.39 kWperTon IPLV: Biz Prescriptive</b>								
2727	Jan 1, 2016		69.30	per ton	0.065	203.1	per ton	20
<b>Wtr-Cool cent Chiller over 300 ton 0.52 kWperTon with 0.42 kWperTon IPLV: Biz Prescriptive</b>								
2728	Jan 1, 2016		63.20	per ton	0.062	182.2	per ton	20
<b>Wtr-Cool cent Chiller over 300 ton 0.52 kWperTon with 0.49 kWperTon IPLV: Biz Prescriptive</b>								
709	Jan 1, 2016		46.11	per ton	0.053	117.1	per ton	20
<b>Wtr-Cool cent Chiller over 300 ton 0.58 kWperTon with 0.35 kWperTon IPLV: Biz Prescriptive</b>								
2729	Jan 1, 2016		47.46	per ton	0.025	170.5	per ton	20
<b>Wtr-Cool cent Chiller over 300 ton 0.58 kWperTon with 0.41 kWperTon IPLV: Biz Prescriptive</b>								
710	Jan 1, 2016		32.54	per ton	0.017	120.8	per ton	20
<b>Wtr-Cool cent Chiller over 300 ton 0.58 kWperTon with 0.44 kWperTon IPLV: Biz Prescriptive</b>								
2730	Jan 1, 2016		25.76	per ton	0.014	95.4	per ton	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Wtr-Cool cent Chiller over 300 ton 0.58 kWperTon with 0.47 kWperTon IPLV: Biz Prescriptive</b>								
2731	Jan 1, 2016		18.98	per ton	0.010	72.3	per ton	20
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.56 kWperTon with 0.34 kWperTon IPLV: Biz Prescriptive</b>								
2709	Jan 1, 2016		203.03	per ton	0.15305	452.09	per ton	20
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.56 kWperTon with 0.43 kWperTon IPLV: Biz Prescriptive</b>								
711	Jan 2, 2013		186	per ton	0.142	422.3	per ton	20
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.56 kWperTon with 0.46 kWperTon IPLV: Biz Prescriptive</b>								
2712	Jan 1, 2016		180.87	per ton	0.13906	356.3	per ton	20
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.56 kWperTon with 0.4 kWperTon IPLV: Biz Prescriptive</b>								
2710	Jan 1, 2016		191.42	per ton	0.14605	403.67	per ton	20
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.56 kWperTon with 0.53 kWperTon IPLV: Biz Prescriptive</b>								
2713	Jan 1, 2016		166.1	per ton	0.12909	285.73	per ton	20
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.63 kWperTon with 0.38 kWperTon IPLV: Biz Prescriptive</b>								
2714	Jan 1, 2016		124.6	per ton	0.09153	329.89	per ton	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.63 kWperTon with 0.45 kWperTon IPLV: Biz Prescriptive</b>								
2715	Jan 1, 2016		111.54	per ton	0.0836	275.5	per ton	20
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.63 kWperTon with 0.48 kWperTon IPLV: Biz Prescriptive</b>								
712	Jan 2, 2013		186	per ton	0.079	276.0	per ton	20
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.63 kWperTon with 0.51 kWperTon IPLV: Biz Prescriptive</b>								
2716	Jan 1, 2016		99.67	per ton	0.07579	222.22	per ton	20
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.63 kWperTon with 0.60 kWperTon IPLV: Biz Prescriptive</b>								
2717	Jan 1, 2016		83.05	per ton	0.06452	142.88	per ton	20
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.7 kWperTon with 0.44 kWperTon IPLV: Biz Prescriptive</b>								
2718	Jan 1, 2016		46.16	per ton	0.03001	207.39	per ton	20
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.7 kWperTon with 0.53 kWperTon IPLV: Biz Prescriptive</b>								
2719	Jan 1, 2016		25.06	per ton	0.01668	116.17	per ton	20
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.7 kWperTon with 0.57 kWperTon IPLV: Biz Prescriptive</b>								
2720	Jan 1, 2016		18.46	per ton	0.01245	88.02	per ton	20
<b>Wtr-Cool Centrifugal Chiller under 150 ton 0.7 kWperTon with 0.5 kWperTon IPLV: Biz Prescriptive</b>								
713	Jan 2, 2013		186	per ton	0.021	164.0	per ton	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Wtr-Cool screw chiller 150 - 300 ton 0.57 kWperTon with 0.34 kWperTon IPLV: Biz Prescriptive</b>								
2771	Jan 1, 2016		149.41	per ton	0.163	423.8	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.57 kWperTon with 0.37 kWperTon IPLV: Biz Prescriptive</b>								
2772	Jan 1, 2016		137.36	per ton	0.159	400.7	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.57 kWperTon with 0.43 kWperTon IPLV: Biz Prescriptive</b>								
2773	Jan 1, 2016		113.26	per ton	0.148	343.7	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.57 kWperTon with 0.45 kWperTon IPLV: Biz Prescriptive</b>								
2774	Jan 1, 2016		103.62	per ton	0.144	322.3	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.57 kWperTon with 0.4 kWperTon IPLV: Biz Prescriptive</b>								
714	Jan 1, 2016		125.31	per ton	0.154	373.3	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.57 kWperTon with 0.51 kWperTon IPLV: Biz Prescriptive</b>								
2775	Jan 1, 2016		79.52	per ton	0.134	266.3	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.65 kWperTon with 0.39 kWperTon IPLV: Biz Prescriptive</b>								
2776	Jan 1, 2016		118.38	per ton	0.1	310	per ton	20



Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Wtr-Cool screw chiller 150 - 300 ton 0.65 kWperTon with 0.42 kWperTon IPLV: Biz Prescriptive</b>								
2777	Jan 1, 2016		104.83	per ton	0.095	283.7	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.65 kWperTon with 0.45 kWperTon IPLV: Biz Prescriptive</b>								
715	Jan 1, 2016		91.27	per ton	0.089	252.9	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.65 kWperTon with 0.48 kWperTon IPLV: Biz Prescriptive</b>								
2778	Jan 1, 2016		77.72	per ton	0.083	219.3	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.65 kWperTon with 0.51 kWperTon IPLV: Biz Prescriptive</b>								
2779	Jan 1, 2016		66.87	per ton	0.078	194.8	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.65 kWperTon with 0.57 kWperTon IPLV: Biz Prescriptive</b>								
2780	Jan 1, 2016		39.76	per ton	0.067	131.8	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.72 kWperTon with 0.43 kWperTon IPLV: Biz Prescriptive</b>								
2781	Jan 1, 2016		87.36	per ton	0.036	201.3	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.72 kWperTon with 0.47 kWperTon IPLV: Biz Prescriptive</b>								
2782	Jan 1, 2016		72.3	per ton	0.031	170.8	per ton	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Wtr-Cool screw chiller 150 - 300 ton 0.72 kWperTon with 0.54 kWperTon IPLV: Biz Prescriptive</b>								
2783	Jan 1, 2016		42.17	per ton	0.017	95.4	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.72 kWperTon with 0.57 kWperTon IPLV: Biz Prescriptive</b>								
2784	Jan 1, 2016		30.12	per ton	0.012	67.3	per ton	20
<b>Wtr-Cool screw chiller 150 - 300 ton 0.72 kWperTon with 0.5 kWperTon IPLV: Biz Prescriptive</b>								
716	Jan 1, 2016		57.24	per ton	0.024	134.5	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.51 kWperTon with 0.31 kWperTon IPLV: Biz Prescriptive</b>								
2757	Jan 1, 2016		114.05	per ton	0.145	380.168	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.51 kWperTon with 0.33 kWperTon IPLV: Biz Prescriptive</b>								
2758	Jan 1, 2016		104.02	per ton	0.141	359.569	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.51 kWperTon with 0.36 kWperTon IPLV: Biz Prescriptive</b>								
717	Jan 1, 2016		93.99	per ton	0.137	335.007	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.51 kWperTon with 0.38 kWperTon IPLV: Biz Prescriptive</b>								
2759	Jan 1, 2016		83.96	per ton	0.132	308.622	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.51 kWperTon with 0.46 kWperTon IPLV: Biz Prescriptive</b>								
2761	Jan 1, 2016		55.87	per ton	0.12	239.719	per ton	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Wtr-Cool screw chiller over 300 ton 0.51 kWperTon with 0.4 kWperTon IPLV: Biz Prescriptive</b>								
2760	Jan 1, 2016		75.93	per ton	0.128	289.599	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.58 kWperTon with 0.35 kWperTon IPLV: Biz Prescriptive</b>								
2762	Jan 1, 2016		93.39	per ton	0.089	277.692	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.58 kWperTon with 0.37 kWperTon IPLV: Biz Prescriptive</b>								
2763	Jan 1, 2016		82.1	per ton	0.084	254.586	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.58 kWperTon with 0.43 kWperTon IPLV: Biz Prescriptive</b>								
2764	Jan 1, 2016		59.53	per ton	0.074	197.441	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.58 kWperTon with 0.45 kWperTon IPLV: Biz Prescriptive</b>								
2765	Jan 1, 2016		50.51	per ton	0.07	175.985	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.58 kWperTon with 0.4 kWperTon IPLV: Biz Prescriptive</b>								
718	Jan 1, 2016		70.82	per ton	0.079	227.053	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.58 kWperTon with 0.51 kWperTon IPLV: Biz Prescriptive</b>								
2766	Jan 1, 2016		27.94	per ton	0.06	119.836	per ton	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Wtr-Cool screw chiller over 300 ton 0.64 kWperTon with 0.38 kWperTon IPLV: Biz Prescriptive</b>								
2767	Jan 1, 2016		72.72	per ton	0.032	176.176	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.64 kWperTon with 0.42 kWperTon IPLV: Biz Prescriptive</b>								
2768	Jan 1, 2016		60.18	per ton	0.027	150.281	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.64 kWperTon with 0.45 kWperTon IPLV: Biz Prescriptive</b>								
719	Jan 1, 2016		47.65	per ton	0.021	119.625	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.64 kWperTon with 0.48 kWperTon IPLV: Biz Prescriptive</b>								
2769	Jan 1, 2016		35.11	per ton	0.015	86.563	per ton	20
<b>Wtr-Cool screw chiller over 300 ton 0.64 kWperTon with 0.51 kWperTon IPLV: Biz Prescriptive</b>								
2770	Jan 1, 2016		25.08	per ton	0.011	62.36	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.63 kWperTon with 0.38 kWperTon IPLV: Biz Prescriptive</b>								
2743	Jan 1, 2016		193.99	per ton	0.4276	469.5	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.63 kWperTon with 0.44 kWperTon IPLV: Biz Prescriptive</b>								
720	Jan 1, 2016		165.46	per ton	0.169	413.5	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.63 kWperTon with 0.47 kWperTon IPLV: Biz Prescriptive</b>								
2745	Jan 1, 2016		151.2	per ton	0.3467	380.7	per ton	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Wtr-Cool screw chiller under 150 ton 0.63 kWperTon with 0.56 kWperTon IPLV: Biz Prescriptive</b>								
2747	Jan 1, 2016		111.25	per ton	0.269	295.4	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.63 kWperTon with 0.5 kWperTon IPLV: Biz Prescriptive</b>								
2746	Jan 1, 2016		139.78	per ton	0.3251	357.0	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.71 kWperTon with 0.43 kWperTon IPLV: Biz Prescriptive</b>								
2748	Jan 1, 2016		148.71	per ton	0.3182	349.4	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.71 kWperTon with 0.46 kWperTon IPLV: Biz Prescriptive</b>								
2749	Jan 1, 2016		132.66	per ton	0.2907	319.2	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.71 kWperTon with 0.53 kWperTon IPLV: Biz Prescriptive</b>								
2750	Jan 1, 2016		100.56	per ton	0.2226	244.4	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.71 kWperTon with 0.56 kWperTon IPLV: Biz Prescriptive</b>								
2751	Jan 1, 2016		87.72	per ton	0.1973	216.6	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.71 kWperTon with 0.5 kWperTon IPLV: Biz Prescriptive</b>								
721	Jan 1, 2016		116.61	per ton	0.097	283.2	per ton	20

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Wtr-Cool screw chiller under 150 ton 0.71 kWperTon with 0.63 kWperTon IPLV: Biz Prescriptive</b>								
2752	Jan 1, 2016		55.63	per ton	0.1361	149.4	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.79 kWperTon with 0.47 kWperTon IPLV: Biz Prescriptive</b>								
2753	Jan 1, 2016		103.43	per ton	0.2044	224.4	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.79 kWperTon with 0.51 kWperTon IPLV: Biz Prescriptive</b>								
2754	Jan 1, 2016		85.59	per ton	0.1738	190.9	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.79 kWperTon with 0.55 kWperTon IPLV: Biz Prescriptive</b>								
722	Jan 1, 2016		67.76	per ton	0.027	150.9	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.79 kWperTon with 0.59 kWperTon IPLV: Biz Prescriptive</b>								
2755	Jan 1, 2016		49.93	per ton	0.0983	107.9	per ton	20
<b>Wtr-Cool screw chiller under 150 ton 0.79 kWperTon with 0.62 kWperTon IPLV: Biz Prescriptive</b>								
2756	Jan 1, 2016		35.66	per ton	0.0701	77.0	per ton	20

### **Business Standard Program Measures:**

The Business Standard Program encourages customer participation through a simple and streamlined process. The program is designed to promote the installation of energy efficient technologies such as lighting, motors, HVAC, and refrigeration in nonresidential properties. Measures included within this program are common in multiple marketplaces and have deemed savings values associated with their energy performance. The listings of these measures are in the Prescriptive Measure Listing above. Applications are filled out and delivered to Ameren Missouri via contractors, customers, or through the Company's website. Ameren Missouri, through its contractor, multiply the measure quantities by the saving per measure in this TRM to determine the total energy and demand saved. Various measures may require a simple calculation to identify measure savings, but the measure level incentives will remain fixed regardless of individual project characteristics.

### **Small Business Direct Install Program Measures:**

The Small Business Direct Install (SBDI) Program encourages small customer participation through an even more streamlined process. The program is designed to promote the installation of energy efficient technologies such as lighting, motors, HVAC, and refrigeration in nonresidential properties. Qualified contractors provide a walk-through energy audit and at the customer request can install the energy saving measures with a high percentage of the cost billed to the program implementation contractor. Energy and demand savings are determined by multiplying the measure quantities by the saving measure in this TRM similar to the Standard Program.

### **Custom, Retro-commissioning and New Construction Program Measure**

#### **Analysis Methodology**

The Business Custom, Retro-commissioning (RCx) and New Construction projects typically require substantial analytic rigor to identifying project savings and costs. The nature of these projects can vary dramatically.

Most commonly found Custom and New Construction measures can be grouped into 14 categories and can be found in, but not limited to, the Prescriptive Measure Listing above:

- Lighting (fixture upgrades, except for exit signs and controls)
- Lighting (Exit signs and controls)
- Packaged Air-Conditioners and Heat Pumps (includes RTUs, ASHPs, WSHPs, GSHPs)
- Chiller
- Cooling Tower

- Refrigeration System
- Motor Drive Installations (i.e. variable-frequency drives [VFDs] )
- Compressed-Air Systems
- Controls and Energy Management Systems (EMS)
- Domestic Water Heating (various options)
- Pump, Fan, Piping, and Duct
- Process Upgrades
- All Other

Most commonly found RCx measures can be grouped into 4 categories and can be found in, but not limited to, the Prescriptive Measure Listing above:

- Lighting Improvements (fixture upgrades, except for exit signs and controls)
- Compressed-Air Systems
- Controls and Energy Management Systems (EMS)
- All Other

Some measures involve replacing an item of equipment with a similar, more-efficient model, while others entail enhancing the performance of existing equipment. For example, a measure may consist of modifying the programming of a control system and perhaps also adding one or more sensors and/or circuit-control devices, or it may involve modifying an existing pump or changing a piping system to reduce pressure drop, such that the motor driving the pump draws less power.

In the case of eligible motor upgrades and the installation of Variable Frequency Drive (VFD) drives on motors, this category will be credited with the savings irrespective of where the motor is located, unless the motor is part of a new item of equipment. For example, replacing the motor driving a fan on a cooling tower is a Motor measure, but replacing the entire cooling tower, which includes a new fan motor, is a Cooling Tower Measure.

A Technical Analysis Study (TAS) or energy savings estimate is required for all Custom and RCx projects. An energy savings estimate can be provided by the customer or a contractor. The Program engineering staff will review all TAS reports and energy savings estimates to ensure all assumptions are reasonable and that the study is based on sound engineering methodology. A TAS Report will contain complete documentation for the proposed project, and forms a vital element for the subsequent Impact Evaluation performed by the evaluation contractor. The TAS is also often used by the customer to get funding approval. More specifically, the TAS:

- Identifies the customer (organization), key customer representatives and their contact information, and the location of the facility that will host the proposed project.



- Describes the host facility (typically with a photograph and/or sketch showing site layout or floor plan).
- Documents monthly electricity use, and identifies Ameren Missouri account number and meter number.
- Describes the baseline equipment and provides its electricity-use (with estimated load shape<sup>1</sup>) and estimated annual O&M costs.
- Describes the new equipment to be added, together with key performance specifications and expected lifetime, or otherwise completes the description of the measure (i.e., Energy Management System (EMS) reprogramming and new control functions).
- Provides estimated electricity-use (and estimated load shape) for the retrofit condition.
- Provides the energy and demand savings calculations,<sup>2</sup> together with 1) the source of input parameter numbers, and 2) justification for each assumption made.
- Provides the cost to implement the project, together with a cost breakdown and, when possible, written quotations for major equipment item(s) and estimates of ongoing annual O&M costs.
- Provides the estimated financial incentive and estimated annual cost savings, together with the financial metric(s) requested by the customer (i.e., simple payback, IRR, ROI).

As it is noted above, some measures may involve modifying existing controls or energy management systems so they perform more functions and act more effectively to minimize electricity use while still producing the desired or needed service outputs as a function of time. Examples include the installation of Variable Air Volume (VAV) fans and sensors and the installation of a multistage efficient chiller, with each of these new systems controlled by an existing energy management system. This type of project will involve reprogramming of the EMS for the new control functions. *It is most important that the TAS fully describe the new equipment recommended, the new ventilation and chiller controls strategies to be implemented, and the specific EMS control functions that require reprogramming.*

After the TAS is submitted together with an application signed by the customer that references the TAS, an engineer on the Program staff will formally review it and independently check the savings calculations. The TAS will either be approved or returned to the customer with a written explanation of what modifications are needed.

---

<sup>1</sup> Load shape expressed as monthly kWh and kW.

<sup>2</sup> Reductions in Greenhouse Gas emissions or other environmental data should be included when available.

When modifications are required, the revision number and date are noted on the cover, new signatures are affixed, and the TAS is resubmitted.

Measure savings calculation for the Energy Management System Pilot will be conducted under these Custom Program procedures.

After final approval for program requirements and cost effectiveness, the customer is authorized to proceed with implementing the project. Program staff will monitor progress and offer advice if this is needed and it is feasible for program staff to provide this assistance.

### ***Calculating Custom, RCx and New Construction Energy and Demand Savings***

The energy and demand savings equations used in these programs can be found in the on-line TRM.

## Custom Program Measures

The Business Custom Incentive Program provides energy efficiency expertise, services, and financial incentives to encourage nonresidential customers to install energy efficient processes and/or equipment that lie outside the Standard program's pre-defined energy efficiency measures and/or guidelines savings. These custom projects are complex and always unique requiring detailed savings calculations to arrive at the appropriate custom incentive level.

The methodology for calculation of energy savings is described in the Custom, Retro-commissioning and New Construction Program Measure Analysis Methodology section.

The following is a listing of the Business Custom Measures extracted from iTRL.

Ameren Missouri Measure Listing for MEEIA Cycle 2016-18

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Custom Measure: Biz Custom</b>								
1169	Jan 2, 2013		variable based on parameters		variable based on parameters	variable based on parameters		

## Retro-commissioning Program Measures

The Business Retro-Commissioning Program will deliver energy savings by helping facilities benchmark existing system performance levels, identify operating system performance optimization improvements, and where applicable, provide financial incentives to assist with the implementation of the recommended efficiency improvements.

The measures are associated with efficiency opportunities with existing mechanical, electrical and thermal systems in nonresidential buildings by providing options for retrofitting equipment that is inefficient and outdated. This program also assists occupants in improving their operation and maintenance practices via compressed air, Building Automation System (BAS), lighting and process system upgrades.

The methodology for calculation of energy savings is described in the Custom, Retro-commissioning and New Construction Program Measure Analysis Methodology section.

The program is listed separately because incentive levels could be different.

The following is a listing of the Business Retro-Commissioning Measures extracted from iTRL.

Ameren Missouri Retro-Commissioning Measures for MEEIA Cycle 2016-18

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>Retro commissioning: Biz RCx</b>								
1191	Jan 2, 2013		variable based on parameters		variable based on parameters	variable based on parameters		

## New Construction Program Measures

The primary goal of this Program is to capture energy savings available in new building construction, major renovations, or tenant build-outs to existing business facilities.

It is important to offer the building community multiple options for their specific projects. The program will accommodate any phase of construction where Program incentives can drive incremental cost effective energy efficiency improvements.

The Program offers financial incentives to encourage building owners/developers and their design/construction team to exceed standard building practices to achieve efficiency, above and beyond, the current building energy code requirements. There are four types of energy efficiency incentives that New Construction Projects can receive through participation in this program.

- **Whole Building Performance Incentives** provide cash incentives to encourage holistic energy efficient building design and construction.
- **Standard Incentives** are available for common, proven energy efficiency measures. These measures have been evaluated and the energy savings/value have been pre-determined.
- **Installed Interior Lighting Incentives** are based upon the efficiency of the installed interior lighting system relative to the baseline lighting power density as defined within ASHRAE 90.1.
- **Custom Incentives** are available for all other energy efficiency measures which are determined to be cost-effective and meet all standards required by the Business Program.

These projects typically require substantial analytic rigor to identifying project savings based on local codes and standards and builder's normal practices and costs.

The methodology for calculation of energy savings is described in the Custom, Retro-commissioning and New Construction Program Measure Analysis Methodology section.

The following is a listing of all the Business New Construction Measures extracted from iTRL.

Ameren Missouri New Construction Measure for MEEIA Cycle 2016-18

Measure Reference No.	Start Date	End Date	Incremental Cost	Cost Unit	Gross Annual Demand Reduction (kW)	Gross Annual Electric Savings (kWh)	Savings Unit	Measure Life
<b>New Construction: Biz New Construction</b>								
3000	Jan 2, 2013		variable based on parameters		variable based on parameters	variable based on parameters		