

**BEFORE THE PUBLIC SERVICE COMMISSION
OF THE STATE OF MISSOURI**

Emma J. McFarlin and Rebecca J. Shepherd,)	
)	
Complainants,)	
)	
v.)	File No. EC-2013-0024
)	
Kansas City Power & Light Company,)	
)	
Respondent.)	

**KANSAS CITY POWER & LIGHT COMPANY'S RESPONSE TO COMMISSION
ORDER REGARDING MOTION FOR SUMMARY DETERMINATION**

COMES NOW, Kansas City Power & Light Company ("KCP&L") and hereby submits supplemental information in response to the Missouri Public Service Commission's March 21, 2013 Order.

1. Attached to this pleading is the affidavit of the individual who performed the meter test at Complainants' premises. This affidavit should be substituted for the affidavit of Corey Paczosa contained in the Motion for Summary Determination filed on March 15, 2013.

Respectfully submitted,

/s/ Roger W. Steiner

Roger W. Steiner, MBN 39586
Corporate Counsel
Kansas City Power & Light Company
1200 Main – 16th Floor
Kansas City, Missouri 64105
Phone: (816) 556-2314
Fax: (816) 556-2787
E-mail: roger.steiner@kcpl.com

Attorney for Kansas City Power & Light Company

CERTIFICATE OF SERVICE

I hereby certify that a true and correct copy of the foregoing have been mailed, hand-delivered, transmitted by facsimile or electronically mailed to all counsel of record on this 28th day of March, 2013.

/s/ Roger W. Steiner

Roger W. Steiner

**BEFORE THE PUBLIC SERVICE COMMISSION
OF THE STATE OF MISSOURI**


Emma J. McFarlin and Rebecca J. Shepherd,)	
)	
Complainants,)	
)	
v.)	File No. EC-2013-0024
)	
Kansas City Power & Light Company,)	
)	
Respondent.)	

AFFIDAVIT

The undersigned, Paul M. Wilson, states under oath as follows:

1. I am employed by Kansas City Power & Light Company, in the Department of Measurement Technology as Meterman Journeyman.
2. On February 19, 2013, I conducted a meter test at 3637 Agnes Avenue, Kansas City, MO 64128 for meter number 1284810714731G and found the meter to test at 100.03% accuracy. Attached as Exhibit A is a copy of the results of the meter test.
3. The above meter test was performed according to the Missouri Public Service Commission rule 4 CSR 240-10.030.


FURTHER AFFIANT SAITH NOT.




Paul M. Wilson

STATE OF MISSOURI)
) ss
COUNTY OF JACKSON)

Subscribed and sworn before me, a Notary Public, on this 26th day of March, 2013.



Notary Public



02/20/2013 13:42 2453625
FIELD INVEST. Meter Test
Service Address: [REDACTED]

MEASUREMENT TECH
KANSAS CITY POWER & LIGHT

PAGE 82/82

Customer Name : MCFARLIN, EMMA JEAN
Ordered By : CUSTOMER RELATIONS
Issued By : SAS7489
Rate : IRS1A

Acct: [REDACTED]
Bill cycle: 10
EFT: No
Area: Manchester
Cycle/Route: 07 / 280D

Instructions
Test meter - formal complaint

Date Taken: 02/14/2013 /

TELEPHONE
Primary [REDACTED]
Work [REDACTED]
Premise [REDACTED]

Elec Addr: M1528330

ALERT : [REDACTED]
Utility : Electric
Location: OS

SOCKET	Meter	Use	Amps	Phase	Wire	Furch
VOLTS	Volts					Year
120/240	120/240	GEN		1	3	2001

Callnet @ 8:27AM
54814

CURRENT Meter Number	Seal	Const	UOM	Dials	Last Readings	Current Readings
1284810714731G	3	1.0	KW	5.2		54814
		1.0	KWH	5.0	54212.0	

New Meter Info	Meter Number	Seal	Const	UOM	Dials	Readings
				KWH		
				KW		

Equipment
2453625
L96K
AF HL-143.9390 = 100.04
LL-88.7997 = 100.01
AQ - 100.03%

Investigation Report Ran load check good voltage. Ran as Found
No creep on meter. Ran 1KWH meter good
AS111T Load 1Kw = 30.78 sec

FEB 19 2013

Talked To Mrs.
Investigated By 9590
Date 2-19-13

Service Order # 1083053496

EXHIBIT A