

*Book
Updated
2/16/95*

ST. JOSEPH LIGHT & POWER COMPANY

ALLOCATION PROCEDURES

CASE NO. EO-94-36

**August 1994
Revised October 1994
Revised December 1994**

January 1, 1995

ST. JOSEPH LIGHT & POWER COMPANY

ALLOCATION PROCEDURES

CASE NO. EO-94-36

I. CAPITAL PLANT ALLOCATION - Lake Road

- A. Portions of LR Capital Plant Allocated 100% to Electric
- B. Portions of LR Capital Plant 100% Assigned to Industrial Steam
- C. Portions of LR Capital Plant Common to Electric and Industrial Steam
- D. Reserve for Depreciation Allocation - Lake Road

II. CAPITAL PLANT ALLOCATION - General Plant

- A. Capital Plant Allocation - General Plant
- B. Reserve for Depreciation Allocation - General Plant

III. INVENTORY - FUEL Lake Road

IV. INVENTORY - Materials and Supplies

- A. Materials and Supplies Inventory Allocation - Lake Road
- B. Other Materials and Supplies

V. OTHER RATE BASE ITEMS

- A. PREPAYMENTS
- B. DEFERRED TAXES
- C. SPECIAL DEPOSITS

VI. EXPENSES - FUEL

- A. Fuel and Daily Ash Expense Allocations
- B. Auxiliary Electric Power Allocation

VII. EXPENSES - O & M EXPENSE ALLOCATION

VIII. Expenses- General & Administrative Expenses

IX. EXPENSES - PROPERTY TAXES

X. EXPENSES - INTEREST FOR TAXES

ST. JOSEPH LIGHT & POWER COMPANY
ALLOCATION PROCEDURES
CASE NO. EO-94-36

I. CAPITAL PLANT ALLOCATION - Lake Road

A. Portions of LR Capital Plant Allocated 100% to Electric

The following LR capital plant is to be allocated 100% to Electric, with the noted exceptions:

1. All "900 lb." steam turbine generators and associated equipment (Acc 314) including the following:
 - main steam piping, with supports, leading to turbines (Acc 314);
 - turbine generator controls and instrumentation (Acc 314);
 - main steam condensers, condensate pumps, piping and auxiliaries (Acc 314);
 - cooling towers and auxiliaries (Acc 314);
 - circulating water pumps and circulating water lines (Acc 314);

BUT EXCLUDING Turbine #1 (Acc 314).
2. All combustion turbine generators, Boiler #7 (HRSG) and associated equipment (Acc 340's).
3. Unit 4/6 (the "1800 lb. system") including Boiler #6 (Acc 312), Turbine Generator #4 (Acc 314), Boiler #6 condensate & feedwater system (including demineralizers) (Acc 312), Boiler #6 coal handling (including crusher house and coal crushing equipment) (Acc 312), Precipitator #6 (Acc 312), and Boiler #6 ash removal system (Acc 312).
4. Turbine building and other buildings and structures housing and/or associated with the 100% electric generation facilities (Acc 311 & 341).

B. Portions of LR Capital Plant 100% Assigned to Industrial Steam

The following LR capital plant is to be allocated 100% to Industrial Steam:

1. All steam piping, supports, desuperheating water piping, pressure reducing stations, attemperating stations, controls and metering equipment from the 200

psi plant output meters (12" and 16" meters), inclusive to the low pressure industrial steam customers (Acc 312).

2. All steam piping, supports, attemperating station, and associated controls and metering equipment from the 900 psi header to the high pressure (850 psi) industrial steam customer (Acc 312).
3. The high pressure (850 psi) industrial steam customer desuperheating pumps, piping, and controls (Acc 312).
4. All industrial steam customer meter houses, buildings and structures which house or are associated with 100% industrial steam facilities (Acc 311).

C. Portions of LR Capital Plant Common to Electric and Industrial Steam

The following LR capital plant is to be allocated between Electric and Industrial Steam, using the allocation methods specified.

1. Automatic Extraction Turbine #1 (Acc 314);

Allocation - Allocate a fraction, E, to the electric users, where E is the ratio between 1) the cost of a new standard turbine, i.e., non-automatic extraction turbine, and 2) the cost of a new automatic extraction turbine. The remaining fraction ($R = 1 - E$) is to be allocated further between electric and steam users since the extraction goes to both electric and steam customers. This fraction (R) shall be allocated between steam and electric users by applying the 900 lb Steam Demand Allocation Factor. A 1994 study of standard and automatic extraction turbine costs established that $E=94.6\%$ and $R=5.4\%$ ($R=0.054$). (See Attached Memorandum dated January 28, 1994 and marked Schedule 1).

2. Boilers 1 through 5, including the following (Acc 312):

- air and fuel supply systems, including coal handling facilities dedicated solely to Boiler #5 (312);
- feedwater pumps, valves and piping (Acc 312);
- deaerator and feedwater storage tanks (Acc 312);
- steam piping to the 900 lb. steam header (Acc 312);
- precipitators, stacks and emission control equipment (Acc 312);
- Ash handling facilities dedicated solely to Boiler #5 (Acc 312);

Allocation - Allocate by applying the 900 lb Steam Demand Allocation Factor.

3. Common coal handling facilities including the following (common to Boilers #5 & #6) (Acc 312):

- rotary car dumper (Acc 312);
- locomotive (Acc 312);
- common coal conveyors (Acc 312);
- dozers (Acc 312).

Allocation - Allocate first between Boiler #5 (allocated plant) and Boiler #6 (100% electric) based on the rate at which each boiler burns coal at its rated maximum output ("rated coal burn rate"). The Boiler 5 rated coal burn rate is 15 tons/hr and the Boiler #6 rated coal burn rate is 43 tons/hr. Thus, allocate a fraction R to Boiler #5, where R is $15/58$, or 25.86%, and then allocate this portion further between electric and industrial steam by applying the 900 lb Steam Demand Allocation Factor. Allocate the fraction $E = 1-R$, or 74.14%, to Boiler #6 and charge 100% to electric.

4. Common ash handling facilities including the following (common to Boilers #5 & #6) (Acc 312):
 - low side ash tank (Acc 312);
 - associated exhausting vacuum system (Acc 312);
 - rotary unloader (Acc 312).

Allocation - Allocate first between Boiler #5 (allocated plant) and Boiler #6 (100% electric) based on the rate of ash production from each boiler at its rated maximum output, after adjusting these values for the fraction of ash from each boiler which actually is directed to the common ash tank. To accomplish this, obtain the maximum ash production rate for each boiler by multiplying the rated coal burn rate (15 tons/hr for Boiler #5 and 43 tons/hr for Boiler #6) by the ash content of the coal (A_5 and A_6 , respectively). Then recognize that 100% of Boiler #5 ash goes to the ash tank, but only a portion (estimated to be 17.7%) of the fly ash and none of the cyclone slag/bottom ash from Boiler #6 goes to the ash tank. Thus, allocate the fraction R to Boiler #5, where R is equal to $(15 \times A_5)$ divided by the quantity $(15 \times A_5 + (43 \times a \times b) \times A_6)$, with a equal to the fraction of Boiler #6 fly ash going to the tank (currently 17.7%) and with b equal to the fraction of fly ash in total ash (30%) coming from Boiler #6. Then allocate this portion (R) further between electric and industrial steam by applying the 900 lb Steam Demand Allocation Factor. Allocate the remainder ($E = 1-R$) to Boiler #6 and charge 100% to electric. (If the two boilers are burning coal with the same ash content, the A_5 and A_6 terms can be dropped.)

5. Water Treatment Facilities (Acc 312);

Allocation - Allocate a fraction E to electric, where E is the ratio between 1) the cost of new water treatment facilities capable of treating only that amount of water needed for electric plant and 2) the cost of new water

treatment facilities capable of treating water for both the electric users and the steam users. Allocate the remaining fraction ($S = 1 - E$) to industrial steam. A 1994 study of Lake Road Feedwater Treatment Facilities established that $E = 17.1\%$ and $S = 82.9\%$. (See Attached Memorandum dated March 8, 1994 and marked Schedule 2).

6. Other plant facilities, buildings, structures and equipment (Accounts 310, 311, 312, 315 and 316, unless covered above).

Allocation

Account 310 - Land and Land Rights:

Allocate based on the ratio derived from the total plant allocated to industrial steam and electric in accounts 311, 312, 314, 315, 316, 341, 342, 344, 345 and 346.

Account 311 - Structures and Improvements:

- Turbine Building will be assigned 100% to Electric.
- Steam Meter Houses will be assigned 100% to Industrial Steam.
- Allocate the Water Softener Building and the Water Treatment Building using the same allocation factor used to allocate the water treatment facilities.
- The remainder of account 311 will be allocated based on the ratio between the total plant allocated to industrial steam and electric in Accounts 312 and 314 only.

Account 315 - Accessory Electric Equipment:

A review was made of the details of Account 315 (L1315) assigned to electric. This review identified that a portion of account 315 should be allocated between electric and industrial steam and that a portion is 100% electric. The review of the industrial steam account 315 (L6315) identified that all of this account should be assigned to industrial steam. The allocable portion of account L1315 should be allocated based on the total plant ratio determined in allocation accounts 311, 312, and 316. (See Attached Memorandum dated March 14, 1994 and marked Schedule 3).

Account 316 - Miscellaneous Power Plant Equipment :

Items under Account 316 should be allocated by applying the 900/1800 lb Steam Demand Factor.

D. Reserve for Depreciation Allocation - Lake Road

A portion of the electric reserve balance for each plant account is allocated to Industrial Steam based on the percentage of the electric plant in service allocated to Industrial Steam.

ST. JOSEPH LIGHT & POWER COMPANY
LAKE ROAD PLANT ALLOCATION - SETTLEMENT SCENARIO
DECEMBER 31, 1993

| ACCOUNT #, TITLE | ELECTRIC P.I.S. @12/31/83 | | TOTAL P.I.S. @12/31/83 | | 100% ELECTRIC | | 100% STEAM | | REMAINING ALLOCABLE | | 900# STEAM DEMAND | | TOTAL PLANT | |
|-------------------------|---------------------------|---------|------------------------|-----------------|---------------|-----------|------------|-----------|---------------------|-------|-------------------|-----------|-------------|----------|
| | | | | | | | | | | | | ELECTRIC | STEAM | ELECTRIC |
| 312 BOLERS | 15,766,689 | 414,810 | 16,203,509 | 6,399,058 (A,B) | 7,18,843 (B) | 9,065,608 | 6,866,888 | 2,098,822 | 76.9% | 23.1% | 13,366,044 | 2,817,465 | | |
| 312A COAL HANDLING | 8,573,722 | | 8,573,722 | 6,353,128 (D) | | 2,220,594 | 1,707,637 | 512,957 | | | 8,060,765 | 512,957 | | |
| 312B ASH HANDLING | 55,663 | | 55,663 | 7,348 (E) | | 48,315 | 37,154 | 11,161 | | | 44,502 | 11,161 | | |
| 314 TURBO GENERATORS | 7,976,637 | | 7,976,637 | 7,827,593 (C) | | 49,044 | 37,715 | 11,329 | | | 7,965,308 | 11,329 | | |
| 341 STRUCTURES & IMPROV | 1,086,796 | | 1,086,796 | 1,086,796 | | 0 | 0 | 0 | | | 1,086,796 | 0 | | |
| 342 FUEL HOLDERS, PROD | 587,259 | | 587,259 | 587,259 | | 0 | 0 | 0 | | | 587,259 | 0 | | |
| 344 PRIME MOVERS/GENRTR | 12,867,276 | | 12,867,276 | 12,867,276 | | 0 | 0 | 0 | | | 12,867,276 | 0 | | |
| 345 ACCESSORY ELECTRIC | 528,112 | | 528,112 | 528,112 | | 0 | 0 | 0 | | | 528,112 | 0 | | |
| 346 MISC POWER PLANT EQ | 41,556 | | 41,556 | 41,556 | | 0 | 0 | 0 | | | 41,556 | 0 | | |
| | 47,505,720 | 414,810 | 47,720,530 | | | | | | | | 44,367,618 | 3,352,912 | | |
| | | | | | | | | | | | 0.930 | 0.070 | | |

| ACCOUNT #, TITLE | ELECTRIC P.I.S. @12/31/83 | | TOTAL P.I.S. @12/31/83 | | 100% ELECTRIC | | 100% STEAM | | REMAINING ALLOCABLE | | 900/1800# STEAM DEMAND | | TOTAL PLANT | |
|-------------------------|---------------------------|---------|------------------------|---------------|---------------|-----------|------------|--|---------------------|-------|------------------------|-----------|-------------|----------|
| | | | | | | | | | | | | ELECTRIC | STEAM | ELECTRIC |
| 310 LAND & LAND RIGHTS | 319,439 | 11,450 | 330,888 | | | 330,888 | | | 89.3% | 10.7% | 307,726 | 23,162 | | |
| 311 STRUCTURES & IMPROV | 5,839,246 | 78,800 | 5,917,946 | 18,168 (F) | 93,012 (F) | 5,805,646 | | | | | 5,399,253 | 486,385 | | |
| 315 ACCESSORY ELECTRIC | 1,861,673 | 357,844 | 2,219,517 | 1,833,808 (G) | 357,844 (G) | 527,765 | | | | | 480,821 | 36,944 | | |
| 316 MISC POWER PLANT | 1,237,264 | 64,573 | 1,401,837 | | | 1,401,837 | | | | | 1,251,840 | 149,997 | | |
| | 9,357,621 | 512,467 | 9,870,088 | | | | | | | | 8,802,794 | 1,067,354 | | |
| | 56,669,341 | 927,277 | 57,596,618 | | | | | | | | 53,170,353 | 4,420,265 | | |

BASED ON TOTAL PLANT RATIO CALCULATED ABOVE

69.0% ELECTRIC 7.0% STEAM

89.3% ELECTRIC 10.7% STEAM

COAL HANDLING ALLOCATED 74.1% ELECTRIC AND 25.9% ALLOCABLE PER LAKE ROAD'S 1994 STUDY

BOLER #5 & #6 COMMON ASH HANDLING EQUIPMENT ALLOCATED 13.2% ELECTRIC AND 86.8% ALLOCABLE BASED ON DEMAND

WATER SOFTENER BUILDING, WATER TREATMENT BUILDING & POWER PLANT BUILDING, 82.9% STEAM & 17.1% ELECTRIC PER LAKE ROAD'S 1994 STUDY

\$527,765 ALLOCABLE PER LAKE ROAD'S 1994 STUDY AND THE REMAINING IS SPECIFICALLY IDENTIFIABLE

1800 lb

COAL Jumper note

20-Dec-94

LAKE ROAD ALLOCATION
DECEMBER 31, 1983 - RESERVE ALLOCATION

| ACCOUNT #, TITLE | ELECTRIC P.I.S. @12/31/83 | STEAM P.I.S. @12/31/83 | TOTAL ALLOCATED STEAM PLANT | ALLOCATION ADJUSTMENT | RATIO OF ADJUSTMENT TO ELECTRIC P.I.S. | ELECTRIC RESERVE BALANCE (2) @12/31/83 | ELECTRIC RESERVE ALLOCATED TO STEAM |
|-------------------------|---------------------------|------------------------|-----------------------------|-----------------------|--|--|-------------------------------------|
| 312 BOILERS | 15,788,699 | 414,810 | 2,917,465 | 2,402,655 | 11.97% (1) | 17,680,609 | 2,116,369 |
| 312A COAL HANDLING | 8,573,722 | 0 | 512,957 | 512,957 | | | 0 |
| 312B ASH HANDLING | 55,663 | 0 | 11,161 | 11,161 | | | |
| 314 TURBO GENERATORS | 7,976,637 | 0 | 11,329 | 11,329 | 0.14% | 5,872,266 | 6,221 |
| 341 STRUCTURES & IMPRO | 1,086,796 | 0 | 0 | 0 | 0.00% | 1,016,795 | 0 |
| 342 FUEL HOLDERS, PROD | 587,259 | 0 | 0 | 0 | 0.00% | 557,092 | 0 |
| 344 PRIME MOVERS/GENRT. | 12,667,276 | 0 | 0 | 0 | 0.00% | 7,218,320 | 0 |
| 345 ACCESSORY ELECTRIC | 528,112 | 0 | 0 | 0 | 0.00% | 523,744 | 0 |
| 346 MISC POWER PLANT E | 41,556 | 0 | 0 | 0 | 0.00% | 18,915 | 0 |
| | 47,305,720 | 414,810 | | | | | |
| 310 LAND & LAND RIGHTS | 319,438 | 11,450 | 23,162 | 11,712 | 3.67% | | 0 |
| 311 STRUCTURES & IMPROV | 5,639,246 | 78,600 | 499,407 | 420,807 | 7.21% | 2,246,069 | 161,942 |
| 315 ACCESSORY ELECTRIC | 1,861,673 | 357,844 | 394,788 | 36,944 | 1.98% | 1,586,729 | 31,615 |
| 316 MISC POWER PLANT | 1,337,264 | 64,573 | 149,937 | 85,424 | 6.39% | 752,464 | 48,084 |
| | 9,357,621 | 512,467 | | | | | |
| | 56,663,341 | 927,277 | 4,420,265 | 3,492,988 | | 37,483,023 | 2,366,231 |

(1) RATIO IS BASED ON A/C'S 312 AND 312A
(2) Source for reserve is Accumulated Provision for Depreciation.

20-Dec-94

ST. JOSEPH LIGHT & POWER COMPANY
 LAKE ROAD PLANT ALLOCATION - SETTLEMENT SCENARIO
 DECEMBER 91, 1993 DATA - PLANT ACCOUNT 312

| | ELECTRIC P.I.S. @12-31-93 | | TOTAL P.I.S. @12-31-93 | | 100% ELECTRIC @12-31-93 | | 100% STEAM @12-31-93 | | ELECTRIC & STEAM ALLOCABLE | | 900% STEAM DEMAND ELECTRIC STEAM | | TOTAL PLANT ELECTRIC STEAM | |
|---|---------------------------|--|------------------------|--|-------------------------|--|----------------------|--|----------------------------|--|----------------------------------|-----------|----------------------------|-----------|
| | | | | | | | | | | | | | | |
| REMAINDER OF 312 INCLUDING BOILERS #1-3 | | | | | | | | | | | | | | |
| TOTAL 1,2 & 3 @12-31-93 | 4,483,572 | | 4,483,572 | | 4,483,572 | | 4,483,572 | | 4,483,572 | | 3,447,867 | 1,035,705 | 3,447,867 | 1,035,705 |
| BOILERS #4 & #5 | | | | | | | | | | | | | | |
| TOTAL 4 & 5 @12-31-93 | 4,546,149 | | 4,546,149 | | 4,546,149 | | 4,546,149 | | 4,546,149 | | 3,487,527 | 1,058,622 | 3,487,527 | 1,058,622 |
| BOILER #6 | | | | | | | | | | | | | | |
| BOILER PRECIPITATOR, CRUSHER, & CRUSHER HOUSE | 6,325,229 | | 6,325,229 | | 6,325,229 | | 6,325,229 | | 6,325,229 | | 0 | 0 | 6,325,229 | 0 |
| STEAM PIPING & WATER PUR. | | | | | | | | | | | | | | |
| in a/c 1312 | 431,749 | | 431,749 | | 431,749 | | 357,920 | | 357,920 | | 0 | 0 | 73,829 | 357,920 |
| in a/c 6912 | | | 414,810 | | 414,810 | | 360,729 | | 54,087 | | 41,593 | 12,494 | 41,593 | 372,217 |
| | 15,786,699 | | 16,203,509 | | 16,203,509 | | 6,399,058 | | 718,643 | | 6,966,987 | 2,098,821 | 13,996,045 | 2,817,484 |
| | | | ELECTRIC | | STEAM | | | | | | | | | |
| FUEL CONSUMPTION DEMAND FACTOR | | | 0.0% | | 0.0% | | 76.9% | | 23.1% | | | | | |

ST. JOSEPH LIGHT & POWER
 PROPERTY WORKSHEET FOR ALLOCATION OF
 STEAM AND ELECTRIC PLANT
 A/C 312

NOTE "A"
 PRECIPITATOR #6, BOILER #6, CRUSHER, & CRUSHER HOUSE

| MO/YR | DESCRIPTION | J.O. # | AMOUNT |
|----------|---|----------|--------------------|
| 09/30/91 | BEGINNING BALANCE FROM PREVIOUS WORKSHEETS | | \$5,983,318 |
| 12/31/92 | NO ACTIVITY FOR THE YEAR | | 0 |
| 09/30/93 | NO ACTIVITY FOR THE YEAR | | 0 |
| | BALANCE @ 09/30/93 | | <u>\$5,983,318</u> |
| 12/31/93 | Vent Line from Slag Tank to East Shothopper – Boiler #6 | 8144-002 | 13,613 |
| 12/31/93 | Dissolved Oxygen Analyzer System – Boiler #6 | 8146-001 | \$3,638 |
| | Dissolved Oxygen Analyzer System Probe – Boiler #6 | " | 1,686 |
| | | | <u>\$18,937</u> |
| | BALANCE @ 12/31/93 | | <u>\$6,002,255</u> |
| | #1 CRUSHER & CRUSHER HOUSE | | 200,626 |
| | #2 CRUSHER | | <u>122,348</u> |
| | TOTAL | | <u>\$6,325,229</u> |

ST. JOSEPH LIGHT & POWER
 PROPERTY WORKSHEET FOR ALLOCATION OF
 STEAM AND ELECTRIC PLANT
 A/C 312

NOTE "B"

STEAM PIPING & WATER PURIFICATION EQUIPMENT

| | <u>DIRECTLY ASSIGNABLE</u> <u>STEAM</u> | <u>ELECTRIC</u> | <u>ALLOCABLE</u> |
|---|--|-----------------|------------------|
| Steam piping & Water Purification equipment in plant account 1312 that is considered | \$357,920 | \$73,829 | |
| Plant account 6312 - 54,087 is considered allocable and the remainder of the plant A/C is considered 100% steam | 360,723 | | 54,087 |
| | <u>\$718,643</u> | <u>\$73,829</u> | |
| Balance @ 12/93 | \$414,810 | | |
| Less Allocable | 54,087 | | |
| 100% Steam | <u>\$360,723</u> | | |

ST. JOSEPH LIGHT & POWER
PROPERTY WORKSHEET FOR ALLOCATION
OF STEAM AND ELCETRIC PLANT
A/C 312

NOTE "B"
(BACKUP)

STEAM PIPING & WATER PURIFICATION EQUIPMENT

| MO/YR | DESCRIPTION | J.O. # | AMOUNT |
|-------|---|----------|------------------|
| | Pipe Steam to Softner | | \$13,948 |
| | Phosphate Pump Discharge | | 6,607 |
| | Phosphate Pump Suction | | 2,086 |
| | Water Purification Equipment | | 29,751 |
| | Softner Equipment | | 138,658 |
| | Supply & Purification Equipment | | 67,344 |
| | Purification Equipment | | 408 |
| | Feedwater System | | 10,665 |
| | Feedwater Pumps | | 2,709 |
| | Unchanged Since 4/11/88 | | <u>\$272,176</u> |
| 12/93 | Vent Condenser - Softner #4 | 8126-010 | \$7,401 |
| 12/93 | Loop Seal Piping - Softner #4 | " | 21,187 |
| 12/93 | Effluent Piping - Softner #4 | " | 10,284 |
| 12/93 | Gate Valves - Softners #1,2,3, & 4 | " | 18,957 |
| 12/93 | Vacuum Breakers - Softners #2 & #3 | " | 1,048 |
| 12/93 | 5" Gate Valve for Backwash - Softner #4 | " | 1,560 |
| 12/93 | 8" Gate Valve - Primary bypass between pump suction header and pressure filter inlet headers. | " | 966 |
| 12/93 | Insulation - Top shell Softner #4 | " | 2,416 |
| 12/93 | 3" Stainless Steel Valve - 316 with EPR Seat for Softners #2 & #3 | " | 2,310 |
| 12/93 | Well Water Piping & Valves Softner #2, 3, & 4. | 8126-012 | 47,686 |
| 12/93 | Booster Pump #1 | 8126-013 | 9,006 |
| 12/93 | Booster Pump #2 | " | 9,006 |
| 12/93 | Booster Pump #3 | " | 11,411 |
| 12/93 | Piping Insulation and Valves - Booster Pumps 1,2,3. | " | 15,001 |
| 12/93 | Skid Drains - 3 booster pumps to sewer | " | 1,334 |
| | Total for 1993 Activity | | <u>\$159,573</u> |
| | New Balance @ 12/31/93 | | \$431,749 |
| | | | X .829 |
| | Balance @ 12/31/93 Directly Assignable to Steam | | <u>\$357,920</u> |
| | Balance @ 12/31/93 Directly Assignable to Electric | | <u>\$73,829</u> |

ST. JOSEPH LIGHT & POWER
PROPERTY WORKSHEET FOR ALLOCATION
OF STEAM AND ELCTERIC PLANT
A/C 6312

NOTE 'B'
(BACKUP)

STEAM PIPING & WATER PURIFICATION EQUIPMENT

| MO/YR | DESCRIPTION | J.O. # | AMOUNT |
|-------|---|--------|-----------------|
| | Items Considered Allocable Plant | | |
| | Boiler #1 Foundation | | \$16,910 |
| | Boiler #2 Foundation | | 16,910 |
| | Fuel Oil Tank #1 | | 3,813 |
| | Fuel Oil Tank #3 | | 7,622 |
| | House Service Tanks | | 362 |
| | Boiler #3 Panels | | 244 |
| | Steam Pressure Equipment | | 4,892 |
| | High Level Storage Tanks | | 849 |
| | Fuel Oil Pipes | | 2,485 |
| | Total Allocable Plant | | <u>\$54,087</u> |

ST. JOSEPH LIGHT & POWER
PROPERTY WORKSHEET FOR ALLOCATION OF
STEAM AND ELECTRIC PLANT
A/C 314

NOTE "C"

TURBINE #1

| MO/YR | DESCRIPTION | J.O. # | AMOUNT |
|-------|-------------------------------|------------|------------------|
| 12/50 | Exciter | 134100 | \$810,185 |
| 12/50 | Reinforced concrete | 134100 | 19,694 |
| 12/50 | Hydrogen cooling system | 134100 | 5,135 |
| 12/56 | #1 Turbine #328D965 | Sum 56-344 | 3,836 |
| 12/56 | 1 1/4" return oil piping | Sum 56-344 | 67 |
| 12/56 | 2 1/2" return oil piping | Sum 56-344 | 107 |
| 12/56 | 3" return oil piping | Sum 56-344 | 51 |
| 12/56 | Pneumatic control pilot | Sum 56-344 | 123 |
| 02/92 | Bailey transmitter 0-12 | 8132-004 | 3,126 |
| 02/92 | Bailey transmitter 0-400 | 8132-004 | 1,563 |
| 02/92 | Bailey transmitter 0-120 | 8132-004 | 1,749 |
| 02/92 | Bailey temp transmitter | 8132-004 | 9,783 |
| 02/92 | Vortex flow meter | 8132-004 | 3,194 |
| 02/92 | Flow totalizer computer | 8132-004 | 4,103 |
| 02/92 | Circular chart recorder | 8132-004 | 24,006 |
| 02/92 | Enhanced control module | 8132-004 | 21,497 |
| | BALANCED @ 12/31/93 | | <u>\$908,219</u> |
| | Allocated to Electric - 94.6% | | \$859,175 |
| | Allocable - 5.4% | | <u>49,044</u> |
| | | | <u>\$908,219</u> |

| DATE | AMOUNT | PROJECT | CD | DESCRIPTION | CD | KEY | CD | PROJECT | CD | DATE | AMOUNT | TOTAL |
|----------|---------|---------|----|----------------|----|-----|----|---------|----|----------|---------|----------|
| 12/10/00 | 1000.00 | 124100 | N | EXHAUST SYSTEM | | | | 124100 | | 12/10/00 | 1000.00 | 1000.00 |
| 12/10/00 | 1000.00 | 124100 | N | EXHAUST SYSTEM | | | | 124100 | | 12/10/00 | 1000.00 | 2000.00 |
| 12/10/00 | 1000.00 | 124100 | N | EXHAUST SYSTEM | | | | 124100 | | 12/10/00 | 1000.00 | 3000.00 |
| 12/10/00 | 1000.00 | 124100 | N | EXHAUST SYSTEM | | | | 124100 | | 12/10/00 | 1000.00 | 4000.00 |
| 12/10/00 | 1000.00 | 124100 | N | EXHAUST SYSTEM | | | | 124100 | | 12/10/00 | 1000.00 | 5000.00 |
| 12/10/00 | 1000.00 | 124100 | N | EXHAUST SYSTEM | | | | 124100 | | 12/10/00 | 1000.00 | 6000.00 |
| 12/10/00 | 1000.00 | 124100 | N | EXHAUST SYSTEM | | | | 124100 | | 12/10/00 | 1000.00 | 7000.00 |
| 12/10/00 | 1000.00 | 124100 | N | EXHAUST SYSTEM | | | | 124100 | | 12/10/00 | 1000.00 | 8000.00 |
| 12/10/00 | 1000.00 | 124100 | N | EXHAUST SYSTEM | | | | 124100 | | 12/10/00 | 1000.00 | 9000.00 |
| 12/10/00 | 1000.00 | 124100 | N | EXHAUST SYSTEM | | | | 124100 | | 12/10/00 | 1000.00 | 10000.00 |

COUNT- 108 909,219.41

COUNT- 108 909,219.41

X 5.4% Stream

49,097.85

Turbine #1

ST. JOSEPH LIGHT & POWER
PROPERTY WORKSHEET FOR ALLOCATION OF
STEAM AND ELECTRIC PLANT
A/C 312

NOTE "D"

COAL HANDLING EQUIPMENT

| MO/YR | DESCRIPTION | J.O. # | AMOUNT |
|----------|---|----------|---------------------------|
| 09/30/91 | BEGINNING BALANCE FROM PREVIOUS WORKSHEETS | | \$8,846,252 |
| 11/91 | ADDITIONAL CLOSING | 8122-029 | 1,494 |
| 11/91 | ADDITIONAL CLOSING | 8122-033 | 855 |
| 12/91 | TWO COAL BATCH RETROFITS | 8128-005 | 34,809 |
| 05/92 | ASH WETTING SYSTEM | 8124-002 | 7,193 |
| 10/92 | CS137 CESIUM - FEEDERS FOR 6-1/6-2 | 8122-035 | 13,596 |
| 09/30/93 | NO ACTIVITY FOR THE YEAR | | 0 |
| | BALANCE @ 09/30/93 | | <u>\$8,904,199</u> |
| 12/93 | 1992 Shuttle Wagon Rail Car Mover (SN 5M3508) | 8124-005 | \$154,608 |
| 12/93 | RETIREMENT - Shuttle Wagon Rail Car Mover | 9124-001 | (112,660) |
| 12/93 | RETIREMENT - Trackmobile M #8 TM White 8015 | 9124-001 | <u>(49,451)</u> |
| | BALANCE @ 12/31/93 | | <u>\$8,896,696</u> |
| | LESS #1 CRUSHER & CRUSHER HOUSE | | (200,626) |
| | LESS #2 CRUSHER | | <u>(122,348)</u> |
| | TOTAL | | <u><u>\$8,573,722</u></u> |

ST. JOSEPH LIGHT & POWER
PROPERTY WORKSHEET FOR ALLOCATION OF
STEAM AND ELECTRIC PLANT
A/C 312

NOTE 'E'

BOILER #5 & #6 – COMMON ASH HANDLING EQUIPMENT

| MO/YR | DESCRIPTION | J.O. # | AMOUNT |
|-------|-----------------------------------|---------|------------------------|
| 12/50 | ASH 20' DIA. X 24' | 1341000 | \$18,055 |
| 12/50 | ASH PIT HOPPER | 1341000 | 3,457 |
| 12/50 | ASH PIT REINFORCED CONCRETE | 1341000 | 734 |
| 12/50 | ASH CONVEYOR SYSTEM | 1341000 | <u>33,417</u> |
| | BALANCE @ 12/31/93 | | <u><u>\$55,663</u></u> |
| | Allocated to Electric – 13.2% | | \$7,348 |
| | Allocable based on Demand – 86.8% | | <u>48,315</u> |
| | | | <u><u>\$55,663</u></u> |

ST. JOSEPH LIGHT & POWER
PROPERTY WORKSHEET FOR ALLOCATION OF
STEAM AND ELECTRIC PLANT
A/C 311 & 6311

NOTE "F"

WATER SOFTNER BLDG, WATER TREATMENT, & POWER PLANT BLDG

| MO/YR | DESCRIPTION | J.O. # | AMOUNT |
|----------|--|--------|------------------|
| 09/30/91 | BEGINNING BALANCE FROM PREVIOUS WORKSHEETS | | \$112,198 |
| 12/31/92 | NO ACTIVITY FOR THE YEAR | | 0 |
| 09/30/93 | NO ACTIVITY FOR THE YEAR | | 0 |
| 12/31/93 | NO ACTIVITY FOR THE YEAR | | 0 |
| | BALANCE @ 12/31/93 | | <u>\$112,198</u> |
| | 17.1% to Electric | | \$19,186 |
| | 82.9% to Steam | | 93,012 |
| | | | <u>\$112,198</u> |

ST. JOSEPH LIGHT & POWER
PROPERTY WORKSHEET FOR ALLOCATION OF
STEAM AND ELECTRIC PLANT
A/C 315

NOTE "G"

ACCESSORY ELECTRIC

| MO/YR | DESCRIPTION | J.O. # | AMOUNT |
|-------|-----------------------------------|---------|------------------|
| 12/50 | Main control panel | 134100 | \$14,868 |
| 9/93 | Motor control center | 8132007 | 12,249 |
| 9/67 | Battery 60 cell 125V 498 AH | 112571 | 8,734 |
| 4/86 | EV-7 Lead calcuim batteries | 8146065 | 8,118 |
| 9/91 | 30 KV inverter w/static switch | 8136001 | 30,086 |
| 9/91 | Installation charges inverter | 8136001 | 18,759 |
| 9/91 | 300 amp battery charger | 8136001 | 16,268 |
| 9/91 | Installation charges battery | 8136001 | 8,767 |
| 9/91 | 60 amp auto transfer switch | 8136001 | 5,213 |
| 9/91 | 100 amp disconnect switch | 8136001 | 10,480 |
| 9/91 | Power distribution panel | 8136001 | 38,770 |
| 12/58 | Load circuit unit 480V | 196000 | 17,639 |
| 4/85 | Load circuit unit 1000V | 8136002 | 24,127 |
| 4/85 | #1 Load ctr. unit | 8136002 | 26,849 |
| 12/50 | Motor control center #1 | 134100 | 8,677 |
| 12/50 | Motor control center #2 | 134100 | 5,723 |
| 12/62 | Motor control center | 8146000 | 6,199 |
| 4/85 | #2 house service trans | 8136002 | 48,865 |
| 12/85 | #1 station lighting trans | 8136002 | 22,172 |
| 12/85 | #1 house service trans | 8136002 | 40,402 |
| 12/50 | 1 1/2" conduit | 134100 | 7,512 |
| 12/50 | 2" conduit | 134100 | 5,207 |
| 12/50 | 3/4" conduit | 134100 | 11,213 |
| 12/63 | 2400 V #2 swchg | 136911 | 7,005 |
| 12/58 | 1" steel conduit | 196000 | 8,742 |
| 12/58 | 3" steel conduit | 196000 | 6,466 |
| 12/58 | 24" cope mesh type | 196000 | 6,358 |
| 12/62 | Conduit station 3/4" steel 3" | 8146000 | 19,415 |
| 9/76 | #1/0 AL 35KV Urd cable | 8122008 | 5,200 |
| 12/58 | Control cubicle assembly | 198000 | 15,162 |
| 12/50 | Swichgear metal clad whse | 134100 | 33,869 |
| 12/50 | 480 V switchgear metal clad molon | 134100 | 15,241 |
| 12/64 | #500 MCM | 184800 | 6,011 |
| 12/58 | 30S grounding syt. | 196000 | 7,399 |
| | ALLOCABLE BALANCE @ 12/31/93 | | <u>\$527,765</u> |

December 16, 1994

ST. JOSEPH LIGHT & POWER COMPANY
 ALLOCATION FACTORS
 Exergy-Basis
 CASE NO. EO-94-36

| | |
|---|-------|
| Plant Capacity Factor (PCTOD) | 12.9% |
| Equivalent Employment Factor (PCTEQR) | 31.3% |
| 900 lb Steam Demand Allocation Factor (PCTMD) | 23.1% |
| 900 lb Steam Fuel Consumption Factor (PCTMF) | 75.5% |
| Coal Burned Allocation Factor (PCTCB) | 31.2% |
| Plant Structure Allocation (PCTPLT) | 13.6% |
| 900 LB Coal Use Factor (PCTCU) | 77.0% |
| Ash Allocation Factor for Steam (daily) (AAFS) | 74.0% |
| Combustion Turbine/Plant Capacity Factor | 38.4% |
| 900/1800 LB Steam Plant Demand Factor | 10.7% |

MEMORANDUM

From the Desk of
John Modlin
Lake Road Results

January 28, 1994

TO: Dwight Svuba, Charles Cline, Mike Smith, Tim Rush

RE: PSC Case EO-94-36: Turbine 1 Capital Cost Allocation Study

I have obtained budgetary cost figures for two 24 MW steam turbine-generator units from a turbine-generator vendor to determine an "allocable fraction" of the Turbine 1 capital cost. The cost of the standard unit is 5.4% less than the auto-extraction unit. The prices include the turbine, generator, exciter, control valves, certain auxiliary systems, factory tests, and technical direction of installation.

I asked the vendor to break out the turbine and turbine-related items, but they replied that they supply a "package price" only. The two quoted units have identical generators, exciters, as well as other common equipment. The vendor did confirm that the cost difference is due to the auto-extraction capability alone.

I reviewed the equipment list provided by General Electric for Turbine 1 (SJLP P.O. 660461, c. 1950). The scope of equipment provided under the Turbine 1 P.O. is essentially the same as that included in the above "packages." It is not appropriate to allocate a portion of the generator and exciter to the industrial steam system. However, it is appropriate to estimate the original cost of the auto-extraction capability by applying a factor based on the current "package" quotes to the actual Turbine 1 "package" price.

Using the vendor's price estimates and the PSC Staff's proposed approach, the fraction of the Turbine 1 capital cost to be attributed to the auto-extraction capability would be 5.4%. If used, this factor should be applied to the complete Turbine 1 "package" only, as noted above.

As we discussed with the PSC Staff, it is possible for an auto-extraction unit to provide the same generating capacity as a standard unit while using a smaller condenser, cooling tower, and related equipment. Therefore, there was a possibility that these components were "under-sized" during design, which would yield capital cost savings to offset the additional cost of the Turbine 1 auto-extraction capability. I researched the design specifications of the Turbine 1 condenser, cooling tower, and related equipment. This equipment was adequately sized to allow the flexibility of operating Turbine 1 near full load as a standard steam turbine. That is, it does not appear that this equipment was "under-sized" due to Turbine 1's auto-extraction capability.

If you have any questions, please call me at extension 266.

cc: file

John + Modlin

- PLANT ALLOCATION PROCEDURE -
LAKE ROAD FEEDWATER TREATMENT FACILITIES

INTRODUCTION

This procedure describes the methodology for allocating feedwater treatment equipment plant investment at Lake Road Plant between the electric and steam jurisdictions. It applies only to the water treatment equipment located in the 900 psi plant; it does not apply to the 1800 psi system demineralizer equipment which is only used for electric purposes serving Boiler 6.

The procedure for determining the allocation factor starts by estimating the peak treated water makeup requirement, in pounds per hour, for the electric jurisdiction (only), assuming the steam jurisdiction is not present. Next, an estimate of the total plant peak makeup requirement is determined, assuming simultaneous maximum makeup demands for each jurisdiction. These two quantities identify the treated water plant sizing criteria needed for the allocation. A conceptual equipment arrangement is prepared for each case, optimizing the design where possible to fit the sizing application. Factors such as redundancy for maintenance, filter backwash and zeolite regeneration requirements, hot versus cold lime treating, and equipment sizing margins are considered in the conceptual analysis. Cost estimates are prepared to implement each conceptual system. The allocation factor for the electric jurisdiction is then calculated by the ratio of the two cost estimates (electric water treatment plant cost divided by total water treatment plant cost). The allocation factor for the steam jurisdiction is one minus the electric jurisdiction factor.

In preparing the cost estimates, budgetary vendor prices were solicited for major system components only (lime softeners, pressure filters, zeolite softeners, and mixed bed demineralizers). It was assumed that all interconnecting pipe, ancillary equipment, and engineering costs associated with constructing the two systems would be proportional to the main component costs and thus would have no effect on the calculated ratio.

Two scenarios were established to identify the maximum-hour treated water makeup loads, a summertime electric (only) peak scenario and a wintertime (electric + steam) total peak scenario. Detailed explanations of each scenario are presented later in the discussion. In developing the scenarios, it was necessary to identify all significant consumptions of treated water and to estimate their approximate magnitudes during peak-use conditions. A discussion of the rationale used in developing each conceptual water treatment system plan is also included.

As an aid to the reader, a brief description of Lake Road Plant is provided first to explain the overall water treatment process and show the location of treated water uses.

DESCRIPTION OF WATER TREATMENT SYSTEM & RELATED WATER USES

Refer to Figure 1 for a simplified schematic diagram of the Lake Road water treatment system and related flow paths of treated water uses identified in this discussion.

Raw well water for treated water makeup is brought into the plant and treated before being used in the 900 psi system boilers. "Treated water makeup" is treated water brought into the system to replenish mass flows of water and steam that leave the plant cycle. Water treatment is necessary because raw well water has too much hardness and other impurities for direct use in the Lake Road boilers.

The water treatment system is comprised of three major equipment components, hot lime softeners, pressure filters and zeolite softeners. The hot lime softeners remove most of the hardness and other contaminants through a chemical reaction that causes the unwanted material to precipitate out of solution where it can be removed as sludge. Lime and other chemicals are added to cause the chemical reaction. Steam is also added to accelerate the reaction by raising the temperature. The system has four hot lime softeners connected in parallel.

After leaving the hot lime softeners, water is sent through the pressure filters for removal of suspended solids. There are eleven pressure filters connected in parallel. Each filter is taken out of service and backwashed once a day to remove accumulated material.

Final treatment is done in the zeolite softeners where essentially all of the remaining hardness is removed. This type of softener contains a resin material that functions as a cation exchanger to collect unwanted calcium and magnesium hardness ions in exchange for sodium ions implanted in the resin. Zeolite softeners must be regenerated periodically to remove collected hardness ions and replace spent sodium ions. It typically takes 8-12 hours to regenerate each softener. The system has four zeolite softeners connected in parallel. A brine system is used to replace spent sodium ions. Backwash, rinse and recycle provisions are also required.

After leaving the water treatment system, makeup water is sent to the deaerator where it is mixed with returned condensate from the plant's 900 psi system turbine cycle. From there it goes to the boiler feedpumps which pump it into the 900 psi system boilers.

Each 900 psi system boiler has two flow outputs, superheated steam and continuous (water) blowdown. Output steam flows into a header distribution system that supplies steam for the industrial steam customers, the 900 psi system turbines and various internal plant uses. Many of these steam functions, including industrial steam, do not allow for returning condensate to the plant cycle. These uses require makeup of new treated water to replenish all lost flows. Figure 1 provides a list of steam flow functions which do not return condensate.

Continuous blowdown is required to prevent solids from accumulating in the boilers. The water treatment system removes essentially all hardness, but does not remove all solids. Due to the evaporation which takes place in boilers, a continuous water blowdown flow is required to bleed off accumulated solids. The amount of blowdown required is equal to approximately 20 percent of the treated water makeup flow. The blowdown flow is first routed through flash tanks which allow part of the blowdown to flash into steam which is saved and sent to steam supply headers. The remaining blowdown water then flows through heat exchangers, which preheat the incoming well water, and is subsequently discharged to the sewer at approximately 80°F. Approximately 35 percent of the total blowdown flow leaving the boilers is recovered in the flashing process, and over 97% of the heat added to the well water is extracted before the water is sent to the sewer. This continuous blowdown sewer flow must be replenished with treated water makeup.

Steam turbines normally return essentially all of their condensate to the plant cycle via the deaerator path mentioned earlier. At Lake Road, the capability exists for routing part of the turbine condensate to an outside storage tank or to various systems and equipment that require condensate input. One of the important uses of this condensate is to supply influent water to the Boiler 6 demineralizer. Boiler 6 is a higher pressure (1800 psi) boiler which requires higher quality water than the 900 psi system boilers. A storage tank is also available for demineralized water. Other uses of condensate are identified on Figure 1. Like steam and continuous blowdown, any condensate removed from the 900 psi plant cycle must be replenished with new treated water makeup. Condensate storage serves the important function of providing a means for short-term water treatment equipment outages, and short duration treated water uses above the capacity of the water treatment equipment. Certain functions, such as filling boilers after annual outages or tube leak repair outages require a large, immediate supply of condensate-quality water.

ELECTRIC (ONLY) WATER TREATMENT PLANT PEAK LOAD SCENARIO

The peak electric (only) water treatment plant load is most likely to occur in the summertime when Lake Road generation requirements are higher and hot weather combustion turbine operation is probable. Wintertime peaks and various other situations can also dictate high electric water treatment demands. For purposes of defining a specific peak electric water treatment load scenario, a summertime situation is used.

The operating scenario used to establish the peak electric water treatment demand is as follows:

- Hot summer weather causing heavy Lake Road generating requirements.
- Unit 4/6 on line with one demineralizer operating at full load.
- All three 900# system steam turbines on line operating at current accreditation capacity (60 MW net).
- Boiler 5 on line burning coal at 250,000 lb/hr steam load.
- Boilers 1, 2, 3, and 4 on line burning oil as required to meet turbine load.
- Combustion Turbine 5 on line at full load burning gas with the evaporative cooler in operation.
- Units 6 & 7 (Jets) not on line.

The treated water makeup requirements corresponding to this operating scenario are as follows:

| <u>Makeup Load Description</u> | <u>Make up Load (1000 lbs/hr)</u> |
|---|---------------------------------------|
| Blr. 6 Demineralizer Makeup | 10.0 |
| Blr. 6 Sootblowing Steam | 3.6 |
| C.T. #5 Evaporative Cooler Makeup | 5.4 |
| 900# Blr. Continuous Blowdown (Closed System) | 1.0 |
| Blrs. #4 & #5 Sootblowing Steam | 0.6 |
| Ash Tank Vacuum System Steam | 3.0 |
| No. 6 Fuel Oil Heating Steam | 2.3 |
| No. 6 Fuel Oil Atomizing Steam | 3.2 |
| Allowance for Unidentified Uses | 1.0 |
| Allowance for Losses | 1.0 |
| 900# Blr. Continuous Blowdown (100% Makeup) | <u>5.6</u> |
| Total Electric (only) Treated Water Load | 36.7 |

TOTAL (ELECTRIC + STEAM) WATER TREATMENT PLANT PEAK LOAD SCENARIO

The peak total (electric + steam) water treatment plant load has historically happened during the winter months when industrial steam loads are highest. Lake Road electric generation requirements may also be high in this situation.

The operating scenario used to establish the peak total water treatment plant demand is as follows:

- Cold winter weather causing peak industrial steam loads and moderately heavy Lake Road generating requirements.
- Unit 4/6 on line with one demineralizer operating at full load.
- All three 900# system steam turbines on line operating at a total load of 34 megawatts.
- Boiler 5 on line burning coal at 250,000 lb/hr steam load.
- Boilers 1, 2, 3 and 4 on line burning oil as required to meet total boiler load.
- No combustion turbines on line.

The treated water makeup requirements corresponding to this operating scenario are as follows:

| <u>Makeup Load Description</u> | <u>Make up Load (1000 lbs/hr)</u> | <u>Removed</u> |
|--|---------------------------------------|----------------|
| Industrial Steam (12"+16"+AGP 850) | 290.0 | 205.0 |
| Industrial Steam (Desup. Water) | 11.0 | 11.0 |
| Blrs. #4 & #5 Sootblowing Steam | 0.6 | 0.6 |
| Ash Tank Vacuum System Steam | 3.0 | 3.0 |
| No. 6 Fuel Oil Heating Steam | 3.1 | 2.3 |
| No. 6 Fuel Oil Atomizing Steam | 3.1 | 2.4 |
| Blr. 6 Demineralizer Makeup | 10.0 | 10.0 |
| Blr. 6 Sootblowing Steam | 3.6 | 3.6 |
| Allowance for Unidentified Uses | 2.0 | 2.0 |
| Allowance for Losses | 3.0 | 3.0 |
| 900# Blr. Continuous Blowdown (100% makeup) | 58.9 | 43.6 |
| Total (Electric + Steam) Treated Water Load | 388.3 | 286.5 |

1/13/93
@1320

3/8/95
Monfort's
Swift + Adh.

CONCEPTUAL DESIGN - ELECTRIC (ONLY) SYSTEM

The following comments explain the design considerations used to develop the conceptual plan for the electric (only) water treatment system. A schematic diagram of the conceptual plan is provided with Figure 2.

TOTAL (ELECTRIC + STEAM) WATER TREATMENT PLANT PEAK LOAD SCENARIO

The peak total (electric + steam) water treatment plant load has historically happened during the winter months when industrial steam loads are highest. Lake Road electric generation requirements may also be high in this situation.

The operating scenario used to establish the peak total water treatment plant demand is as follows:

- Cold winter weather causing peak industrial steam loads and moderately heavy Lake Road generating requirements.
- Unit 4/6 on line with one demineralizer operating at full load.
- All three 900# system steam turbines on line operating at a total load of 34 megawatts.
- Boiler 5 on line burning coal at 250,000 lb/hr steam load.
- Boilers 1, 2, 3 and 4 on line burning oil as required to meet total boiler load.
- No combustion turbines on line.

The treated water makeup requirements corresponding to this operating scenario are as follows:

| <u>Makeup Load Description</u> | <u>Make up Load (1000 lbs/hr)</u> |
|--|---------------------------------------|
| Industrial Steam (12"+16"-AGP 850) | 290.0 |
| Industrial Steam (Desup. Water) | 11.0 |
| Blrs. #4 & #5 Sootblowing Steam | 0.6 |
| Ash Tank Vacuum System Steam | 3.0 |
| No. 6 Fuel Oil Heating Steam | 3.1 |
| No. 6 Fuel Oil Atomizing Steam | 3.1 |
| Blr. 6 Demineralizer Makeup | 10.0 |
| Blr. 6 Sootblowing Steam | 3.6 |
| Allowance for Unidentified Uses | 2.0 |
| Allowance for Losses | 3.0 |
| 900# Blr. Continuous Blowdown (100% makeup) | 58.9 |
| Total (Electric + Steam) Treated Water Load | 388.3 |

1/13/93
@ 1320

CONCEPTUAL DESIGN - ELECTRIC (ONLY) SYSTEM

The following comments explain the design considerations used to develop the conceptual plan for the electric (only) water treatment system. A schematic diagram of the conceptual plan is provided with Figure 2.

- The conceptual electric (only) water treatment system is sized for a continuous output capacity of 40,000 lbs/hr. This is determined by rounding up the calculated peak electric (only) treated water load (36,700 lb/hr).
- The same general arrangement of major equipment components is used for the conceptual electric (only) water treatment system as that used in the actual existing system, with the exception that the zeolite softeners are replaced with mixed bed demineralizers (lime softener - pressure filter - zeolite softener/demineralizer).
- Cold lime softeners are used in the electric (only) system instead of hot lime softeners. Cold lime softeners are less costly to install, but are not practical for the larger sizes required for the full-sized system. They could be used in the smaller electric (only) system.
- A 25 percent capacity design margin is used to size the lime softeners. This is based on SCLP experience. Increased size is needed to accommodate backwashing of pressure filters and zeolite softeners, sludge blowdown and stable sludge bed operation under varying load conditions.
- Two half-capacity lime softeners are used instead of one full-sized one to allow a means of taking units out of service for maintenance during reduced load periods.
- Three half-capacity pressure filters are used to allow for daily backwashing of each filter while still maintaining full throughput capacity. It is assumed units could be taken out of service for maintenance on a planned basis during low load periods. Pressure filters are slightly oversized to provide additional flow capacity needed for zeolite rinsing and recycling.
- Zeolite softeners do not adequately treat water from cold lime softeners for use in 900 psi boilers. Therefore, mixed bed demineralizers must be used for the final stage of feedwater treatment. Three half-capacity mixed bed demineralizers are used to allow for regeneration of each demineralizer. It is assumed units could be taken out of service for maintenance on a planned basis during low load periods. No capacity margin is used to size the demineralizers.

CONCEPTUAL DESIGN - TOTAL (ELECTRIC + STEAM) SYSTEM

The following comments explain the design considerations used to develop the conceptual plan for the total (electric + steam) water treatment system. A schematic diagram of the conceptual plan is provided with Figure 3.

- The conceptual total (electric + steam) water treatment system is sized for a continuous (gross) output capacity of 450,000 lbs/hr. This value is determined by increasing the calculated peak makeup load (388,300 lbs/hr) by 13.2 percent to account for 3 psi steam flow and then rounding up to 450,000 lbs/hr. The (net) treated water output capacity of the system is 397,500 lbs/hr. Use of hot lime softeners increases the size requirements of downstream pressure filters and zeolite softeners due to the additional flow of 3 psi steam through these components.
- The same general arrangement of major equipment components is used for the conceptual total (electric + steam) water treatment system as that used in the actual existing system (lime softener - pressure filter - zeolite softener).
- Hot lime softeners are used in the total (electric + steam) system due to the prohibitively large physical size of equivalent capacity cold lime softeners.
- Three pound steam (equal to approximately 13.2 percent of the influent well water flow) is used to provide heat for the hot lime softeners.
- A 25 percent capacity design margin is used to size the lime softeners. This is based on SUIP experience. Increased size is needed to accommodate backwashing of pressure filters and zeolite softeners, sludge blowdown and stable sludge bed operation under varying load conditions.
- Four one-fourth capacity lime softeners are used instead of one full sized one to allow a means of taking units out of service for maintenance during reduced load periods. This is the same number of lime softeners in the existing system.
- Eleven one-tenth capacity pressure filters are used to allow for daily backwashing of each filter while still maintaining full throughput capacity. It is assumed units could be taken out of service for maintenance on a planned basis during low load periods. Pressure filters are slightly oversized to provide additional flow capacity for zeolite rinsing and recycling. This is the same number of pressure filters as in the existing system.
- Four one-third capacity zeolite softeners are used to allow for regeneration of each zeolite softener. It is assumed units could be taken out of service for maintenance on a planned basis during low load periods. No capacity margin is used to size the zeolite softeners. There are four zeolite softeners in the existing system.

EQUIPMENT PRICES

The following budgetary vendor prices were obtained for the major water treatment system components.

Electric (only) System:

| | |
|---|---------------------|
| Cold Lime Softener (28,000 lbs/hr capacity) | Price: \$ 34,000 ea |
| Pressure Filters (23,000 lbs/hr capacity) | Price: \$ 10,000 ea |
| Mixed Bed Demineralizers (23,000 lbs/hr capacity) | Price: \$ 25,000 ea |

Total (Electric + Steam) System:

| | |
|--|----------------------|
| Hot Lime Softeners (140,000 lbs/hr capacity) | Price: \$ 161,250 ea |
| Pressure Filters (50,000 lbs/hr capacity) | Price: \$ 20,455 ea |
| Zeolite Softeners (150,000 lbs/hr capacity) | Price: \$ 35,000 ea |

CALCULATION OF ALLOCATION FACTOR


The electric jurisdiction water treatment equipment plant allocation factor is calculated as follows:

$$\begin{aligned}
 EF &= \frac{\text{Total Electric (only) Water Treatment Plant Cost}}{\text{Total (Electric + Steam) Water Treatment Plant Cost}} \\
 &= \frac{2(\text{LS}) + 3(\text{PF}) + 3(\text{DM})}{4(\text{LS}) + 11(\text{PF}) + 4(\text{ZS})} \\
 &= \frac{2(34,000) + 3(10,000) + 3(25,000)}{4(161,250) + 11(20,455) + 4(35,000)} = \frac{173,000}{1,010,005} \\
 &= \underline{0.1713}
 \end{aligned}$$

The steam jurisdiction water treatment equipment plant allocation factor is calculated as follows:

$$\begin{aligned}
 SF &= 1.0 - EF \\
 &= 1.0 - 0.1713 \\
 &= \underline{0.8287}
 \end{aligned}$$


SCHEMATIC FLOW DIAGRAM
ELECTRIC (ONLY) CONCEPTUAL WATER TREATMENT SYSTEM
(FIGURE 2)



NOTES

1. NUMBERS SHOWN ON SCHEMATIC ARE FLOW RATES IN 1000 LBS./HR.
2. NUMBERS SHOWN INSIDE DEVICES ARE EQUIPMENT CAPACITY RATINGS USED FOR PRICING.
3. NUMBERS SHOWN OUTSIDE DEVICES ARE FLOW RATES THAT WOULD OCCUR AT RATED SYSTEM CAPACITY. IT IS ASSUMED THAT ONE PRESSURE FILTER IS OUT OF SERVICE FOR BACKWASH AND ONE DEMINERALIZER IS OUT OF SERVICE FOR REGENERATION (IN ITS RINSE CYCLE).


SCHEMATIC FLOW DIAGRAM
 TOTAL (ELECTRIC & STEAM) CONCEPTUAL WATER TREATMENT SYSTEM
 (FIGURE 3)



NOTES


1. NUMBERS SHOWN ON SCHEMATIC ARE FLOW RATES IN 1000 LBS./HR.
2. NUMBERS SHOWN INSIDE DEVICES ARE EQUIPMENT CAPACITY RATINGS USED FOR PRICING.
3. NUMBERS SHOWN OUTSIDE DEVICES ARE FLOW RATES THAT WOULD OCCUR AT RATED SYSTEM CAPACITY. IT IS ASSUMED THAT ONE PRESSURE FILTER IS OUT OF SERVICE FOR BACKWASH AND ONE ZEOLITE SOFTENER IS OUT OF SERVICE FOR REGENERATION (IN ITS RINSE CYCLE).
4. DIFFERENCE IN GROSS VERSUS NET TREATED WATER OUTPUT IS DUE TO 3 PSI STEAM.

SCHEMATIC FLOW DIAGRAM
ELECTRIC (ONLY) CONCEPTUAL WATER TREATMENT SYSTEM
(FIGURE 2)




NOTES

1. NUMBERS SHOWN ON SCHEMATIC ARE FLOW RATES IN 1000 LBS./HR.
2. NUMBERS SHOWN INSIDE DEVICES ARE EQUIPMENT CAPACITY RATINGS USED FOR PRICING.
3. NUMBERS SHOWN OUTSIDE DEVICES ARE FLOW RATES THAT WOULD OCCUR AT RATED SYSTEM CAPACITY. IT IS ASSUMED THAT ONE PRESSURE FILTER IS OUT OF SERVICE FOR BACKWASH AND ONE DEMINERALIZER IS OUT OF SERVICE FOR REGENERATION (IN ITS RINSE CYCLE).



CONDENSATE:

- (17) BOILER NO. 6 DEMINERALIZER (DI) MAKEUP
- (18) SEARING COOLING WATER SYSTEM MAKEUP
- (19) BOILER FILLING & HYDRO TESTING
- (20) CONDENSER FLOODING FOR LEAK TESTING
- (21) C.T. EVAPORATIVE COOLER MAKEUP
- (22) USE OF CONDENSATE FOR CITY WATER BACKUP



Rates & Market Research
March 14, 1994

OFFICE MEMORANDUM

TO: File

FROM: Tim Rush *TR*

SUBJECT: Allocation Case - Account L1315, Electric Accessory Equipment

A review of our plant account L1315 was made by Mike Ceglenski, Maintenance/Construction Superintendent, over the last several weeks. This review was precipitated by an earlier review from John Modlin which determined that some of the items in account L1315 would be more appropriately allocated between electric and steam. Currently, this account is directly assigned to electric plant.

The attached is a summary of each item considered allocable. This amounts to \$527,765.27 which would be allocable between steam and electric. The remaining amount should be directly assigned to electric. To be consistent with our current allocation method, I would recommend that the allocable portion of the account L1315 be allocated based on the total plant ratio determined in allocating accounts 311, 312, 312A and 316.

Attachment

ST. JOSEPH LIGHT & POWER COMPANY
Account #315

| Asset # | Description | Total Asset Cost |
|-------------|---------------------------------------|-----------------------|
| 13150026400 | Main Control Panel | \$14,868.04 |
| 13150115000 | Motor Control Center | 12,248.88 |
| 13150027100 | Battery 60 Cell 125V 498 AH | 8,733.75 |
| 13150027301 | EV-7 Lead Calcium Batteries | 8,117.65 |
| 13150107000 | 30 KVA Inverter W/Static Swt. | 30,086.46 |
| 13150108000 | Installation Charges Inverter | 18,759.06 |
| 13150109000 | 300 Amp Battery Charger | 16,267.61 |
| 13150110000 | Installation Charges - Battery | 8,767.14 |
| 13150111000 | 60 Amp Auto Transfer Switch | 5,212.60 |
| 13150112000 | 100 Amp Disconnect Switch | 10,479.95 |
| 13150113000 | Power Distribution Panel | 38,769.79 |
| 13150005400 | Load Ctr. Unit Substn. 480V | 17,639.01 |
| 13150005500 | Load Ctr. Unit Substn. 1000KVA | 24,126.79 |
| 13150004500 | #1 Load Ctr. Unit Substation | 26,849.28 |
| 13150024200 | Motor Control Center #1 | 8,677.15 |
| 13150024300 | Motor Control Center #2 | 5,722.53 |
| 13150025200 | Motor Control Center | 6,199.36 |
| 13150004600 | #2 House Service Trans. | 48,864.60 |
| 13150004400 | #1 Station Lighting Trans. | 22,172.15 |
| 13150004408 | #1 House Service Trans. | 40,401.25 |
| 13150021502 | Conduit Rigid 1 1/2" C. Stat | 7,511.93 |
| 13150021503 | Conduit Rigid 2" C. Station | 5,206.59 |
| 13150021500 | Conduit Rigid 3/4" Conductor | 11,212.99 |
| 13150010700 | Lake Road Sub-2400V #2 Swchg. | 7,004.94 |
| 13150020401 | 1" Steel | 8,742.09 |
| 13150020405 | 3" Steel | 6,466.33 |
| 13150020803 | 24" Cope Mesh Type 2/Blt-in C | 6,358.34 |
| 13150021000 | C. Station 3/4" Steel 3" | 19,415.18 |
| 13150019502 | #1/0 Al 35KV Urd Cable | 5,200.49 |
| 13150000600 | Control Cubicle Assem | 15,162.46 |
| 13150001600 | Switchgear Metal Clad Whse. | 33,868.93 |
| 13150000400 | 480V Swchgr. Metal Clad Molon | 15,241.30 |
| 13150003101 | #500 MCM 13KV Kerite Cable | 6,011.49 |
| 13150022400 | 30S Grounding Syst.-500M, 37 Str. Cp. | 7399.16 |
| | TOTAL 04 | <u>\$527,765.27</u> |
| | TOTAL 01 | <u>\$1,333,908.07</u> |
| | GRAND TOTAL | <u>\$1,861,673.34</u> |

ST. JOSEPH LIGHT & POWER COMPANY**Lake Road Feedwater Treatment Expense Allocation Study**

Prepared by
John T. Modlin & Michael S. Smith
February 24, 1994

BACKGROUND

As part of the MPSC Docket EO-94-36, SJLP agreed to review the allocation of expense account 2502-010, "Boiler Feedwater Expenses," and determine if a different allocation approach is appropriate. The current SJLP allocation procedure allocates 90% of the expenses in account 2502-010 to the industrial steam jurisdiction and 10% to the electric jurisdiction. This report summarizes the findings of that study.

STUDY PROCEDURE

The study was composed of three parts. The first part was to review the expenses charged to the account. The second part of the study was to investigate feedwater consumption of plant processes so that the allocation factor could be assessed and modified, if necessary. Note that non-feedwater uses (cooling tower water, house service water, etc.) were not included in the study. The quantity of feedwater used for plant uses was found by various means, including direct measurement, equipment design information, flow calculations, and specifically-designed tests. Finally, the above information was used to develop specific recommendations regarding the allocation of this account and other related expenses.

RESULTS

The total 1993 expenses charged to account 2502-010 was \$234,490. This account currently contains three distinct groups of expenses, listed below:

1. 900# Plant feedwater expenses. These expenses are composed primarily of payroll and chemical costs associated with operating lime softeners, pressure filters, and zeolite softeners in the 900# Plant. For 1993, these expenses were calculated to be \$200,500 by subtracting out the following expenses from the actual account total.

2. Unit 4/6 feedwater treatment expenses. These expenses are composed primarily of payroll and chemical expenses associated with additional treatment of the feedwater used in Boiler 6. These expenses are unique and separate from those of the 900# plant, above. For 1993, these expenses were calculated to be \$24,900, based on actual expenses and Boiler 6 operation during the year.

3. Nitrogen expense. Nitrogen is an inert gas used to fill out-of-service boilers, heat exchangers, and piping to protect them from corrosion. Although it can be used in all of the boilers, it is primarily used in Boilers 1, 2, 3, 6, and 7 and the Unit 4/6 feedwater heaters. The 1993 bulk nitrogen expense was \$9,126.

The results of the feedwater use study are shown on the attached sheet, entitled "SJLP Lake Road Plant - Annual 900# Feedwater Use." Based on 1993 data, approximately 96% of the total plant feedwater consumption can be attributed to the industrial steam jurisdiction.

DISCUSSION

The Unit 4/6 feedwater treatment expenses are 100% electric in nature and should be charged directly to a Unit 4/6 operating expense account. Account 2502-016,

"Boiler 6 Cleaning," is an "available" account for this purpose that is now used solely for Boiler 6 chemical-cleaning expenses. The SJLP account numbering practice has been to use 2502-01 and -02 account numbers for feedwater-related and boiler-related expenses, respectively. Following this practice, it is appropriate to place the Unit 4/6 feedwater treatment expenses in account 2502-016.

Boiler chemical-cleaning is a boiler-related expense that is more appropriately charged to the 2502-02 group of accounts. Chemical-cleaning of the 900# boilers (Boilers 1-5) has historically been charged to 2502-020, "Steam Expenses Other." The proper allocation of boiler expenses dictates that this type of expense be charged consistently for all of the boilers. Thus, it initially seems appropriate to charge Boiler 6 chemical-cleaning to 2502-020. However, this would result in moving a significant and measurable 100% electric expense to an allocated account, which reduces the accuracy of the allocation process.

Boiler 6 chemical cleaning is similar to other direct Boiler 6 expenses that are now charged to the allocated 2502-020 account. These expenses include the costs of cleaning the gas-side of the boiler, air heater, and gas ducts. These are normally contracted or other well-defined activities that could be charged to different expense accounts relatively easily. To improve the accuracy of the allocation process, it is desirable to place these expenses in a 100% electric boiler expense account. These same activities also occur on the 900# boilers and are now charged to 2502-020. It would be inappropriate to allocate these 900# boiler expenses on a total steam plant allocation factor when the corresponding Boiler 6 expenses are excluded from this account. Therefore, if direct Boiler 6 expenses are placed in a dedicated Boiler 6 expense account, a similar allocated account must be used for the 900# boilers. This latter account would be allocated on a 900# steam plant factor, rather than a total steam plant factor.

Because the amount of chemical treatment depends directly on the amount of

water processed, 900# feedwater chemical expenses should be allocated based upon water consumption. On the other hand, feedwater labor expense is an essentially fixed cost, which is appropriate to allocate on a demand basis. An appropriate demand factor can be calculated from the water treatment capital cost study being prepared by SJLP. The 900# feedwater treatment expenses (account 2502-010) are roughly 50% chemicals and 50% labor. Therefore, a 50% consumption, 50% demand factor is appropriate for allocating this account.

RECOMMENDATIONS

The Unit 4/6 feedwater treatment expenses are 100% electric in nature and should not be allocated. Account 2502-016, "Boiler 6 Cleaning," should be renamed "Boiler 6 Feedwater Expenses" and be used for these expenses. Boiler 6 chemical-cleaning expenses, which are now charged to 2502-016, should be charged to a new account 2502-022, described below.

A new, 100% electric, operating expense account 2502-022, entitled "Boiler 6 Direct Operating Expenses," should be established. This account would receive all direct Boiler 6 non-maintenance cleaning expenses, such as expenditures for chemical-cleaning and cleaning of the gas-side of the boiler, air heater, and gas ducts.

A new, allocated, operating expense account 2502-021, entitled "Boiler 1-5 Direct Operating Expenses," should also be established. All direct 900# boiler (excluding Boiler 7) non-maintenance cleaning expenses would be charged to this account. This account would be allocated using a 900# steam plant demand approach, similar to that proposed for the whole steam plant account 2502-020.

The nitrogen expense, although related to feedwater treatment in that it is a chemical that protects boilers and other components from corrosion, is more appropriately charged against the boilers directly via account 2502-020. This

expense should be transferred to that account.

The remaining expenses in account 2502-010 should be allocated 50% on water consumption and 50% on demand. Using a consumption factor of 0.962 and a demand factor of 0.905¹ yields a 50/50 factor of 0.934.

The feedwater use study, which provides the 0.962 water consumption factor, was based both on specific 1993 data and generic annual water consumption calculations. The feedwater use study and the consumption factor should be updated if plant operation changes significantly or if Unit 4/6 auxiliary steam metering is installed.

SUMMARY OF RECOMMENDATIONS

1. Rename account 2502-016 to "Boiler 6 Feedwater Expenses."
2. Charge Boiler 6 feedwater treatment expenses directly to account 2502-016 (100% electric).
3. Charge bulk nitrogen expenses to account 2502-020.
4. Establish a new account 2502-021, entitled "Boiler 1-5 Direct Operating Expenses." Allocate this account on a 900# plant demand factor.
5. Establish a new account 2502-022, "Boiler 6 Direct Operating Expenses." This account will be 100% electric.
6. Charge direct boiler cleaning expenses to the appropriate account, either 2502-021 or -022.
7. Allocate 93.4% of the account 2502-010 expenses to industrial steam and 6.6% to electric.
8. Review the feedwater consumption factor if Unit 4/6 metering is installed or if plant operation changes significantly. Update factors in recommendation 7, above, as necessary.

¹ Based on SJLP 1994 Water Treatment Capital Cost Study design flows of 36,700 pph for electric and ~~388,300~~ pph for a combined system.

286502
5 2 w/ Manport: Swift All removed
4/95
MSS

SJLP LAKE ROAD PLANT - ANNUAL 900# FEEDWATER USE
MPSC Allocation Case EO-94-36

TOTAL MLBS FROM 1993 DATA¹

| Description | Total Annual Flow | Percent of Water In | Ind Stm Factor ² | Industrial Steam Total | Comment |
|-------------------------------------|------------------------|---------------------|-----------------------------|------------------------|--|
| Industrial Steam, 200# Headers | 1,372,141 | 61.82 | 1.000 | 1,372,141 | Lake Road Results Summary |
| Ind Steam, Customer Desup | 78,209 | 3.52 | 1.000 | 78,209 | Lake Road Results Summary |
| 850# Steam Customer | 186,084 | 8.38 | 1.000 | 186,084 | Lake Road Results Summary |
| No. 2 Fuel oil heating - credit | (2,229) | -0.10 | 1.000 | (2,229) | Supplied from industrial steam system |
| No. 2 Fuel oil heating | 2,229 | 0.10 | 0.000 | 0 | Testing performed 2/1/94 |
| Boiler 6 Sootblowing | 5,429 | 0.24 | 0.000 | 0 | Testing performed 2/1/94 |
| Unit 4/6 Condensate Make-up | 20,260 | 0.91 | 0.000 | 0 | Demineralizer meter readings |
| Unit 4/6 hot storage | 2,443 | 0.11 | 0.000 | 0 | Calculated, DA tank level changes |
| Units 5,6,7 Evap Coolers | 444 | 0.02 | 0.000 | 0 | Calculated, evap cooler heat balance |
| Unit 4/6 seals on start-up | 416 | 0.02 | 0.000 | 0 | Seal flows from B&V heat balance diagram |
| Blrs 6 & 7 filling & hydro-testing | 984 | 0.04 | 0.000 | 0 | Lake Road Lab estimates |
| Turbine 1,2,3 hoppers, warm-up | 533 | 0.02 | 0.000 | 0 | Calculated warm-up flow, hogger design flow |
| Condenser flooding for leaks | 500 | 0.02 | 0.000 | 0 | Lake Road Lab estimates |
| Turb 1,2,3 Condensate sampling | 804 | 0.04 | 0.000 | 0 | Lake Road Lab measurements |
| Turbine 1,2,3 Cooling Twr Trtmnt | 707 | 0.03 | 0.000 | 0 | Lake Road Lab estimates |
| No. 6 Fuel oil heating (firing) | 1,751 | 0.08 | 0.809 | 1,417 | Heat balance, firing tank to oil guns |
| No. 6 Fuel oil atomization | 3,704 | 0.17 | 0.809 | 2,996 | B&W Steam book estimate |
| No. 6 Fuel oil tank heating | 5,620 | 0.25 | 0.809 | 4,547 | Testing 2/5/94; tank heat loss calculations |
| Blrs 1-5 filling & hydro-testing | 672 | 0.03 | 0.796 | 535 | Lake Road Lab estimates |
| Blr 1-5 vents, start/stop, hot-bank | ? | 0.00 | 0.796 | 0 | Included in unaccounted-for, allocated on fuel |
| 900# Blr plant sampling | 4,096 | 0.18 | 0.796 | 3,260 | Lake Road Lab measurements |
| Boiler 4, 5 Sootblowing | 1,753 | 0.08 | 0.796 | 1,395 | Boiler 5 sootblowing tests, supplier data |
| Ash tank vacuum system | 16,050 | 0.72 | 0.721 | 11,572 | Design steam use, estimated hours, MSS factor |
| 900# Deaerator vents | 1,752 | 0.08 | 0.796 | 1,395 | Calculated vent flows |
| Continuous Blowdown to sewer | 310,666 | 14.00 | 0.962 | 298,861 | Measured flows in monthly results files |
| Softener sludge & rinse | 65,935 | 2.97 | 0.962 | 63,429 | Measured flows in monthly results files |
| Water treatment sampling | 3,679 | 0.17 | 0.962 | 3,539 | Lake Road Lab measurements |
| Softener vents | 131 | 0.01 | 0.962 | 126 | Calculated vent flows |
| Unaccounted for | 134,873 | 6.08 | 0.796 | 107,359 | Unaccounted for, allocate on 900# fuel |
| Totals | 2,219,635 ¹ | 100.00 | 0.962 | 2,134,636 | 96.2% |

¹ Some quantities are "annual," not specifically for 1993.

² Factors calculated from 1993 data.

ST. JOSEPH LIGHT & POWER COMPANY
ALLOCATION PROCEDURES
CASE NO. EO-94-36

II. CAPITAL PLANT ALLOCATION - General Plant

A. Capital Plant Allocation - General Plant

General plant refers to land, structures, furniture and equipment common to SJLP's three utility operations, electric, natural gas and industrial steam. General plant is classified in FERC accounts 389 through 398.

SJLP utilizes several different allocation procedures for the General Plant accounts to reflect the unique circumstances of each account.

Allocation Procedures

Accounts 389-390 - Land and Structures

Land and structure accounts consists of eight main locations. Because each location has different service territories and functions, a different allocation method is necessary for each area. Unless noted, land and structures for each location will use the same allocation method.

1. Location—St. Joseph T&D
Function—Electric

Allocation Factor—100% Electric except for garage

The engineering, estimating, line and electrical departments are located at T&D, as well as a storeroom, garage, pole and transformer yards, relay shop, etc. The work performed at the line and electrical departments, storeroom, pole and transformer yards and relay shop is 100% electric. Periodically, the engineering department may perform gas and steam related tasks. Because the primary purpose of the T&D service center is to provide electric service and any gas or steam work is very immaterial, the T&D land and building with the exception of the garage will be considered 100% electric with no allocation necessary.

The garage is used to service vehicles for the entire company so it is necessary to allocate the garage to the three departments. Because the basic function of the garage is to maintain the transportation equipment in

account 392, the garage will be allocated on the same basis as account 392.

2. Location—General Office
Function—Electric, Gas and Steam

Allocation Factors—Adjusted Plant, Gross Margin and Direct Expenses (excluding fuel and purchased power)

The purpose of the general office building is to provide general and administrative services to the entire company with the exception of the SOC area which is used primarily for electric operations. For structure allocation, the SOC area will be classified as 100% electric as determined by square footage calculations. For all other areas, a composite factor based on the weighted average of adjusted plant, gross margin and direct expenses (as determined by the G&A calculation) will be used because the primary purpose of the general office staff is to control these rate base and cost of service items.

3. Locations—Maryville, Mound City and Tarkio Offices and Warehouses
Function—Electric and Gas

Allocation Factor—Payroll

The Maryville, Mound City and Tarkio offices provide electric and gas service to customers. Payroll charges for each location provide a reasonable basis for determining the type of work performed. Because there is a direct relationship between the task employees perform and the purpose of providing property to assist in the accomplishment of those tasks, labor charges for each location will be used as the allocation factor for each area.

4. Location—Microwave System (Account 389)
Function—Electric

Allocation Factor—100% Electric

The land account 389 relates entirely to the Iatan microwave system which is 100% electric. The equipment related to the microwave system is classified under communications equipment (Account 397). Currently, there are two systems: 1) SOC to Iatan and 2) SOC to Lake Road.

5. Location—Building Services Shop
Function—Electric, Gas and Steam

Allocation Factors—Square Footage and Number of Employees

Building services provide services to each of the main structures in the company. Each location is weighted according to square footage and number of employees and then allocated based on corresponding adjusted structure percentages after allocations. These factors provide the most direct relationship between services provided and associated costs.

**6. Location—Savannah Office
Function—Electric****Allocation Factor—100% Electric**

The Savannah office provides only electric services to the customers in that location.

Accounts 391-398—Equipment

General equipment consists of a variety of office, shop and miscellaneous machines which are used at the main locations described above. Whenever appropriate, each equipment account will be broken down by location and allocated according to the method prescribed for the corresponding structure at that location.

**Account 391—Office Furniture
Function—Electric, Gas and Steam**

Allocation Factor—Same as structures for corresponding locations.

Due to the direct relationship between office furniture and the structures where housed, the same allocation factors are utilized.

**Account 391.1—Computer Equipment
Function—Electric, Gas and Steam**

Allocation Factor—Number of Customers, Adjusted Plant, Gross Margin and Direct Expense (excluding fuel and purchased power)

The majority of computer equipment is housed at the St. Joseph office to provide general and administrative services to the entire company. Therefore, the allocation factors used to allocate the general office are used with the additional factor of number of customers. This factor was added because the billing and meter reading systems relate directly to the number of customers. The SCADA system is considered 100% electric.

Account 391.2—Office Machines
Function—Electric, Gas and Steam

Allocation Factor - Same as structures for corresponding locations.

Account 392—Transportation Equipment
Function—Electric, Gas and Steam

Allocation Factors—Specific Identification and Adjusted Plant, Gross Margin and Direct Expense for St. Joseph division and Payroll for North division

All gas department, meter reader, line department, T&D and relay vehicles which are specifically identifiable are assigned to their respective departments. The remaining vehicles are allocated based on assigned locations with North Division vehicles allocated on payroll and St. Joseph division based on adjusted plant, gross margin and direct expenses.

Account 393—Stores Equipment
Function—Electric, Gas and Steam

Allocation Factors—Materials and Supplies less Iatan

Because stores equipment is used primarily in the handling and maintenance of inventory, there is a direct correlation between the allocation basis for inventory and the equipment used to store and process the inventory. Therefore, stores equipment will be allocated on a like percentage.

Account 394—Tools, Shop and Garage
Function—Electric and Steam

Allocation Factors—Transportation Equipment Allocation Factor

Because tools, shop and garage equipment are used to maintain transportation equipment, the allocation of this account shall correspond to the transportation account.

Account 395—Lab Equipment
Function—Electric and Steam

Allocation Factors—Lake Road Allocation Ratio

Lab equipment is located at all major locations, with the majority in St. Joseph. Equipment at T&D, Maryville and Tarkio is considered 100% electric, with the remaining Lake Road equipment allocated based on the Lake Road Allocation

ratio. Maryville and Tarkio equipment consists of voltmeters and test panels which are used entirely in electric operations.

Account 396—Power Operated Equipment
Function—Electric, Gas and Steam

Allocation Factor—Same as structures for corresponding locations.

Power operated equipment is located at St. Joseph, Maryville and Mound City. The majority of equipment at St. Joseph is located at T&D and will be classified as electric with Maryville and Mound City allocated consistent with the structures at those locations.

Account 397—Communication Equipment
Function—Electric, Gas and Steam

Allocation Factor—Same as structures for corresponding locations (except Microwave - 100% electric).

Communication equipment is located at St. Joseph, Maryville and Mound City. SOC equipment and microwave equipment are considered 100% electric. The remaining equipment allocations will be based on corresponding structure factors.

Account 398—Miscellaneous General Equipment
Function—Electric, Gas and Steam

Allocation Factor—Same as structures for corresponding structure factors.

Miscellaneous equipment is located at St. Joseph, Maryville and Mound City. Allocations are based on corresponding structure factors.

B. Reserve for Depreciation Allocation - General Plant

Depreciation reserve balances for accounts 390-398 are allocated based on the allocation percentages for each plant account. This method proves the most reasonable allocation basis between departments and it also preserves the consistency between plant and reserve balances.

14-Dec-94

ST. JOSEPH LIGHT & POWER COMPANY
GENERAL ALLOCATION
12-31-93

| ACCT | DESCRIPTION | PLANT BALANCE | LESS 100% ELECTRIC | COMMON PLANT | ELECTRIC | SETTLEMENT | |
|------|------------------------------|------------------|--------------------------|--------------|-------------|------------|------------------|
| | | | | | | GAS | INDUSTRIAL STEAM |
| 389 | Land | | | | | | |
| | T&D, St. Joseph | \$545,188 | \$490,388 | 54,800 | 48,158 | 3,896 | 1,748 |
| | General Office/Savannah | 100,602 | | 100,602 | 91,659 | 3,581 | 5,362 |
| | Maryville Office & Whse | 41,502 | | 41,502 | 29,612 | 11,890 | |
| | Mound City Service Center | 23,456 | | 23,456 | 21,406 | 2,050 | |
| | Tarkio Office | 2,396 | | 2,396 | 1,723 | 673 | |
| | Microwave System | 4,584 | 4,584 | | | | |
| | Building Services Shop | 15,793 | | 15,793 | 14,529 | 474 | 790 |
| | Total Acct. 389 | \$733,521 | \$494,972 | \$238,549 | \$208,085 | \$22,564 | \$7,900 |
| 390 | Structures | | | | | | |
| | T&D, St. Joseph | \$4,388,951 | \$3,947,790 | 441,161 | 395,721 | 31,367 | 14,073 |
| | General Office | 4,525,410 | 248,804 | 4,276,606 | 3,896,416 | 152,247 | 227,943 |
| | Maryville Office & Whse | 1,012,652 | | 1,012,652 | 722,527 | 290,125 | |
| | Mound City Service Center | 136,480 | | 136,480 | 124,552 | 11,928 | |
| | Tarkio Office | 76,722 | | 76,722 | 55,186 | 21,536 | |
| | Building Services Shop | 238,637 | | 238,637 | 219,546 | 7,159 | 11,932 |
| | Savannah Office & Grant City | 41,557 | 41,557 | 0 | | | |
| | Total Acct. 390 * | \$10,420,409 | \$4,238,151 | \$6,182,258 | \$5,413,948 | \$514,362 | \$253,948 |

| ACCT | DESCRIPTION | PLANT BALANCE | LESS 100% ELECTRIC | COMMON PLANT | ELECTRIC | GAS | INDUSTRIAL STEAM |
|-------|--------------------------|------------------|--------------------------|--------------|--------------|-------------|------------------|
| | | | | | | | |
| 391.1 | Computer Equipment | 7,149,990 | 1,005,563 | \$6,144,427 | 5,587,128 | 311,522 | 245,777 |
| 391.2 | Office Machines | 233,388 | | \$233,388 | 213,160 | 10,804 | 9,424 |
| 392 | Transportation Equipment | 4,456,315 | | \$4,456,315 | 3,997,491 | 316,827 | 141,997 |
| 393 | Stores Equipment | 271,729 | | \$271,729 | 260,180 | 4,022 | 7,527 |
| 394 | Tools, Shop, & Garage | 678,115 | | \$678,115 | 608,296 | 48,211 | 21,608 |
| 395 | Laboratory Equipment | 259,881 | 110,366 | \$149,515 | 138,039 | 0 | 11,476 |
| 396 | Power Operated Equipment | 480,050 | 388,470 | \$91,580 | 87,280 | 24,300 | 0 |
| 397 | Communication Equipment | 1,803,220 | 1,395,866 | \$407,354 | 343,858 | 47,615 | 15,881 |
| 398 | Misc. General Equipment | 110,873 | | \$110,873 | 101,016 | 3,947 | 5,910 |
| | Total | \$27,632,125 | \$7,633,366 | \$19,998,737 | \$17,895,844 | \$1,339,097 | \$763,796 |

* Total Structures is per RS-10. RS-84 reports \$10,427,481.

92.39%

4.85%

2.76%

PRINT: PLTALOC

Settlement

Allocation of General Reserve
Based on 12-31-93 PlantAllocation of General Plant Reserve
Accumulated Reserve Acct. 390-398

| | | | |
|---|---------------------------|---------------------|-----------------------|
| Total Reserve per Accumulated Provision @ December, 1993 | \$13,343,135 | | |
| Allocation Percentages per general plant allocation | <u>Electric</u> 92.39% | <u>Gas</u> 4.85% | <u>Steam</u> 2.76% |
| ALLOCATION OF G. P. RESERVE @ December, 1993 | \$12,327,722 | \$647,142 | \$368,271 |

SETTLEMENT

ST. JOSEPH LIGHT & POWER COMPOSITE ALLOCATION FACTORS
BASED ON PLANT, GROSS MARGIN & DIRECT EXPENSES

| PLANT BASE | PLANT 12-31-93 | LESS COMMON | LAKE ROAD ALLOCATION | ADJUSTED PLANT BALANCE | % |
|------------|-------------------|----------------|-------------------------|------------------------------|---------|
| Electric | \$258,937,608 | (\$19,998,737) | (\$3,492,988) | \$235,445,883 | 94.81% |
| Gas | 5,807,562 | | | \$5,807,562 | 2.34% |
| Steam | 3,584,835 | | 3,492,988 | \$7,077,823 | 2.85% |
| | \$268,330,005 | (\$19,998,737) | \$0 | \$248,331,268 | 100.00% |

| BOOKED GROSS MARGIN | 12-Months Ended 12-31-93 | % | |
|---------------------|-----------------------------|---------|---|
| Electric | \$51,497,609 | 91.22% | (Sales revenue less fuel & interchange) |
| Gas | 2,248,863 | 3.98% | (Sales revenue, including gas transportation, less gas purchased) |
| Steam | 2,704,744 | 4.80% | (Sales revenue less steam fuel) |
| | \$56,451,216 | 100.00% | |

| DIRECT EXPENSE | 12-31-93 | % |
|----------------|--------------|---------|
| Electric | \$21,592,237 | 87.29% |
| Gas | 1,078,162 | 4.36% |
| Steam | 2,064,450 | 8.35% |
| | \$24,734,849 | 100.00% |

| COMPOSITE BASE | ADJUSTED PLANT BASE | GROSS MARGIN BASE | DIRECT EXPENSES | COMPOSITE ALLOCATION |
|----------------|---------------------------|-------------------------|--------------------|-------------------------|
| Electric | 94.81% | 91.22% | 87.29% | 91.11% |
| Gas | 2.34% | 3.98% | 4.36% | 3.56% |
| Steam | 2.85% | 4.80% | 8.35% | 5.33% |
| | 100.00% | 100.00% | 100.00% | 100.00% |

Adjusted Lake Road Plant Balances (Per L.R. Study) 12-31-93

| | | |
|----------|------------|---------|
| Electric | 53,170,353 | 92.32% |
| Steam | 4,420,265 | 7.68% |
| Total | 57,590,618 | 100.00% |

T&D Garage Allocation

| | | |
|--------------------------|--------|--------|
| Garage Square Footage | 8,800 | 10.05% |
| Total T&D Square Footage | 87,548 | |

| | |
|----------------|-----------|
| Total T&D Land | \$545,188 |
|----------------|-----------|

10.05%

Total land allocable to garage

\$54,800
=====

Total T&D Structures

\$4,388,951

10.05%

Total structures allocable to garage

\$441,161
=====

T & D allocation of garage

| | |
|----------|--------|
| Electric | 89.70% |
|----------|--------|

| | |
|-------|-------|
| Steam | 7.11% |
|-------|-------|

| | |
|-----|-------|
| Gas | 3.19% |
|-----|-------|

BUILDING SERVICES ALLOCATION

| Location | Square Footage | Weighted | Electric | Gas | Steam |
|-----------------|----------------|----------|----------|-----|-------|
| General Office | 51,144 | 10% | 9% | 0% | 1% |
| T & D | 87,548 | 16% | 15% | 1% | 0% |
| Maryville | 27,600 | 5% | 4% | 1% | |
| Mound City | 4,187 | 1% | 1% | 0% | |
| Tarkio | 3,150 | 1% | 1% | 0% | |
| Lake Road Plant | 345,366 | 65% | 60% | | 5% |
| Edmond Street | 15,810 | 2% | 2% | 0% | 0% |
| | 534,805 | 100% | 92% | 2% | 6% |

| Location | # of Employees 12-31-93* | Weighted | Electric | Gas | Steam |
|-----------------|-----------------------------|----------|----------|-----|-------|
| General Office | 132 | 37% | 34% | 1% | 2% |
| T & D/Savannah | 99 | 27% | 27% | | |
| Maryville | 32 | 9% | 6% | 3% | |
| Mound City | 11 | 3% | 3% | 0% | |
| Tarkio | 4 | 1% | 1% | 0% | |
| Lake Road Plant | 75 | 21% | 19% | | 2% |
| Edmond Street | 9 | 2% | 2% | 0% | 0% |
| | 362 | 100% | 92% | 4% | 4% |

*Per MKT

| COMPOSITE BASE | SQUARE FOOTAGE BASE | EMPLOYEE BASE | COMPOSITE ALLOCATION |
|----------------|------------------------|------------------|-------------------------|
| Electric | 92% | 92% | 92% |
| Gas | 2% | 4% | 3% |
| Steam | 6% | 4% | 5% |
| | 100% | 100% | 100% |

Maryville, Mound City, and Tarkio
Payroll Charges

Source: GACCREQ1 at 12-31-93

| | \$ | % |
|-----------------------|-----------------------|---------|
| Maryville—Location 6 | | |
| Electric | \$787,283.00 | 71.35% |
| Gas | \$316,134.00 | 28.65% |
| Total | <u>\$1,103,417.00</u> | 100.00% |
| Mound City—Location 8 | | |
| Electric | \$386,541.00 | 91.26% |
| Gas | \$37,030.00 | 8.74% |
| Total | <u>\$423,571.00</u> | 100.00% |
| Tarkio—Location 7 | | |
| Electric | \$83,468.00 | 71.93% |
| Gas | \$32,570.00 | 28.07% |
| Total | <u>\$116,038.00</u> | 100.00% |

OFFICE FURNITURE & EQUIPMENT
ACCOUNT 391

Sources--RS10

| Location | 12-31-93 | Electric | Gas | Steam |
|--------------------------|-------------|-----------|----------|----------|
| St. Joseph | 570,150 | | | |
| General Office | 145,729 | | | |
| Total St. Joseph | 715,879 | 652,238 | 25,485 | 38,156 |
| Savannah | 18,279 | 18,279 | | |
| T & D | 207,923 | 207,923 | | |
| Building Services | 1,536 | 1,413 | 46 | 77 |
| Lake Road Main Structure | 33,702 | | | |
| Lake Road Office\Control | 8,793 | | | |
| Lake Road Store Room | 2,375 | | | |
| Lake Road Lab | 8,747 | | | |
| Total Lake Road | 53,617 | 49,502 | | 4,115 |
| Maryville | 21,989 | | | |
| Grant City | 546 | | | |
| Butler Metal Office | 3,267 | | | |
| Total Maryville | 25,802 | 18,410 | 7,392 | |
| Mound City | 5,920 | | | |
| Oregon | 578 | | | |
| Total Mound City | 6,498 | 5,930 | 568 | |
| Tarkio | 5,100 | 3,668 | 1,432 | |
| | \$1,034,634 | \$957,363 | \$34,923 | \$42,348 |

**COMPUTER EQUIPMENT
ACCOUNT 391.1**

Sources—OR Pages 6, 10 & 11

| CUSTOMERS 12-31-93 | # | % |
|--------------------|--------|---------|
| Electric | 60,098 | 90.41% |
| Gas | 6,370 | 9.58% |
| Industrial Steam | 8 | 0.01% |
| | 66,476 | 100.00% |

| COMPOSITE BASE | CUSTOMER BASE | ADJUSTED PLANT BASE | GROSS MARGIN BASE | DIRECT EXPENSES BASE | COMPOSITE ALLOCATION |
|----------------|------------------|---------------------------|-------------------------|----------------------------|-------------------------|
| Electric | 90.41% | 94.81% | 91.22% | 87.29% | 90.93% |
| Gas | 9.58% | 2.34% | 3.98% | 4.36% | 5.07% |
| Steam | 0.01% | 2.85% | 4.80% | 8.35% | 4.00% |
| | 100.00% | 100.00% | 100.00% | 100.00% | 100.00% |

OFFICE MACHINES
ACCOUNT 391.2 & 391.9

Sources—RS10

| Location | 12-31-93 | Electric | Gas | Steam |
|--------------------------------|-----------|-----------|----------|---------|
| St. Joseph | 71,354 | | | |
| General Office | 48,687 | | | |
| MVNG | 15,113 | | | |
| Total St. Joseph | 135,154 | 123,139 | 4,811 | 7,204 |
| Savannah | 4,156 | 4,156 | | |
| T & D & Building Services | 36,686 | 36,686 | | |
| Lake Road Main Structure & Lab | 28,931 | 26,710 | | 2,221 |
| Maryville | 14,590 | 10,410 | 4,180 | |
| Mound City | 10,768 | 9,827 | 941 | |
| Tarkio | 3,103 | 2,232 | 871 | |
| | \$233,388 | \$213,160 | \$10,804 | \$9,424 |

TRANSPORTATION EQUIPMENT
ACCOUNT 392

| | Electric | Gas | Steam | Total |
|-------------------------|-------------|-----------|-----------|-------------|
| Specific Identification | \$1,317,580 | \$135,199 | \$0 | \$1,452,779 |
| Allocable | | | | |
| St. Joseph | 2,427,268 | 94,842 | 141,997 | 2,664,107 |
| Maryville | 188,228 | 75,581 | 0 | 263,809 |
| Mound City | 47,314 | 4,531 | 0 | 51,845 |
| Tarkio | 17,101 | 6,674 | 0 | 23,775 |
| | \$3,997,491 | \$316,827 | \$141,997 | \$4,456,315 |
| | 89.70% | 7.11% | 3.19% | |

STORES EQUIPMENT
ACCOUNT 393

Sources—Other Allocations

| Materials & Supplies | \$ | % |
|----------------------|--------------------|----------------|
| Electric less latan | \$3,911,596 | 95.94% |
| Gas | 60,455 | 1.48% |
| Industrial Steam | 105,348 | 2.58% |
| | <u>\$4,077,399</u> | <u>100.00%</u> |

POWER EQUIPMENT
ACCOUNT 396

Sources—RS10

| Location | 12-31-93 | Electric | Gas | Steam |
|------------|--------------------|--------------------|-------------------|--------------|
| St. Joseph | \$388,470 | \$388,470 | | |
| Maryville | 81,850 | 58,400 | 23,450 | |
| Mound City | 9,730 | 8,880 | 850 | |
| | ----- \$480,050 | ----- \$455,750 | ----- \$24,300 | ----- \$0 |
| | ===== | ===== | ===== | ===== |

Plant account 396 consists of trencher, backfill blade, sickle, snowblower, backhoe/loader, tractor, mobile oil processor, chipper, ditchwitch trailer, etc.

St. Joseph equipment is primarily at T & D which is considered 100% electric.

COMMUNICATION EQUIPMENT
ACCOUNT 397

Sources—RS10

| Location | Allocable 12-31-93 | Electric | Gas | Steam |
|-------------------|-----------------------|------------------|-----------------|-----------------|
| St. Joseph | 125,061 | \$113,944 | \$4,452 | \$6,666 |
| Microwave at L.R. | 120,058 | 110,844 | | 9,215 |
| Maryville | 118,196 | 84,333 | 33,863 | |
| Mound City | 15,836 | 14,452 | 1,384 | |
| Tarkio | 28,202 | 20,285 | 7,916 | |
| | <u>\$407,354</u> | <u>\$343,858</u> | <u>\$47,615</u> | <u>\$15,881</u> |

| | |
|-----------------|------------------|
| Total Acct 1397 | \$1,803,220 |
| Total electric | <u>1,395,866</u> |
| Allocable | <u>\$407,354</u> |

| | |
|------------------------|-----------------------------|
| Conception (Microwave) | \$67,817.13 (100% Electric) |
| Iatan | 2,355.89 (100% Electric) |
| Maryville | 118,196.36 |
| M.C. | 15,836.46 |
| Savannah (Microwave) | 147,542.08 (100% Electric) |
| St Joe | 967,114.57 (100% Electric) |
| Tarkio | 28,201.64 |
| Electric-100 | 1,176.51 (100% Electric) |
| Electric-101 | 659.76 (100% Electric) |
| Electric-Microwave | 15,724.25 (100% Electric) |
| St Joe-Gen Office | 115,008.82 |
| T&D | 26,608.21 (100% Electric) |
| Building Service | 1,192.95 |
| Radio & Relay | 8,859.42 |
| LR-Main | 120,058.41 |
| LR-Substation | 166,867.75 (100% Electric) |
| | <u>\$1,803,220.21</u> |

