

Exhibit No.:  
Issue(s): Distribution Investments  
Witness: Ryan M. Arnold  
Type of Exhibit: Direct Testimony  
Sponsoring Party: Union Electric Company  
File No.: ER-2022-0337  
Date Testimony Prepared: August 1, 2022

**MISSOURI PUBLIC SERVICE COMMISSION**

**FILE NO. ER-2022-0337**

**DIRECT TESTIMONY**

**OF**

**RYAN M. ARNOLD**

**ON**

**BEHALF OF**

**UNION ELECTRIC COMPANY**

**D/B/A AMEREN MISSOURI**

**St. Louis, Missouri  
August, 2022**

**DIRECT TESTIMONY**

**OF**

**RYAN M. ARNOLD**

**FILE NO. ER-2022-0337**

1           **Q.     Please state your name and business address.**

2           A.     Ryan M. Arnold, Union Electric Company d/b/a Ameren Missouri ("Ameren  
3 Missouri" or "Company"), One Ameren Plaza, 1901 Chouteau Avenue, St. Louis, Missouri 63103.

4           **Q.     What is your position with Ameren Missouri?**

5           A.     I am the Vice President of Division Operations for Ameren Missouri.

6           **Q.     Please describe your educational background and employment experience.**

7           A.     I earned a Bachelor of Science degree from William Woods University in 2004,  
8 and a Master of Business Administration, also from William Woods University, in 2008. I began  
9 my career at Ameren Missouri in 1999 as temporary meter reader. Shortly, thereafter I accepted  
10 an apprentice lineworker position ultimately earning my Journeyman lineworker certificate in  
11 2001, where I had responsibility for many types of line work such as overhead, underground, steel  
12 towers, and storm response. In 2005, I accepted a first line supervisor role in Decatur, Illinois with  
13 Ameren Illinois Company. In that role, my responsibilities were to lead construction crews and  
14 interact with customers during construction and maintenance jobs. I held a similar position with  
15 Ameren Missouri starting the next year. In 2011, I was promoted to be a Labor Relations  
16 representative for Ameren Missouri, and the following year was promoted to Superintendent,  
17 electric operations in the North Metro area of St. Louis. My role as Superintendent was to lead  
18 supervisors, multiple crews, and oversee the overall district budget. I was promoted again in 2015  
19 to the Director of Ameren Missouri's Gateway Division which covers the St.Charles, Dorsett, and

1 Berkeley operating centers. In this role, I was responsible for the safety of customers and  
2 employees, financial costs, and direct leadership within this geographic area. In 2019, I took a  
3 lateral move to distribution operations and led our distribution control rooms across the state along  
4 with our metro first responders. In 2021, I was promoted to Vice-President, Division Operations.  
5 As Vice-President, Division Operations, I am responsible for the delivery of safe, reliable, and  
6 affordable power to our customers across the state of MO and all division construction related  
7 employees that report up through my organization (ex: lineworkers, engineering, fleet, supervisors,  
8 etc.).

9 **Q. What is the purpose of your direct testimony?**

10 A. The purpose of my direct testimony is twofold. First, I provide an update to the  
11 Commission on our efforts to address the needs of our energy delivery (i.e., distribution) system  
12 as part of the Company's Smart Energy Plan. Second, I report on our ongoing collaboration with  
13 the Missouri Public Service Commission Staff ("Staff") and the Office of the Public Counsel  
14 ("OPC"), which arose out of our agreements with them as part of resolving our last electric rate  
15 review, File No. ER-2021-0240.

16 **Q. Please summarize the Company's investment strategy when it comes to its**  
17 **energy delivery system.**

18 A. As Ameren Missouri witness Mark Birk outlined in his rebuttal testimony in File  
19 No. ER-2021-0240, we are engaged in a multi-year effort to make foundational investments in our  
20 system needed to modernize and upgrade it given that many of its components are aged or obsolete,  
21 and in many cases are near, at, or past their expected design lives. We are making those investments  
22 across five main categories – system hardening, substations, underground cable upgrades,  
23 revitalization of the Downtown St. Louis underground network, and grid resiliency. In addition,

1 we are investing in a sixth category, smart grid technology, to provide customers multiple benefits.  
2 Taken together, this program is designed to get our grid into a condition that will enable us to  
3 provide reliable service for decades to come, including laying the necessary foundation for the  
4 enhanced demands that will be placed on the distribution grid as greater and greater quantities of  
5 distributed energy resources ("DERs")<sup>1</sup> come onto the system.

6 **Q. What are the details of the six categories of investments you listed above?**

7 A. Those details are addressed in Schedule RMA-D1 to my testimony. Schedule  
8 RMA-D1 is a slide deck that we discussed in detail with the Commission's Staff and OPC in our  
9 first of a series of discussions with them about how we proposed to evaluate and document  
10 justification for the investments we are making in these categories. The schedule contains details  
11 and data on the age and condition of many components of our system, how that relates to the  
12 investment need, what our plans for the next five to ten years are, and where we will stand on  
13 addressing system needs in these categories once we execute our plans over the next five to ten  
14 years.

15 **Q. Could you please provide a couple of examples?**

16 A. Sure. I will touch on a few slides in the system hardening and substation categories.  
17 Slide 9 of Schedule RMA-D1 shows that 39% of our subtransmission circuits (approximately  
18 1,600 miles) – these are the circuits connecting substations to substations across our large service  
19 territory – are already older than their expected life, with another 25% approaching that point. On  
20 average, these assets are 37 years old versus an expected life of 45 years. As the slide indicates,  
21 we start to see failure rates that are several multiples higher than newer equipment once it reaches  
22 an age of 31 years or more, with even more failures once it reaches 45 years. As slide 13 shows,

---

<sup>1</sup> DERs can include a myriad of items, such as solar panels, batteries, hot water heaters, electronic thermostats, and electric vehicles.

1 we are investing at a level designed to replace approximately 55 miles per year through 2033.  
2 Additionally, when we execute upgrades to these aged assets, we are building to a current design  
3 standard that includes stronger wood and composite poles, wind and ice deflecting wire, as  
4 applicable, and standoff insulators or composite cross arms, all of which will provide customers  
5 more reliable service for decades to come.

6 Another example is our distribution substations. Approximately 280 out of 530 of these  
7 substations serving over 600,000 of our customers contain critical components that are, today,  
8 beyond their expected lives. Consequently, as shown on slide 19 of Schedule RMA-D1, we are  
9 working to replace 70 of those substations (including those replaced starting in 2019) through 2023  
10 and another 210 by 2033. We are addressing these aged assets with current design standards that  
11 include fully enclosed switchgear housing, remote communication and control abilities, and  
12 sufficient capacity to serve customers well into the future. Additional information on these two  
13 categories is provided in Schedule RMA-D1, as well as data and information on the other six  
14 categories.

15 **Q. When will refreshing these items and making these foundational investments**  
16 **wind down?**

17 A. There will of course always be a need to continue to replace system components,  
18 and the length of the period needed to fully refresh the assets varies by category. We expect to  
19 essentially be done with this effort for the Downtown St. Louis underground system by 2028. For  
20 substations, if we are able to maintain our planned investment levels, we believe we can get the  
21 average age down to a level by approximately 2035 where we can reduce the annual investment  
22 in this category by a bit more than one-half of where it is now and where it is expected to be over  
23 the next 10 years or so. As we sit here today, we would expect our smart grid investments to reduce

1 from current annual levels after about 2028. The timelines for other categories vary, and for all of  
2 the categories we do look at the needs and the progress toward meeting them on an ongoing basis;  
3 certainly, each year as we develop our one- and five-year investment plans.

4 **Q. You referenced ongoing collaboration with Staff and OPC arising out of the**  
5 **resolution of the Company's last electric rate review. Could you please update the**  
6 **Commission on those efforts?**

7 A. As the Commission knows, we agreed to meet with Staff and OPC on at least three  
8 separate occasions to discuss the categories or projects I referenced above. In sum, the goal from  
9 my perspective is to develop more formalized evaluation methodologies that we could apply to  
10 investments in these categories and document starting in 2023. We also agreed to consider their  
11 input on these topics. The evaluation methodologies will have at least one (and in some cases likely  
12 more) quantifiable aspects to them, and will also capture qualitative considerations, which are  
13 especially important given the nature of the investments we are making. In June, we provided Staff  
14 and OPC with drafts of evaluation methodologies for three of the six categories, which I have  
15 attached to my testimony as Schedule RMA-D2. In late June, we met with Staff and OPC to discuss  
16 the methodologies and get their feedback. From my perspective, that meeting reflected that there  
17 was an alignment among all parties that the methodologies take the right approach, are reasonable,  
18 and will be useful to Staff and OPC in reviewing our investments in future rate reviews. We will  
19 be making some minor updates based on feedback from OPC and Staff, including providing  
20 baselines in the methodology, to those three categories we discussed and providing methodologies  
21 for the other three categories, and then will meet again in early September. I am optimistic that we  
22 will align on the appropriateness of the methodologies.

1           **Q.    Has this collaboration been helpful?**

2           A.    From my perspective, yes. We view these discussions as an opportunity to increase  
3 transparency on what we are doing and why we are doing it, and to get better at explaining the  
4 projects we need to complete in order to refresh and maintain our vast energy delivery system,  
5 which in the end we believe will serve to benefit our customers. It is very obvious to us that our  
6 system has very significant needs and will continue to have significant needs for some time, but it  
7 is of course a good thing to align with Staff, OPC, and others and formalize as much as we  
8 reasonably can, and explain the reasons why we are doing which projects when. This is so we can  
9 get the most bang for our buck so-to-speak as we replace these aging components and otherwise  
10 modernize our system.

11          **Q.    Does this conclude your direct testimony?**

12          A.    Yes, it does.



---

# Ameren Missouri Energy Delivery Investments Discussion:

**April 6, 2022**



# Agenda

## First of a Series of Three Meetings (or more, as needed)

1. Introduction – Tom Byrne
2. Presentation Regarding Energy Delivery Investment Needs and Plans
  - Kevin Anders
  - Ryan Arnold
  - Jim Huss
3. Next Steps – Tom Byrne



---

# State of the Missouri Grid

# Ameren Missouri's Service Territory

Ameren Missouri delivers electricity to ~1.2M customers across 33,000+ circuit miles (including over 800,000 poles), 62 counties and more than 500 communities

## Overview

- Much of Ameren Missouri's existing system was built-out during the 1950's and 1960's.
  - This was a period of increased electricity use driven by **significant suburbanization, increased use of air conditioners and industrial growth**
  - Today, decades later, Ameren Missouri must upgrade these aging assets, not only to reduce equipment failures but also to continue to meet the expanding needs of our customers
- When SEP investments began in 2019, **over 250 of our distribution substations** contain either a transformer or circuit breaker that was installed more than 50 years ago.
  - These substations with aged critical components serve over 500,000 of our 1.2 million customers.
  - If we had not begun upgrading our substation fleet in 2019, by 2023 over 50 additional distribution substations serving an additional 200,000 customers would have a critical component reach 50 years of age.

Electric System	# of Circuits	OH Miles	UG Miles	Total Miles
Distribution	~2,300	~21,300	~7,600	~28,900
Subtransmission	~470	~4,200	~300	~4,500
<b>Total Line Miles</b>	<b>~2,770</b>	<b>~25,500</b>	<b>~7,900</b>	<b>~33,400</b>
Substation Type		Total Number of Substations		
Distribution Substations		~530		

## Ameren Missouri's Service Territory



 Ameren Missouri Service Territory

# Our System Continues to Age

## As our assets continue to age and approach or exceed end-of-life, they contribute to reliability issues and safety risks

- As the system continues to age, many of Ameren Missouri's assets are nearing or exceeding their expected life
  - End-of-life assets lead to an ever-increasing chance of failure due to malfunction or breakage
  - Additionally, many assets deployed more than 50 years ago were built to standards now generally considered outdated and not sufficient to reduce or prevent outages
- Aging assets pose a significant and ever-increasing risk due to their susceptibility to failure
  - Substantial portions of Ameren Missouri's distribution grid require upgrades:
    - ✓ ~325 substation transformers are currently over expected life
    - ✓ ~250 substation Oil Circuit Breakers (OCBs) are currently over expected life
    - ✓ ~775 substation Air Circuit Breakers (ACBs) are currently over expected life
    - ✓ ~2,900 miles of Underground Cable is currently over expected life, with another ~700 miles quickly approaching expected life (next 2-8 years)
  - Almost 1,600 miles of subtransmission have end-of-life assets requiring upgrades, including poles, cross-arms and insulators, and brittle conductors
    - ✓ ~39% of poles are currently past their expected life

“  
*Most of the nation's transmission and distribution lines were constructed in the 1950s and 1960s, with a 50-year life expectancy, meaning they have reached or surpassed their intended lifespan.*


American Society of Civil Engineers  
“Failure to Act: Electric Infrastructure Investment Gaps in a Rapidly Changing Environment”  
2020

”

# Our System Is Increasingly Impacted By Weather & Other Major Events


While our reliability metrics have held up relatively well (w/o considering storms), aging infrastructure poses an increasing risk to performance, esp. during storms

Major and Minor Storms for the Previous Ten Years



On average, number of **major storms** from 2017-2021 rose nearly **32%** compared to 2012-2016

Customer Minutes Out Due to Storms (Million Minutes)



On average, **customer minutes out** from 2017-2021 rose nearly **4%** compared to 2012-2016

## Key Takeaways:

- **Storms and extreme weather events have a significant impact on system reliability**
- The worst outages on Ameren Missouri's system are usually caused by major storms and these events are **increasing in both frequency and intensity**:
  - ✓ Tornadoes and windstorms have increased 5.5% annually during the last decade<sup>1</sup>
  - ✓ Annual precipitation has increased 5 to 10% during the last 50 years<sup>2</sup>
  - ✓ Rainfall on the four days per year with the greatest precipitation has increased 35% and the worst flooding has increased 20%<sup>2</sup>
- This has led to ever **more frequent major damage and significant losses due to these extreme events**
  - ✓ The average number of billion-dollar climate disasters in Missouri over the last ten years was ~4, which is a significant increase compared to the average from the prior ten years, ~2 disasters annually<sup>3</sup>


<sup>1</sup>Geophysical Research Letters, *Increasingly Powerful Tornadoes in the United States*, December 2018.

<sup>2</sup>Environmental Protection Agency, *What Climate Change Means for Missouri*, 2016.

<sup>3</sup>NOAA's National Centers for Environmental Information, "Missouri Billion-Dollar Weather and Climate Disasters: Time Series", 2021.


# Building Today's Grid into the Grid of the Future

The journey towards the grid of the future starts with securing the foundational infrastructure of today's grid as the platform for the what's to come



## Today

- Grid – Reliable, efficient, meets peak demand, aging infrastructure, one directional energy flow
- Customer – Homogenous service, few special offerings



## Tomorrow

- Grid – Upgraded infrastructure, resiliency, smart technology, sensors and data analytics to drive reliability, efficiencies,
- Customer – Expectations include highly reliable service with few momentaries and quick storm response times



---

## Category Discussion: System Hardening


# The Infrastructure That Supplies Dx Substations Is Rapidly Aging

Each subtransmission circuit feeds an average of 2,500 customers, ~39% of them have a majority of assets that are beyond their expected life

Asset	Total OH Miles	Expected Life (Years)	Timeline to Refresh System at Current Investment Levels	Current Average Age of the System	Miles Over Expected Life Today	# of Customers Served by Old Asset
Subtransmission System (Proxy: Wood Poles <sup>1</sup> Age)	~4,200	45	~76 years (@ forecasted 55 mi/yr.)	~37 years	~1,600	~460,000

<sup>1</sup>On average, one line mile includes 26 poles

What's the distribution of the age of our poles (years)?



What's the inspection failure rate by age group?

\*Based on ground line inspections

1. Poles age 31 – 45 are **four times more likely** to fail inspections than those 30 or less.
2. Poles age 45 or more are **eight times more likely** to fail inspections than those 30 or less.

**Red** indicates asset has exceeded expected life    **Orange** indicates asset is approaching expected life    **Green** indicates asset is significantly under expected life



# We See The Impact Of An Aging Subtransmission System

As equipment and hardware age, there is an ever-increasing chance of causing customer outages



## Narrative

- The photo illustrates the fragility of an aging system
  - In this case, a single insulator caused the cross-arm and pole to catch fire resulting in a circuit outage
- Tree damage, lighting damage, or aging insulators can create an extended power outage on a large portion of our existing facilities that were built with a previous design standard
- One damaged piece of hardware took this entire circuit out of power

# We Are Upgrading The System With A Modern Design Standard

The new standard reduces the number of potential failure points, increasing the resiliency of the system, while making it easier and safer to operate

Before: Previous Design Standard



**15 total** pieces of hardware (minus bolts)

After: Updated Design Standard



**6 total** pieces of hardware (minus bolts)



# We Are Upgrading The System With Stronger Poles

Use of composite poles allows for faster restoration, even with a direct impact from a tornado




*Non-Hardened Line, Cascading Failure*




*Hardened Line, Limited Cascading Failure*

# Subtransmission Hardening Plan & Refresh Rate

While current investment levels help reduce the degradation, the system is still aging beyond its expected life



Miles of OH Subtransmission	Forecasted Average Yearly Upgrades	Required Yearly Upgrades to Maintain System
~4,200	~55 Miles	~90 Miles



<sup>2</sup>Long-term targets are contingent on funding levels



---

## Category Discussion :


### Substation – Condition Based Monitoring

# Distribution Substation Key Components


Distribution substations, with critical components beyond their expected life, serve over 700,000 of our ~1.2 million customers

Asset Type	Total Distribution Assets	Expected Life	Average Age (Years)	Assets Over Expected Life	Customers Served by Assets over expected life
Transformer	~900	50	~41	~325	~450k
OCBs	~350	50	~53	~250	~700k
ACBs	~1,200	50	~53	~775	~400k

Transformers by Age




Switchgear Breakers by Age



Red indicates asset has exceeded expected life    Orange indicates asset is approaching expected life    Green indicates asset is significantly under expected life

# Expected Life of Substation Transformers – 50 Years

## Transformer Failure Data Illustrates Risk Of Aged Assets, Particularly At 50+ Years Old And Confirms That Certain Vintages Are Problematic (1960 To 1969)




### Observations

- **Transformer Age at Failure**: Transformer failures increasingly occur as assets near and exceed 50 years in service.
- **Manufacturer Year of Transformer at Failure**: Most of the transformers experiencing failures were manufactured between 1960 and 1969, suggesting that these units are failure prone. In particular, from 1964 to 1969, manufacturers were producing transformers quickly with lower quality in response to a rapid increase in demand from the growth of the electrical system from around the country.

# Substation ACB Failure Trends

ACB designs are more complex and generally less reliable than modern technology and standards



## Observations

- **ACB Age at Outage**: Greater counts of outages around 35-45 years old
- **Asset Design Challenges**: The air blast technology used across the industry up to the 1980's has proven to cause stress on the asset components due to the force exerted to extinguish the electrical current and arc. Over time, this repeated circuit breaking operation impacts the asset's future ability to successfully break the flow of electricity and restore service as intended.



# Instances of Substation Asset Failures

Substation modernization will support customer reliability and co-worker safety by mitigating risk of asset failure



**Transformer Failure (O'Fallon 21)**




**Switchgear Failure (Mullanphy)**





# Substation CBM Plan


While current plan helps slow the rate of degradation due to an aging system, assets are still aging past their expected life



<sup>1</sup>Long-term targets are contingent on funding levels

Asset	Pre-SEP Investment (2019) Avg Age	Current Investment Levels (2023) Projected Avg Age
Transformers	~37 years	~39 years
ACBs	~50 years	~54 years
VCBs	~18 years	~19 years

### Investment Timeline



To proactively replace aged equipment prior to failure:

- Substation CBM investments need to average **~\$120 Million per year for the next 12 years (2023 - 2035)**
- After 12 years, Substation CBM investments could **levelize at ~\$50 Million per year (post 2035)**

*Figures above do not include inflation*



---

## Category Discussion :

### Underground Cable Upgrades

# The Age of Our Underground System Continues to Increase

2,900+ miles of our underground system has already exceeded its expected life, and presents an increasing risk to customer reliability and safety

URD Cable Vintage	Mileage	Cable Age (Years)	Expected Life (Years)	Lateral Failures per Mile
First Generation & Older	~850	45+	40	2.42
Second Generation	~1,600	38 – 45	40	1.70
Third Generation	~700	32 – 38	40	1.22
Fourth Generation	~4,300	Present - 32	40	0.88

Obsolete Feeder Exit Cable Type	Mileage	Cable Age (Years)	Expected Life (Years)	Feeder Outages Due to Lead Cable
Lead Cable (PILC)	~450+	32 – 101	60	~60 outages per year

# Instances of Asset Failure

## Faulted UG Cable with exposed concentric neutral

Exposed concentric neutral cable in ground with the neutral eroded away



Faulted Direct buried #2 Al Cable with exposed concentric neutral





# Abnormal PILC Joints Present Significant Safety Risks to Co-Workers

As the system ages and repairs to PILC become necessary abnormal joints can occur, of which there are many instances recorded across the system




## Paper Insulated Lead Cable (PILC)

- Conductor is wrapped in oil impregnated paper which is surrounded by a lead jacket
- Becomes very brittle with age
- Leaking oil causes this cable to present an environmental hazard
- When failures occur, it is commonly repaired in small sections using EPR. This can lead to an abnormal/at risk joint due to imploding and/or swelling at the repair site

# Underground Cable Plan & Refresh Rate


While current plan levels help slow system degradation, the system is still aging beyond its expected life



<sup>1</sup>Long-term targets are contingent on funding levels

Miles of UG Cable	Forecasted Average Yearly Upgrades	Required Yearly Upgrades to Maintain System	Average Age of Cable (years)	# of Customers Served by Aged Asset
7,900	~80 Miles	~200 Miles	URD - 28 Lead - 61	~370,000

## Forecasted Investment Budget





---

## Category Discussion :

### Underground Revitalization



# Underground Revitalization Category Strategy

Underground revitalization will increase reliability and safety by upgrading aging infrastructure and reduce single points of failure

## Why Revitalize?

- **Age Of The System**
  - Much of the downtown system was originally installed in the early 20th century
- **Infrastructure Failure**
  - Many original cables and routes are no longer viable due to cable failures and duct bank collapses
- **Lack of Route Diversity**
  - Increased risk of a manhole fire, which could cut power to much of downtown for an extended time
- **Increasing Safety Risk**



Clay tile duct bank in disrepair (still in use with existing fiber)



5" plastic (EB-35) conduit duct face



Abnormal PILC cable joints




Highly congested manhole on 7<sup>th</sup> St.

# Category Strategy and Related Benefits

Underground revitalization is providing a host of benefits which is positively impacting customers and the community

## Upgrade Strategy

- **Fully rebuild the Downtown St. Louis system**
  - Conduit replacement
  - Cable upgrades
  - Install pathways for fiber optic command, control, and monitoring protocols
  - Work with the City of St. Louis to limit any potential impact on downtown commerce and street repair/paving efforts
- **Reduce outage frequency and impact risk**
  - Deploy a system where any 2 network primary circuits & any 1 radial circuit can be out of service without additional customer outages or overloading remaining cables
- **3 radial cables and 2 network cables per manhole / duct bank**
  - Limits the risk of one failure impacting many additional cables
- **Limit switching locations to a maximum of 4**




# Downtown St. Louis Revitalization Timeline

Our program to modernize the downtown St. Louis grid began in 2010 and will ensure continued safe and reliable service for customers

Asset	Amount
PILC in System	~45 Miles
PILC Joints	~600
Manholes at Risk	~600
Duct Bank at Risk	~2 Miles

### Downtown St. Louis UG Revitalization

- We have been executing a program to modernize the full downtown St. Louis grid since around 2010
- We expect that once we are complete with this effort, the downtown St. Louis grid will be in place to reliably serve customers for decades to come with only minor ongoing maintenance and minimal capital upgrades




<sup>1</sup>HT=Historical Total (2011 -2021 Budget)



# Downtown St. Louis Upgrades

Green lines indicate 5" PL duct banks constructed since 2012, blue lines are duct banks in construction, orange lines are future planned work





---

## Category Discussion :

### Grid Resiliency

# Category Strategy and Related Benefits

Grid resiliency investments support customer reliability through the grid's ability to respond and reconfigure during severe weather events and other outages

## Upgrade Strategy

### Grid Flexibility Constraints – addressed on targeted basis

- Line capacity constraints
  - Upgrade conductor to higher capacity rating OR
  - Construct new lines
- Substation capacity constraints
  - Construct new substation OR
  - Upgrade existing transformers OR
  - Add transformers to existing substations
- Convert select 4kV substations to 12kV substations




### Why Invest?

- Conservative operations
  - Operational flexibility
  - Improved ability to handle severe weather events due to the upgrading and replacement of old infrastructure at new standards
  - Less stress on assets & increased asset longevity
- Supports future load growth



# Select Grid Resiliency Projects

Grid resiliency supports customer reliability by providing a contingent supply across lines and substations in the case of a failure or storm damage



## Select Projects


- **Pershall:** This substation upgrade project provides tie capacity to a nearby substation and provides load relief to additional substations in the area which will improve their ability to serve customers
- **Hayti:** A new line was added as the primary supply to Steele substation, leaving the original line as an alternative supply to reduce risk of outages



# Grid Resiliency Plan and Timeline

Improving grid resiliency and operating flexibility will ensure continued customer reliability and safe service

Asset	Number at Risk	Customers Served	Timeline to Mitigate at Current Investment Levels
Subs on Manual	~30	~120,000	15 - 20 years
Subs w/ Active ALR	~30	~120,000	15 - 20 years
Load Analysis Risk	~50	~115,000	15 - 20 years
Distribution Line Capacity	Upgrading as needed to provide switching options for faster customer restoration	--	--







---

## Category Discussion :

Smart Grid

# Smart Grid Deployment Strategy

Smart grid supports customer reliability through new technologies that enable a smarter and more modernized grid

## Strategy

### Install Smart Switches System Wide

- Provides increased reliability benefits, up to ~40% improvement
- Allows for fault isolation to smaller zones
- Rapidly restore sensitive loads (hospitals, 911 call centers, large schools, large commercial centers)

### Target installations on yearly 12kV Worst Performing Circuits

- Sectionalizes feeders into sections of approximately 400 customers
- Limits the magnitude of any outage
- Limited 4kV deployment

### Install cutout reclosing devices (Tripsavers) in place of fuses

- 140T, 100T, 80T, 65T, and 40T fuses on 12kV
- Help resolve MDI (multiple device interruption) issues
- ~40% of Ameren Missouri's fuse outages in 2018 had no repair action other than replace fuse, reclosers minimize outage time and truck rolls


### Install FCI's on feeder terminal poles & key midpoints

- More quickly identify the cause and location of an outage
- Rapidly resolve and restore if possible or isolate to smallest zone and quickly restore other customers
- ~12% of all feeder outages are from failing feeder exit cables
- CAIDI improvement


### Build a Private LTE network

- Allows us to more economically connect and operate smart grid devices for customer reliability benefit

# Example of Distribution Automation Restorative Actions




1. Fault Occurs




2. Fault Located, Upstream Tie Opens

# Example of Distribution Automation Restorative Actions



3. Fault Isolated, Downstream Tie Opens



4. Customers Re-supplied by Substation C

# Smart Grid Technologies

Smart grid technologies support customer reliability through enhanced & proactive monitoring of overall operations & health of the system



New Automated Switchgear

Interruption



Manual Switchgear Before Replacement

Tripsaver

FCI



# Smart Grid Benefits

Smart grid technologies offer a wide range of benefits from reliability and safety to enabling the grid of the future and customer productivity



## Benefits

- Distribution Automation switches power sources to isolate damage and is delivering up to 40% improvement in reliability on circuits equipped with the technology and other associated upgrades
- Customers experience nearly 9,000 extended outages annually caused by a blown fuse in which no other damage to the system can be found. We expect trips savers will eliminate most of these and customers will only experience a momentary as the device opens to clear the fault & restores service
- FCI's will reduce the time customers are out by allowing Ameren Missouri to inspect predetermined points of a circuit for damage and make faster switching decisions
- Storm Impact Mitigation Examples
  - *July 10<sup>th</sup> 2021: A storm caused over 50,000 customers to lose power, but an additional 12,000 customers were protected from outages due to the over 200 DA operations over the several days of storms and restoration*
  - *August 12<sup>th</sup> 2021: Severe weather led to over 90,000 customers without power, but around 8,500 customers were protected from outages due to DA, reducing the total outage count from the storm by 8%*



# Modernization Plan

We plan to enable a smarter, more reliable grid, focusing on Tripsavers, DA, FCIs, and fiber / wireless



<sup>1</sup>Long-term targets are contingent on funding levels



# Wrap Up



1. Next Steps
2. Next Meeting Date and Location





---

# ED Project Evaluation Methodologies– 2<sup>nd</sup> OPC & PSC Staff Meeting

**June 2022**

# DRAFT Evaluation Methodology – System Hardening



Criteria	Variable	Definition	Threshold	Documentation / Data Required
<b>Age/Asset Vintage</b>	Exceeding Expected Engineered/Useful Life	Age of critical components	<ul style="list-style-type: none"> <li>✓ Beyond expected life</li> <li>✓ &gt;1.5x beyond expected life</li> </ul>	Quantify age; Include documentation on which quantification is based.
<b>Asset Condition</b>	Engineering Risk Assessment	Estimated asset health and risk of failure based on inspection results and/or operating history of similar vintages	<ul style="list-style-type: none"> <li>✓ Failed or unfavorable tests/inspections; medium likelihood of near-term failure</li> </ul>	Test/inspection records required if criteria is to be used as a justification factor
<b>Asset Performance</b>	Circuit Interruption(s)	The number of times asset-driven circuit interruption(s) have occurred	<ul style="list-style-type: none"> <li>✓ 2 interruptions in a year or 5 interruptions over 3 years</li> </ul>	Quantify historical interruptions; Include documentation of specific interruptions.
<b>Potential for Community Impact</b>	Number or type of potentially-affected customers	High-impact customers (e.g. school or university, hospital, airport), a large employer, or a large number of individual customers (~>1,000)	<ul style="list-style-type: none"> <li>✓ Potential for substantial community impact</li> </ul>	Documented impact to the local community is required
<b>Final Evaluation</b>		Two check marks result in eligibility for a System Hardening capital project		




# The Infrastructure That Supplies Dx Substations Is Rapidly Aging

Each subtransmission circuit feeds an average of 2,500 customers, ~36% of them have a majority of assets that are beyond their expected life

Asset	Total OH Miles	Expected Life (Years)	Timeline to Refresh System at Current Investment Levels	Current Average Age of the System	Miles Over Expected Life Today	# of Customers Served by Old Asset
Subtransmission System (Proxy: Wood Poles <sup>1</sup> Age)	~4,200	45	~76 years (@ forecasted 55 mi/yr.)	~35 years	~1,600	~460,000

<sup>1</sup>On average, one line mile includes 26 poles

What's the distribution of the age of our poles (years)?



What's the inspection failure rate by age group?

\*Based on ground line inspections

1. Poles age 31 – 45 are **four times more likely** to fail inspections than those 30 or less.
2. Poles age 45 or more are **eight times more likely** to fail inspections than those 30 or less.

# DRAFT Evaluation Methodology – Sub CBM





Criteria	Variable	Definition	Threshold	Documentation / Data Required
<b>Age/Asset Vintage</b>	Exceeding Expected Engineered/Useful Life	Age of critical components (Transformers or Breakers)	<ul style="list-style-type: none"> <li>✓ Beyond expected life</li> <li>✓ &gt;1.5x beyond expected life</li> </ul>	Quantify age; Include documentation on which quantification is based.
<b>Asset Condition</b>	Engineering Risk Assessment	Estimated asset health and risk of failure based on inspection results and/or operating history of similar vintages	<ul style="list-style-type: none"> <li>✓ Failed or unfavorable tests/inspections; medium likelihood of near-term failure</li> </ul>	Test/inspection records required if criteria is to be used as a justification factor
<b>Asset Performance</b>	Substation Interruption(s)	Substation interruption(s) or instance(s) of non-availability due to malfunction has occurred	<ul style="list-style-type: none"> <li>✓ Historical substation interruption(s) or instance(s) of non-availability</li> </ul>	Quantify interruption(s) or instance(s) of non-availability; Include documentation of specific interruptions or instance(s) of non-availability.
<b>Potential for Community Impact</b>	Number or type of potentially-affected customers	High-impact customers (e.g. school or university, hospital, airport), a large employer, or a large number of individual customers (~>1,000)	<ul style="list-style-type: none"> <li>✓ Potential for substantial community impact</li> </ul>	Document impact to the local community is required
<b>Safety</b>	Physical safety risk to stakeholders (employees, community, etc.)	Potential for safety issue due to old or improperly functioning equipment	<ul style="list-style-type: none"> <li>✓ Asset has known safety concerns, cannot be inspected/maintained while operating</li> </ul>	Include documentation of safety issue
<b>Final Evaluation</b>	Two check marks result in eligibility for a Substation CBM capital project			

# Distribution Substation Key Components

Distribution substations, with critical components beyond their expected life, serve over 700,000 of our ~1.2 million customers

Asset Type	Total Distribution Assets	Expected Life	Average Age (Years)	Assets Over Expected Life	Customers Served by Assets over expected life
Transformer	~800	50	~41	~315	~430k
OCBs	~350	50	~53	~250	~700k
ACBs	~1,200	50	~53	~775	~400k




Red indicates asset has exceeded expected life

Orange indicates asset is approaching expected life

Green indicates asset is significantly under expected

# Expected Life of Substation Transformers – 50 Years

## Transformer Failure Data Illustrates Risk Of Aged Assets, Particularly At 50+ Years Old And Confirms That Certain Vintages Are Problematic (1960 To 1969)




### Observations

- **Transformer Age at Failure:** Transformer failures increasingly occur as assets near and exceed 50 years in service.
- **Manufacturer Year of Transformer at Failure:** Most of the transformers experiencing failures were manufactured between 1960 and 1969, suggesting that these units are failure prone. In particular, from 1964 to 1969, manufacturers were producing transformers quickly with lower quality in response to a rapid increase in demand from the growth of the electrical system from around the country.

# Substation ACB Failure Trends

ACB designs are more complex and generally less reliable than modern technology and standards



## Observations

- **ACB Age at Outage:** Greater counts of outages around 35-45 years old
- **Asset Design Challenges:** The air blast technology used across the industry up to the 1980's has proven to cause stress on the asset components due to the force exerted to extinguish the electrical current and arc. Over time, this repeated circuit breaking operation impacts the asset's future ability to successfully break the flow of electricity and restore service as intended.

# DRAFT Evaluation Methodology – UG Cable



Criteria	Variable	Definition	Threshold	Documentation / Data Required
<b>Age/Asset Vintage</b>	Exceeding Expected Engineered/Useful Life	Age of Cable	<ul style="list-style-type: none"> <li>✓ Beyond expected life</li> <li>✓ &gt;1.5x beyond expected life</li> </ul>	Quantify age; Include documentation on which quantification is based.
<b>Asset Condition</b>	Engineering Risk Assessment	Estimated asset condition based on known risks of asset degradation or change to landscape	<ul style="list-style-type: none"> <li>✓ Direct Buried or Route Inappropriate</li> </ul>	Documentation of asset condition or landscape impacting asset if criteria is to be used as a justification factor
<b>Asset Performance</b>	Cable Failure(s)	Customer interruption(s) resulting from cable failure(s)	<ul style="list-style-type: none"> <li>✓ Historical Cable Failure(s)</li> </ul>	Quantify historical interruption(s); Include documentation of specific interruptions.
<b>Potential for Community Impact</b>	Number or type of potentially-affected customers	High-impact customers (e.g. school or university, hospital, airport), a large employer, or a large number of individual customers (~>1,000)	<ul style="list-style-type: none"> <li>✓ Potential for substantial community impact</li> </ul>	Documentation of impact to the local community is required
<b>Safety</b>	Physical safety risk to stakeholders (employees, community, etc.)	Potential for safety issue due to old or improperly functioning equipment	<ul style="list-style-type: none"> <li>✓ Asset has known safety concerns, cannot be inspected/maintained while operating</li> </ul>	Include documentation of safety issue
<b>Final Evaluation</b>	Two check marks result in eligibility for a UG Cable capital project			



# The Age of Our Underground System Continues to Increase

2,900+ miles of our underground system has already exceeded its expected life, and presents an increasing risk to customer reliability and safety

URD Cable Vintage	Mileage	Cable Age (Years)	Expected Life (Years)	Lateral Failures per Mile
First Generation & Older	~850	45+	40	2.42
Second Generation	~1,600	38 – 45	40	1.70
Third Generation	~700	32 – 38	40	1.22
Fourth Generation	~4,300	Present - 32	40	0.88

Obsolete Feeder Exit Cable Type	Mileage	Cable Age (Years)	Expected Life (Years)	Feeder Outages Due to Lead Cable
Lead Cable (PILC)	~450+	32 – 101	60	~60 outages per year

Red indicates asset has exceeded expected life    Orange indicates asset is approaching expected life

Green indicates asset is significantly under expected

**BEFORE THE PUBLIC SERVICE COMMISSION  
OF THE STATE OF MISSOURI**

In the Matter of Union Electric Company    )  
d/b/a Ameren Missouri's Tariffs to Adjust    )                    Case No. ER-2022-0337  
Its Revenues for Electric Service.            )

**AFFIDAVIT OF RYAN M. ARNOLD**

**STATE OF MISSOURI    )**  
                                                      )**ss**  
**CITY OF ST. LOUIS    )**

Ryan M. Arnold, being first duly sworn states:

My name is Ryan M. Arnold, and on my oath declare that I am of sound mind and lawful age; that I have prepared the foregoing *Direct Testimony*; and further, under the penalty of perjury, that the same is true and correct to the best of my knowledge and belief.



---

Ryan M. Arnold

Sworn to me this 1<sup>st</sup> day of August, 2022.