

FINNEGAN, CONRAD & PETERSON, L.C.

ATTORNEYS AND COUNSELORS AT LAW

1209 PENNTOWER OFFICE CENTER
3100 BROADWAY
KANSAS CITY, MISSOURI 64111

(816) 753-1122
TELECOPIER (816) 756-0373

JEREMIAH FINNEGAN, P.C.
STUART W. CONRAD
C. EDWARD PETERSON*

*ALSO ADMITTED IN
KANSAS AND MASSACHUSETTS

December 16, 2005

Ms. Cully Dale
Secretary/Chief Regulatory Law Judge
Missouri Public Service Commission
P.O. Box 360
Jefferson City, MO 65102

FILED²
DEC 22 2005
Missouri Public
Service Commission

**RE: Case No. SA-2005-0297 - Timber Creek Sewer Company
DNR Construction Permit No. 21-8365**


Dear Ms. Dale:

Enclosed for filing in the case papers of the above-named case find the notification letter from the DNR and the attached Construction Permit for the sewer system to be constructed to serve the Oakbrook Subdivision in Clay County.

Very truly yours,

FINNEGAN, CONRAD & PETERSON, L.C.

By:


Jeremiah D. Finnegan

JDF:crb

Enclosures

cc: Willis Sherry
Office of the Public Counsel
Keith Krueger

F:\DOCS\JDF\65478.1

Oakbrook Wastewater Treatment Facility
Clay County
MO-0131971

FILED²
DEC 22 2005

Missouri Public
Service Commission



Matt Blunt, Governor • Doyle Childers, Director

DEPARTMENT OF NATURAL RESOURCES

www.dnr.mo.gov

December 14, 2005

Mr. Brian Burton
136th Street Properties
607 Harborview Drive
Smithville, MO 64089

Dear Mr. Burton:

Your application for a collection system and wastewater treatment system for Oak Brook Subdivision has been approved by the Department of Natural Resources as evidenced by Construction Permit Number 21-8365.

This permit will expire one year from the date of issuance unless justification for extension is presented thirty (30) days prior to expiration.

In addition to the requirements for a construction permit, land disturbance activities of one acre or more require a Missouri State Operating Permit to discharge storm water (10 CSR 20-6.200). The permit requires best management practices sufficient to control runoff and sedimentation to protect waters of the state. To obtain this permit, submit Missouri Forms E and G and a permit fee of \$300.00 to the Missouri Department of Natural Resources, Kansas City Regional Office, 500 Northeast Colbern Road, Lee's Summit, Missouri 64085.

Following completion of construction please submit the following:

1. Form B-Application for Construction or Operating Permit signed by an officer having responsibility for the overall operation of the regulated facility
2. The first annual permit fee of \$3,000
3. The enclosed engineering certification form

If you have any questions, please contact the Kansas City Regional Office at 500 Northeast Colbern Road, Lee's Summit, Missouri 64086 or (816) 622-7000. Thank you.

Sincerely,

KANSAS CITY REGIONAL OFFICE

Handwritten signature of Karl Fett in black ink.

Karl Fett
Interim Regional Director

KFF/tbd

Enclosures

c: Mr. Wilbur M. Souders, P.E.; Aylett, Flowers Survey and Engineering Company
Timber Creek Sewer Company

LAWATER POLLUTION\TLB\CP-TP\21-8365 OakBrook TP.doc Recycled Paper

OakBrook WWTP
Activated Sludge

Permit #21-8365
Kansas City

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



CONSTRUCTION PERMIT

The Missouri Department of Natural Resources hereby issues a permit to:
Brian Burton
607 Harborview Drive
Smithville, Missouri 64089

for the construction of (described facilities):

SEE ATTACHED DESCRIPTION OF FACILITIES

Permit Conditions:

SEE ATTACHED SEWER EXTENSION CONDITIONS

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo, and regulation promulgated thereunder, or this permit may be revoked by the Department of Natural Resources.

As the Department of Natural Resources does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features.

A representative of the department may inspect the work covered by this permit during construction. Issuance of a permit to Operate by the department will be contingent on the work substantially adhering to the approved plans and specifications.

This permit applies only to the construction of water pollution control components; it does not apply to other environmentally regulated areas.

December 9, 2005
Effective Date

Doyle Childers

Doyle Childers, Director, Department of Natural Resources
Executive Secretary, Clean Water Commission

December 9, 2006
Expiration Date

Karl Fett

Karl Fett, Interim Regional Director, Kansas City Regional Office

MO 780-1151 (05-00)

WQP 3 34
Rev. 05-00

\$750 filing fee paid

DESCRIPTION OF FACILITIES

Installation of an Aero-Mod prefabricated Wastewater Treatment Plant with a 1,500-gallon pretreatment tank, surge tank, two aeration tanks, one clarifier, anaerobic digester, two blowers and UV disinfection equipment with all required appurtenances as specified in the plans and specifications to make this a complete and usable treatment facility.

Collection System: The collection system consists of 1,613 linear feet of a 3-inch PVC force main; 1,073 linear feet of a 2.5-inch PVC force main; 3,397 linear feet of a 2-inch PVC force main; and 4,244 linear feet of a 1.5-inch PVC force main.

This treatment facility will serve Oakbrook Subdivision, has a design population equivalent of 300 with a design flow of 30,000 gallons per day, is located in the SW 1/4, SE 1/4 of Section 7, T 52 N, R 31 W in Clay County, Missouri, and will discharge to an Unnamed Tributary to Fishing Creek.