

Exhibit No.:  
Issues: Transmission  
Witness: Edward C. Pfeiffer  
Sponsoring Party: Union Electric Company  
d/b/a AmerenUE  
Type of Exhibit: Direct Testimony  
Case No.: EA-2005-0180  
Date Testimony Prepared: December 20, 2004

**MISSOURI PUBLIC SERVICE COMMISSION**

Case No. EA-2005-0180

**DIRECT TESTIMONY**  
**OF**  
**EDWARD C. PFEIFFER**  
**ON**  
**BEHALF OF**  
**UNION ELECTRIC COMPANY**  
**d/b/a AmerenUE**

**St. Louis, Missouri**  
**December 20, 2004**

**BEFORE THE PUBLIC SERVICE COMMISSION  
OF THE STATE OF MISSOURI**

Application of Union Electric Company )  
for a Certificate of Public Convenience and )  
Necessity authorizing it to construct, install, )  
own, operate, control, manage and maintain )  
electric plant, as defined in § 386.020(14), RSMo. )  
to provide electric service in a portion of )  
New Madrid, County, Missouri, as an )  
extension of its existing certificated area )


Case No. EA-2005-0180

**AFFIDAVIT OF EDWARD C. PFEIFFER**


STATE OF MISSOURI    )  
                                  ) ss  
CITY OF ST. LOUIS    )

Edward C. Pfeiffer, being first duly sworn on his oath, states:


1. My name is Edward C. Pfeiffer. I work in St. Louis, Missouri, and I am employed by Ameren Services Company as Manager of the Electric Planning Department.
2. Attached hereto and made a part hereof for all purposes is my Direct Testimony consisting of 12 pages, and Schedules ECP-1 through ECP-2, all of which have been prepared in written form for introduction into evidence in the above-referenced docket.
3. I hereby swear and affirm that my answers contained in the attached testimony to the questions therein propounded are true and correct.

  
Edward C. Pfeiffer

Subscribed and sworn to before me this 20<sup>th</sup> day of December, 2004.

  
Notary Public

My commission expires: 4-1-2006



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21

**DIRECT TESTIMONY**  
**OF**  
**EDWARD C. PFEIFFER**  
**CASE NO. EA-2005-0180**

**Q. Please state your name and business address.**

A. My name is Edward C. Pfeiffer. My business address is One Ameren Plaza, 1901 Chouteau Avenue, St. Louis, Missouri 63103.

**I. INTRODUCTION**

**Q. Please describe your background and by whom, and in what capacity, you are currently employed.**

A. After receiving Bachelor of Science and Master of Science degrees in Electric Systems and Science Engineering from Southern Illinois University in Carbondale, I began my career with Union Electric Company (now d/b/a AmerenUE) in 1978. I worked for AmerenUE as an Engineer in the Transmission Planning Department for approximately 20 years. I am a registered professional engineer in the State of Missouri.

I am currently employed by Ameren Services Company (“Ameren Services”) as the Manager of the Electric Planning Department. Among other responsibilities, our department is responsible for both operational and expansion planning for the AmerenUE transmission system.

1 **Q. What is the purpose of your testimony?**

2 A. The purpose of my testimony is to describe the transmission and distribution facilities  
3 that will be used in order for AmerenUE to provide electric service to Noranda  
4 Aluminum, Inc (“Noranda”). I also address the impact on these facilities as a result  
5 of incorporating the Noranda load into the AmerenUE service territory as requested in  
6 AmerenUE’s Application. I will show that there will not be any adverse impact from  
7 a transmission or distribution perspective either to AmerenUE or to its customers as a  
8 result of AmerenUE serving Noranda.

9 **II. DESCRIPTION OF FACILITIES USED TO SERVE NORANDA**

10 **Q. Please describe AmerenUE’s transmission system.**

11 A. The AmerenUE transmission system consists of approximately 3,000 miles of  
12 transmission facilities operated at or above 100 kV which are predominately located  
13 in the eastern one-half of the state of Missouri. The highlighted area in Missouri on  
14 the attached map of facilities in the Mid-America Interconnected Network (“MAIN”)  
15 provides a good indication of AmerenUE’s Missouri service territory and  
16 transmission facilities. This map is marked as Schedule ECP-1.  
17 AmerenUE owns and operates all of these transmission facilities. However,  
18 functional control of the AmerenUE transmission system was transferred to the  
19 Midwest Independent Transmission System Operator, Inc. (“MISO”) on May 1, 2004,  
20 pursuant to this Commission’s approval of AmerenUE’s participation in the MISO in  
21 Case No. EO-2003-0271. As a result, effective May 1, 2004, the MISO became the  
22 transmission provider under whose Open Access Transmission Tariff (“OATT”) all  
23 transmission service provided over the AmerenUE transmission system, and other

1 transmission systems in the MISO's footprint, is administered. Transmission service  
2 under the MISO OATT is subject to the jurisdiction of the Federal Energy Regulatory  
3 Commission ("FERC").

4 **Q. Are AmerenUE's facilities the only transmission facilities located throughout the**  
5 **AmerenUE service territory?**

6 A. No. Associated Electric Cooperative, Inc. ("AECI") and its member cooperatives  
7 have service territories and transmission facilities that are interspersed throughout the  
8 AmerenUE service territory. Similarly, AmerenUE has transmission facilities which  
9 traverse the AECI service territory and which serve load that is surrounded by AECI  
10 service territory. To allow for the efficient use of their overlapping transmission  
11 systems, AmerenUE and AECI many years ago entered into an Interchange  
12 Agreement which enables each to use the other's facilities and thereby avoids the  
13 construction of duplicate and redundant facilities.

14 **Q Does AmerenUE currently use the AECI transmission system to serve its**  
15 **bundled retail load in Missouri?**

16 A. Yes. The AmerenUE service territory is not homogeneous or contiguous. In  
17 particular, certain parts of AmerenUE's service area are not directly connected to  
18 other parts. For example, AmerenUE's service area involving Excelsior Springs in  
19 western Missouri is not directly connected to its service area in central and eastern  
20 Missouri involving St. Louis County and adjacent areas. Instead, AmerenUE relies  
21 on AECI's transmission facilities to deliver power to Excelsior Springs and other  
22 similar locations.

1 **Q. Please describe the transmission and distribution facilities that currently serve**  
2 **Noranda.**

3 A. As more particularly described in AmerenUE's Application and the attachments  
4 thereto, Noranda is located in New Madrid County, Missouri. This is an area where  
5 AECI owns, operates and maintains transmission and generation facilities. Noranda  
6 owns its own distribution substation which is supplied by a series of radial 161 kV  
7 feeders which it also owns. These radial lines originate from the AECI New Madrid  
8 Substation complex. AECI's New Madrid Substation complex consists of 161 kV,  
9 345 kV, and 500 kV substations which are connected to five 161 kV lines (in addition  
10 to the Noranda 161 kV feeders noted above), two 345 kV lines, one 500 kV line, and  
11 two AECI-owned generators each of which is greater than 600 MW. In contrast, the  
12 AmerenUE 345/161 kV substation at Kelso is the closest AmerenUE facility capable  
13 of supplying a load of this magnitude. The Kelso Substation is approximately  
14 40 miles from New Madrid/Noranda.

15 **Q. Please describe the electrical generation that is located in the area.**

16 A. From an electrical standpoint, Noranda is surrounded by significant amounts of base  
17 load generation. This includes the following generation: the above-mentioned  
18 1,200 MW of AECI generation at New Madrid; Arkansas Power & Light Company's  
19 1,600 MW Independence Plant; AmerenUE's 1,200 MW Rush Island Plant; Electric  
20 Energy Inc's 1,000 MW Joppa Plant; and Tennessee Valley Authority's 1,500 MW  
21 Shawnee Plant.

22 All of this generation has been in service for a number of years, and is expected to  
23 remain in service for the foreseeable future. As mentioned, all of it is base load

1 generation which means that it is typically producing electricity in large quantities on  
2 a sustained basis.

3 **Q. Is the fact that Noranda is surrounded by all of this base load generation**  
4 **significant for purposes of AmerenUE's Application?**

5 A. Yes. From an electrical standpoint, the power from these existing base load  
6 generating plants is used by, and sinks in, Noranda's aluminum plant because of  
7 Noranda's close electrical proximity to these plants. Because of the laws of physics  
8 and regardless of which supplier is authorized to serve Noranda, whether by contract  
9 or regulatory order, local generation will serve local load. In other words, power will  
10 tend to flow directly from these base load units which are constantly running to  
11 Noranda which is constantly consuming power produced by them. If Noranda were  
12 to cease operations, the power from these surrounding generating sources would flow  
13 to a new sink and destination. This could create significant amounts of congestion in  
14 the area until additional outlet capacity could be built. It is unlikely that normal load  
15 growth would add new loads to substitute for that of a disappearing Noranda absent a  
16 replacement large-load customer. Thus, Noranda's continued operation is important  
17 to avoid congestion on the AmerenUE and AECI transmission systems.

18 **Q. Have AmerenUE's and AECI's transmission systems been used to deliver power**  
19 **to Noranda in the past?**

20 A. Yes. The interconnected transmission systems of AmerenUE and AECI have for  
21 many years been used to supply Noranda's electrical needs. From an electrical  
22 standpoint, not only do the laws of physics dictate that essentially the same generating  
23 plants will continue to physically supply the power Noranda consumes, but also the

1 same transmission system (and Noranda’s own distribution assets) will continue to be  
2 used to deliver that power to Noranda.

3 **Q. From what generation source does Noranda’s current supplier obtain or**  
4 **purchase electrical supply?**

5 A. To the best of my knowledge, Noranda load is not served by any designated  
6 generating resources. It is my understanding that the agent for Noranda secures  
7 energy from the market to serve the load. This affected how we analyzed the impact  
8 of AmerenUE serving the Noranda load. In power flow modeling an explicit source  
9 for each load is required. As a result, the source which has been used in regional  
10 power flow models to supply the Noranda load has been the incremental dispatch of  
11 AECI generation. Consequently, to analyze the effect on power flows of transferring  
12 the Noranda load into AmerenUE’s service territory we reduced the output of the  
13 “last on/first off” AECI generation and increased the available AmerenUE generation.  
14 The results are discussed below.

15 **Q. What overall impact, if any, is there on the AmerenUE system and on the AECI**  
16 **system once AmerenUE begins to serve Noranda instead of Noranda purchasing**  
17 **from the market?**

18 A. As mentioned above, the inclusion of the Noranda load in the AmerenUE service  
19 territory does not represent an incremental increase in the load attached to the  
20 transmission system at the AECI New Madrid Substation and there should be little or  
21 no change in the generation dispatch of the base load units to which the Noranda load  
22 is in close electrical proximity. Therefore, the transfer of the Noranda load into the



1 AmerenUE service territory should result in little or no change on any of the local  
2 flows in and around Noranda.

3 **Q. Has AmerenUE performed any modeling or analysis to verify the impact on**  
4 **power flows on the AmerenUE and AECI transmission systems as a result of**  
5 **AmerenUE beginning to serve the Noranda load?**

6 A. Yes. We have performed a power flow analysis that verified that there will not be  
7 any significant change to the flows on the transmission systems of AECI and of  
8 AmerenUE. The results are attached as Schedule ECP-2.

9 **Q. Is the AmerenUE transmission system capable of supplying Noranda?**

10 A. Yes. As stated before, there should be little or no change in the flows in eastern  
11 Missouri as there will be no incremental change in the load or close by generation due  
12 to the transfer of Noranda into the AmerenUE service territory. The impact on the  
13 AmerenUE transmission system would be from the dispatch of additional resources to  
14 meet the increased demand on generation due to the transfer. These generating  
15 resources are dispersed across the AmerenUE system and there are no known  
16 constraints associated with full output from any of the AmerenUE generating units.

17 **III. ARRANGEMENTS FOR TRANSMISSION SERVICE TO SERVE NORANDA**

18 **Q. What transmission facilities will be used in order for AmerenUE to supply**  
19 **electricity to Noranda?**

20 A. If our Application is granted and Noranda becomes a native bundled load customer of  
21 AmerenUE, the Noranda load would be included in AmerenUE's Network  
22 Integration Transmission Service ("NITS") under the MISO OATT. This is the same  
23 transmission service that is used to serve all of AmerenUE's other bundled retail

1 native load. The fact that Noranda is not contiguous with the rest of the AmerenUE  
2 service territory does not affect the need for NITS service, nor does it affect this  
3 service in any way.

4 As previously noted, the AmerenUE service territory is currently not contiguous or  
5 homogenous. As a result, AmerenUE has other bundled retail native load customers  
6 (the Excelsior Springs example noted earlier) who use NITS service under the MISO  
7 OATT in the same fashion. Because of the lack of contiguity and homogeneity,  
8 AmerenUE and AECI have over time developed the Interchange Agreement I  
9 mentioned earlier which addresses the fact that each has pockets of load in isolated  
10 service territories that are not contiguous to their respective transmission systems.

11 This physical relationship has resulted in the creation of Delivery Points. A Delivery  
12 Point is a connection at which the load of one party is directly connected to the  
13 transmission of the other. This arrangement allows for the load to be served reliably  
14 without the need to build duplicate transmission facilities.

15 In the case of Noranda, a new Delivery Point will be defined as the point at which the  
16 customer owned substation will be directly connected to the AECI New Madrid  
17 Substation via a series of 161 kV feeders. The Delivery Point for Noranda will  
18 include notice and termination provisions which will be consistent with the notice and  
19 termination provisions in the Agreement between AmerenUE and Noranda, which is  
20 attached as an exhibit to Mr. Craig Nelson's testimony.

21 **Q. Has AmerenUE contacted the MISO about Delivery Point arrangements for**  
22 **Noranda?**

1 A. Yes. AmerenUE contacted the MISO to determine how this Delivery Point would be  
2 treated under the MISO OATT. The MISO took the position that, since this Delivery  
3 Point connection was being established under the terms of a grandfathered agreement  
4 (namely, the AmerenUE-AECI Interchange Agreement), that the Noranda load would  
5 be supplied via NITS service under the MISO OATT and would not be subject to the  
6 MISO's regional through and out rates. Further, the use of a Delivery Point under the  
7 AmerenUE-AECI Interchange Agreement brings the Noranda load into the MISO  
8 energy market consistent with the policy of MISO and the FERC for the development  
9 of regional energy markets. In summary, the MISO has verified that it will provide  
10 NITS service to the Noranda load via a Delivery Point under the AmerenUE-AECI  
11 Interchange Agreement.

12 **Q. Is the Noranda Delivery Point provision between AmerenUE and AECI subject**  
13 **to regulatory approval?**

14 A. Yes. The new Delivery Point is being filed with the FERC and is subject to FERC  
15 approval.

16 **Q. What would happen if FERC did not approve the Delivery Point service for**  
17 **Noranda?**

18 A. In the event that AmerenUE and AECI were, for whatever reason, not allowed by  
19 FERC to use the Interchange Agreement to serve Noranda, the Midwest ISO has  
20 indicated that AmerenUE would have to secure additional Point to Point transmission  
21 service to deliver the power outside of the MISO footprint to the Noranda load.  
22 (MISO's tariff does not allow NITS service to be used for power that is transmitted

1 outside of its footprint.) This Point to Point service also is likely to include a charge  
2 under the MISO's regional through and out rates.

3 **Q. Who would be responsible for the additional transmission costs if FERC does**  
4 **not allow the use of Delivery Point service for Noranda?**

5 A. Noranda would be responsible for the costs of any alternate transmission  
6 arrangements. In particular, Noranda would be responsible for the costs of any Point  
7 to Point transmission service that AmerenUE would have to secure from the MISO to  
8 take the power outside of the MISO footprint. As a result, the LTS tariff provides  
9 that if MISO imposes charges based on the fact that Noranda is not connected to  
10 AmerenUE's system, such charges are the responsibility of Noranda.

11 **Q. Would Noranda pay for transmission service on the AECI system?**

12 A. Yes. It is my understanding that Noranda will pay AECI for transmission service on  
13 the AECI system for the power delivered by AmerenUE when AmerenUE starts  
14 serving Noranda as of June 1, 2005. As a result, the LTS tariff provides that it is  
15 Noranda's responsibility to secure and pay for firm transmission service if necessary  
16 for service outside of AmerenUE's control area (that is, on AECI's system).

17 **IV. EFFECT ON THE AMERENUE SYSTEM**

18 **A. UPGRADES**

19 **Q. Are any upgrades required to the AmerenUE system in order for AmerenUE to**  
20 **serve Noranda?**

21 A. No. The transfer of the Noranda load into the AmerenUE service territory does not  
22 represent an incremental change in the load connected to the transmission system and  
23 as such does not require any upgrades.

1           **B.       OPERATIONS**

2   **Q.       What is the effect of serving Noranda on AmerenUE's transmission operations?**

3   A.       The transfer of the Noranda load to the AmerenUE service territory would not create  
4           any significant change in system operations. AmerenUE and AECI have each added  
5           Delivery Points over the last several years so the addition of a Noranda Delivery  
6           Point would not be a major change to the operation of the system. The 470 MW  
7           Noranda load has a very high load factor and as such is not a difficult load to follow  
8           as compared to an arc furnace or other highly variable load which would introduce  
9           operational issues. The inclusion of the Noranda load in the AmerenUE control area  
10          can also be an operational benefit with respect to minimum generation dispatch  
11          requirements during off peak conditions.

12 **Q.       Would loss of the Noranda load affect transmission operations?**

13 A.       Yes, from a reliability perspective, it is in the overall best interest of the transmission  
14          system that the load at Noranda remain in service. If for example, Noranda were to  
15          cease operations, the net effect of the removal of the Noranda load from the  
16          transmission system would be the rough equivalent of adding a 470 MW generating  
17          unit at New Madrid. Although not explicitly studied, the addition of the equivalent of  
18          a 470 MW unit at New Madrid without some additional generation transmission  
19          outlet capacity could result in congestion along the AmerenUE interface to TVA and  
20          Entergy

1 **V. CONCLUSION**

2 **Q. Please summarize your testimony.**

3 A. The AmerenUE transmission system is fully capable of allowing AmerenUE to  
4 supply Noranda's electrical needs in a reliable manner for the foreseeable future.  
5 AmerenUE would do so under the MISO OATT for delivery of the power from  
6 AmerenUE's generators to Noranda as part of AmerenUE's bundled retail native load  
7 in conjunction with the Delivery Point provisions of the AmerenUE-AECI  
8 Interchange Agreement. No network upgrades are required due to the transfer of the  
9 Noranda load to the AmerenUE service territory. Further, there would be no adverse  
10 impact to the transmission system or any transmission related harm to AmerenUE or  
11 its other customers. No AmerenUE distribution facilities will be involved in serving  
12 Noranda, and so there could be no adverse impact to such facilities.

13 **Q. Does that conclude your testimony?**

14 A. Yes, it does.

# Principal Power Supply Facilities Existing and Authorized - April 2004

Revised 08/09/04


Electric Transmission Lines		Electric Generating Plants	
115 KV and Above			Fossil Fuel
DC Line			Nuclear
765 KV			Hydro
500 KV			Pumped Storage
345 KV			Wind
230 KV			Synchronous Condenser
115-161 KV			Transmission Stations
Authorized**			

- Regular Members**
- Allegheny Energy Supply Co., LLC
  - Alliant Energy Corporate Services
  - Ameren
  - American Transmission Company, LLC
  - Central Iowa Power Cooperative
  - City Water, Light and Power
  - Columbia (Missouri) Water & Light
  - Commonwealth Edison Co.
  - Constellation Power Source, Inc.
  - Coral Power, LLC
  - Duke Energy North America, LLC
  - Edison Mission Marketing and Trading
  - Electric Energy, Inc.
  - El Paso Merchant Energy
  - Illinois Municipal Electric Agency
  - Illinois Power Co.
  - LG&E Energy Marketing, Inc.
  - Madison Gas & Electric Co.
  - Midwest ISO
  - Mirant Americas, Inc.
  - Northern Indiana Public Service Co.
  - NRG Energy, Inc.
  - PG&E Corp.
  - PJM Interconnection, LLC
  - PPL EnergyPlus, LLC
  - Sempra Energy Trading
  - Tractebel Energy Marketing, Inc.
- Regular Members**
- Southern Illinois Power Cooperative
  - Soyland Power Cooperative, Inc.
  - Tenaska Power Services Co.
  - Williams Energy Services Co.
  - Wisconsin Electric Power Co.
  - Wisconsin Public Power Inc.
  - Wisconsin Public Service Corp.
- Associate Members**
- BP Energy Company
  - Cargill Power Markets, LLC
  - Cinergy Corp.
  - Energy-Koch Trading L.P.
  - First Energy Solutions Corp.
  - GridAmerica, LLC
  - TXU Energy Trading Co.

This map is published by:  
**Mid-America Interconnected Network, Inc.**  
 939 Parkview Boulevard  
 Lombard, IL 60148-3267

\* Voltage noted on map.  
 \*\* Scheduled in service this year unless otherwise designated.  
 (External to MAIN last updated 01/01/03)

Scale in Miles  
 25 0 25



From: Sullivan, John E
Sent: Monday, November 29, 2004 9:31 AM
To: Pfeiffer, Edward C
Subject: Flow Changes with Change in Noranda Supply

Sensitivity: Private



comparison.doc (40 KB)

The attached Word document contains PTI PSS/E output comparing two powerflow cases. One case, shown as the 'working case', is a 2005 Summer model, with Ameren and Associated Electric generation shifted to show Ameren generation supplying the Noranda load. The second case, shown as the 'saved case', is the same 2005 Summer model, but without the generation shift between Ameren and Associated Electric for the Noranda load.

The Ameren generation shift was made by increasing generation at Pinckneyville and Venice, with the Associated Electric generation shift coming from the following facilities:

Table with 3 columns: Facility Name, Capacity (MW), and Location. Rows include St. Francis Unit 1 & 2, Holden Unit 1 & 2, Nodaway Unit 1, Essex, Chouteau Unit 1, 2, & 3.

Total: 460 MW

Two tabulations of line flow comparisons are included in the attachment. One covers flow changes between the cases where branch flows changed by 50 MW or greater. The second covers flow changes where branch flows changed by 100 MW or greater.

In comparing the two powerflow cases, the greatest flow changes were on facilities near the Pinckneyville and Venice Plants, where the Ameren generation shift was modeled for this comparison. Other facilities with appearing in the 50 MW flow change tabulation, such as the Montgomery-McCredie-Overton 345 kV line (Montgomery-Overton-5) would appear to be in the list because of the generation pattern change, rather than having anything specific to do with Noranda load.

\*\*\*\*\*
John E. Sullivan, Engineer
Ameren Services
JSullivan@ameren.com
(314) 554-3833
\*\*\*\*\*



PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E WED, NOV 24 2004 16:28  
COMPARISON OF THE WORKING CASE AND THE SAVED CASE C:\AECI\05s-final.sav

WORKING CASE:  
2004 MMWG, 2005 SUMMER - GEN SHIFT FOR NORANDA  
AMEREN AND AMERENCILCO DETAIL

SAVED CASE C:\AECI\05s-final.sav:  
2004 MMWG, 2005 SUMMER  
AMEREN AND AMERENCILCO DETAIL

BUSES FROM THE TWO CASES ARE CONSIDERED TO BE THE  
SAME BUS WHEN THEY HAVE THE SAME BUS NUMBER AND NAME

WORKING CASE SUBSYSTEM BUSES OMITTED FROM BUS COMPARISON LIST:  
BUS # X-NAME-X BASE KV  
STAR POINT BUSES OF 733 THREE-WINDING TRANSFORMERS

C:\AECI\05s-final.sav SUBSYSTEM BUSES OMITTED FROM BUS COMPARISON LIST:  
BUS # X-NAME-X BASE KV  
STAR POINT BUSES OF 733 THREE-WINDING TRANSFORMERS

WORKING CASE CONTAINS 45210 BUSES AND 60228 BRANCHES  
1703 BUSES IN SELECTED SUBSYSTEM

C:\AECI\05s-final.sav CONTAINS 45210 BUSES AND 60228 BRANCHES  
1703 BUSES IN SELECTED SUBSYSTEM

1598 BUSES TO BE COMPARED

1752 BRANCHES IN COMPARE LIST

0 MULTI-SECTION LINES IN COMPARE LIST

BUSES WITH MW GENERATION DIFFERING BY MORE THAN 0.0 MW:

X----- BUS -----X	IN WORKING CASE			IN C:\AECI\05s-final.sav		
	MW	MVAR	%	MW	MVAR	%
31400 [OSAGE 138]	140.0	117.9	189.4	99.6	49.4	35.3
31504 [PICKVL 413.8]	44.0	-0.4	0.0	0.0	-44.0	100.0
31505 [PICKVL 513.8]	72.0	-0.5	0.0	0.0	-72.0	100.0
31506 [PICKVL 613.8]	72.0	-0.5	0.0	0.0	-72.0	100.0
31882 [VENICE3 15.0]	165.0	75.0	0.0	0.0	-165.0	100.0
31883 [VENICE4 15.0]	165.0	75.0	0.0	0.0	-165.0	100.0
96002 [1THLG2 22.0]	187.6	44.8	189.8	46.8	2.2	1.2
96010 [1STFRG1 16.0]	189.0	80.8	220.0	77.9	31.0	16.4
96011 [1STFRG2 16.0]	189.0	19.1	220.0	22.8	31.0	16.4
96012 [1HOLDEN113.8]	0.0	0.0	90.0	8.4	90.0	999.9
96013 [1HOLDEN213.8]	0.0	0.0	90.0	8.4	90.0	999.9
96025 [1NDWYG1 13.8]	0.0	0.0	70.0	43.6	70.0	999.9
96029 [1ESSEXG 13.8]	0.0	0.0	80.0	37.3	80.0	999.9
96031 [1CHOTCT113.8]	138.0	14.0	160.0	17.5	22.0	15.9
96032 [1CHOTCT213.8]	138.0	14.0	160.0	17.5	22.0	15.9
96033 [1CHOTST313.8]	144.0	14.0	168.0	17.5	24.0	16.7

BRANCHES WITH FROM BUS END FLOWS DIFFERING BY MORE THAN 50.0 MW OR MVAR:

X----	FROM BUS	-----X	X-----	TO BUS	-----X	IN WORKING CASE		IN C:\VAECI\05s-final.sav		MVAR	%	MVAR	%
						MW	MVAR	MW	MVAR				
30045	[ASHLEY 2 138]	30046	[ASHLEY 3 138]	1	6.8	28.6	-75.1	-3.9	-81.9	999.9	-32.5	113.8	
30045	[ASHLEY 2 138]	31825	[TRIGENMO 138]	1	-59.4	-20.2	7.7	5.4	67.1	113.0	25.7	126.9	
30046	[ASHLEY 3 138]	30215	[CAHOK 1 138]	1	-5.1	29.1	-87.2	-3.6	-82.1	999.9	-32.7	112.3	
30102	[BELLEAU 345]	30535	[ENON 345]	1	40.9	-90.7	-34.5	-85.8	-75.4	184.5	4.9	5.4	
30102	[BELLEAU 345]	31747	[SIOUX 345]	1	-324.9	14.3	-251.8	11.2	73.1	22.5	-3.1	21.8	
30154	[BLAND 345]	30886	[LABADIE 345]	1	-309.5	-33.7	-246.1	-36.1	63.3	20.5	-2.4	7.2	
30154	[BLAND 345]	96041	[7FRANKS 345]	1	594.5	96.7	530.2	89.8	-64.2	10.8	-6.8	7.1	
30216	[CAHOK 3 138]	31592	[RIDGE 138]	1	28.7	-3.1	83.1	9.1	54.4	189.5	12.2	396.4	
30249	[CABEL T 345]	30265	[CAMPBELL 345]	1	254.3	36.9	314.1	63.7	59.8	23.5	26.8	72.6	
30249	[CABEL T 345]	31651	[ROXFORD 345]	1	-83.0	-86.7	-181.7	-114.3	-98.7	118.8	-27.7	32.0	
30265	[CAMPBELL 345]	30266	[CAMPBELL 345]	1	254.2	37.8	314.0	64.3	59.8	23.5	26.5	70.1	
30266	[CAMPBELL 138]	31273	[MSD 138]	1	-3.7	18.4	75.5	42.7	79.2	999.9	24.3	132.1	
30266	[CAMPBELL 138]	31877	[VENICE 2 138]	1	-20.3	6.1	31.2	25.9	51.5	253.6	19.7	323.5	
30535	[ENON 345]	31230	[MONTGMYR 345]	1	-253.2	-98.7	-318.5	-92.9	-65.3	25.8	5.8	5.9	
30886	[LABADIE 345]	31230	[MONTGMYR 345]	1	263.4	7.5	213.3	8.7	-50.2	19.0	1.2	15.8	
30974	[LUTESVIL 345]	96038	[7ESSEX 345]	1	307.4	-5.2	247.6	-3.5	-59.8	19.5	1.7	33.6	
31051	[MASON 13 345]	31747	[SIOUX 345]	1	38.1	58.3	88.5	57.9	50.4	132.1	-0.4	0.7	
31088	[MCCREDIE 345]	31230	[MONTGMYR 345]	1	-292.5	-39.6	-198.2	-49.2	94.3	32.2	-9.6	24.3	
31088	[MCCREDIE 345]	31408	[OVERTON 345]	1	340.8	39.6	275.7	41.8	-65.1	19.1	2.2	5.7	
31273	[MSD 138]	31876	[VENICE 1 138]	1	-102.5	-0.8	-8.5	28.7	94.0	91.7	29.5	999.9	
31320	[N COULTR 230]	31500	[PICKNYVL 230]	1	-233.1	5.6	-153.4	-6.2	79.7	34.2	-11.8	211.1	
31500	[PICKNYVL 230]	31505	[PICKVL 513.8]	1	-71.9	6.1	0.0	0.0	71.9	100.0	-6.1	100.0	
31500	[PICKNYVL 230]	31506	[PICKVL 613.8]	1	-71.9	6.1	0.0	0.0	71.9	100.0	-6.1	100.0	
31500	[PICKNYVL 230]	31785	[STJOHNAM 230]	1	84.6	-33.3	-22.5	-20.2	-107.1	126.6	13.1	39.2	
31592	[RIDGE 138]	31877	[VENICE 2 138]	1	-56.0	-20.3	0.5	-1.5	56.5	100.9	18.8	92.8	
31651	[ROXFORD 345]	31747	[SIOUX 345]	1	412.3	-82.3	302.6	-93.4	-109.7	26.6	-11.1	13.5	
31785	[STJOHNAM 230]	31924	[W.FRKFT 230]	1	14.3	-16.4	-82.4	-3.5	-96.7	675.5	12.9	78.5	
31825	[TRIGENMO 138]	31877	[VENICE 2 138]	1	-52.4	-20.4	14.7	5.3	67.1	128.1	25.7	125.7	
31876	[VENICE 1 138]	31877	[VENICE 2 138]	1	-201.2	-82.5	-46.4	-30.5	154.8	76.9	51.9	63.0	
31877	[VENICE 2 138]	31882	[VENICE3 15.0]	1	-165.0	-58.4	0.0	0.0	165.0	100.0	58.4	100.0	
31877	[VENICE 2 138]	31883	[VENICE4 15.0]	1	-165.0	-58.4	0.0	0.0	165.0	100.0	58.4	100.0	
31924	[W.FRKFT 230]	31925	[W.FRKFT 138]	1	153.7	31.9	91.2	34.8	-62.5	40.7	2.9	9.0	
96012	[1HOLDEN113.8]	96124	[5HOLDEN 161]	1	0.0	0.0	90.0	8.4	90.0	999.9	8.4	999.9	
96013	[1HOLDEN213.8]	96124	[5HOLDEN 161]	1	0.0	0.0	90.0	8.4	90.0	999.9	8.4	999.9	
96025	[1NDWYG1 13.8]	96104	[5NODWAY 161]	1	0.0	0.0	70.0	43.6	70.0	999.9	43.6	999.9	
96029	[1ESSEXG 13.8]	96075	[5ESSEX 161]	1	0.0	0.0	80.0	37.3	80.0	999.9	37.3	999.9	
96071	[5CLINTN 161]	96124	[5HOLDEN 161]	1	0.1	6.2	-82.2	9.2	-82.3	999.9	3.0	48.6	
96110	[5PITTSV 161]	96124	[5HOLDEN 161]	1	17.1	-14.5	-64.6	-9.2	-81.7	477.0	5.2	36.0	

BRANCHES WITH FROM BUS END FLOWS DIFFERING BY MORE THAN 100.0 MW OR MVAR:

X----	FROM BUS	-----X	TO BUS	-----X	IN WORKING CASE		IN C:\AECI\05s-final.sav		MVAR	%		
					MW	MVAR	MW	MVAR			DELTA MW	%
31500	[PICKNYVL 230]	31785	[STJOHNAM 230]	1	84.6	-33.3	-22.5	-20.2	-107.1	126.6	13.1	39.2
31651	[ROXFORD 345]	31747	[SIOUX 345]	1	412.3	-82.3	302.6	-93.4	-109.7	26.6	-11.1	13.5
31876	[VENICE 1 138]	31877	[VENICE 2 138]	1	-201.2	-82.5	-46.4	-30.5	154.8	76.9	51.9	63.0
31877	[VENICE 2 138]	31882	[VENICE3 15.0]	1	-165.0	-58.4	0.0	0.0	165.0	100.0	58.4	100.0
31877	[VENICE 2 138]	31883	[VENICE4 15.0]	1	-165.0	-58.4	0.0	0.0	165.0	100.0	58.4	100.0

**CERTIFICATE OF SERVICE**

I hereby certify that a copy of the foregoing was served via e-mail, to the following parties on the 20th day of December, 2004.

Office of the General Counsel  
Missouri Public Service Commission  
Governor Office Building  
200 Madison Street, Suite 100  
Jefferson City, MO 65101  
[gencounsel@psc.state.mo.us](mailto:gencounsel@psc.state.mo.us)

Office of the Public Counsel  
Governor Office Building  
200 Madison Street, Suite 650  
Jefferson City, MO 65101  
[opcservice@ded.state.mo.us](mailto:opcservice@ded.state.mo.us)

Stuart W. Conrad, Esq.  
Attorney for Noranda Aluminum, Inc.  
Finnegan, Conrad & Peterson, L.C.  
1209 Penntower Office Center  
3100 Broadway  
Kansas City, Missouri 64111  
[stucon@fcplaw.com](mailto:stucon@fcplaw.com)

**/s/James B. Lowery**  
James B. Lowery