

Rulemaking No.: 12-03-014
Exhibit No.: SCE-1
Witnesses: Garry Chinn
Colin Cushnie
Mark Nelson
Jonathan Rumble
Carl Silsbee



(U 338-E)

***TRACK 4 TESTIMONY OF SOUTHERN
CALIFORNIA EDISON COMPANY***

Before the
Public Utilities Commission of the State of California

Rosemead, California
August 26, 2013

1 sections and breakers) violates system performance requirements specified by the
2 NERC Reliability Standards.¹⁶

3 The United States Congress created an electric reliability organization
4 (ERO) through the Energy Policy Act of 2005. The Federal Energy Regulatory
5 Commission (FERC) certified NERC as the ERO on July 20, 2006. NERC
6 develops, implements, and enforces mandatory reliability standards for the bulk
7 power system. NERC performs its duties in accordance with Section 215 of the
8 Federal Power Act. The statute requires users, owners and operators of the bulk
9 power system in the United States to be subject to FERC approved NERC
10 Reliability Standards.

11 These standards require the simulation of a range of potential conditions
12 from no contingencies (Category A) to extreme events (Category D). The two
13 intermediate categories of contingencies, Category B, events resulting in the loss
14 of a single element and Category C, event(s) resulting in the loss of two or more
15 elements constitute the majority of contingencies examined in SCE's studies. An
16 example of a Category B contingency is the fault and loss of one transformer
17 bank. An example of a Category C contingency is the fault and simultaneous loss
18 of two transmission lines that share a common tower.

19 Attachment 1 is Table 1 from NERC Reliability Standard TPL-001-3
20 which provides a complete description of Category A through D contingencies
21 and the associated system performance requirements. Table 1 is common to
22 transmission planning standards TPL-001-3, TPL-002-2b, TPL-003-2b, and TPL-
23 004-2a. These NERC Transmission Planning (TPL) Reliability Standards require
24 the system to be stable and both thermal and voltage limits to be within facility

¹⁶ NERC transmission planning Reliability Standards include TPL-001-3 (Category A), TPL-002-2b (Category B), TPL-003-2b (Category C), and TPL-004-2a (Category D).

1 ratings for Categories A through C. NERC TPL Reliability Standards generally
2 do not permit loss of demand, such as load shedding, for Categories A and B.
3 However, if planned and controlled, NERC TPL Reliability Standards permit loss
4 of demand for Category C. Category D contingencies are extreme events with no
5 specific performance requirements other than an evaluation for risks and
6 consequences. SCE's power flow studies examined Category A through D
7 conditions for facilities in SCE and SDGE's service areas.

8 **b) SCE's Studies Look For Thermal Overloading and Voltage Violations**
9 **During These Contingencies**

10 SCE's studies identify both thermal overload and voltage violations for
11 Category A through D conditions. The studies look for power flows in excess of
12 normal (Category A) and emergency (Categories B through D) thermal ratings of
13 transmission facilities. SCE establishes the thermal ratings of transmission
14 facilities as the owner of these facilities to prevent damage to equipment and
15 assure safe clearances are maintained in accordance with General Order No. 95.
16 The studies also look for voltages at substations outside of specific bandwidths
17 and percentage deviations in excess of thresholds established by the CAISO as
18 provided in Table III-2 below¹⁷. Maintaining voltages at substations prevents
19 voltage collapse events in which voltages in a portion of the electric system
20 decrease catastrophically causing a blackout. The CAISO established these
21 voltage limits via an open stakeholder process in 2011. Based on the identified
22 thermal overloads and voltage violations, SCE develops mitigation options to
23 improve system performance.

¹⁷ "California ISO Planning Standards", June 23, 2011, Section II.3., page 4

**Table III-2
CAISO VOLTAGE REQUIREMENTS**

(Voltages are relative to the nominal voltage of the system studied)

Voltage level	Normal Conditions (TPL-001)		Contingency Conditions (TPL-002 & TPL-003)		Voltage Deviation	
	Vmin (pu)	Vmax (pu)	Vmin (pu)	Vmax (pu)	TPL-002	TPL-003
≤ 200 kV	0.95	1.05	0.90	1.1	≤5%	≤10%
≥ 200 kV	0.95	1.05	0.90	1.1	≤5%	≤10%
≥ 500 kV	1.0	1.05	0.90	1.1	≤5%	≤10%

c) **SCE Then Adds New Generation At Key Locations To Mitigate Violations**

SCE’s studies first use generation as mitigation to establish a base line to address violations. SCE located the generation at several existing substations including: Alamitos, Huntington Beach, Johanna, Santiago, and San Onofre. SCE selected Alamitos, San Onofre, and Huntington Beach substations because they are existing OTC sites and are favorably located to relieve identified violations. Coastal southern California is both densely populated and well regulated. So, locating sufficient land for new generation development is challenging.

Developing new generation at existing OTC sites may be possible. However, not all existing OTC sites were favorably located to relieve identified violations. Johanna and Santiago are not existing OTC sites, but proved beneficial locations to minimize the total generation needed to address violations in specific scenarios.

The generation modeled at these substations is a proxy for any generation in the vicinity that is electrically equivalent. SCE adds the minimum amount of generation required to mitigate all identified thermal and voltage violations. After establishing a minimum generation solution, SCE then tests transmission projects and Preferred Resources to determine the incremental reduction in the amount of generation required for each alternative.