

**BEFORE THE PUBLIC SERVICE COMMISSION
OF THE STATE OF MISSOURI**

In the Matter of the Application of)	
Osage Utility Operating Company, Inc.)	
to Acquire Certain Water and Sewer)	Case No.: WA-2019-0185 &
Assets and for a Certificate of)	SA-2019-0186
Convenience and Necessity)	

**REFLECTIONS CONDOMINIUM OWNERS ASSOCIATION, INC.’S
RESPONSE TO STAFF RECOMMENDATION AND MEMORANDUM**

Pursuant to 4 CSR 240-2.080 and the Order Granting Motion for Extension of Time, dated May 14, 2019, Reflections Condominium Owners Association, Inc. (“**Reflections Condo Association**”) responds to the Staff Recommendation and Memorandum, dated May 24, 2019 (the “**Memorandum**”) as follows:

1. On page 17 of the Memorandum, the Staff makes several statements regarding the status of the Reflections’ water system which Reflections Condo Association believes are incorrect. The Board of Directors of Reflections Condo Association does not recall ever being informed by DNR that certain PVC piping and valving does not meet DNR requirements, or that the above-ground section of piping needs a heat source. Nor does Reflections Condo Association believe that the well house siding and roofing are in need of repair or replacement, since the roofing and siding on the well house are the same materials as the roofing and siding on the condominium buildings and those parts of the condominium buildings are not in need of repair or replacement. The water quality of the Reflections water system is routinely tested and monitored.

2. The Staff is correct that the most recent DNR inspection of the Reflections’ water system conducted on August 9, 2017 only noted operating without a permit as a compliance issue.

3. Attached hereto as **RCOA-1** is a letter from DNR dated May 21, 2018. In this letter, DNR approved an engineering report prepared by Michael Stalzer, P.E. dated April 9, 2018 regarding the Reflections' water system, which report only recommended the addition of three (3) hydropneumatic tanks and a new chlorination system. The engineering report by Michael Stalzer is attached as **RCOA-2**. Reflections Condo Association believes that these are the only repairs/improvements that need to be made to its water system to satisfy DNR.

4. Reflections Condo Association contends that Applicant's proposal to make \$165,213.00 of repairs and improvements to the Reflections' water system is unreasonable, excessive, and unnecessary. The proposed repairs to the Reflections' systems greatly exceed the repairs that Michael Stalzer, P.E. and DNR have indicated are necessary.

5. On page 17 of the Memorandum, the Staff states that the Reflections' sewer system has two pump stations; however, there is only one pump station with two pumps. On page 18 of the Memorandum, there is a reference to a June 29, 2016 DNR inspection of the sewage system. This inspection report has not been provided to Reflections Condo Association.

6. The Applicant has not provided any engineering report as to the needed repairs and improvements to the Reflections' sewage system. Once that report is provided, Reflections Condo Association will have it reviewed by its engineering experts.

7. Reflections Condo Association is concerned that the Applicant intends to make unnecessary expenditures to the Reflections' water and sewer systems beyond what is required by DNR.

8. The Applicant is paying ** _____ ** for the Reflections water and sewer systems. Yet, the Applicant and the Staff are recommending a net book value credit of \$313,440.00 for those systems (based on information provided by the Applicant), plus an

acquisition premium. This will result in the Applicant getting substantial future benefit and future revenues on funds the Applicant never expended, to the detriment of the condo owners. Reflections Condo Association opposes the Staff recommendation on net book value credit and acquisition premium.

9. The Staff indicates that the Reflections customers will begin to receive separate bills for their units, even though there are no separate meters and the Reflections Condo Association has always paid for water and sewage expenses. Reflections Condo Association requests that bills be sent to it for payment by it out of assessment revenues received by it from the condo owners.

WHEREFORE, Reflections Condominium Owners Association, Inc. respectfully requests that the Commission note this response, disregard the Staff's Recommendation and Memorandum as addressed by this Response, to order a procedural conference, and such other relief as the Commission deems just and proper.

ROUSE FRETS WHITE GOSS
GENTILE RHODES, P.C.

By: /s/ Christopher L. Kurtz


Christopher L. Kurtz MO #61654
Stanley N. Woodworth MO #29217
5250 West 116th Place, Suite 400
Leawood, KS 66211
Phone: (913) 387-1600
Fax: (913) 928-6739
ckurtz@rousepc.com

ATTORNEYS FOR REFLECTIONS
CONDOMINIUM OWNERS
ASSOCIATION, INC.

CERTIFICATE OF SERVICE

I hereby certify that a true and correct copy of the foregoing was served, either electronically or by First Class United States Mail, postage prepaid, on this 3rd day of June, 2019, with notice of the same being sent to all counsel of record.

/s/ Christopher L. Kurtz



RECEIVED NOV 23 2018
Missouri Department of dnr.mo.gov

NATURAL RESOURCES

Eric R. Greitens, Governor

Carol S. Comer, Director

May 21, 2018

Mr. John Wright, President
Reflections Condominiums
Owners Association, Inc.
P.O. Box 2409
Lake Ozark, MO 65049

RE: Reflections Condos, MO3071337, Camden County, Review No. 5000063-18

Dear Mr. Wright:

The Missouri Department of Natural Resources' Public Drinking Water Permits and Engineering Section has reviewed the Engineering Report for the Reflections Condos, in Camden County, Missouri. The report was examined as to sanitary features which may affect the operation of the system, including size, capacities, of units, and factors which may affect efficiency and ease of operation. Approval of the Engineering Report as regards to these points is hereby given. This approval is valid for two years.

It is suggested that you proceed to make arrangements for financing the proposed projects and instruct your engineer to prepare the necessary detailed plans and specifications for the proposed improvements.

Regulations require written approval of detailed plans and specifications before awarding the contract or initiating construction. Upon receipt of the detailed plans and specifications, we will proceed with our review and advise you by written report of our approval. An updated Engineering Report must be submitted with the detailed plans and specifications if there is a change in the scope of the project or if the original report is more than two years old.

If you have any questions concerning this letter or if you need any further assistance, please contact Ms. Diane Muenks by phone at 573-751-5924, or contact the engineer by email at brandon.bach@dnr.mo.gov, or email me at maher.jaafari@dnr.mo.gov. Thank you

Sincerely,

WATER PROTECTION PROGRAM

Maher Jaafari, Ph.D., P.E., Chief
Drinking Water Permits and Engineering Section

MJ:bbm

Enclosure

c: Mr. Michael Stalzer, P.E.
Southwest Regional Office



DEPARTMENT OF NATURAL RESOURCES OF MISSOURI
ENGINEERING EVALUATION FOR APPROVAL OF ENGINEERING
REPORT

Reflections Condos
Camden County, Missouri
May 21, 2018

INTRODUCTION

Review Number 5000063-18

An Engineering Report dated April 9, 2018, for Reflections Condos, in Camden County, Missouri were submitted for review and approval by Michael Stalzer, P.E., of Tampa, Florida.

BRIEF DESCRIPTION

An Engineering Report for Reflections Condos has been reviewed. The report was examined as to sanitary features which may affect the operation of the project, including size, capacities of units, and factors which may affect efficiency and ease of operation.

The Engineering Report consists of the following:

- Description of the existing water.
 - The water system currently consists of 50 condominiums. Twelve of these are occupied year round.
 - The system is supplied by one well equipped with a 125 gallon per minute (gpm) submersible pump
 - Storage is provided by seven 119 gallon hydropneumatic tanks.
- A brief description of the exposed water main is included that indicates the water main currently has no leaks and is acceptable as constructed.

The Engineer Report recommends the following


- Based on an average daily flow of 3,700 gpm and a population equivalent of 74 people. The Engineering Report recommends the addition of three additional 119 gallon hydropneumatic tanks.
- New chlorination system at the well including solution tank, metering pump, and injection tap at the well house.

NOTE

- Should the exposed water main develop issues it needs to be properly installed and bedded below ground.
- Before the installation of the new hydropneumatic tanks a construction permit along with plans and specifications must be submitted to the Department for review and approval.

STAFF RECOMMENDATION

On the basis of the review in accordance with Missouri Drinking Water Regulation 10 CSR 60-10.010(1), I recommend this Engineering Report be granted approval.



Brandon Bach, E.I.
Drinking Water Permits and Engineering Section

Reflections Condos, Approval
Page 2

APPROVAL TO CONSTRUCT

The engineering plans and specifications described above were examined as to sanitary features of design which may affect the operation of the sanitary works, including size, capacities of the units, and factors which may affect the efficiency and ease of operation. Approval as regards these points is hereby given.

Approval is given with the understanding that final inspection and approval of the completed work shall be made by the Department of Natural Resources before same is accepted and placed in operation. If construction is not commenced two (2) years after the date of issue or there is a halt in construction of more than two years, the approval to construct will be void unless an extension of time has been granted by the department.

In the examination of plans and specifications, the Department of Natural Resources, Public Drinking Water Program does not examine the structural features of design or efficiency of mechanical equipment. This approval does not include approval of these features.

The Department of Natural Resources, Public Drinking Water Program reserves the right to withdraw the approval of plans and specifications at any time it is found that additional treatment or alterations are necessary to assure reasonable operating efficiency and to afford adequate protection to public health.

ENGINEERING REPORT

WATER SYSTEM IMPROVEMENT
REFLECTIONS CONDOMINIUM
CAMDEN COUNTY, MISSOURI

OWNER:
REFLECTIONS CONDOMINIUM OWNERS'
ASSOCIATION, INC
HCR 82, BOX 5040
CAMDENTON, MO 65020

April 9, 2018



Michael Stalzer 4/9/18

MICHAEL STALZER, P.E.
CPWG
3918 N. Highland Ave
Tampa, FL 33603
417-860-9697

Table of Contents

1	Introduction.....	2
2	Description.....	2
3	Operation and Maintenance	2
4	Drinking Water Facility Description	3
4.1	<i>Disinfection</i>	3

Appendices

- A. Location Map
- B. Pressure Tank Specification
- C. Chlorination System Specification
- D. MDNR – High Yield and Public Well Record

1 Introduction

This report is for the purpose of obtaining the approval from the State of Missouri for the addition of new bladder tanks to the water system serving Reflections Condominium, Camdenton, Missouri. This improvement will bring the system into compliance based on the number of units served. The site location in Section 8, Township 39 North, Range 17 West, Camden County, Missouri.

2 Description

Currently, the distribution system serves fifty condominium units, of which twelve are occupied year round. The metered water usage from 2016 resulted in an average demand of 3,700 gallons per day, and a peak daily demand of 7,400 gallons.

According to the MDNR High Yield and Public Well Record and Pump Information Data report #A072734, the state approved deep well has a pump rate of 125 gallons per minute (gpm) and a well yield of 193 gpm. The well is controlled by 7 - 119 gallon bladder tanks and a 20/40 pounds per square inch (psi) pressure switch. The water storage for the system is provided by the 7 bladder tanks. At an operating pressure range of 20/40 psi, the usable tank volume is 47.8 gallons or a combined total of 334.6 gallons.

The system does not provide a minimum fire hydrant flow rate of 250 gpm as required by MDNR, however, under NFPA 13-R the water system does provide adequate flow and pressure for a fire sprinkler system. The required fire flow is 0.05 gpm per square feet of area sprinkled.

Based on a well production rate of 125 gallons per minute, a sprinkled system can serve a floor area of:

Well pumping rate = 125 gpm
Domestic demand = 10.27 gpm

Flow available for fire suppression = $(125 - 10.27) = 114.73$ gpm

Floor area served = $114.73 \text{ gpm} / 0.05 \text{ gpm/sf} = 2,294$ sf

With the existing maximum unit size at approximately 1,100 sf, the system as constructed is adequate to serve both the needed domestic flow and the needed flow for the fire suppression system.

3 Operation and Maintenance

Great Southern Bank currently owns the land and improvements where the water system is located; and Reflections Condominium Owners' Association operates and maintains the system. Both such entities intend to turn the system over to Ozarks Clean Water Company to own, operate, and maintain.

The exposed water main has been inspected, and there are no issues or leaks. The main, as constructed, is acceptable.

4 Drinking Water Facility Description

Based on available metered flow data from 2016, the average daily flow was 3,700 gpd. Given an average flow of 3,700 gpd, the maximum daily demand would be 7,400 gpd. At twice the maximum day demand, the maximum hour demand would be 14,800 gallon per day or 10.27 gallons per minute.

Based on metered usage, the population served by the system is:

$$3,700 \text{ gpd} / 50 \text{ gpd/person} = 74 \text{ people}$$

For this population equivalent, the required number of bladder tanks is:

$$74 \text{ people} \times 6.25 \text{ gallons/person served} = 462.5 \text{ gallons}$$

$$\text{Usable tank volume per bladder tank at 20/40 psi} = 47.8 \text{ gal}$$

$$\text{Required number of tanks} = 462.5/47.8 \text{ gal} = 9.67 \text{ use } 10$$


With seven bladder tanks currently installed, three additional tanks are needed. After approval of the engineering report, a construction permit application will be submitted for the installation of the additional bladder tanks and chlorination system.

4.1 Disinfection

A review of the water quality reports indicates that the water system is in compliance with the applicable water quality standards. Although the system does not have the needed water storage capacity for the required 30 minutes of chlorine contact time, a tap for a chlorine injection pump has been included. If water quality deteriorates prior to the addition of a ground level storage tank, an LMI model P122-352S1 metering pump with a 35 gallon T40-0003 solution tank may be used as a chlorination system. The system operator will need to meter the pump in a manner necessary to meet the allowable chlorine level.

Appendix A

SECTION 8, T39N, R17W
CAMDEN COUNTY, MISSOURI



SITE LOCATION

Appendix B



WELL-X-TROL PROFESSIONAL
Pre-Pressurized
**Water System
Tanks**



WELL-X-TROL® Professional revolutionizes the industry

WELL-X-TROL® Professional redefined the industry with its advanced engineering and innovative product design including the pre-pressurized well tank, sealed-in air charge, and unique water chamber design. With proven performance since 1963, WELL-X-TROL Professional continues to deliver unparalleled results making it **the most trusted choice of professionals** in today's market. WELL-X-TROL Professional offers many unique features that result in consistent, reliable performance, including design elements that prevent tank corrosion and reduce wear and tear on the well pump.

Features and Benefits

Exclusive butyl diaphragm, along with the 100% corrosion resistant virgin polypropylene liner, are secured by a positive hoop ring seal for added strength and reliability. This totally integrated system outperforms other types of water chamber designs.

The stainless steel air valve is welded rather than threaded to prevent loss of air pressure.

The finest quality, custom mill steel is used in the deep drawn dome for extra strength while keeping tank weight to a minimum.

More choices mean more flexibility

WELL-X-TROL Professional offers more options and sizes than any other well tank manufacturer, including both vertical and horizontal designs, and sizes ranging from 2 gallons to 119 gallons so you can configure a system that's right for any application.

First on Industry Safety Standards

WELL-X-TROL Professional tanks were the first to meet all industry standards for quality and safety. The butyl diaphragm in all models meets EPA requirements for potable water as defined in the Safe Drinking Water Act of 1986. The entire tank which includes the virgin polypropylene liner, butyl diaphragm, and acceptance fittings for a 100% corrosion resistant water reservoir is listed by NSF International Standard 61.

Advanced

design features

continue to set industry standards

- Stainless steel air valve is welded in position rather than mechanically threaded to prevent loss of air pressure and to minimize stress on the well's pump system. It also carries a tamper-evident warning label.
- Deep-drawn steel domes offer twice the strength of rolled steel while minimizing weight.
- Unique positive hoop ring seal secures diaphragm and liner for added strength and reliability.
- Heavy duty butyl diaphragm features seamless construction for uniform strength and flexibility. It conforms exactly to the shell configuration without stretching, creasing, or forming bubbles or corners that could trap water or sediment. Butyl is the best known elastomer to prevent air loss.
- Heavy duty butyl diaphragm is extremely resistant to bacterial growth and meets FDA requirements for potable water supply.
- Virgin polypropylene liner provides a 100% corrosion resistant, non-metallic rigid water reservoir that is listed by NSF International Standard 61.
- Stainless-steel system connection withstands aggressive water.
- Exclusive welding process eliminates interior rough spots and sharp edges which prevent damage to the diaphragm and liner.
- Each finished tank is pressure tested for safety.
- Each finished tank is pre-pressurized to the most common pump cut-in pressure.
- Exterior appliance-like finish looks attractive while protecting the tank from the elements.



WELL-X-TROL
Professional by AMTROL

RCOA-2

esp

(Effective System Protection):

maximum system output with minimal pump starts

The ESP sizing procedure covers modern residential water-use habits, increased off-peak demands and the general increase in water use that have occurred over the past twenty-five years.

ESP sizing is designed to reduce pump wear and tear, and reduce energy consumption by keeping pump starts to a minimum.

Choose the amount of protection you need.


ESP I: Tank selection is based on approximately one minute minimum pump running time. This is recommended for pumps up to 3/4 H.P.

ESP II: Tank selection is based on approximately two minute minimum pump running time. This is recommended for 3/4 H.P. or larger pumps.


ESP Sizing Table

PUMP DISCHARGE RATE GPM (Approx.)	OPERATING PRESSURE - PSIG					
	20/40	ESP I 30/50	40/60	20/40	ESP II 30/50	40/60
5	WX-202	WX-202	WX-202	WX-202XL	WX-205	WX-205
7	WX-202	WX-202	WX-202XL	WX-205	WX-250	WX-251
10	WX-202XL	WX-205	WX-205	WX-251	WX-251	WX-255
12	WX-205	WX-250	WX-250	WX-251	WX-255	WX-255
15	WX-250	WX-250	WX-251	WX-255	WX-302	WX-350
20	WX-251	WX-251	WX-255	WX-350	WX-350	(2) WX-255
25	WX-251	WX-255	WX-302	(2) WX-251	(2) WX-255	(2) WX-302
30	WX-255	WX-302	WX-350	(2) WX-255	(2) WX-302	(2) WX-350
35	WX-302	WX-350	WX-350	(2) WX-302	(2) WX-350	(2) WX-350
40	WX-350	WX-350	(2) WX-255	(2) WX-350	(2) WX-350	(3) WX-302


WELL-X-TROL Professional tank operation time-tested design




1
WELL-X-TROL Professional has a sealed in air chamber that is pre-pressurized before it leaves our factory. Air and water do not mix.



2
When the pump starts, water enters the WELL-X-TROL Professional. Only usable water is stored.



3
When the pressure in the chamber reaches cut-out pressure, the pump stops. The WELL-X-TROL Professional is filled.




4
When water is demanded, pressure in the air chamber forces water into the system. Since WELL-X-TROL Professional consistently delivers the maximum usable water, minimum pump starts are assured.



WELL-X-TROL Professional

residential models


In-Line Models



Model No.	Dimensions		Total Volume (gals)	Max. Accept. Factor	System Drawdown			Shipping Wt. (Vol.) lbs (cu ft)
	Diameter (ins)	Height (ins)			20/40 (gals)	30/50 (gals)	40/60 (gals)	
WX-101	8	12 5/8	2.0	0.45	.8	.7	.6	5 (0.6)
WX-102	11	15	4.4	0.55	1.8	1.5	1.3	9 (1.2)
WX-103	11	22 1/4	7.6	0.42	3.1	2.6	2.2	15 (1.8)
WX-104	15 3/8	17 3/4	10.3	1.00	4.1	3.5	3.0	20 (2.6)
WX-200	15 3/8	22	14.0	0.81	5.6	4.8	4.1	22 (3.3)

Precharge Pressure for WX-101 & WX-102 is 20 PSIG and Sys. Conn. is 3/4" NPTM.
 Precharge Pressure for WX-103 is 30 PSIG and Sys. Conn. is 3/4" NPTM.
 Precharge Pressure for WX-104 and WX-200 is 30 PSIG and Sys. Conn. is 1" NPTM.
 Maximum Working Pressure is 125 PSIG and Maximum Working Temperature is 200° F.
 WX-101 and WX-102 models available with Ultra TUF-KOTE™ exterior coating option.

Stand Models




Model No.	Dimensions		Total Volume (gals)	Max. Accept. Factor	System Drawdown			Shipping Wt. (Vol.) lbs (cu ft)
	Diameter (ins)	Height (ins)			20/40 (gals)	30/50 (gals)	40/60 (gals)	
WX-104-S	15 3/8	19 1/4	10.3	1.00	4.1	3.5	3.0	23
WX-201	15 3/8	23 7/8	14.0	0.81	5.6	4.8	4.1	25
WX-202	15 3/8	31 5/8	20.0	0.57	8.0	6.8	5.9	33
WX-202XL	15 3/8	38 1/4	26.0	0.44	10.5	8.8	7.6	36
WX-203	15 3/8	46 1/2	32.0	0.35	—	10.9	9.4	43
WX-205	22	29 5/8	34.0	1.00	13.7	11.6	10.0	61
WX-250	22	36	44.0	0.77	17.7	15.0	12.9	69
WX-251	22	46 3/4	62.0	0.55	24.9	21.1	18.2	92
WX-255	22	56 3/8	81.0	0.41	32.6	27.5	23.8	103
WX-252	22	62 1/4	86.0	0.39	34.6	29.2	25.3	114
WX-302	26	47 1/4	86.0	0.54	34.6	29.2	25.3	123
WX-350	26	61 7/8	119.0	0.39	47.8	40.5	35	166

Precharge Pressure for WX-104-S thru WX-203 is 30 PSIG and Sys. Conn. is 1" NPTF.
 Precharge Pressure for WX-205 thru WX-350 is 38 PSIG and Sys. Conn. is 1 1/4" NPTF.
 Maximum Working Temperature is 200° F. Maximum Working Pressure for all models except WX-252 is 125 PSIG.
 Maximum Working Pressure for WX-252 is 100 PSIG.
 All models available with Ultra TUF-KOTE™ except WX-104-S, WX-201, and WX-252.
 All models except, WX-104S, WX-201, WX-252 are available with Pro-Access.

Tank Specified

Underground Models



Model No.	Dimensions		Total Volume (gals)	Max. Accept. Factor	System Drawdown			Shipping Wt. (Vol.) lbs (cu ft)
	Diameter (ins)	Height (ins)			20/40 (gals)	30/50 (gals)	40/60 (gals)	
WX-200-UG	15 3/8	22	14.0	0.81	5.6	4.8	4.1	22
WX-202-UG	15 3/8	30	20.0	0.57	8.0	6.8	5.9	30 (4.9)
WX-250-UG	22	33 3/8	44.0	0.77	17.7	15.0	13.0	60 (9.8)
WX-251-UG	22	44 1/8	62.0	0.55	24.9	21.1	15.3	83 (13.9)

Precharge Pressure for WX-202-UG is 30 PSIG and Sys. Conn. is 1" NPTF Coupling.
 Precharge Pressure for WX-205-UG and WX-251-UG is 38 PSIG and Sys. Conn. is 1 1/4" NPTF Coupling.
 Maximum Working Pressure is 125 PSIG and Maximum Working Temperature is 200° F.



WELL-X-TROL Professional

specialty residential models

Pump Stand Models

Model No.	Height (ins)	Dimensions			Total Volume (gals)	Max. Accept. Factor	System Drawdown			Shipping Wt. (Vol.) lbs (cu ft)
		Width (ins)	Length (ins)				20/40 (gals)	30/50 (gals)	40/60 (gals)	
WX-105-PS	11	10 9/16	18 1/4	5.3	0.80	2.1	1.8	1.6	13	
WX-200-PS	16	15 3/8	20 7/8	14.0	0.81	5.6	4.8	4.1	29	


Precharge Pressure is 30 PSIG and Sys. Conn. is 3/4" NPTM Fitting for 103-PS and 105-PS; and 1" NPTF Coupling for 200-PS. Maximum Working Pressure is 125 PSIG and Maximum Working Temperature is 200° F.



Offset Connector Models

Model No.	Dimensions		Total Volume (gals)	Max. Accept. Factor	System Drawdown			Shipping Wt. (Vol.) lbs (cu ft)
	Diameter (ins)	Height (ins)			20/40 (gals)	30/50 (gals)	40/60 (gals)	
WX-202-OC	15 3/8	29	20.0	.57	8.0	6.8	5.9	32 (5.0)


1" Barb Connection. 30 PSIG Precharge Pressure. 100 PSI Maximum Working Pressure. 200° (F) Maximum Working Temperature



Space Saver Model

Model No.	Height (ins)	Dimensions			Total Volume (gals)	Max. Accept. Factor	System Drawdown			Shipping Wt. (Vol.) lbs (cu ft)
		Width (ins)	Length (ins)				20/40 (gals)	30/50 (gals)	40/60 (gals)	
WX-202-H	28 5/8	15 3/8	15 1/4	20.0	0.57	8.0	6.8	5.9	33 (4.9)	

Precharge Pressure is 30 PSIG. System connection is 1" NPTF (straight coupling connection). Maximum Working Pressure is 125 PSIG. Maximum Working Temperature is 200° F.



Specialty Options

Ultra TUF-KOTE

A new improved paint finish available only on WELL-X-TROL tanks. This new paint has been re-formulated for outdoor applications where acids, salts and moisture can harm regular paint. It is crack proof and impermeable to moisture.

PRO Access

PRO Access Stainless Steel System Connection piped through the stand is available on most WELL-X-TROL models. Indicate PRO Access when ordering.



RCOA-2

AMTROL has

innovative ways to help you grow your business

 **AMTROL** INC.
Water Treatment Technologies

Water Treatment Technologies

 **ODOR OXIDIZER**
Professional by AMTROL

Hydrogen Sulfide Removal System

 **SORB-TROL**
by AMTROL

Arsenic Removal System

 **ARMOR-TROL**
PRESSURIZED OXIDATION
IRON REMOVAL SYSTEM by AMTROL

Iron Removal System

 **Water Soft** INC.

Water Softening and Filtration

 **AMTROL** INC.
Hydronic Technologies

Hydronic Technologies

 **EXTROL**
by AMTROL

Boiler Expansion Tanks

 **THERM-X-TROL**
by AMTROL

Water Heater Expansion Tanks

 **BOILER MATE**
by AMTROL

Indirect-Fired Water Heaters

Ask for Quality. Ask for AMTROL®.

 **AMTROL** INC.
www.amtrol.com

Corporate Headquarters
1400 Division Road
West Warwick, RI 02893
Telephone: 401-884-6300
Fax: 401-884-5276

AMTROL Canada, Ltd.
275 Shoemaker Street
Kitchener, Ontario N2E 3B3
Telephone: 519-748-1138
Fax: 519-748-4231



ANSI/NSF 61



Appendix C

CHLORINATION SYSTEMS: LIQUID SODIUM HYPOCHLORITE INJECTION



Household Bleach is 5 1/4% Sodium Hypochlorite

Liquid Pool Chlorine is 12 1/2% Sodium Hypochlorite

For best results use 12 1/2% NSF certified chlorine designed for potable water, or use fresh pool chlorine, and size of system and injection rate so that you make up fresh solution once a month.

LMI Metering Pumps: The standard for excellence in electronic diaphragm metering pumps. Unlike cheaper pumps made from pvc or polypropylene, these units use heavy-duty, chemically resistant PVDF pump heads for very long usage between replacement. Pump 12% sodium hypochlorite with no failures. All pumps come standard with the LMI Four Function Valve for safety and ease-of-use.

Part #	LMI Model	GPD	PSI	VOLT	Price Each
P5001030	P121-352SI	5	150	120	\$424
P5001110	P122-352SI	5	150	240	\$424
P5001020	P131-392SI	10	110	120	\$431
P5001140	P132-392SI	10	110	240	\$431
P5001040	P141-352SI	14	250	120	\$441
P5001150	P142-352SI	14	250	240	\$441
P5000810	P151-392SI	24	110	120	\$450
P5000820	P152-392SI	24	110	240	\$450
P5000830	P161-362SI	48	50	120	\$467
P5000840	P162-362SI	48	50	240	\$467

Three Sizes of Solution Tanks to Choose From:

10-Gallon

Pump Installs on Top



T40-0004 \$119.00

35-Gallon

Pump Installs on Tank Shelf for Flooded Suction



T40-0003 \$289.00

50-Gallon

Pump Installs on Top




T40-0006 \$209.00

Hundreds of Metering Pumps and Accessories For Practically Any Flow Rate Available Including:

- Proportionally Fed Systems
- Electronic Flow Meters
- Flow Computers
- Check Valves, Anti-Syphon Valves
- Static Mixers
- Electrical Mixers

Typical Installation of Metering Pumps for Chlorination:



How To Figure out What Size Pump to Use, and How To Set the Speed and the Stroke To Achieve Proper Dosage:

- Step One : Determine Flow Rate of the water stream you are injecting into, in Gallons Per Minute (GPM)
 Step Two : Determine the parts per million of chlorine you are trying to achieve (PPM).
 Step Three : Use the formula below to compute the gallons per day and select the pump.
 Step Four : Adjust the output of the metering pump to achieve proper dosage.

Multiply the FLOW RATE (GPM) times the Applied Dosage in Parts Per Million Desired times 1440. Then Divide by the Solution Strength being used. Household bleach is 5 1/4%, Pool Chlorine is 12%. You can vary the applied dosage of chlorine by adjusting the solution strength and by adjusting the speed knob and/or the stroke knob of the metering pump. If both the speed and stroke knobs are set to 100%, then the metering pump will deliver 100% of its rated output in gallons per day. After you use the formula below to compute the gallons per day adjust the knobs to end up with the desired dosage.

$$\frac{12 \text{ GPM} \times 1.5 \text{ PPM} \times 1440}{1,000,000 \times 5 \frac{1}{4}\%} = 0.49 \text{ Gallons Per Day}$$

Divide the Gallons Per Day figure by the Rated Maximum Output of the Metering Pump: For Instance: Using Model P50-0005 which has a maximum output of 10 Gallons Per day: 0.49 divided by 10 = .049 or 5% SO! You could set the metering for 5% of its rated output by adjusting the Speed Knob to 10 and the Stroke Knob to 50, since 10% x 50% = 5%.



743 41st Ave. Santa Cruz, California 95062
 Tel: 831.462.8359 Fax: 831.476.0832

<http://www.advancedh2o.com> E-mail: info@advancedh2o.com




Dedicated to Safe Drinking Water
 American Water Works Assoc.
 Proud Members for 10 Years



PACIFIC WATER
 QUALITY ASSOCIATION

Appendix D



MISSOURI DEPARTMENT OF
NATURAL RESOURCES
DIVISION OF
GEOLOGY AND LAND SURVEY
(573) 368-2165

**HIGH YIELD AND PUBLIC WELL RECORD
AND PUMP INFORMATION DATA**

REF NO 00252901	DATE RECEIVED 11/01/2001
CR NO	
STATE CERT NO APPROVED DATE A072734 11/30/2001	CHECK NO. 2485
DATE ENTERED PHASE 1 PHASE 2 PHASE 3 11/01/2001 11/13/2001 11/13/2001	ROUTE PCD
	REVENUE NO. 110101

INFORMATION SUPPLIED BY WELL OR PUMP INSTALLATION CONTRACTOR		DNR VARIANCE NUMBER _____
OWNER NAME REFLECTIONS CONDOMINIUMS	TELEPHONE (OPTIONAL)	CASING DEPTH NUMBER _____ Applicable only if casing depth or variance were obtained from DNR
OWNER ADDRESS HCR 76 BOX 733	CITY CAMDENTON	STATE MO
ADDRESS OF WELL (IF DIFFERENT THAN ABOVE)	CITY	STATE MO
		ZIP 65020
		ZIP

PROPOSED USE OF WELL **SEE BACK OF FORM FOR WELL CLASSIFICATIONS**

Water Supply for Irrigation (capable of producing more than 70 gpm to surface)
Unconsolidated Material Well Bedrock Well

Water Supply for a High-Capacity Well capable of producing more than 70 gpm to surface - get casing depth from GSRAD before start

Open Loop Heat Pump

Supply Well Return Well

Water Supply to a Public Facility (convenience store, restaurant, church, business, condo, mobile home park, rural or urban water supply)
CONTACT THE DNR REGIONAL OFFICE to get instructions for water supply to a PUBLIC FACILITY

CASING DETAILS

CASING LENGTH 440.0 FT. O.D. OF CASING 6.62 IN. DIAMETER OF DRILL HOLE 10.0 IN.

CASING MATERIAL STEEL PLASTIC CONCRETE

POSITION OF GROUT SEAL BOTTOM FULL LENGTH TOP

CASING GROUT MATERIAL CEMENT TYPE 1 HI-EARLY BENTONITE SLURRY CHIPS GRANULAR PELLETS

METHOD OF GROUT INSTALLATION GRAVITY OPEN HOLE POS. DISPLACEMENT TREMIE

PRESSURE GROUT THROUGH CASING THROUGH TREMIE

DRILLING SUSPENDED NO YES 72 HRS

NO. OF SACKS USED 230.0 POUNDS PER SACK _____

LINER DETAILS

LENGTH 440.0 FT. O.D. OF LINER 6.62 IN. LINER MATERIAL STEEL PLASTIC

POSITION OF SEAL FULL LENGTH BOTTOM TOP

LINER GROUT MATERIAL CEMENT TYPE 1 HI-EARLY BENTONITE SLURRY CHIPS GRANULAR PELLETS

METHOD OF GROUT INSTALLATION GRAVITY OPEN HOLE POS. DISPLACEMENT TREMIE

LINER USED TO: HOLD BACK FORMATION SEAL OUT UNDESIREABLE AQUIFER CONDITIONS PREVENT RUST

NO. OF SACKS USED _____ POUNDS PER SACK 94

ABANDONED WELL ON SITE? YES PLUGGED? YES

LOCATION OF WELL

LAT. 38° 7' 53.5" LONG. 92° 49' 12.5" COUNTY CAMDEN

DEPTH TO FIRST GROUNDWATER FEET _____ PUMP RATE 125.0 GPM

WELL YIELD 193.0 GPM PUMP SET DEPTH 357.0 FEET

STATIC WATER LEVEL 131.0 FEET PUMP INSTALLATION DATE _____

WELL COMPLETION DATE 10/12/2001 pump info required this record or on pump card

Please be aware that we do not guarantee the accuracy of the data. It is submitted to us by a third party and has not been field verified.

DEPTH		FORMATION DESCRIPTION	(OPTIONAL) ELEVATION	LEGAL LOCATION (OPTIONAL) ____ NE 1/4 ____ SW 1/4 ____ SW 1/4	AREA 1B _____
FROM	TO				
0.0	220.0	WT LS	787 FT.	SEC. 8 TWN. 39 RNG. 17 W	C DATA REQ'D <input type="checkbox"/>
220.0	225.0	OPEN BRKN			
225.0	305.0	LS			
305.0	325.0	WT SS			
325.0	430.0	WT LS			
430.0	432.0	BLK SHELL			
432.0	900.0	GRY LS			

I HEREBY CERTIFY THE WELL/PUMP INFORMATION DESCRIBED HEREIN IS TRUE AND ACCURATE

PRIMARY CONTRACTOR SIGNATURE LLOYD MORELAND	PERMIT NUMBER 002450	DATE
WELL DRILLER SIGNATURE LLOYD MORELAND	PERMIT NUMBER 002450	DATE
PUMP INSTALLER SIGNATURE LLOYD MORELAND	PERMIT NUMBER 002450	DATE
APPRENTICE DRILLER SIGNATURE	PERMIT NUMBER	DATE
APPRENTICE PUMP SIGNATURE	PERMIT NUMBER	DATE

DEPTH TO BEDROCK _____ FEET

TOTAL DEPTH 900.0 FEET