| Technology | Recip. Engine | Steam Turbine | Gas Turbine | Microturbine | Fuel Cell |
|---|---|--|---|--|---|
| Electric efficiency (HHV) | 27-41% | 5-40+% ² | 24-36% | 22-28% | 30-63% |
| Overall CHP efficiency (HHV) | 77-80% | near 80% | 66-71% | 63-70% | 55-80% |
| Effective electrical efficiency | 75-80% | 75-77% | 50-62% | 49-57% | 55-80% |
| Typical capacity (MW _*) | .005-10 | 0.5-several hundred MW | 0.5-300 | 0.03-1.0 | 200-2.8 commercial CHP |
| Typical power to heat ratio | 0.5-1.2 | 0.07-0.1 | 0.6-1.1 | 0.5-0.7 | 1-2 |
| Part-load | ok | ok | poor | ok | good |
| CHP Installed costs (\$/kW _s) | 1,500-2,900 | \$670-1,100 | 1,200-3,300 (5-40 MW) | 2,500-4,300 | 5,000-6,500 |
| Non-fuel O&M costs (\$/kWh _e) | 0.009-0.025 | 0.006 to 0.01 | 0.009-0.013 | 0.009013 | 0.032-0.038 |
| Availability | 96-98% | 72-99% | 93-96% | 98-99% | >95% |
| Hours to overhauls | 30,000-60,000 | >50,000 | 25,000-50,000 | 40,000-80,000 | 32,000-64,000 |
| Start-up time | 10 sec | 1 hr - 1 day | 10 min - 1 hr | 60 sec | 3 hrs - 2 days |
| Fuel pressure (psig) | 1-75 | n/a | 100-500 (compressor) | 50-140 (compressor) | 0.5-45 |
| Fuels | natural gas, biogas, LPG, sour gas, industrial waste gas, manufactured gas | a <u></u> | natural gas, synthetic gas, landfill gas, and fuel oils | natural gas, sour gas, liquid fuels | hydrogen, natural gas, propane, methanol |
| Uses for thermal output | space heating, hot water, cooling, LP steam | process steam, district heating, hot water, chilled water | heat, hot water, LP-HP steam | hot water, chiller, heating | hot water, LP-HP steam |
| Power Density (kW/m²) | 35-50 | >100 | 20-500 | 5-70 | 5-20 |
| NO _x (lb/MMBtu) (not including SCR) | 0.013 rich burn 3-way cat. 0.17 lean burn | 0.013 rich burn 3-way Gas 0.12 Wood 0.25 Coal 0.3-1.2 0.17 lean burn | 0.036-0.05 | 0.015-0.036 | 0.00250040 |
| NO _x (lb/MWh _{TotalOutput}) (not including SCR) | 0.06 rich burn 3-way cat. 0.8 lean burn | Gas 0.4-0.8 Wood 0.9-1.4 Coal 1.2-5.0. | 0.52-1.31 | 0.14-0.49 | 0.011-0.016 |

² Power efficiencies at the low end are for small backpressure turbines with boiler and for large supercritical condensing steam turbines for power generation at the high end.

Schedule J-3 Page 1