

MPSC CASE NO GR-2014-0086

SURREBUTTAL TESTIMONY OF TIMOTHY R JOHNSTON

SCHEDULE TRJ - 4

Summit Natural Gas of Missouri, Inc.
MPSC Case No. GR-2014-0086
Account 105 Transfer from Warsaw and Branson

Line No	Particulars (a)	SNG filed data at 9-31-13		Staff EMS runs 12-31-13	
		References (b)	Warsaw (c)	Warsaw (e)	Branson (f)
Rate Base Adjustment					
Gross Plant					
1	Account 101-376 - SNG as filed	as filed, TDP-2, exh 2	\$ 12,821,542	\$ 13,310,226	\$ 36,985,144
2	Account 101-378 - SNG as filed	as filed, TDP-2, exh 2	49,057	79,254	319,932
3	percent of account to acct 105	capacity percent tab	63.92%	63.92%	81.18%
4	reduction to settlement gross plant - acct 101-376	line 10 * line 13	\$ 8,195,144	\$ 8,507,496	\$ 30,024,142
5	reduction to settlement gross plant - acct 101-378	line 11 * line 13	31,356	50,657	259,717
6	total Gross Plant reduction	line 4 + line 5	\$ 8,226,499	\$ 8,558,153	\$ 30,283,859
Reserve for Depreciation					
7	Account 108-376 - SNG as filed	as filed, TDP-2, exh 3	\$ (912,293)	(1,090,989)	(2,117,624)
8	Account 108-378 - SNG as filed	as filed, TDP-2, exh 3	(3,422)	(6,823)	(8,242)
9	percent of account to acct 105	capacity percent tab	63.92%	63.92%	81.18%
10	reduction to settlement RDA - acct 108-376	line 21 * line 24	\$ (583,110)	\$ (697,327)	\$ (1,719,064)
11	reduction to settlement RDA - acct 108-378	line 22 * line 14	(2,187)	(4,361)	(6,691)
12	total Reserve for Depreciation reduction	line 10 + line 11	\$ (585,297)	\$ (701,688)	\$ (1,725,755)

GR-2014-0086
Surrebuttal Schedule TRJ-4

surrebuttal testimony
Schedule TRJ-4
page 2 of 2

Summit Natural Gas of Missouri, Inc.
MPSC Case No. GR-2014-0086
Main Line Capacity Utilization Percentage Calculation


Line No	Particulars (a)	Reference (b)	Warsaw (c)	Branson (d)
1	Relevant pipe capacity (Mcf/day)	note 1	<u>6,288</u>	<u>15,240</u>
	Relevant Peak day calculations			
	Warsaw			
	2012-2013 winter regression statistics			
2	base load per retail customer - Dt's	2013-14 Gas Supply Plan	0.0983	
3	retail usage per HDD - Dt's	2013-14 Gas Supply Plan	0.0241	
4	peak HDD'S - Sedalia WTP	2013-14 Gas Supply Plan	82	
5	test period total retail customer count	Rebuttal Schedule TDP-3	1,111	
6	peak retail usage in Dt's	(ln 4 * ln 3 + ln 2) * ln 5	2,301	
7	peak retail usage in Mcf at 1.014 BTU factor - 2013 PGA	ln 6 ÷ 1.014	2,269	
8	transportation customer usage	NA	<u>-</u>	
9	Mainline capacity usage factor	ln 7 ÷ ln 1	36.08%	
10	Mainline capacity reduction factor	1 - ln 9	63.92%	
	Branson			
	2013-2014 winter regression statistics			
11	base load per retail customer	2014-15 Gas Supply Plan		0.4018
12	retail usage per HDD	2014-15 Gas Supply Plan		0.0223
13	peak HDD'S	2014-15 Gas Supply Plan		73
14	test period total retail customer count	Rebuttal Schedule TDP-3		843
15	peak retail usage in Dt's	(ln 13 * ln 12 + ln 11) * ln 14		1,709
16	peak retail usage in Mcf at 1.025 BTU factor - 2013 PGA	ln 15 ÷ 1.025		1,667
17	transportation customer usage - Jan 6, 2014 - Mcf	imbalance management analysis		1,201
18	total usage in Mcf	ln 16 + ln 17		2,868
19	Mainline capacity usage factor	ln 18 ÷ ln 1		18.82%
20	Mainline capacity reduction factor	1 - ln 19		81.18%

Notes (1) capacity values taken from System Flow Diagrams attached

AURORA TAP
P=425 PSIG
Q_{in}=635 MCFH OR 15,240 MCFD

SYSTEM SUMMARY

SUMMIT NATURAL GAS OF MISSOURI (SNGMO) RECEIVES GAS FROM SOUTHERN STAR IN THE TOWN OF AURORA AT A PRESSURE OF 425 PSI. BASED ON THIS INLET PRESSURE, THE BRANSON PIPELINE HAS A PEAK CAPACITY OF 635 MCFH ALLOWING FOR SUFFICIENT PRESSURES AT THEIR REGULATOR STATIONS.



PIPE LENGTH AND SIZE TABLE		
NO.	LENGTH	PIPE SIZE
1	38.0 MILES	8.625" X .188
2	5.12 MILES	6.625" X .219

PRODUCT
NATURAL GAS

PIPE
ROUGHNESS: 0.00070 INCHES
EFFICIENCY: 100%
GRADE: B

MODEL
SOFTWARE: GASWORKS 9.0
FORMULA: PANHANDLE-A

[NULL NODE]
P=278 PSIG

BRANSON
CITY GATE STATION
P=149 PSIG
Q=635 MCFH OR 15,240 MCFD

NOTES

1. ALL PIPE LENGTH DIMENSIONS ARE FROM NODE-TO-NODE
2. ALL LOADS ARE PEAK PROJECTED LOADS TO DESIGN PIPELINE CAPACITY
3. PEAK CAPACITY LOAD OF 635 MCFH ALLOWS FOR SUFFICIENT INLET PRESSURES AT ALL REGULATOR STATIONS
4. PIPELINE SIZED TO ACCOMMODATE FUTURE GROWTH



Branson, MO
System Flow Diagram
Peak Capacity Modeling


S:\Engineering&Construction\Engineering\GASWORKS
Models\SNGMO\Branson\Steel_06-26-14

Revision	Date
Modeled by: GDC	06-27-14
Checked by: BEW	06-27-14

SYSTEM SUMMARY

SUMMIT NATURAL GAS OF MISSOURI (SNGMO) RECEIVES GAS FROM SOUTHERN STAR IN THE TOWN OF SADALIA. ALONG WITH THEIR TAP, SNGMO OPERATES A COMPRESSOR STATION TO MEET SYSTEM DEMANDS.

UNDER CURRENT CONDITIONS, SNGMO MAINTAINS A PRESSURE OF 195 PSI AT THEIR LOO TEE WHERE THE WARSAW LATERAL BEGINS. BASED ON THIS INLET PRESSURE, THE WARSAW LATERAL HAS A PEAK CAPACITY OF 262 MCFH ALLOWING FOR SUFFICIENT PRESSURES AT THEIR REGULATOR STATIONS.



PIPE LENGTH AND SIZE TABLE		
NO.	LENGTH	PIPE SIZE
1	4.49 MILES	6.625" X .188
2	3.32 MILES	6.625" X .188

WARSAW CITY GATE
P=151 PSIG
Q=262 MCFH OR 6,288 MCFD

PRODUCT
NATURAL GAS

PIPE
ROUGHNESS: 0.00070 INCHES
EFFICIENCY: 100%
GRADE: B

MODEL
SOFTWARE: GASWORKS 9.0
FORMULA: PANHANDLE-A

NOTES

1. ALL PIPE LENGTH DIMENSIONS ARE FROM NODE-TO-NODE
2. ALL LOADS ARE PEAK PROJECTED LOADS TO DESIGN PIPELINE CAPACITY
3. PEAK CAPACITY LOAD OF 262 MCFH ALLOWS FOR SUFFICIENT INLET PRESSURES AT ALL REGULATOR STATIONS
4. PIPELINE SIZED TO ACCOMMODATE FUTURE GROWTH



Warsaw, MO
System Flow Diagram
Peak Capacity Modeling

S:\Engineering&Construction\Engineering\GASWorkS
Models\SNGMO\Warsaw\Warsaw_Steel_RC

Revision	Date
Modeled by: GDC	06-27-14
Checked by: BEW	06-27-14

Panhandle-A Equation

$$Q = 435.87 \left(\frac{T_{sc}}{P_{sc}} \right)^{1.0788} * \left(\frac{P_1^2 - P_2^2}{G^{.8539} * L_e * T_m * Z} \right)^{.5394} * D^{2.6182} * E$$

$$L_e = \frac{(e^S - 1)L}{S}$$

$$S = \frac{.0375 * G * \Delta z}{T_m}$$

Variables

T_{sc} = Temperature at standard conditions

P_{sc} = Pressure at standard conditions (atmospheric pressure)

T_m = Average temperature of the pipeline (Absolute)

P_1 & P_2 = Pressure at the pipeline entrance and exit (absolute)

L = Length of pipe in miles

G = Gas density with respect to water

Z = Compressibility factor for gas

E = Pipeline efficiency

L_e = Effective length of the pipeline

Δz = Elevation difference from entrance to the exit of the pipe