



MISSOURI
 DEPARTMENT OF
 NATURAL RESOURCES
 DIVISION OF ENVIRONMENTAL QUALITY
CONTACT LOG

File:
 029.pdwp.BentwoodCondos.mo3238190.WellPump.20
 19.05.20.fy19.cav.x.ymf

Subject: Pump out and no pressure		Dept. Staff: Franklin, Yvonne	
May 21, 2019		Region: Southwest	
Type: Telephone		Media: Public Drinking Water	
CONTACT PERSON AND FACILITY			
Polly Bellmer		Bentwood Condos 569 Cedar Road Lake Ozark, MO 65049	
573-280-8985		573-346-3810	
polly@thebeelergroup.com		Facility ID: MO3238190	
COMMUNICATION SUMMARY			
<p>Assisted Polly Bellmer a resident at Bentwood Condos located in Camden County. She had questions whether an emergency waiver or construction permit was needed to replace the well pump after it went out May 20, 2019.</p> <p>I told her as long as the pump is the same size (horsepower) as the one being replaced a permit with engineering would not be required.</p>			

c: