



MISSOURI GAS ENERGY

3420 Broadway, • Kansas City, MO • 64111-2404 • (816) 360-5755

ROBERT J. HACK
SENIOR ATTORNEY

April 23, 1997

FILED

APR 24 1997

MISSOURI
PUBLIC SERVICE COMMISSION

Mr. Cecil I. Wright
Executive Secretary
Missouri Public Service Commission
P.O. Box 360
Jefferson City, MO 65102

60-97-242

Re: Tariff File No. 9700715

Dear Mr. Wright:

Enclosed for filing in the above-referenced tariff file please find three copies of P.S.C. MO. No. 1 First Revised Sheet No. R-42.1 canceling Original Sheet No. R-42.1 to be substituted for the originally filed tariff sheet. This substitute filing is made at the request of the Commission's staff to correct a typographical error.

Thank you in advance for bringing this to the attention of the appropriate Commission personnel and the Commission for approval. If you have any questions, please call me at 816/360-5755.

Sincerely,

CC: Mack McDuffey
Charles B. Hernandez
Office of the Public Counsel

10.

Missouri Gas Energy,
a Division of Southern Union Company

For: All Missouri Service Areas

GENERAL TERMS AND CONDITIONS FOR GAS SERVICE

5.06 METER SEALS: Seals may be placed by Company on any meter or meter enclosure. Such seals shall not be broken or disturbed by any person other than persons authorized by Company.

5.07 EVIDENCE OF CONSUMPTION: The registration of Company's meters will be accepted and received at all times and placed as prima facie evidence of the amount of gas taken by customer.

5.08 DELIVERY PRESSURE: Company shall generally supply gas at a delivery pressure of 4 to 7 inches water column; however, Company may, at its option, deliver gas at such higher pressure as may be authorized by rules of the Commission.

If Company agrees to provide a higher deliver pressure in order to satisfy the requirements of any customer, Company reserves the right to correct volumes delivered at such higher pressures to 6.93 inches water column (4 ounces per square inch gauge) for billing purposes.

5.09 ACCURACY AND TESTS: The accuracy and testing of Company's meters shall be in accordance with the General Orders of the Commission applicable thereto.

Pursuant to the Commission's Order in Case No. GO-91-353, the Company has been granted a variance from the requirements of 4 CSR 240-10.030 (19) relating to the removal, testing and inspection of gas meters. The variance authorizes the Company to employ statistical sampling for determining when certain meters should be removed from service for testing.

Pursuant to the Commission Order in Case No. GO-97-242, the Company has been granted a temporary variance, to extend two years from April 29, 1997, from the requirements of 4 CSR 240-10.030 (19) and the Commission's Order in Case No. GO-91-353. The temporary variance authorizes the Company to substitute the retirement and replacement of certain older meters for the removal and testing of a like number of meters that would be tested per the statistical sampling method.

DATE OF ISSUE April 21 1997
month day year

DATE EFFECTIVE May 21 1997
month day year

ISSUED BY Charles B. Hernandez Director, Pricing and Regulatory Affairs
Missouri Gas Energy, Kansas City, MO. 64111