

Missouri American Water

P.O. Box 578, Alton IL 62002
1-866-430-0820

FILED³

MAY 19 2006

**Missouri Public
Service Commission**

03/06/2006

Gene's Properties LLC
725 Judson Manor Dr
Saint Louis MO 63141-6018

Account Number: 35-0617887-4
Premise Number: 350048637
10952 Whitehall Manor Dr

Dear Customer:

On Thursday, February 16, 2006, water meter number 270165 was removed from the above referenced premise and brought into our shop for evaluation of its accuracy.

The meter reading was 3628.00 when removed and tested. The results of the tests are shown below and are within the limits approved by the Missouri Public Service Commission.

When tested at a rate of 10 gallons of water per minute, the meter registered 101.00%.

When tested at a rate of 2 gallons of water per minute, the meter registered 101.80%.

When tested at a rate of .25 gallons of water per minute, the meter registered 98.00%.

We will hold this meter in our shop for two months. If you dispute this information or wish to see the meter retested in your presence, please contact our Customer Service Center at 1-866-430-0820. We are available 24 hours per day, 7 days a week for your convenience.

Sincerely,

Customer Service

MTRTSTMO

16781016

 Exhibit No.
Case No(s). WC-2006-0248
Date 4-25-06 **Rptr** KF