



**2010-2029 Integrated Resource Plan
for
The Empire District Electric Company**

**Volume III
Supply-Side Resources Analysis (4 CSR 240-22.040)**

September 2010

Table of Contents

S.0 Volume III Summary S-1

 S.1 Existing Resources..... S-1

 S.2 Assumptions S-2

 S.3 Conventional Future Supply-Side Resources S-3

 S.4 Renewable Future Supply-Side Resources S-4

 S.5 Transmission and Smart Grid S-4

 S.6 Screening Analysis S-5

1.0 Introduction..... 1

 1.1 Background..... 1

 1.2 Regulatory Requirements..... 1

 1.2.1 4 CSR 240-22.040 Supply-Side Resources Analysis 1

 1.2.2 Followup to the 2007 IRP Unanimous Stipulation and Agreement (dated May 6, 2008) 7

2.0 Existing and Committed Supply-Side Resources 9

 2.1 Existing Resources..... 9

 2.1.1 Asbury..... 11

 2.1.2 Riverton..... 11

 2.1.3 Iatan..... 12

 2.1.4 State Line 13

 2.1.5 Empire Energy Center..... 13

 2.1.6 Ozark Beach..... 14

 2.1.7 Plum Point..... 14

 2.1.8 Purchased Power..... 14

 2.1.8.1 Conventional 14

 2.1.8.2 Renewables 15

 2.1.9 Retirements 15

 2.1.10 Emission Controls on Existing Units 15

 2.1.11 Existing Plant Upgrades..... 15

 2.2 Committed Resources 16

3.0 Assumptions..... 19

 3.1 Fuel Usage 19

 3.2 Coal Price Forecast 20

 3.3 Natural Gas Price Forecast..... 23

 3.3.1 Natural Gas Price Forecasting Methodology 24

 3.3.2 Natural Gas Risk Management Policy 25

 3.4 FuelOil Price Forecast..... 25

 3.5 Market Price Forecast 25

 3.6 Capacity Margin..... 27

 3.7 Financial Parameters..... 27

 3.8 Emission Costs..... 27

Table of Contents (continued)

4.0 New Conventional Resources32

 4.1 Supercritical Coal.....32

 4.2 Combustion Turbine33

 4.3 Combined Cycle.....34

 4.4 Nuclear.....35

 4.5 Distributed Generation.....36

 4.6 Integrated Gasification Combined Cycle.....36

5.0 New Renewable Resources.....38

 5.1 Renewable Portfolio Standards.....38

 5.1.1 RPS – Missouri38

 5.1.2 RPS – Kansas.....39

 5.1.3 RPS – Oklahoma.....40

 5.2 Renewable Resources41

 5.2.1 Wind.....41

 5.2.1.1 Wind – Missouri42

 5.2.1.2 Wind – Kansas44

 5.2.1.3 Wind – Oklahoma46

 5.2.1.4 Wind – Arkansas.....49

 5.2.2 Biomass.....50

 5.2.2.1 Biomass – Chicken/Turkey Waste.....51

 5.2.2.2 Biomass – Landfill Gas.....51

 5.2.2.3 Biomass – Additional Biomass54

 5.2.3 Solar55

6.0 Transmission59

 6.1 Losses.....60

 6.2 Smart Grid.....61

7.0 Screening Analysis.....62

 7.1 Base Environmental Costs62

 7.2 Probable Environmental Costs.....64

Appendix A – SPP Transmission Expansion Plan Projects.....68

Appendix B – Empire District STEP Projects77

Appendix C – Empire Transmission and Distribution Construction Budget79

Abbreviations92

List of Tables

Table S-1. Natural Gas Price Forecast (\$/MMBtu) S-2

Table S-2. Emission Costs – Base Environmental..... S-3

Table 1-1. Clarification – Transmission and Distribution Planning.....4

Table 1-2. Summary of Compliance with Reporting Requirements for IRP Rule for Supply-Side Resource Analysis (4 CSR 240-22.040(9)).....7

Table 1-3. Summary of Compliance with the Requirements of the 2007 IRP Unanimous Stipulation and Agreement.....8

Table 2-1. Empire Supply-Side Resources – Existing and Committed.....10

Table 2-2. Load and Capacity Summary 2010-2029 with Existing Resources, Committed Resources and Potential Retirements and Contract Expirations with Based Load Forecast for this IRP and no Contemplated Additions (MW).....18

Table 3-1. Empire’s Historical Delivered Fuel Costs (\$/MMBtu)19

Table 3-2. Asbury Coal Price Forecast (\$/MMBtu)21

Table 3-3. Riverton Coal Price Forecast (\$/MMBtu)21

Table 3-4. Iatan Coal Price Forecast (\$/MMBtu)22

Table 3-5. Plum Point Coal Price Forecast (\$/MMBtu)22

Table 3-6. Natural Gas Price Forecast (\$/MMBtu)23

Table 3-7. Levelized Fixed Charge Rates.....27

Table 3-8. Emission Costs28

Table 3-9. Carbon Dioxide Tax Assumptions28

Table 3-10. Projected Coal Prices for Future Coal-Fired Resources – Carbon Scenarios (\$/MMBtu)29

Table 3-11. Projected Oil Prices – Carbon Scenarios (\$/MMBtu)29

Table 3-12. Projected SO₂ Allowance Prices (\$/ton).....30

Table 3-13. Projected Annual NO_x Allowance Prices (\$/ton)30

Table 3-14. Projected Mercury Allowance Prices (\$000/ton)31

Table 4-1. Supercritical Coal Performance Parameters.....33

Table 4-2. Combustion Turbine Performance Parameters.....34

Table 4-3. Combined Cycle Performance Parameters.....35

Table 4-4. Nuclear PPA Performance Parameters.....36

Table 4-5. Distributed Generation Performance Parameters36

Table 4-6. IGCC Performance Parameters37

Table 5-1. Missouri Renewable Portfolio Standard.....39

Table 5-2. Empire Renewable Resources39

Table 5-3. Kansas Renewable Portfolio Standard39

Table 5-4. Installed Wind Energy in the U.S. (July 2010)42

Table 5-5. Wind Energy Projects in Missouri44

List of Tables (continued)

Table 5-6. Wind Energy Projects in Kansas46
Table 5-7. Wind Energy Projects in Oklahoma48
Table 5-8. Wind Performance Parameters50
Table 5-9. Biomass Performance Parameters54
Table 5-10. Solar Performance Parameters58

Table 6-1. Historical System MWh Losses60

List of Figures

Figure S-1. Henry Hub Gas Prices.....S-3
 Figure S-2. Baseload Screening Curves – Base EnvironmentalS-6

Figure 2-1. 2009 Energy Provision by Fuel Type9
 Figure 2-2. Load and Capability Summary.....17

Figure 3-1. Henry Hub Gas Prices.....24
 Figure 3-2. 7x24 Market Prices - SPP26
 Figure 3-3. 5x16 Market Prices - SPP26

Figure 5-1. Wind Turbine Configurations41
 Figure 5-2(a). Wind Resources in Missouri.....43
 Figure 5-2(b). Wind Resources in Missouri43
 Figure 5-3(a). Kansas Wind Resource Map.....45
 Figure 5-3(b). Kansas Wind Resource Map45
 Figure 5-4(a). Oklahoma Wind Resource Map.....47
 Figure 5-4(b). Oklahoma Wind Resource Map47
 Figure 5-5(a). Arkansas Wind Resource Map49
 Figure 5-5(b). Arkansas Wind Resource Map50
 Figure 5-6. Biomass Resources in Missouri52
 Figure 5-7. Modern Landfill53
 Figure 5-8. Landfill Gas Energy Potential Based on 2005-2014 Minimum Gas
 Flows.....53
 Figure 5-9. Biomass Wood Waste Facility54
 Figure 5-10. Photovoltaic Cell.....55
 Figure 5-11. Solar Photovoltaic Resource of the United States.....56
 Figure 5-12. Concentrating Solar Power Facility57
 Figure 5-13. Concentrating Solar Power Resource of the United States.....57

Figure 7-1. Baseload Screening Curves – Base Environmental62
 Figure 7-2. Intermediate Screening Curves – Base Environmental.....63
 Figure 7-3. Intermittent Screening Curves – Base Environmental63
 Figure 7-4. Peaking Screening Curves – Base Environmental64
 Figure 7-5. Critical Uncertain Factors65
 Figure 7-6. Baseload Screening Curves – Probable Environmental.....65
 Figure 7-7. Intermediate Screening Curves – Probable Environmental66
 Figure 7-8. Intermittent Screening Curves – Probable Environmental.....66
 Figure 7-9. Peaking Screening Curves – Probable Environmental.....67

S.0 Volume III Summary

This supply-side volume of Empire’s 2010 Integrated Resource Plan (IRP) contains:

- information on Empire’s existing resources including opportunities to upgrade or retire specific resources
- assumptions used for the optimization modeling and risk analysis
- the supply-side resources – both conventional and renewable – that were available for the model to consider in the optimization
- information on transmission system additions and associated smart grid plans
- the screening analysis with the resulting rankings used prior to resource modeling in the optimization models.

S.1 Existing Resources

Empire’s existing resources to meet customer obligations include coal-fired units, natural gas-fired combustion turbines (CT), a hydroelectric facility, ownership shares in coal-fired units, an ownership share in a combined cycle (CC) unit, and long-term PPAs for coal and wind. Modifications and upgrades to Empire’s existing units have occurred periodically in the past. Other modifications and upgrades are expected to occur in the future:

- Selective catalytic reduction equipment was installed in Asbury in 2008. In the future, it may be necessary to install additional air pollution control equipment at Asbury including a baghouse, scrubber, and powder activated carbon system (collectively referred to as the Asbury Air Quality Control System (AQCS)).
**
_____**
- **
_____**
_____**
- When Riverton 12 was installed, adequate natural gas piping and transmission were designed and built to accommodate its conversion to a combined cycle unit at some point in the future. The potential Riverton 12 conversion to a combined cycle unit was considered as a candidate resource in this IRP.
- No major upgrades or environmental equipment are expected for either State Line or the Empire Energy Center units during the planning horizon.
- New water wheels were installed at Ozark Beach during the 2002-2004 time frame. If the U.S. Army Corps of Engineers implements the White River Reallocation Project, the amount of energy that Ozark Beach will provide in the future will be reduced.
- Empire’s normal, ongoing maintenance program at each of its plants addresses critical operational and mechanical issues to ensure the longevity of the units.

S.2 Assumptions

A wide variety of data assumptions must be made for IRP modeling. These assumptions include fuel price forecasts, market price forecasts, capacity margin requirements, financial parameters, and emission costs. Parameters for generating resources, e.g., heat rates, operating and maintenance (O&M) costs, maintenance schedules, and forced outage rates, must also be specified. The load and energy forecast, an important series of assumptions, is described in Volume II.


Two of the most significant assumptions underlying this IRP are the natural gas price assumptions and the costs for various forms of air emissions. These assumptions are shown in Table S-1, Figure S-1, and Table S-2. Four levels of carbon regulation, including a no carbon regulation case, were evaluated. Empire has assumed that if carbon regulation were implemented, it would be in the form of a cap and trade system.

Table S-1
Natural Gas Price Forecast (\$/MMBtu)

| Year | Base CO ₂ Case | No CO ₂ Case | Low CO ₂ Case | High CO ₂ Case |
|------|---------------------------|-------------------------|--------------------------|---------------------------|
| 2010 | 6.16 | 6.16 | 6.16 | 6.16 |
| 2011 | 6.30 | 6.30 | 6.30 | 6.30 |
| 2012 | 6.12 | 6.13 | 6.12 | 6.12 |
| 2013 | 6.35 | 6.37 | 6.35 | 6.35 |
| 2014 | 7.07 | 7.11 | 7.07 | 7.07 |
| 2015 | 7.63 | 7.58 | 7.59 | 7.92 |
| 2016 | 8.03 | 7.95 | 7.98 | 8.47 |
| 2017 | 8.34 | 8.27 | 8.31 | 8.90 |
| 2018 | 8.94 | 8.84 | 8.90 | 9.58 |
| 2019 | 9.39 | 9.23 | 9.33 | 10.06 |
| 2020 | 10.49 | 10.29 | 10.45 | 11.19 |
| 2021 | 11.00 | 10.68 | 10.89 | 11.60 |
| 2022 | 11.17 | 10.78 | 11.00 | 11.70 |
| 2023 | 11.72 | 11.20 | 11.49 | 12.16 |
| 2024 | 12.17 | 11.55 | 11.90 | 12.51 |
| 2025 | 12.56 | 11.80 | 12.21 | 12.77 |
| 2026 | 13.13 | 12.28 | 12.77 | 13.22 |
| 2027 | 13.59 | 12.69 | 13.25 | 13.57 |
| 2028 | 14.23 | 13.29 | 13.89 | 14.06 |
| 2029 | 14.99 | 14.02 | 14.63 | 14.73 |

Source: Ventyx

Figure S-1



Source: Ventyx

Table S-2
Emissions Costs – Base Environmental

| Year | SO ₂ (\$/ton) | NO _x (\$/ton) | Hg (\$000/ton) | CO ₂ (\$/ton) |
|------|--------------------------|--------------------------|----------------|--------------------------|
| 2015 | 153 | 1,006 | 40,000 | 21.48 |
| 2016 | 162 | 1,035 | 40,000 | 24.12 |
| 2017 | 170 | 1,063 | 40,000 | 27.04 |
| 2018 | 177 | 1,090 | 40,000 | 30.09 |
| 2019 | 182 | 1,106 | 40,000 | 32.21 |
| 2020 | 186 | 1,120 | 40,000 | 34.66 |
| 2021 | 188 | 1,131 | 40,000 | 37.22 |
| 2022 | 188 | 1,131 | 40,000 | 40.19 |
| 2023 | 188 | 1,131 | 40,000 | 43.23 |
| 2024 | 188 | 1,131 | 40,000 | 46.87 |
| 2025 | 188 | 1,131 | 40,000 | 50.18 |
| 2026 | 188 | 1,131 | 40,000 | 53.90 |
| 2027 | 188 | 1,131 | 40,000 | 58.00 |
| 2028 | 188 | 1,131 | 40,000 | 62.35 |
| 2029 | 188 | 1,131 | 40,000 | 67.18 |

Source: Hg developed by Empire. Other costs developed by Ventyx

S.3 Conventional Future Supply-Side Resources

Empire considered a broad range of conventional resources as options for the future. These included: supercritical coal (ownership and power purchase agreement (PPA)), combustion turbine (CT), combined cycle (CC), nuclear (PPA only), distributed

generation, and integrated gasification combined cycle (IGCC). To take advantage of economies of scale, Empire assumed that the nuclear option involved a PPA from a unit built by one or more other utilities in the region. The supercritical coal option was modeled as an ownership share of a unit built in the region. Combined cycle options included both new units as well as the conversion of Riverton 12 to a CC unit.

Resources using carbon capture and sequestration (CCS) were not assumed to be commercially viable within the planning horizon for the IRP. Parameters were developed for each of supercritical coal with CCS, combined cycle with CCS and IGCC with CCS and are presented in the tables containing data on each of the options. However, these resources were not options considered in the optimization modeling as they were not available during the twenty-year planning horizon of this IRP.

S.4 Renewable Future Supply-Side Resources

A range of potential renewable resources were considered as possible future supply-side resources. These included wind, landfill gas, biomass and solar thermal. Solar photovoltaics (PV) was considered as a demand-side option but did not pass the cost effectiveness screening and was therefore not considered further in the modeling.

S.5 Transmission and Smart Grid

Empire believes that at least some of the resources that will be required over the planning horizon may have significant transmission costs associated with them. Empire is a member of the Southwest Power Pool (SPP) and, as such, is now reliant on the SPP's determination of which transmission lines will be built and on what schedule. As a member of SPP, Empire is assigned a cost sharing allocation of all lines that are built in the SPP. That cost allocation varies per line.

The SPP conducts three studies directly associated with transmission planning: Large Generation Interconnect Studies, Aggregate Transmission Service Studies, and the SPP Transmission Expansion Plan (STEP). The Large Generation Interconnect Study determines all of the modifications needed to connect a new generator into the transmission system. The Aggregate Transmission Service Studies determine system upgrades required to grant transmission service from a generation source to a load. The STEP determines upgrades required for a reliable transmission system and provides a screening of potential economic projects. Until a specific line is submitted to the SPP, it is not possible to estimate what the actual cost to Empire will be. Therefore, Empire modeled a generic transmission cost adder for each alternative resource examined in this IRP.

As of January 2005, the SPP uses a Federal Energy Regulatory Commission (FERC)-approved process called an Aggregate Transmission Service Study. In this process, SPP combines all long-term point-to-point and all long-term network resource transmission service requests received during a sequential four-month open season into a single aggregate transmission service study. Such an aggregated analysis should result in a

more optimal expansion of the SPP transmission system than occurred previously with less aggregated analyses.

Empire actively participates in transmission planning in the SPP through committee membership, attending meetings, participation as a customer and a transmission owner in the development and implementation of SPP's transmission studies, and other methods. In two recent cases involving the Open Access Transmission Tariff in the SPP, Empire filed protests with the FERC. These cases involved the OATT "Highway/Byway" cost allocation methodology and the modified transmission planning process referred to as the Integrated Transmission Plan (ITP).


In March 2010, Empire assembled a team to develop a pilot program that would research and test the available metering products and technologies for an advanced metering infrastructure system such as would be required for Smart Grid. The main benefits of such a system are automated meter reading, on-demand meter reads, and instant outage notification. The proposed pilot program will include residential, commercial, and industrial customers, and will cover single-phase and three-phase applications. The plan is for the pilot program to implement two different communication technologies via two separate phases. The details of the pilot program are pending completion as this IRP was being finalized.

S.6 Screening Analysis

In accordance with the IRP supply-side rules, screening cost curves were developed under base environmental costs and probable environmental costs for baseload, intermediate, intermittent, and peaking resources (a total of eight screening cost curves). Rankings can be deduced by examination of those curves for any given capacity factor. As an example, the screening cost curve for baseload resources under the base environmental assumptions is presented in Figure S-2. Note that resources are compared for the capacity factors from 50% to 100% and that supercritical coal is the top resource across the entire range.

**Figure S-2
 Baseload Screening Curves – Base Environmental**

Comparison of Base Load Resources
 Based on 2015 In-Service Date (Base Environmental)



Source: Venytx

1.0 Introduction

1.1 Background

The Empire District Electric Company (Empire) is an operating public utility engaged in the generation, purchase, transmission, distribution and sale of electricity in parts of Missouri, Kansas, Oklahoma and Arkansas. Empire's service territory includes an area of about 10,000 square miles with a population of over 450,000. The service territory is located principally in southwestern Missouri and also includes smaller areas in southeastern Kansas, northeastern Oklahoma and northwestern Arkansas. The principal activities of these areas include light industry, agriculture and tourism.

Empire's total 2009 retail electric revenues were derived approximately 89.1% from Missouri customers, 5.1% from Kansas customers, 3.0% from Oklahoma customers and 2.8% from Arkansas customers. Empire supplies electric service at retail to 120 incorporated communities and to various unincorporated areas and at wholesale to four municipally owned distribution systems. The largest urban area served is the city of Joplin, Missouri, and its immediate vicinity, with a regional population of approximately 157,000. Empire's system hit a new maximum hourly demand of 1,199 MW on January 8, 2010 during extreme cold weather. The previous maximum demand of 1,173 MW was set on August 15, 2007. Empire's 2009 native customer load was 5,263,206 MWh (net system input or NSI). Empire's electric operating revenues in 2009 were derived as follows: residential 41.6%, commercial 31.4%, industrial 15.2%, wholesale on-system 4.2%, wholesale off-system 3.3% and other 4.3%.

1.2 Regulatory Requirements

1.2.1 4 CSR 240-22.040 Supply-Side Resources Analysis

PURPOSE: This rule establishes minimum standards for the scope and level of detail required in supply-side resource analysis.

- (1) The analysis of supply-side resources shall begin with the identification of a variety of potential supply-side resource options which the utility can reasonably expect to develop and implement solely through its own resources or for which it will be a major participant. These options include new plants using existing generation technologies; new plants using new generation technologies; life extension and refurbishment at existing generating plants; enhancement of the emission controls at existing or new generating plants; purchased power from utility sources, cogenerators or independent power producers; efficiency improvements which reduce the utility's own use of energy; and upgrading of the transmission and distribution systems to reduce power and energy losses. The utility shall collect generic cost and performance information for each of these potential resource options which shall include at least the following attributes where applicable:
 - (A) Fuel type and feasible variations in fuel type or quality;
 - (B) Practical size range;

- (C) Maturity of the technology;
 - (D) Lead time for permitting, design, construction, testing and startup;
 - (E) Capital cost per kilowatt;
 - (F) Annual fixed operation and maintenance costs;
 - (G) Annual variable operation and maintenance costs;
 - (H) Scheduled routine maintenance outage requirements;
 - (I) Equivalent forced-outage rates or full and partial-forced-outage rates;
 - (J) Operational characteristics and constraints of significance in the screening process;
 - (K) Environmental impacts, including at least the following:
 1. Air emissions including at least the primary acid gases, greenhouse gases, ozone precursors, particulates and air toxics;
 2. Waste generation including at least the primary forms of solid, liquid, radioactive and hazardous wastes;
 3. Water impacts including direct usage and at least the primary pollutant discharges, thermal discharges and groundwater effects; and
 4. Siting impacts and constraints of sufficient importance to affect the screening process; and
 - (L) Other characteristics that may make the technology particularly appropriate as a contingency option under extreme outcomes for the critical uncertain factors identified pursuant to 4 CSR 240-22.070(2).
- (2) Each of the supply-side resource options referred to in section (1) shall be subjected to a preliminary screening analysis. The purpose of this step is to provide an initial ranking of these options based on their relative annualized utility costs as well as their probable environmental costs and to eliminate from further consideration those options that have significant disadvantages in terms of utility costs, environmental costs, operational efficiency, risk reduction or planning flexibility, as compared to other available supply-side resource options. All costs shall be expressed in nominal dollars.
- (A) Cost rankings shall be based on estimates of the installed capital costs plus fixed and variable operation and maintenance costs levelized over the useful life of the resource using the utility discount rate. In lieu of levelized cost, the utility may use an economic carrying charge annualization in which the annual dollar amount increases each year at an assumed inflation rate and for which a stream of these amounts over the life of the resource yields the same present value.
 - (B) The probable environmental costs of each supply-side resource option shall be quantified by estimating the cost to the utility to comply with additional environmental laws or regulations that may be imposed at some point within the planning horizon.
 1. The utility shall identify a list of environmental pollutants for which, in the judgment of utility decision-makers, additional laws or regulations may be imposed at some point within the planning horizon which would result in compliance costs that could have a significant impact on utility rates.
 2. For each pollutant identified pursuant to paragraph (2)(B)1., the utility shall specify at least two (2) levels of mitigation that are more stringent than

existing requirements which are judged to have a nonzero probability of being imposed at some point within the planning horizon.

3. For each mitigation level identified pursuant to paragraph (2)(B)2., the utility shall specify a subjective probability that represents utility decision-maker's judgment of the likelihood that additional laws or regulations requiring that level of mitigation will be imposed at some point within the planning horizon. The utility, based on these probabilities, shall calculate an expected mitigation level for each identified pollutant.
 4. The probable environmental cost for a supply-side resource shall be estimated as the joint cost of simultaneously achieving the expected level of mitigation for all identified pollutants emitted by the resource. The estimated mitigation costs for an environmental pollutant may include or may be entirely comprised of a tax or surcharge imposed on emissions of that pollutant.
- (C) The utility shall rank all supply-side resource options identified pursuant to section (1) in terms of both of the following cost estimates: utility costs and utility costs plus probable environmental costs. The utility shall indicate which supply-side options are considered to be candidate resource options for purposes of developing the alternative resource plans required by 4 CSR 240- 22.060(3). The utility shall also indicate which options are eliminated from further consideration on the basis of the screening analysis and shall explain the reasons for their elimination.
- (3) The analysis of supply-side resource options shall include a thorough analysis of existing and planned interconnected generation resources. The analysis can be performed by the individual utility or in the context of a joint planning study with other area utilities. The purpose of this analysis shall be to ensure that the transmission network is capable of reliably supporting the supply resource options under consideration, that the costs of transmission system investments associated with supply-side resources are properly considered and to provide an adequate foundation of basic information for decisions about the following types of supply-side resource alternatives:
 - (A) Joint participation in generation construction projects;
 - (B) Construction of wholly-owned generation or transmission facilities; and
 - (C) Participation in major refurbishment, upgrading or retrofitting of existing generation or transmission resources.
 - (4) The utility shall identify and analyze opportunities for life extension and refurbishment of existing generation plants, taking into account their current condition to the extent that it is significant in the planning process.
 - (5) The utility shall identify and evaluate potential opportunities for new long-term power purchases and sales, both firm and nonfirm, that are likely to be available over all or part of the planning horizon. This evaluation shall be based on an analysis of at least the following attributes of each potential transaction:
 - (A) Type or nature of the purchase or sale (for example, firm capacity, summer only);
 - (B) Amount of power to be exchanged;
 - (C) Estimated contract price;
 - (D) Timing and duration of the transaction;
 - (E) Terms and conditions of the transaction, if available;

- (F) Required improvements to the utility’s generating system, transmission system, or both, and the associated costs; and
 - (G) Constraints on the utility system caused by wheeling arrangements, whether on the utility’s own system, or on an interconnected system, or by the terms and conditions of other contracts or interconnection agreements.
- (6) For the utility’s preferred resource plan selected pursuant to 4 CSR 240-22.070(7), the utility shall determine if additional future transmission facilities will be required to remedy any new generation-related transmission system inadequacies over the planning horizon. If any such facilities are determined to be required and, in the judgment of utility decision-makers, there is a risk of significant delays or cost increases due to problems in the siting or permitting of any required transmission facilities, this risk shall be analyzed pursuant to the requirements of 4 CSR 240-22.070(2). [CLARIFICATION PROVIDED]
- (7) The utility shall assess the age, condition and efficiency level of existing transmission and distribution facilities, and shall analyze the feasibility and cost-effectiveness of transmission and distribution system loss-reduction measures as a supply-side resource. This provision shall not be construed to require a detailed line-by-line analysis of the transmission and distribution system, but is intended to require the utility to identify and analyze opportunities for efficiency improvements in a manner that is consistent with the analysis of other supply-side resource options. [CLARIFICATION PROVIDED]

**Table 1-1
Clarification– Transmission and Distribution Planning**

| |
|---|
| <p>Applies to: 4 CSR 240-22.040 (6) 4 CSR 240-22.040 (7)</p> |
| <p>The existing IRP Rule predates the current Southwest Power Pool, Inc regional transmission organization’s (SPP RTO) transmission planning process and does not contemplate such an organization. SPP conducts three studies directly associated with transmission planning: Large Generation Interconnection Studies, Aggregate Transmission Service Studies, and the SPP Transmission Expansion Plan. Empire actively participates, as a customer and transmission owner, in the development and implementation of all of the transmission studies conducted by SPP. In addition, Empire is continually monitoring the distribution system and looking for cost effective ways to maintain and improve the distribution system.</p> <p>Empire will provide a section outlining the SPP transmission planning processes and the extent of Empire’s participation in these processes in its upcoming IRP filing. The distribution system maintenance and improvements that are under consideration will also be described in the IRP report. The results of the studies and the impacts on Empire will also be summarized. Like Empire’s last IRP filing, the SPP Expansion Plan projects and Empire’s most current Transmission and Distribution Construction Budget will be provided as appendices to the Supply-Side Resource Analysis report.</p> |

- (8) Before developing alternative resource plans and performing the integrated resource analysis, the utility shall develop ranges of values and probabilities for several important uncertain factors related to supply resources. These values can also be used to refine or verify information developed pursuant to section (2) of this rule. These

cost estimates shall include at least the following elements and shall be based on the indicated methods or sources of information:

- (A) Fuel price forecasts over the planning horizon for the appropriate type and grade of primary fuel and for any alternative fuel that may be practical as a contingency option.
 - 1. Fuel price forecasts shall be obtained from a consulting firm with specific expertise in detailed fuel supply and price analysis or developed by the utility if it has expert knowledge and experience with the fuel under consideration. Each forecast shall consider at least the following factors as applicable to each fuel under consideration:
 - A. Present reserves, discovery rates and usage rates of the fuel and forecasts of future trends of these factors;
 - B. Profitability and financial condition of producers;
 - C. Potential effect of environmental factors, competition and government regulations on producers, including the potential for changes in severance taxes;
 - D. Capacity, profitability and expansion potential of present and potential fuel transportation options;
 - E. Potential effects of government regulations, competition and environmental legislation on fuel transporters;
 - F. In the case of uranium fuel, potential effects of competition and government regulations on future costs of enrichment services and cleanup of production facilities; and
 - G. Potential for governmental restrictions on the use of the fuel for electricity production.
 - 2. The utility shall consider the accuracy of previous forecasts as an important criterion in selecting providers of fuel price forecasts.
 - 3. The provider of each fuel price forecast shall be required to identify the critical uncertain factors that drive the price forecast and to provide a range of forecasts and an associated subjective probability distribution that reflects this uncertainty;
- (B) Estimated capital costs including engineering design, construction, testing, startup and certification of new facilities or major upgrades, refurbishment or rehabilitation of existing facilities.
 - 1. Capital cost estimates shall either be obtained from a qualified engineering firm actively engaged in the type of work required or developed by the utility if it has available other sources of expert engineering information applicable to the type of facility under consideration.
 - 2. The provider of the estimate shall be required to identify the critical uncertain factors that may cause the capital cost estimates to change significantly and to provide a range of estimates and an associated subjective probability distribution that reflects this uncertainty;
- (C) Estimated annual fixed and variable operation and maintenance costs over the planning horizon for new facilities or for existing facilities that are being upgraded, refurbished or rehabilitated.

1. Fixed and variable operation and maintenance cost estimates shall be obtained from the same source that provides the capital cost estimates.
 2. The critical uncertain factors that affect these cost estimates shall be identified and a range of estimates shall be provided, together with an associated subjective probability distribution that reflects this uncertainty;
- (D) Forecasts of the annual cost or value of sulfur dioxide emission allowances to be used or produced by each generating facility over the planning horizon.
1. Forecasts of the future value of emission allowances shall be obtained from a qualified consulting firm or other source with expert knowledge of the factors affecting allowance prices.
 2. The provider of the forecast shall be required to identify the critical uncertain factors that may cause the value of allowances to change significantly and to provide a range of forecasts and an associated subjective probability distribution that reflects this uncertainty; and
- (E) Annual fixed charges for any facility to be included in rate base or annual payment schedule for leased or rented facilities.
- (9) Reporting Requirements. To demonstrate compliance with the provisions of this rule, and pursuant to the requirements of 4 CSR 240-22.080, the utility shall furnish at least the following information:
- (A) A summary table showing each supply resource identified pursuant to section (1) and the results of the screening analysis, including:
1. The calculated values of the utility cost and the probable environmental cost for each resource option and the rankings based on these costs;
 2. Identification of candidate resource options that may be included in alternative resource plans; and
 3. An explanation of the reasons why each supply-side resource option rejected as a result of the screening analysis was not included as a candidate resource option;
- (B) A list of the candidate resource options for which the forecasts, estimates and probability distributions described in section (8) have been developed or are scheduled to be developed by the utility's next scheduled compliance filing pursuant to 4 CSR 240-22.080;
- (C) A summary of the results of the uncertainty analysis described in section (8) that has been completed for candidate resource options; and
- (D) A summary of the mitigation cost estimates developed by the utility for the candidate resource options identified pursuant to subsection (2)(C). This summary shall include a description of how the alternative mitigation levels and associated subjective probabilities were determined and shall identify the source of the cost estimates for the expected mitigation level.

Table 1-2 documents how the reporting requirements for 4 CSR 240-22.040, the IRP Rules for Supply-Side Resource Analysis, have been addressed.

Table 1-2
Summary of Compliance with Reporting Requirements for IRP Rule for Supply-Side Resource Analysis (4 CSR 240-22.040 (9))

| Rule | Description | Location in Report |
|----------------|---------------------------------|---|
| 22.040 (9) (A) | Summary table requirements | Tables 7-1 through 7-10 |
| 22.040 (9) (B) | Candidate resource options | Section 4.0 and Section 5.0 |
| 22.040 (9) (C) | Results of uncertainty analysis | Volume V |
| 22.040 (9) (D) | Summary of mitigation costs | Emission rates – Section 4.0 Allowance Costs – Section 3.0 |

1.2.2 Followup to the 2007 IRP Unanimous Stipulation and Agreement (dated May 6, 2008)

In the 2007 IRP Unanimous Stipulation and Agreement dated May 6, 2008, Empire agreed to undertake the following tasks related to supply-side resource analysis prior to or as a part of its next IRP filing:

- Any costs not listed separately shall be identified with documentation that those costs are included in the total costs.
- Consider and analyze upgrades to all existing plant and detail that analysis.
- Cost rankings for supply-side resources will be provided unless Empire is granted a waiver from this requirement or there is a change in this part of the IRP rule.
- Consider other long-term PPAs [in addition to wind] as candidate resources.
- Identify critical uncertain factors for annual fixed and variable operation and maintenance costs, describe why these costs were or were not deemed critical factors unless Empire is granted a waiver from this requirement or there is a change in this part of the IRP rule.
- Analyze dispatchable renewable resources such as landfill gas generation and additional biomass technologies; solar-based non-dispatchable renewable technologies such as photovoltaic (PV) and solar thermal generation resources; and potential energy efficiency improvements of existing resources.
- If any resource options are eliminated during the screening phase, the Company will provide an explanation of the process used to eliminate it.

Table 1-3 provides the location in this volume or in another volume of this IRP in which a specific portion of the requirements from the 2007 IRP Unanimous Stipulation and Agreement has been addressed.

**Table 1-3
Summary of Compliance with the Requirements of the 2007 IRP Unanimous
Stipulation and Agreement**

| S&A Issue – Brief Description | Location in Report |
|--|--|
| Costs not identified separately to be documented as being in the total costs | Sections 3.0, 4.0 and 5.0 |
| Document analysis of consideration of upgrades for existing plants | Section 2.1.11 |
| Cost rankings for supply-side resources | Tables 7-1 through 7-10 |
| Long-term PPAs in addition to wind considered as possible resources | Section 4.0 – Coal PPA and Nuclear PPA |
| Critical uncertain factors for annual fixed and variable O&M costs | Section 4.0 and Volume V |
| Analyze dispatchable renewable resources such as landfill gas and biomass | Section 5.2.2 |
| Analyze solar-based non-dispatchable such as PV and solar thermal | Section 5.2.3 and Volume IV (solar PV as a DSM resource) |
| Analyze potential energy efficiency improvements of existing resources | Section 6.1 |
| Explanation for any resource options eliminated during a screening phase | Section 4.1, Section 4.3 |

2.0 Existing and Committed Supply-Side Resources


The existing supply-side resources described in this IRP include those conventional and renewable resources that are in operation on the Empire system or for which Empire has power purchase agreements (PPA). Committed resources include those conventional and renewable resources for which commitments have already been made. Existing and committed as well as future resources were examined in the modeling process for this IRP.

2.1 Existing Resources

Empire's existing resources to meet customer obligations include coal-fired units, natural gas-fired combustion turbines (CT), a hydroelectric facility, ownership shares in coal-fired units, an ownership share in a combined cycle (CC) unit, and long-term PPAs for coal and wind. These resources are summarized on Table 2-1. All unit ratings and environmental retrofit information described in this IRP represent ratings and assumptions in effect at the time the IRP was in the process of being completed. Units are rerated from time to time and all assumptions are subject to change.

In 2009, 54.5% of Empire's total system input (in kWh) was supplied by its steam and thermal generation units, 1.5% was supplied by its hydroelectric generation, and the remaining 44% was purchased power, including wind energy. As also shown on Figure 2-1, coal-fired energy purchased from others under contract constituted 18.6% of Empire's 2009 energy profile and wind energy purchases amounted to 15%.

Figure 2-1
2009 Energy Provision by Fuel Type



**Table 2-1
Empire Supply-Side Resources – Existing and Committed**

| Power Plant | Fuel Type | State | Interest (%) | Empire Capacity (MW) | Start Date | Facility Age (Years) |
|--|-----------------|-------|--------------|----------------------|----------------------------|----------------------|
| Asbury 1 & 2 | Coal | MO | 100 | 207 | 1970 & 1986 | 40 & 24 |
| Riverton 7 & 8 | Coal | KS | 100 | 92 ¹ | 1950 & 1954 | 60 & 56 |
| Iatan 1 | Coal | MO | 12 | 85 | 1980 | 30 |
| Iatan 2 ² | Coal | MO | 12 | 102 | 2010 | <1 |
| Plum Point | Coal | AR | 7.52 | 50 | 2010 | <1 |
| Riverton CTs (9-12) ³ | Natural Gas | KS | 100 | 194 | 1964, 1988, 1988 & 2007 | 46, 22, 22, & 3 |
| Empire Energy Center CTs | Natural Gas/Oil | MO | 100 | 267 | 1978 & 1981 2003 & 2003 | 32 & 29 7 & 7 |
| State Line CT | Natural Gas/Oil | MO | 100 | 96 | 1995 | 15 |
| State Line CC | Natural Gas | MO | 60 | 300 ⁴ | 1997 & 2001 ⁵ | 13 & 9 |
| Ozark Beach | Hydro | MO | 100 | 16 | 1913 | 97 |
| Total Empire Installed Capacity | | | | 1,409 | | |
| Long Term Power Purchases | Type | | | | End Date | Term |
| Plum Point | Coal | | | 50 | 2015 ⁸ | |
| Elk River Windfarm (150 MW PPA) | Wind | | | 7 ⁶ | 2025 ⁶ | 20 ⁶ |
| Meridian Way Wind Farm (105 MW PPA) | Wind | | | 8 ⁷ | 2028 ⁷ | 20 ⁷ |
| Capacity Summary | | | | | | |
| Total Coal | | | | 536 | | |
| Total Gas Turbine | | | | 557 | | |
| Total Combined Cycle | | | | 300 | | |
| Total Hydro | | | | 16 | | |
| Total Purchase including Wind | | | | 65 | | |
| TOTAL | | | | 1,474 | | |

¹Riverton 7 is rated at 38 MW, but can produce about 25 MW when solely burning coal. Riverton 8 is rated at 54 MW, but can produce about 45 MW when solely burning coal. Both units achieve the remainder of the capacity by over-firing natural gas.

²Iatan 2 is characterized as a committed unit. It is expected to enter commercial operation Fall of 2010.

³Riverton 10 and 11 were manufactured in 1967 but were installed at Empire in 1988; they are 43 years old.

⁴Represents Empire's 60% share of a 500 MW State Line Combined Cycle (SLCC) unit.

⁵One of the gas turbines at State Line CC was installed in 1997 and hence is 13 years old. The other gas turbine and the steam turbine were installed in 2001.

⁶The Elk River Windfarm consists of 100 1.5 MW turbines for a total of 150 MW. For purposes of the IRP, 7 MW of its installed capacity is counted toward the Company's reserve margin. Although the term of the PPA is 20 years, the term can be extended once for a period of 5 years at Empire's option.

⁷The Meridian Way Windfarm began commercial operation on December 15, 2008. The facility is rated at 105 MW and approximately 8 MW is counted toward the Company's reserve margin.

⁸Empire owns an undivided ownership interest of 7.52% (approximately 50 MW) in Plum Point and has signed a PPA for an additional 50 MW. Empire has the right to convert the PPA to an undivided ownership interest in 2015.

2.1.1 Asbury

The Asbury plant, located near Asbury, Missouri consists of two coal-fired units totaling 207 MW. Unit 1 was installed in 1970. Unit 2 was installed in 1986.

Many modifications have been made to the Asbury plant since Unit 1 achieved commercial operation in 1970. The precipitators were upgraded in 1977. The generator was rewound in 2007. A new state-of-the-art coal unloading facility was completed in 1990. In 1999, a new cooling tower was installed – the new fiberglass tower replaced the previous wood one. The cyclones were replaced in 2001, after they had operated for 30 years. Also in 2001, a distributed control system was installed. Selective catalytic reduction (SCR) for nitrous oxides (NO_x) control was completed in 2008; equipment to overfire air (also for NO_x control) was installed in 2001 and 2004. Routine maintenance, annual maintenance, and long-term maintenance is conducted on each of the units reflecting short-term and long-term cycles. As an example, the turbines are torn down approximately every 5-6 years (depending on hours of operation and the number of starts) and blades are replaced periodically as necessary. **

**

In the future, it may be necessary to install additional pollution control equipment (referred to as Air Quality Control System (AQCS)) at the Asbury station for compliance with regulations relating to SO₂, particulates and mercury. During the period of time that the IRP was being prepared, studies were being conducted by Black & Veatch and analysis was conducted in the IRP modeling to examine the economic desirability of installing the AQCS at Asbury versus retiring the plant. The AQCS equipment being examined included a scrubber, baghouse and powder activated carbon system.

**

**

In anticipation of potential regulation for ash ponds being issued in the future, Empire has also been examining the need for a new ash landfill and a bottom ash conveyance system. A study is being performed by Aquaterra. The equipment required and the costs for implementation have been identified for this IRP.

2.1.2 Riverton

Empire's Riverton generating plant located at Riverton, Kansas, has two steam-electric generating units (Riverton 7 and 8) with an aggregate generating capacity of 92 MW and four natural gas-fired combustion turbine units (Riverton 9, 10, 11 and 12) with an aggregate generating capacity of 194 MW. Riverton 7 is rated at 38 MW, but can only produce about 25 MW when solely burning coal. The remainder of the capacity is

achieved by over-firing natural gas. Riverton 8 is rated at 54 MW, but can produce about 45 MW when solely burning coal. The remainder of the capacity is achieved by over-firing natural gas.

Riverton 7 and 8 burn a blend of coal and petroleum coke. The units all have their original control systems. Precipitators were installed in 1976 for dust and particulate control.

Riverton 9 (12 MW and currently 46 years old) is capable of burning oil in addition to natural gas and is permitted such that it can burn oil. The operation of Riverton units 9 and Riverton 7 are linked. Riverton 10 and 11 (installed in 1988) have the capability to burn oil but under their permit may only do so under emergency conditions. Riverton 10 and 11 both have black start capability.

Routine maintenance is performed on all units. The units are inspected at regular intervals and teardowns occur according to the manufacturers' recommendations. When Riverton 12 was installed in 2007, adequate natural gas piping and transmission were designed and built to accommodate its conversion to a combined cycle unit at some point in the future. Riverton 12's summer rating is currently 150 MW. If Riverton 12 were converted to a combined cycle unit, the CC rating would be a total of 250 MW, representing an addition of 100 MW. The conversion of Riverton 12 to a CC from a CT is a candidate resource in this IRP. **

_____**

** _____

_____** is driven by requirements for the U.S. Environmental Protection Agency (EPA) to promulgate final standards addressing mercury and other hazardous air pollutants by November 2011. The mercury standards must delineate maximum achievable control technology (MACT). If the EPA does not meet the requirement to promulgate rules by 2012, all existing units will need to meet a 90% MACT standard by 1/1/2015. The 90% MACT standard would **

_____**

2.1.3 Iatan 1

Empire owns a 12% undivided interest in the nominal 670 MW coal-fired Iatan 1 located near Weston, Missouri, 35 miles northwest of Kansas City, Missouri, as well as a 3% interest in the site and a 12% interest in certain common facilities. Empire is entitled to

12% of the unit's available capacity and is obligated to pay for that percentage of the operating costs of the unit.

AQCS additions at Iatan 1 included an SCR for the removal of NO_x, a wet scrubber for the removal of sulfur dioxides (SO_x), a fabric filter baghouse for the removal of particulate matter, and a powder-activated carbon system for the removal of mercury. These additions, made in order to comply with U.S. Environmental Protection Agency regulations and to meet the requirements for an air permit for Iatan 2, were completed on April 19, 2009.

2.1.4 State Line

Empire's State Line Power Plant, located west of Joplin, Missouri, presently consists of State Line Unit 1, a CT with generating capacity of 96 MW and a CC unit (State Line CC) with generating capacity of 500 MW, of which Empire is entitled to 60%, or 300 MW. All units at the State Line Power Plant burn natural gas as a primary fuel, with State Line Unit 1 having the ability to also burn fuel oil as a backup fuel. Burning fuel oil requires water injection. The combined cycle consists of two CTs with a heat recovery steam generator (HRSG) on the back of each CT. Steam from the HRSGs is fed to the steam turbine. The CC can operate in two modes: 1) 1 x 1 mode (one CT and the steam turbine) with capacity of 150 MW (Empire's share) and 2) 2 x 1 mode (two CTs and the steam turbine) with total capacity of 300 MW (Empire's share). The total State Line CC heat rate is roughly 7,400 Btu/kWh.

No major upgrades or additional environmental equipment are expected for any unit at the State Line facility during the planning horizon. Routine maintenance will be conducted. The SLCC CTs have dry low NO_x burners and there is an SCR on each HRSG.

2.1.5 Empire Energy Center

Empire has four CT peaking units at the Empire Energy Center in Jasper County, Missouri (near the town of La Russell), with an aggregate generating capacity of 267 MW. Energy Center units 1 and 2 were installed in 1978 and 1981. They are simple cycle frame CTs. Energy Center units 3 and 4 are aeroderivative CTs installed in 2003. These two newer units have the ability to be on line in ten minutes or less and are thus considered quick start units.

These peaking units operate on natural gas as well as fuel oil. These units do not require water injection when they burn fuel oil. All units undergo routine maintenance with inspections on a regular cycle and equipment is refurbished as needed. All of the CTs use water injection to control NO_x.

2.1.6 Ozark Beach

Empire's hydroelectric generating plant, located on the White River at Ozark Beach, Missouri, has a generating capacity of 16 MW (four 4 MW units). This facility entered operation in 1913 and will shortly be 100 years old.

New water wheels were installed at Ozark Beach in the 2002-2004 timeframe. In this IRP, the energy available from Ozark Beach was reduced in every year starting in 2011 to reflect the energy lost from the reallocation of water in the White River by the U.S. Army Corps of Engineers.

2.1.7 Plum Point

The Plum Point Energy Station, a new 665-MW, sub-critical coal-fired generating facility being built near Osceola, Arkansas met in-service criteria on August 12, 2010 and has since been declared to be in commercial operation. Empire owns 7.52% (approximately 50 MW) of the project. In addition, Empire has a 30-year PPA for an additional 50 MW of capacity and an option to purchase an undivided ownership share of the 50 MW covered by the PPA in 2015.

Plum Point is equipped with an SCR for NO_x removal, a dry scrubber for SO_x control, combustion controls for Volatile Organic Compounds (VOC) mitigation, and a fabric filter baghouse for the removal of particulate matter.

2.1.8 Purchased Power

Empire has existing PPAs for both conventional and renewable resources during the planning horizon.


2.1.8.1 Conventional

During the first part of 2010, Empire purchased power under a PPA with Westar Energy. The capacity and energy purchased under this contract were provided from the three coal-fired generating units at Westar's Jeffrey Energy Center. This contract was for 162 MW of capacity and energy. It expired on May 31, 2010.

In addition to its undivided ownership share of 7.52% (approximately 50 MW) in the Plum Point Energy Station, Empire entered into a PPA for an additional approximate 50 MW of capacity. Empire has the option to convert this PPA into an undivided ownership interest of approximately 50 MW in 2015.

During 2010, Empire entered into a short-term PPA with Merrill Lynch for 41 MW over a four-month period to help meet its summer peak demand. It expires September 30, 2010.

**Figure 2-2
Load and Capability Summary
Highly Confidential in its Entirety**



3.0 Assumptions

A wide variety of data assumptions must be made for IRP modeling. Many of these assumptions are described in the following paragraphs and include fuel price forecasts, market price forecasts, capacity margin requirements, financial parameters, and emission costs. Parameters for generating resources, e.g., heat rates, operating and maintenance (O&M) costs, maintenance schedules, and forced outage rates, must also be specified. The load and energy forecast, an important series of assumptions, is described in Volume II.

3.1 Fuel Usage

Table 3-1 shows a comparison of historical fuel costs, including transportation and other fuel-related costs, for Empire's facilities:

Table 3-1
Empire's Historical Delivered Fuel Costs (\$/MMBtu)

| Fuel Type | 2009 | 2008 | 2007 |
|------------------|-------------|-------------|-------------|
| Coal - Iatan | 1.186 | 1.070 | 0.978 |
| Coal - Asbury | 1.763 | 1.577 | 1.432 |
| Coal - Riverton | 1.768 | 1.724 | 1.548 |
| Natural Gas | 7.376 | 6.909 | 7.050 |
| Oil | 14.318 | 16.721 | 14.870 |

Empire's weighted cost of fuel burned per kWh generated was 3.1698 cents in 2009, 3.1307 cents in 2008, and 3.2197 cents in 2007.

The Asbury Plant is fueled primarily by coal with oil being used as the start-up fuel and tire-derived fuel (TDF) being used as a supplemental fuel. In 2009, Asbury burned a coal blend consisting of approximately 86.8% Western coal (referred to in this report as either Western or Powder River Basin – PRB coal) and 13.2% local coal (so-called blend coal) on a tonnage basis. Since Empire began burning TDF at Asbury, the equivalent of nearly 4.5 million passenger tires has been consumed as fuel.

The Riverton Plant fuel requirements are primarily met by coal with the remainder supplied by natural gas, petroleum coke, and oil. A Siemens V84.3 A2 combustion turbine (Unit 12) was installed at the Riverton plant in 2007. Riverton 12 and three other smaller units are fueled by natural gas. During 2009, Riverton Units 7 and 8 burned an estimated blend of approximately 82.1% Western coal and 17.9% petroleum coke on a tonnage basis.

All of the Western coal for Asbury and Riverton Units 7 and 8 is shipped to the Asbury Plant by rail, a distance of approximately 800 miles. The Western coal is transported from Asbury to Riverton via truck. Both local coal and petroleum coke are transported to Riverton and Asbury via truck.

Unit 1 at the Iatan Plant is a jointly-owned coal-fired generating unit. Empire's ownership share is 12% (approximately 85 MW). KCP&L is the operator of this plant and is responsible for arranging its fuel supply. The PRB coal burned in Iatan 1 is transported by rail by the Burlington Northern and Santa Fe (BNSF) Railway Company.

The coal-fired Plum Point Energy Station met the in-service criteria on August 12, 2010. Empire owns, through an undivided interest, 7.52% (approximately 50 MW) of the project's capacity. Empire has entered into a capital lease for railcars to provide the coal for this facility. Empire also has a long-term power purchase agreement (PPA) for an additional 50 MW from this facility.

The Energy Center and State Line simple cycle combustion turbine facilities are fueled primarily by natural gas with fuel oil available for use as needed. During 2009, fuel consumption at the Energy Center was 99.8% natural gas on a kWh generated basis. Essentially all of the State Line unit 1 generation came from natural gas in 2009. The SLCC unit is fueled 100% by natural gas.

Empire has firm transportation agreements with Southern Star Central Pipeline, Inc. for the transportation of natural gas to the State Line Power Plant for the jointly-owned combined cycle unit. This transportation agreement can also supply natural gas to State Line Unit No. 1, the Energy Center or the Riverton Plant, as elected by Empire on a secondary basis. In 2002, Empire signed a precedent agreement with Williams Natural Gas Company (now Southern Star Central), that provides additional transportation market zone capability through 2022. This contract provides firm market zone transport to the sites that previously were only served on a secondary basis. The majority of Empire's physical natural gas supply requirements will be met by short-term forward contracts and spot market purchases. Forward natural gas commodity prices and volumes are hedged in accordance with Empire's Risk Management Policy in an attempt to lessen the volatility in the Company's fuel expense and gain predictability.

3.2 Coal Price Forecast

The first five years of the coal price forecasts used for the Asbury, Riverton, Iatan, and Plum Point facilities were derived by Empire fuels personnel and reflect contract knowledge over those years. The values for subsequent years use escalators based on the U.S. Department of Energy's Energy Information Administration's (EIA) May 2010 projections.

Coal price projections for Asbury are shown in Table 3-2, those for Riverton are in Table 3-3, the coal price projections for Iatan 1 and 2 are shown in Table 3-4, and Plum Point's coal price projections are found in Table 3-5. Many utilities that consume coal have recently experienced cost increases due to increases in the cost of coal transportation.

3.3 Natural Gas Price Forecast


The natural gas price forecast used for this IRP is based on the Ventyx Fall 2009 Power Market Advisory Service Electricity & Fuel Price Outlook modified by Ventyx. Natural gas prices were developed for four carbon scenarios: no carbon, and low, base and high carbon tax assumptions. Any carbon tax would start no earlier than 2015. The natural gas prices are correlated to the CO₂ prices and are shown on Table 3-6 and Figure 3-1.

Table 3-6
Natural Gas Price Forecast (\$/MMBtu)

| Year | Base CO₂ Case | No CO₂ Case | Low CO₂ Case | High CO₂ Case |
|-------------|---------------------------------|-------------------------------|--------------------------------|---------------------------------|
| 2010 | 6.16 | 6.16 | 6.16 | 6.16 |
| 2011 | 6.30 | 6.30 | 6.30 | 6.30 |
| 2012 | 6.12 | 6.13 | 6.12 | 6.12 |
| 2013 | 6.35 | 6.37 | 6.35 | 6.35 |
| 2014 | 7.07 | 7.11 | 7.07 | 7.07 |
| 2015 | 7.63 | 7.58 | 7.59 | 7.92 |
| 2016 | 8.03 | 7.95 | 7.98 | 8.47 |
| 2017 | 8.34 | 8.27 | 8.31 | 8.90 |
| 2018 | 8.94 | 8.84 | 8.90 | 9.58 |
| 2019 | 9.39 | 9.23 | 9.33 | 10.06 |
| 2020 | 10.49 | 10.29 | 10.45 | 11.19 |
| 2021 | 11.00 | 10.68 | 10.89 | 11.60 |
| 2022 | 11.17 | 10.78 | 11.00 | 11.70 |
| 2023 | 11.72 | 11.20 | 11.49 | 12.16 |
| 2024 | 12.17 | 11.55 | 11.90 | 12.51 |
| 2025 | 12.56 | 11.80 | 12.21 | 12.77 |
| 2026 | 13.13 | 12.28 | 12.77 | 13.22 |
| 2027 | 13.59 | 12.69 | 13.25 | 13.57 |
| 2028 | 14.23 | 13.29 | 13.89 | 14.06 |
| 2029 | 14.99 | 14.02 | 14.63 | 14.73 |

Source: Ventyx

Figure 3-1



Source: Ventyx

3.3.1 Natural Gas Price Forecasting Methodology

Ventyx produces natural gas price forecasts for each month at individual pricing hubs using its Natural Gas Sub-Module. The Operations Component for the sub-module consists of a model of the aggregate U.S. natural gas sector. For each month and iteration, it executes in the following manner:

- The Operations Component includes an econometric model of the continental U.S. demand in each of the sectors other than power, relating monthly consumption to the Henry Hub price.
- For each iteration of the Operations Module, natural gas demand by the power sector is taken from the prior iteration of the Power Module.
- Liquid natural gas (LNG) supply is forecast using a proprietary global LNG model and Henry Hub prices from the previous iteration. This model utilizes forecasts of global LNG demand and supply.
- Domestic supply is represented in the Operations Components by exogenous continental U.S. production declines and exogenous assumptions about deliveries from Alaska; a pair of econometric equations relating continental U.S. productive capacity additions to Henry Hub prices in previous months and continental U.S. capacity utilization to the current Henry Hub/West Texas Intermediate (WTI) price; and net storage withdrawals to balance supply and demand to the extent available storage capacity will permit.
- The Henry Hub price is simulated as the price that balances demand and supply, including net storage withdrawals.

3.3.2 Natural Gas Risk Management Policy

Empire originally enacted a Risk Management Policy (RMP) in 2001 that establishes the approach and internal policy that Empire will use to manage specifically its natural gas commodity risk. The policy is revised approximately each year to reflect increased knowledge and changes in markets and financial instruments. The RMP targets for hedging of natural gas are:

- A minimum of 10% of year four expected gas burn
- A minimum of 20% of year three expected gas burn
- A minimum of 40% of year two expected gas burn
- A minimum of 60% of year one expected gas burn¹
- Up to 80% of any future year's expected requirement can be hedged if appropriate given the associated volume risk.

The RMP serves to minimize the exposure that Empire has to the impacts of fluctuating natural gas prices.

3.4 Fuel Oil Price Forecast

To forecast No. 2 Fuel Oil, Ventyx uses a technique similar to natural gas, where representative current New York Mercantile Exchange (NYMEX) pricing is blended to its internal forward view. Since crude oil is the raw material used to produce distillate oil, jet kerosene, and heavy fuel oil (e.g., various sulfur grades of #6 residual oil) as well as gasoline, Ventyx derives fuel oil forecasts for generators from its WTI Reference Case Forecast.

Ventyx produces its WTI Reference Case based on NYMEX future prices for WTI Oil and Fuel Oil #2, product price relationships between fuel oils and long-term supply and demand analysis of the WTI and global crude oil markets. The WTI forecast is based on 72 months of NYMEX Futures prices and on subsequent supply/demand fundamentals for the remainder for the forecast period. The WTI NYMEX prices are incorporated directly for the first 36 months and for the following 36 months by mean regression analysis with the supply/demand analysis.

A similar estimation technique as used to forecast monthly natural gas prices is used to project monthly oil prices.


3.5 Market Price Forecast

Market prices for the Southwest Power Pool (SPP) were projected by Ventyx for use in the modeling. These prices reflect conditions in the market expected to be experienced by Empire and use the most recent market information available. Market prices were

¹ For example, as of July 2010, Year 1 is 2011, Year 2 is 2012, Year 3 is 2013 and Year 4 is 2014.


determined for each of the carbon tax scenarios. The projected on-peak market prices used for the modeling in this IRP are shown in Figures 3-2 and 3-3.

Figure 3-2
7 x 24 Market Prices – SPP



Source: Ventyx

Figure 3-3
5 x 16 Market Prices – SPP



Source: Ventyx

3.6 Capacity Margin

As a member of the SPP, Empire is required to maintain a minimum 12% capacity margin which is approximately equivalent to a 13.7% reserve margin. This value was used as the minimum reserve margin value for capacity planning in this IRP.

3.7 Financial Parameters

Empire's discount rate used for planning purposes is 7.78%. The Gross Domestic Product (GDP) Deflator used in all of the model runs is 2.5% per year throughout the forecast period. Levelized fixed charge rates were only applied in the screening portion of the modeling (in the Capacity Expansion Module). The values used are shown in Table 3-7.

**Table 3-7
Levelized Fixed Charge Rates**

| Technology | Levelized Fixed Charge Rate (%) |
|------------------------|--|
| Combustion turbine | 11.59% |
| Combined cycle | 11.17% |
| Coal/IGCC | 10.59% |
| Distributed Generation | 12.90% |
| Biomass | 12.90% |

Levelized fixed charge rates were not applied to capital costs for the units in the MIDAS modeling since the model was used to perform a full financial analysis including accelerated depreciation, annual rate base calculations, construction S-curves, and Allowance for Funds Used During Construction (AFUDC). All present value of revenue requirements (PVRR) calculations have been expressed in 2010 dollars.

No future resource is expected to have leased or rented facilities.

3.8 Emission Costs

Emission costs modeled in the IRP analysis included sulfur dioxide (SO₂), nitrogen oxides (NO_x), and Mercury (Hg). For the base case, carbon dioxide (CO₂) taxes began in 2015. Because the Clean Air Mercury Rule (CAMR) was vacated, the EPA is required to issue a new rule on how mercury is to be regulated by the end of 2011. Empire assumed a resumption of mercury emission costs and controls as of the beginning of 2015.

NO_x and SO₂, along with many other pollutants, are regulated by a number of state and federal statutes that complicates price projections for the costs of emissions, the limits on the emissions themselves, and the projected future levels of emissions. The emissions costs assumed in the analysis, reflecting a combination of state and federal requirements, are shown in Table 3-8.

Table 3-8
Emissions Costs – Base Environmental

| Year | SO₂ (\$/ton) | NO_x (\$/ton) | Hg (\$000/ton) | CO₂ (\$/ton) |
|-------------|--------------------------------|--------------------------------|-----------------------|--------------------------------|
| 2015 | 153 | 1,006 | 40,000 | 21.48 |
| 2016 | 162 | 1,035 | 40,000 | 24.12 |
| 2017 | 170 | 1,063 | 40,000 | 27.04 |
| 2018 | 177 | 1,090 | 40,000 | 30.09 |
| 2019 | 182 | 1,106 | 40,000 | 32.21 |
| 2020 | 186 | 1,120 | 40,000 | 34.66 |
| 2021 | 188 | 1,131 | 40,000 | 37.22 |
| 2022 | 188 | 1,131 | 40,000 | 40.19 |
| 2023 | 188 | 1,131 | 40,000 | 43.23 |
| 2024 | 188 | 1,131 | 40,000 | 46.87 |
| 2025 | 188 | 1,131 | 40,000 | 50.18 |
| 2026 | 188 | 1,131 | 40,000 | 53.90 |
| 2027 | 188 | 1,131 | 40,000 | 58.00 |
| 2028 | 188 | 1,131 | 40,000 | 62.35 |
| 2029 | 188 | 1,131 | 40,000 | 67.18 |

Source: Ventyx (Hg estimate from Empire)

Four levels of CO₂ regulation were examined including a case in which no CO₂ regulation was enacted. Table 3-9 shows the projected CO₂ costs (\$/ton) in a cap and trade system (referenced as a carbon tax in this IRP), assumed to be applicable no earlier than 2015. Because the optimization models are capable of expressly modeling allowance costs and impacts of carbon taxes, no separate environmental mitigation costs needed to be calculated for the supply-side resources enumerated in this Volume of the IRP report.

Table 3-9
Carbon Dioxide Tax Assumptions

| | Low CO₂ Scenario | Base CO₂ Scenario | High CO₂ Scenario |
|------|------------------------------------|-------------------------------------|-------------------------------------|
| 2015 | 12.55 | 21.48 | 27.77 |
| 2016 | 13.58 | 24.12 | 30.38 |
| 2017 | 15.05 | 27.04 | 35.81 |
| 2018 | 16.35 | 30.09 | 40.37 |
| 2019 | 18.07 | 32.21 | 43.57 |
| 2020 | 19.43 | 34.66 | 48.23 |
| 2021 | 21.23 | 37.22 | 51.74 |
| 2022 | 22.98 | 40.19 | 55.65 |
| 2023 | 25.72 | 43.23 | 60.39 |
| 2024 | 28.51 | 46.87 | 65.29 |
| 2025 | 30.81 | 50.18 | 69.23 |
| 2026 | 33.84 | 53.90 | 73.84 |
| 2027 | 36.35 | 58.00 | 79.20 |
| 2028 | 38.60 | 62.35 | 85.03 |
| 2029 | 40.63 | 67.18 | 90.44 |

Source: Ventyx

For the low and high CO₂ scenarios, changes in SO₂, NO_x and mercury emission allowances prices and gas, oil, and coal prices were correlated with the CO₂ prices. Tables 3-10 through 3-14 show the correlated price projections for all four of the carbon tax scenarios. The coal prices shown are those that would be expected for any new coal-fired generation built in the future.

Table 3-10
Projected Coal Prices for Future Coal-Fired Resources – Carbon Scenarios
(\$/MMBtu)

| | No CO ₂ Scenario | Low CO ₂ Scenario | Base CO ₂ Scenario | High CO ₂ Scenario |
|------|-----------------------------|------------------------------|-------------------------------|-------------------------------|
| 2017 | 2.34 | 2.30 | 2.13 | 1.95 |
| 2018 | 2.46 | 2.40 | 2.17 | 1.95 |
| 2019 | 2.57 | 2.49 | 2.22 | 1.95 |
| 2020 | 2.70 | 2.59 | 2.28 | 1.93 |
| 2021 | 2.84 | 2.70 | 2.33 | 1.93 |
| 2022 | 3.03 | 2.84 | 2.40 | 1.97 |
| 2023 | 3.22 | 2.95 | 2.46 | 2.09 |
| 2024 | 3.46 | 3.10 | 2.52 | 2.25 |
| 2025 | 3.70 | 3.25 | 2.58 | 2.42 |
| 2026 | 4.03 | 3.43 | 2.66 | 2.62 |
| 2027 | 4.19 | 3.47 | 2.72 | 2.72 |
| 2028 | 4.32 | 3.49 | 2.81 | 2.81 |
| 2029 | 4.45 | 3.51 | 2.89 | 2.89 |

Source: Ventyx

Table 3-11
Projected Oil Prices – Carbon Scenarios (\$/MMBtu)

| | No CO ₂ Scenario | Low CO ₂ Scenario | Base CO ₂ Scenario | High CO ₂ Scenario |
|------|-----------------------------|------------------------------|-------------------------------|-------------------------------|
| 2015 | 22.29 | 22.97 | 25.21 | 27.20 |
| 2016 | 23.31 | 24.23 | 27.20 | 29.34 |
| 2017 | 24.01 | 25.30 | 29.04 | 32.13 |
| 2018 | 24.66 | 26.32 | 30.93 | 34.52 |
| 2019 | 25.18 | 27.38 | 32.38 | 36.23 |
| 2020 | 25.51 | 28.16 | 33.71 | 37.89 |
| 2021 | 25.80 | 29.08 | 35.03 | 39.01 |
| 2022 | 25.92 | 29.83 | 36.22 | 39.66 |
| 2023 | 26.17 | 31.15 | 37.55 | 39.26 |
| 2024 | 26.34 | 32.43 | 38.81 | 39.51 |
| 2025 | 26.68 | 33.76 | 40.06 | 40.06 |
| 2026 | 27.23 | 35.67 | 41.49 | 41.49 |
| 2027 | 28.03 | 37.72 | 43.03 | 43.03 |
| 2028 | 29.88 | 41.13 | 44.82 | 44.82 |
| 2029 | 31.11 | 43.65 | 46.66 | 46.66 |

Source: Ventyx

Table 3-12
Projected SO₂ Allowance Prices (\$/ton)

| | No CO₂ Scenario | Low CO₂ Scenario | Base CO₂ Scenario | High CO₂ Scenario |
|------|---------------------------------------|--|---|---|
| 2015 | 170 | 171 | 153 | 134 |
| 2016 | 189 | 189 | 162 | 138 |
| 2017 | 212 | 209 | 170 | 127 |
| 2018 | 240 | 233 | 177 | 111 |
| 2019 | 264 | 251 | 182 | 106 |
| 2020 | 296 | 275 | 186 | 118 |
| 2021 | 336 | 304 | 188 | 135 |
| 2022 | 400 | 350 | 188 | 160 |
| 2023 | 470 | 388 | 188 | 188 |
| 2024 | 470 | 362 | 188 | 188 |
| 2025 | 470 | 339 | 188 | 188 |
| 2026 | 470 | 305 | 188 | 188 |
| 2027 | 470 | 274 | 188 | 188 |
| 2028 | 470 | 244 | 188 | 188 |
| 2029 | 470 | 214 | 188 | 188 |

Source: Ventyx, Based on 2009 Fall Reference Case

Table 3-13
Projected Annual NO_x Allowance Prices (\$/ton)

| | No CO₂ Scenario | Low CO₂ Scenario | Base CO₂ Scenario | High CO₂ Scenario |
|------|---------------------------------------|--|---|---|
| 2015 | 1,083 | 1,083 | 1,006 | 914 |
| 2016 | 1,155 | 1,149 | 1,035 | 925 |
| 2017 | 1,243 | 1,227 | 1,063 | 871 |
| 2018 | 1,352 | 1,321 | 1,090 | 821 |
| 2019 | 1,438 | 1,386 | 1,106 | 776 |
| 2020 | 1,548 | 1,472 | 1,120 | 681 |
| 2021 | 1,682 | 1,567 | 1,131 | 617 |
| 2022 | 1,850 | 1,686 | 1,131 | 541 |
| 2023 | 2,069 | 1,810 | 1,131 | 446 |
| 2024 | 2,414 | 2,009 | 1,131 | 483 |
| 2025 | 2,836 | 2,251 | 1,131 | 567 |
| 2026 | 3,483 | 2,573 | 1,131 | 697 |
| 2027 | 4,489 | 3,098 | 1,131 | 898 |
| 2028 | 5,072 | 3,251 | 1,131 | 1,014 |
| 2029 | 5,655 | 3,404 | 1,131 | 1,131 |

Source: Ventyx, Based on 2009 Fall Reference Case

Table 3-14
Projected Mercury Allowance Prices (\$000/ton)

| | No CO₂ Scenario | Low CO₂ Scenario | Base CO₂ Scenario | High CO₂ Scenario |
|------|---------------------------------------|--|---|---|
| 2015 | 41,159 | 40,974 | 40,000 | 39,153 |
| 2016 | 41,521 | 41,246 | 40,000 | 39,140 |
| 2017 | 41,942 | 41,522 | 40,000 | 38,827 |
| 2018 | 42,391 | 41,828 | 40,000 | 38,724 |
| 2019 | 42,701 | 41,934 | 40,000 | 38,708 |
| 2020 | 43,051 | 42,108 | 40,000 | 38,712 |
| 2021 | 43,398 | 42,210 | 40,000 | 38,903 |
| 2022 | 43,767 | 42,325 | 40,000 | 39,230 |
| 2023 | 44,093 | 42,245 | 40,000 | 39,519 |
| 2024 | 44,397 | 42,125 | 40,000 | 37,294 |
| 2025 | 44,575 | 41,957 | 40,000 | 37,443 |
| 2026 | 44,645 | 41,593 | 40,000 | 37,502 |
| 2027 | 44,715 | 41,324 | 40,000 | 37,560 |
| 2028 | 44,785 | 41,111 | 40,000 | 37,619 |
| 2029 | 47,619 | 43,470 | 40,000 | 40,000 |

Source: Empire/Ventyx

4.0 New Conventional Resources

Future supply-side resources available to Empire over the twenty-year planning horizon include both conventional and renewable resources. The conventional resources considered in the IRP are described in this Section of the report. The renewable resources considered in the IRP are described in Section 5.0.

A variety of conventional resources were examined in the course of preparing this IRP. These resources included supercritical coal, CT, CC, nuclear (PPA only), distributed generation, integrated gasification combined cycle (IGCC), and the conversion of Riverton 12 from a CT to CC. The capital costs modeled for each resource option include only generic costs for new transmission required; not those costs expected at any specific location due to the current methods that the SPP uses to plan and cost out new transmission projects. Costs are included for the switching station at the power plant. O&M cost estimates are provided. Empire believes the uncertainty that surrounds the O&M costs for any future power plant is significantly overshadowed by the uncertainty related to any of natural gas prices, market prices, and the level of carbon taxes. Thus, the uncertainty associated with O&M costs is not considered further in this IRP.

4.1 Supercritical Coal

In a supercritical coal unit, chunks of coal are crushed into fine powder in the pulverizers and are fed into a combustion unit (boiler or furnace) where it is burned. Heat from the burning coal is used to generate steam that is used to spin one or more turbines to generate electricity. Coal units currently generate about half of the electricity produced annually in the U.S.

As modeled, the coal option available to Empire represents its ownership share of a larger unit. As larger units benefit from economies of scale, this modeling choice was made to ensure Empire was able to take advantage of the cost effectiveness represented by the larger units. However, the actual timing and ownership share of units that Empire might be able to participate in will be dependent on plans of other utilities in the region and are expected to be largely out of Empire's control. The data used in the modeling are shown in Table 4-1.

Cost and emission data are based on information from a supercritical coal unit currently under construction in the region. Supercritical coal units with carbon capture and sequestration are not assumed to be commercially viable within the planning horizon modeled in this IRP. Costs were developed for a coal unit equipped with CCS prior to making a judgment on the earliest feasible year of installation. The data are presented to show the estimated cost and efficiency differences between a traditional coal-fired unit and one equipped with CCS.

**Table 4-1
Supercritical Coal Performance Parameters**

| Parameter | No CCS | With CCS | PPA – No CCS |
|--|---------------|-----------------------------------|---------------------|
| Earliest feasible year of installation | 2020 | Outside of planning horizon | 2017 |
| Size, MW (net) | 50* | 50* | 50* |
| Full load heat rate, Btu/kWh | 9,220 | 11,986 | 9,220 |
| Lead time, months | 60 | 60 | |
| Capital cost, \$/kW (2010 \$) | 2,400 | 4,591 | - |
| Fixed O&M, \$/kW-year | 27.53 | 32.15 | 363.29 |
| Variable O&M, \$/MWh | 4.59 | 6.15 | 4.59 |
| Equivalent Forced Outage Rate, % | 6.0 | 7.0 | 6.0 |
| Maintenance Outage Rate, % | 6.5 | 7.5 | 6.5 |
| SO ₂ Emissions, lbs/MMBtu | 0.03 | 0.03 | 0.03 |
| NO _x Emissions, lbs/MMBtu | 0.05 | 0.05 | 0.05 |
| CO ₂ Emissions, lbs/MMBtu | 210 | 21 | 210 |
| Mercury Emissions, lbs/MMBtu | 0.001 | 0.001 | 0.001 |
| *Ownership share of a larger unit. | | | |

With the assumption that carbon dioxide (CO₂) may eventually be regulated (either cap and trade or a tax) with an associated requirement to significantly reduce CO₂ emissions in the future, CCS may need to be proven as a viable technology in order for coal-fired generation to continue to be a future new resource option. As part of its efforts to examine CCS, Empire is one of the five electric utilities participating in the Missouri Carbon Sequestration Project (MCSP). This project is researching the feasibility of shallow carbon sequestration within geologic formations in Missouri.

Phase I of the MCSP has been completed and funds to move the project into its second phase were announced in April 2010. Carbon capture is currently under development. Because carbon sequestration is the other component necessary for successful CCS, the Missouri utilities are supporting research efforts to determine feasibility.

Other utility participants include AmerenUE, Associated Electric Cooperative, City Utilities of Springfield, and KCP&L. Research members of the project include City Utilities of Springfield, Missouri Department of Natural Resources, Missouri State University, and Missouri University of Science & Technology. Supporting Organizations include Missouri Energy Development Association, Missouri Public Service Commission, Missouri Public Utility Alliance, and the EPA Region VII.

4.2 Combustion Turbine

Combustion turbines typically burn natural gas and/or No. 2 fuel oil and are available in a wide variety of sizes and configurations. CTs are generally used for peaking and reserve purposes because of their relatively low capital costs, higher full load heat rate, and the higher cost of fuel when compared to conventional coal-fired baseload capacity. CTs,

particularly aeroderivatives, have the added benefit of providing quick-start capability in certain configurations. In this IRP, both simple cycle and aeroderivative CTs were options in the optimization modeling with data used as shown on Table 4-2. Data for capital costs for the CTs are based on manufacturers' information provided by Siemens, General Electric, and Pratt and Whitney.

Table 4-2
Combustion Turbine Performance Parameters

| Parameter | Aeroderivative CT | Simple Cycle CT |
|--|--------------------------|------------------------|
| Earliest feasible year of installation | 2015 | 2015 |
| Size, MW (net) | 60 | 115 |
| Full load heat rate, Btu/kWh | 11,000 | 10,500 |
| Lead time, months | 48 | 48 |
| Capital cost, \$/kW (2010 \$) | 674 | 573 |
| Fixed O&M, \$/kW-year | 10.85 | 13.23 |
| Variable O&M, \$/MWh | 3.00 | 3.00 |
| Equivalent Forced Outage Rate, % | 3.6 | 3.6 |
| Maintenance Outage Rate, % | 4.1 | 4.1 |
| NO _x Emissions, lbs/MMBtu | 0.03 | 0.03 |
| CO ₂ Emissions, lbs/MMBtu | 120 | 120 |

4.3 Combined Cycle

In a combined cycle (CC) facility, the hot exhaust gases from one or more CTs pass through a heat recovery steam generator (HRSG). The steam generated by the HRSG is expanded through a steam turbine which, in turn, drives an additional generator. Combustion turbine combined cycle systems typically burn natural gas and are available in a wide variety of sizes and configurations. In Empire's IRP, two CC options were available for selection: 1) a new unsited CC facility, and 2) the conversion of the Riverton 12 CT to a CC unit. Riverton 12 can be converted into a CC unit through the addition of an HRSG and a steam turbine which would result in 100 MW of additional capacity. The Riverton12 conversion costs are based on an estimate prepared by Segal, Inc., an engineering and technical services company based in Overland Park, Kansas. The general CC unit capital costs are based on a cost estimate from a CT manufacturer plus the conversion cost estimates from Segal. CC with CCS is assumed to not be commercially viable during the planning horizon modeled for this IRP. The data used for modeling are shown on Table 4-3.

**Table 4-3
Combined Cycle Performance Parameters**

| Parameter | General CC | CC with CCS | Riverton 12 Conversion |
|---|-------------------|-----------------------------|-------------------------------|
| Earliest feasible year of installation | 2015 | Outside of planning horizon | 2015 |
| Size, MW (net) | 250 | 250 | 100* |
| Full load heat rate, Btu/kWh | 7,500 | 9,750 | 7,500 |
| Lead time, months | 48 | 48 | 48 |
| Capital cost, \$/kW (2010 \$) | 720 | 1,584 | 1,253 |
| Fixed O&M, \$/kW-year | 12.48 | 22.10 | 12.48 |
| Variable O&M, \$/MWh | 2.07 | 3.15 | 2.07 |
| Equivalent Forced Outage Rate, % | 5.50 | 5.50 | 5.50 |
| Maintenance Outage Rate, % | 7 | 6 | 7 |
| NO _x Emissions, lbs/MMBtu | .01 | .01 | .01 |
| CO ₂ Emissions, lbs/MMBtu | 120 | 12 | 120 |
| *Represents the incremental capacity of the CC unit only, not the total including the CT. 1. Same fixed costs as currently projected for Riverton 12 as a CT. Thus, no additional fixed costs. | | | |

4.4 Nuclear

New nuclear units are currently being pursued around the country at brownfield sites – meaning additional units are being planned at sites with operating units. New nuclear unit designs have been submitted to the U.S. Nuclear Regulatory Commission (NRC) and have received or are awaiting design approval. Small Modular Reactors (SMR) are receiving much attention and interest as well. These are new reactor designs for which each module is much smaller than the typical approximately 1,000 MW associated with the nuclear units designed and built in the 1970s and 1980s.

Although Empire is not aware of any opportunities for it to become a joint owner of a nuclear unit in the region, for purposes of the IRP, Empire considered a nuclear unit PPA as an option starting in 2025. At some point in the future, possibly within the planning horizon and possibly later than the end of the planning horizon, it is conceivable that, within the region, one or more new nuclear units could be pursued as an additional unit at an existing nuclear power plant site.

The IRP modeling assumes that Empire would participate in a PPA with the owner of a new nuclear unit. However, the actual timing and size of such a PPA will be dependent on plans of other utilities in the region and are expected to be largely out of Empire's control.

**Table 4-4
Nuclear PPA Performance Parameters**

| Parameter | Value |
|---|--------------|
| Earliest feasible year of installation | 2025 |
| Size, MW (net) | 50* |
| Full load heat rate, Btu/kWh | 10,300 |
| PPA cost, \$/kW-year | 1035.74 |
| Variable O&M, \$/MWh | 0.49 |
| Equivalent Forced Outage Rate, % | 3.8 |
| Maintenance Outage Rate, % | 6.2 |
| Emissions | None |
| *Represents share of a larger jointly-owned unit. | |

4.5 Distributed Generation

Distributed generation (DG) refers to small-scale power plants that differ from traditional electricity supply due to their small size, location, and grid connection. DGs are located at or near the point at which the power is used. Such installations relieve congestion in power lines during periods of peak demand, helping to defer investments in additional transmission and distribution capacity. DG facilities are often installed on the distribution system as opposed to on the transmission system, where generation is typically connected. DG facilities may also be used to boost the quality and reliability of local electricity service by providing voltage control and backup power to customers who require such “premium” service. Data used to model distributed generation are shown in Table 4-5.

**Table 4-5
Distributed Generation Performance Parameters**

| Parameter | Value |
|--|--------------|
| Earliest feasible year of installation | 2014 |
| Size, MW (net) | 5 |
| Full load heat rate, Btu/kWh | 10,000 |
| Lead time, months | 12 |
| Capital cost, \$/kW (2010 \$) | 1,404 |
| Fixed O&M, \$/kW-year | 16.03 |
| Variable O&M, \$/MWh | 7.12 |
| Equivalent Forced Outage Rate, % | 0 |
| Maintenance Outage Rate, % | 0 |

4.6 Integrated Gasification Combined Cycle (IGCC)

Coal gasification is a process that converts solid coal into a synthetic gas composed mainly of carbon monoxide and hydrogen. Integrated gasification combined cycle (IGCC) combines both steam and gas turbines (“combined cycle”). The fuel gas leaving the gasifier must be cleaned (to very high levels of removal efficiencies) of sulfur compounds and particulates in order to be a suitable fuel for combustion. After the fuel

gas has been cleaned, it is burned and expands in a gas turbine. Steam is generated and superheated in both the gasifier and the heat recovery unit downstream from the gas turbine. The flue gas is then directed through a steam turbine to produce electricity. IGCC plants can achieve up to 45 percent efficiency depending on the level of integration of the various processes, greater than 99 percent SO₂ removal, and NO_x below 50 parts per million.² The analysis assumes that Empire would participate in a share of a larger jointly-owned unit. Data used to model IGCC are shown in Table 4-7.

Table 4-6
IGCC Performance Parameters

| Parameter | Value |
|---|--------------|
| Earliest feasible year of installation | 2020 |
| Size, MW (net) | 50* |
| Full load heat rate, Btu/kWh | 9,300 |
| Lead time, months | |
| Capital cost, \$/kW (2010 \$) | 2437 |
| Fixed O&M, \$/kW-year | 38.67 |
| Variable O&M, \$/MWh | 2.92 |
| Equivalent Forced Outage Rate, % | 6.0 |
| Maintenance Outage Rate, % | 6.5 |
| SO ₂ Emissions, lbs/MMBtu | .02 |
| NO _x Emissions, lbs/MMBtu | .01 |
| CO ₂ Emissions, lbs/MMBtu | 210 |
| Mercury Emissions, lbs/MMBtu | .0005 |
| *Represents a share of a larger jointly-owned unit. | |

IGCC with CCS is assumed to not be commercially viable during the planning horizon modeled for this IRP.

² Source: "Clean Coal Technologies for Developing Countries," World Bank Technical Paper No. 286, Energy Series, E. Stratos Tavoulareas and Jean-Pierre Charpentier, July 1995.
<http://www.worldbank.org/html/fpd/em/power/EA/mitigatn/igccsubs.stm>, accessed May 2006.

5.0 New Renewable Resources

The regulatory requirements for renewable resources in certain of Empire's jurisdictions are discussed first in the section on Renewable Portfolio Standards. The second section contains a discussion of the renewable resources considered in this IRP.

5.1 Renewable Portfolio Standards

Renewable Portfolio Standards (RPS) or Renewable Energy Standards have been established by the voters or the legislature in Missouri, Kansas, and Oklahoma. The requirements for each are provided below.

5.1.1 RPS – Missouri

The RPS (Proposition C) approved by the voters during the November 4, 2008 election, and currently undergoing rulemaking at the MPSC, mandates percentages of an electric utility's sales that are to be provided by renewable energy resources by the dates shown in Table 5-1. The RPS further requires that a specific percentage be provided by solar energy unless a utility is exempted. Renewable energy resources as approved by the voters and as defined in the proposed rules in Docket EX-2010-0169 (July 1, 2010, as posted in the August 16, 2010 *Missouri Register*) are:

- Wind
- Solar, including solar thermal sources utilized to generate electricity, photovoltaic cells, or photovoltaic panels
- Dedicated crops grown for energy production
- Cellulosic agricultural residues
- Plant residues
- Methane from landfills or wastewater treatment
- Clean and untreated wood, such as pallets
- Hydropower (not including pumped storage) that does not require a new diversion or impoundment of water and that has generator nameplate ratings of ten (10) MW or less
- Fuel cells using hydrogen produced by any of the renewable energy resources shown in the list above
- Other sources of energy not including nuclear that become available after November 4, 2008, and are certified as renewable by the department [Missouri Department of Natural Resources].

A multiplier of 1.25 will apply to all in-state resources (meaning that each 1 kWh of renewable energy generated within Missouri will count as 1.25 kWh for purposes of determining compliance with the Missouri RPS).

Table 5-1
Missouri Renewable Portfolio Standard

| Dates | RES Percentage (no less than) |
|---|--------------------------------------|
| 2011-2013 | 2 |
| 2014-2017 | 5 |
| 2018-2020 | 10 |
| Beginning in 2021 | 15 |
| Notes: | |
| 1. Percentage of an electric utility's sales. | |
| 2. Some or all of the requirement may be satisfied by the purchase of Renewable Energy Credits (REC). | |
| 3. Each kWh of eligible energy generated within Missouri will count as 1.25 kWh. | |

As of January 20, 2009, Empire had renewable energy resource aggregate nameplate capacity equal to or greater than 15% of its fossil-fired generating capacity.

Table 5-2
Empire Renewable Resources

| Name of Resource | Type of Resource | Nameplate (MW) |
|--|-------------------------|-----------------------|
| Ozark Beach | Hydroelectric | 4 units – 16 MW total |
| Elk River | Wind | 150* |
| Meridian Way | Wind | 105* |
| TOTAL RENEWABLE | | 271 |
| Total 2010 Fossil-Fired Capacity | | 1241 |
| % of Total represented by Renewables | | 21.8% |
| *Represents the nameplate capacity for these facilities. Actual rated capacity is 7 MW and 8 MW, respectively. | | |

5.1.2 RPS – Kansas

The state legislature passed HB 2369 in 2009 establishing an RPS in Kansas. The rulemaking process at the Kansas Corporation Commission related to the RPS is ongoing. Utilities are required to generate or purchase a certain amount of their electricity peak demand for Kansas-only customers from eligible renewable resources as shown in Table 5-3.

Table 5-3
Kansas Renewable Portfolio Standard

| Years | Percentage of Utility Peak Capacity Demand |
|---|---|
| 2011-2015 | 10% |
| 2016-2019 | 15% |
| 2020 and onward | 20% |
| Note: % calculated based on the average demand of the prior three years | |

Renewable energy resources are defined by the statute to include:

- Wind
- Solar thermal sources
- Photovoltaic cells and panels
- Dedicated crops grown for energy production
- Cellulosic agricultural residues
- Plant residues
- Methane from landfills or from wastewater treatment
- Clean and untreated wood products such as pallets
- Existing hydropower
- New hydropower, not including pumped storage, that has a nameplate rating of 10 MW or less
- Fuel cells using hydrogen produced by one of the above-named renewable energy resources
- Other sources of energy, not including nuclear power, that become available after the legislation becomes effective, and that are certified as renewable by rules and regulations of the Kansas Corporation Commission.

Renewable resources installed in Kansas qualify for a 1.1 multiplier for the purpose of compliance. The RPS will apply to all power sold to Kansas retail customers whether the power they consume is generated or purchased inside or outside of the state.

5.1.3 RPS – Oklahoma

In May 2010, Oklahoma enacted HB 3028 that established a renewable energy goal for electric utilities operating in the state. The goal is “that 15% of all installed capacity of electricity generation within the state by the year 2015 be generated from renewable energy sources.” Qualifying renewable energy resources include:

- Wind
- Solar
- Photovoltaic
- Hydropower
- Hydrogen
- Geothermal
- Biomass, including agricultural crops, wastes, and residues, wood, animal and other degradable organic wastes, municipal solid waste, and landfill gas
- Distributed generation from an eligible renewable energy resource less than 5 MW
- Other renewable energy resources approved by the Commission
- Demand-side management and energy efficiency.

The percentage of renewable energy shall be determined by dividing all installed capacity of renewable electricity generation in Oklahoma by the total installed capacity of all electricity generation in Oklahoma.

Empire has no electric generating resources in Oklahoma.


5.2 Renewable Resources

Empire examined a range of renewable resources in this IRP. These include wind, biomass (chicken/turkey waste, landfill gas and others), and solar (PV and solar thermal). Empire currently burns fuel derived from tires at its Asbury station. Empire purchases wind energy from Elk River Windfarm, LLC, whose wind generation facility (Elk River Windfarm) is near Beaumont, Kansas. Empire also purchases wind energy from Cloud County Wind Farm, LLC (the Meridian Way Wind Farm) in Cloud County, Kansas.

5.2.1 Wind

Wind energy systems for utility applications transform the kinetic energy of the wind into electrical energy. Horizontal-axis turbines (propeller-style machines) are the most common wind turbine configuration today, constituting almost all of the utility-scale (greater than 100 kW) applications. Figure 5-1 shows this typical wind turbine configuration.

Figure 5-1
Wind Turbine Configuration



Turbine subsystems include:

- A rotor, or blades, that convert the wind's energy into rotational shaft energy

- A nacelle (enclosure) containing a drive train, usually including a gearbox (not all turbines require a gearbox) and a generator
- A tower to support the rotor and drive train
- Electronic equipment such as controls, electrical cables, ground support equipment, and interconnection equipment.³

The American Wind Energy Association (AWEA) reported as of mid-2010 that the U.S. had 36,303 MW of installed wind energy capacity. The top fifteen states as reported by AWEA as of mid-2010 are shown in Table 5-4.

**Table 5-4
Installed Wind Energy Capacity in the U.S. (July 2010)**

| State | Installed Capacity (MW) | Rank |
|--------------|-------------------------|------|
| Texas | 9,707 | 1 |
| Iowa | 3,670 | 2 |
| California | 2,739 | 3 |
| Oregon | 1,920 | 4 |
| Washington | 1,914 | 5 |
| Illinois | 1,848 | 6 |
| Minnesota | 1,797 | 7 |
| New York | 1,274 | 8 |
| Colorado | 1,248 | 9 |
| North Dakota | 1,222 | 10 |
| Oklahoma | 1,130 | 11 |
| Indiana | 1,127 | 12 |
| Wyoming | 1,101 | 13 |
| Kansas | 1,026 | 14 |
| Pennsylvania | 748 | 15 |

5.2.1.1 Wind – Missouri

The profile of wind resources shown on Figure 5-2 reveals that Class 3 or lower wind resources exist in Empire’s Missouri service territory. Generally wind resources need to be at least Class 3 (the highest wind ranking is Class 7) in order to be considered suitable for wind energy development. This map shows some suitable resources in the Ozark Plateau. Wind resource maps from other sources have indicated that the northwest corner of the State has the highest class wind rankings.⁴ The resources that AWEA reports to be on-line in Missouri are shown in Table 5-5.

³ Figure, general information and state project information from web site of the American Wind Energy Association www.awea.org.

⁴ Figure 3-44, “Missouri annual average wind power,” Wind Energy Resource Atlas of the United States, <http://rredc.nrel.gov/wind/pubs/atlas/maps/chap3/3-44m.html>.

Figure 5-2(a)
Wind Resources in Missouri





Figure 5-2(b)
Wind Resources in Missouri



**Table 5-5
Wind Energy Projects in Missouri**

| Year of Operation | Size (MW) | Name | Developer | Utility Purchaser |
|--------------------------|------------------|-------------------------------------|---------------------------------------|--|
| 2007 | 56.7 | Bluegrass Ridge Wind energy project | Wind Capital Group/John Deere Capital | Associated Electric Cooperative (AECI) |
| 2008 | 5 | Loess Hills Wind Energy Center | Wind Capital Group/John Deere Capital | Missouri Joint Municipal Electric Utility Commission |
| 2008 | 50.4 | Cow Branch Wind Energy Center | Wind Capital Group/John Deere Capital | AECI |
| 2008 | 50.4 | Conception Wind Project | Wind Capital Group/John Deere Capital | AECI |
| 2009 | 146 | Farmers City | Iberdrola Renewables | |
| 2010 | 148.5 | Lost Creek Ridge Wind Farm | Wind Capital Group | AECI |

5.2.1.2 Wind – Kansas

The American Wind Energy Association ranks Kansas third in the nation (behind North Dakota and Texas) in potential wind energy production. The resource map in Figure 5-3(a) and (b) shows the Class 3 and 4 wind resources in Kansas.⁵ The resources that AWEA reports to be on-line in Kansas are shown in Table 5-6.

⁵ Figure 3-42, “Kansas annual average wind power,” Wind Energy Resource Atlas of the United States, <http://rredc.nrel.gov/wind/pubs/atlas/maps/chap3/3-42m.html>.

Figure 5-3(a)
Kansas Wind Resource Map





Figure 5-3(b)
Kansas Wind Resource Map



**Table 5-6
Wind Energy Projects in Kansas**

| Year of Operation | Size (MW) | Name | Developer | Utility Purchaser |
|--------------------------|------------------|---------------------------------|------------------------------|---------------------------------------|
| 1999 | 1.5 | St. Mary's | Western Resources | Western Resources |
| 2001 | 112.2 | Gray County Wind Farm | FPL Energy | Aquila |
| 2005 | 150 | Elk River Wind Farm | PPM Energy ¹ | Empire |
| 2006 | 100.5 | Spearville Wind Energy Facility | Kansas City Power & Light | Kansas City Power & Light |
| 2008 | 100.8 | Smoky Hills Wind Farm | Tradewind Energy | Sunflower Electric/Midwest Energy/BPU |
| 2008 | 148.5 | Smoky Hills II | Tradewind Energy | |
| 2008 | 96 | Meridian Way | Horizon Wind Energy | Westar |
| 2008 | 105 | Meridian Way II | Horizon Wind Energy | Empire |
| 2009 | 100 | Flat Ridge Wind Farm | BP Alternative Energy/Westar | Westar |
| 2009 | 99 | Central Plains | Westar | Westar |
| 2010 | 12.5 | Greensburg | John Deere Wind | |

1. Elk River Wind Farm is now owned by Iberdrola Renewables.

5.2.1.3 Wind – Oklahoma

Oklahoma ranks eighth nationwide in potential wind energy production with most Class 3 and higher wind resources located in the western portion of the state. The resource map in Figure 5-4(a) and (b) shows the Class 3 and 4 wind resources in Oklahoma.⁶ The resources that AWEA reports to be on-line and under construction in Oklahoma are shown in Table 5-7.

⁶Figure 3-45, "Oklahoma annual average wind power," Wind Energy Resource Atlas of the United States, <http://rredc.nrel.gov/wind/pubs/atlas/maps/chap3/3-45m.html>.

Figure 5-4(a)
Oklahoma Wind Resource Map





Figure 5-4(b)
Oklahoma Wind Resource Map




**Table 5-7
Wind Energy Projects in Oklahoma**

| Year of Operation | Size (MW) | Name | Developer | Utility Purchaser |
|---------------------------|------------------|--------------------------------|--|--|
| Operational | | | | |
| 2003 | 102 | Oklahoma Wind Power Center | FPL Energy | Oklahoma Municipal Power Authority; Oklahoma Gas & Electric |
| 2003 | 74.25 | Blue Canyon Wind Power | Consortium | Western Farmers Electric Coop |
| 2005 | 147 | Weatherford Wind Energy Center | FPL Energy | Public Service Company of Oklahoma (AEP) |
| 2005 | 0.05 | Bergey Windpower Headquarters | Bergey Windpower | Bergey Windpower Headquarters |
| 2005 | 151.2 | Blue Canyon II | Horizon Wind Energy | Public Service Company of Oklahoma (AEP) |
| 2006 | 60 | Centennial Wind Energy Project | Invenergy | Oklahoma Gas & Electric (OG&E) |
| 2007 | 94.5 | Sleeping Bear | Chermac Energy Corp/Edison Mission Group | Public Service Company of Oklahoma (AEP) |
| 2007 | 60 | Centennial Wind Energy Project | Chermac Energy/Invenergy | OG&E |
| 2008 | 123 | Red Hills | Acciona | |
| 2008 | 18.9 | Buffalo Bear | Edison Mission Group | Western Farms Electric Coop |
| 2009 | 34.5 + 64.5 | Blue Canyon V | Horizon-EDPR | Public Service Company of Oklahoma (AEP) |
| 2009 | 98.9 | Elk City | NextEra Energy Resources | |
| 2009 | 101.2 | OU Spirit | CPV/OG&E | OG&E |
| Under Construction | | | | |
| | 151.8 | Keenan II | CPV Renewable Energy | OG&E |
| | 99.2 | Minco Wind | NextEra Energy Resources | |
| | 129.6 | Taloga | Edison Mission Group | OG&E |

5.2.1.4 Wind – Arkansas


The resource map in Figure 5-5(a) and (b) shows the Class 3 and 4 wind resources in Arkansas.⁷ Only one very small wind resource is reported to be operational by AWEA, 0.1 MW at the Bitworks Prairie Grove Industrial Park. AWEA reports no proposed projects.

Figure 5-5(a)
Arkansas Wind Resource Map



⁷ Figure 3-41, “Arkansas annual average wind power,” Wind Energy Resource Atlas of the United States, <http://rredc.nrel.gov/wind/pubs/atlas/maps/chap3/3-41m.html>.

Figure 5-5(a)
Arkansas Wind Resource Map



The SPP has certified the capacity that Empire counts for both Elk River (7 MW) and Meridian Way (8 MW). For purposes of planning in the IRP, 5% of the nameplate of any new wind resource counts toward the capacity margin calculation.

Wind performance parameters are shown in Table 5-8.

Table 5-8
Wind Performance Parameters

| Parameter | PPA |
|---|------|
| Earliest feasible year of installation | 2017 |
| Size, MW (net) | 100 |
| Energy Cost, \$/MWh (2010 \$)* | 59 |
| Fixed O&M, \$/kW-year | - |
| Variable O&M, \$/MWh (wind regulation only) | 5.13 |
| Equivalent Forced Outage Rate, % | - |
| Capacity Factor, % | 43 |
| *Production tax credit assumed to expire in 2012 which results in an adjustment to the energy cost. | |

5.2.2 Biomass

Biomass electric generation is currently the largest source of renewable energy that is not hydroelectric in the U.S. Biomass means any plant-derived organic matter available on a renewable basis including dedicated energy crops and trees, agricultural food and feed

crops, agricultural crop wastes and residues, wood wastes and residues, aquatic plants, animal wastes, municipal wastes and other waste materials. Waste energy consumption generally falls into categories that include municipal solid waste, landfill gas, and other. Other biomass includes agriculture byproducts/crops, sludge waste, tires, and other biomass solids, liquids, and gases. Biofuels being developed from biomass resources include ethanol, methanol, biodiesel, Fischer-Tropsch diesel, and gaseous fuels such as hydrogen and methane.⁸

Biomass resources available in Missouri, as reported by the National Renewable Energy Laboratory, are shown on Figure 5-6. For the sixteen counties⁹ that comprise the Empire service territory, the biomass resource potential is quite small.

5.2.2.1 Biomass – Chicken/Turkey Waste

Chicken and/or turkey wastes represent a form of biomass that is prevalent in Empire's service territory. Research on studies conducted for facilities in states outside of Missouri concluded that the cost of power from such a facility would be about 8 cents/kWh and that the heat content of the fuel (chicken or turkey waste mixed with a wood waste product) would be 5,000 to 7,000 Btu/lb.¹⁰

5.2.2.2 Biomass – Landfill Gas

The U.S. Energy Information Administration describes landfill gas as follows¹¹:

Municipal solid waste contains significant portions of organic materials that produce a variety of gaseous products when dumped, compacted, and covered in landfills. Anaerobic bacteria thrives in the oxygen-free environment, resulting in the decomposition of the organic materials and the production of primarily carbon dioxide and methane. Carbon dioxide is likely to leach out of the landfill because it is soluble in water. Methane, on the other hand, which is less soluble in water and lighter than air, is likely to migrate out of the landfill. Landfill gas energy facilities capture the methane (the principal component of natural gas) and combust it for energy.



⁸ U.S. Department of Energy, Energy Efficiency and Renewable Energy, "Biomass Topics," <http://www.eere.energy.gov/RE/biomass.html>.

⁹ Barry, Barton, Cedar, Christian, Dade, Dallas, Greene, Hickory, Jasper, Lawrence, McDonald, Newton, Polk, St. Clair, Stone, and Taney.

¹⁰ Mississippi_band_choctaw_tep_nov03.pdf.


¹¹ "Landfill Gas," U.S. Department of Energy – Energy Information Administration, <http://www.eia.doe.gov/cneaf/solar.renewables/page/landfillgas/landfillgas.html>.

**Figure 5-6
Biomass Resources in Missouri**



Source: National Renewable Energy Laboratory


Figure 5-7
MODERN LANDFILL



Source: The National Energy Education Project

Figure 5-8


Landfill Gas Energy Potential Based on 2005-2014 Minimum Gas Flows



5.2.2.3 Biomass – Additional Biomass

Additional biomass has been interpreted by Empire to mean wood waste and municipal solid waste. The U.S. Department of Energy – Energy Information Administration reports that wood waste, consisting of forest lands, private land clearing, urban tree and landscape residues, manufacturing and wood processing wastes, as well as construction and demolition debris can serve as a source of fuel to generate electricity. Municipal solid waste (garbage) can be sorted and the combustible products that are not recycled can be used to generate electricity.

Figure 5-9
Biomass – Wood Waste Facility



The biomass characteristics modeled in the optimization planning are shown on Table 5-9.

Table 5-9
Biomass Performance Parameters

| Parameter | Value |
|--|--------------|
| Earliest feasible year of installation | 2015 |
| Size, MW (net) | 5 |
| Full load heat rate, Btu/kWh | 10,000 |
| Capital cost, \$/kW (2010 \$) | 3766 |
| Fixed O&M, \$/kW-year | 64.45 |
| Variable O&M, \$/MWh | 6.71 |
| Equivalent Forced Outage Rate, % | 5 |
| SO ₂ Emissions, lbs/MMBtu | 0.01 |
| NO _x Emissions, lbs/MMBtu | 0.01 |
| CO ₂ Emissions, lbs/MMBtu | 210 |

5.2.3 Solar

The solar radiation that comes from the sun can be harnessed and converted to electricity in two primary ways: solar photovoltaics (solar PV) and concentrating solar power (CSP). PVs or solar cells change sunlight directly into electricity. A typical PV cell is shown in Figure 5-10. The potential for PV applications as reported by the National Renewable Energy Laboratory is shown in Figure 5-11.

Figure 5-10
Photovoltaic cell





Figure 5-11



Source: National Renewable Energy Laboratory


Concentrating solar power (CSP) is one of the technologies classified as solar thermal. Any solar thermal technology involves a process where the solar energy is used to heat a fluid thereby creating steam that drives a turbine to generate electricity. The existing CSP facilities in the U.S. are found in California, Arizona, and Nevada. An example of a CSP facility is shown in Figure 5-12.

Figure 5-12
Concentrating Solar Power Facility



The potential for concentrating solar power as developed by the National Renewable Energy Laboratory is shown in Figure 5-13. Missouri has lower CSP potential than the potential for PV applications.

Figure 5-13



Source: National Renewable Energy Laboratory

Residential solar PV was considered as a potential program in the DSM analysis. It was screened out as not being cost effective. The data used for modeling solar thermal in the IRP are shown in Table 5-10.

**Table 5-10
Solar Performance Parameters**

| Parameter | Solar Thermal |
|--|----------------------|
| Earliest feasible year of installation | 2015 |
| Size, MW (net) | 100 |
| Capital cost, \$/kW (2010 \$) | 5069.96 |
| Fixed O&M, \$/kW-year | 57.30 |

6.0 Transmission

Empire believes that at least some of the resources that will be required over the planning horizon may have significant transmission costs associated with them. Empire is a member of the Southwest Power Pool (SPP) and, as such, is now reliant on the SPP's determination of which transmission lines will be built and on what schedule. As a member of SPP, Empire is assigned a cost sharing allocation of all lines that are built in the SPP. That cost allocation varies per line.

The SPP conducts three studies directly associated with transmission planning: Large Generation Interconnect Studies, Aggregate Transmission Service Studies, and the SPP Transmission Expansion Plan (STEP). The Large Generation Interconnect Study determines all of the modifications needed to connect a new generator into the transmission system. The Aggregate Transmission Service Studies determine system upgrades required to grant transmission service from a generation source to a load. The STEP determines upgrades required for a reliable transmission system and provides a screening of potential economic projects. Until a specific line is submitted to the SPP, it is not possible to estimate what the actual cost to Empire will be. Therefore, Empire modeled a generic transmission cost adder for each alternative resource examined in this IRP.

As of January 2005, the SPP uses a Federal Energy Regulatory Commission (FERC)-approved process called an Aggregate Transmission Service Study. In this process, SPP combines all long-term point-to-point and all long-term network resource transmission service requests received during a sequential four-month open season into a single aggregate transmission service study. Such an aggregated analysis should result in a more optimal expansion of the SPP transmission system than occurred previously with less aggregated analyses.

Empire actively participates in transmission planning in the SPP through committee membership, attending meetings, participation as a customer and a transmission owner in the development and implementation of all of SPP's transmission studies, and other methods. In two recent cases involving the Open Access Transmission Tariff in the SPP, Empire filed protests with the FERC. These cases involved the OATT "Highway/Byway" cost allocation methodology and the modified transmission planning process referred to as the Integrated Transmission Plan (ITP).

For the purposes of Empire's 2010 IRP, Empire did assign transmission costs on a \$/kW basis for each candidate resource examined in this IRP. The cost was \$90/kW in 2010 \$, escalating at 2.5% per year.

Empire is providing information in this IRP on future transmission projects within Empire's control area that are planned by the SPP in the STEP (see Appendices A and B). This information has been approved by the SPP Board of Directors.

Since not all of Empire’s planned construction projects are accounted for in the STEP, details from Empire’s 2010-2014 Construction Budget for planned transmission and distribution projects are presented in Appendix C. Empire’s 2010-2014 Transmission and Construction Budget includes transmission system additions, transmission system rebuilds, distribution system additions, distribution system rebuilds, and distribution system extensions and service.

Plans for transmission projects within the SPP change frequently as conditions on utility systems, including Empire’s, change.

6.1 Losses

Empire works to reduce system losses in a variety of ways. One is by evaluating losses of power transformers at the time of purchase. As old transformers are replaced, newer transformers have lower levels of losses. Another is by strategically installing capacitor banks on the distribution system. In the late 1990s, Empire undertook a power factor campaign targeting installation of capacitor banks around the system. As can be seen in Table 6-1, Empire’s total system losses have decreased over time – its 2008 electric system losses were less than 7% as compared to losses of over 8% in 1995.

**Table 6-1
Historical System MWh Losses¹²**

| Year | Firm Sales (MWh) | Total Losses (MWh) | % Annual Losses | % 5-Year Rolling Average Losses |
|-------------|-------------------------|---------------------------|------------------------|--|
| 1995 | 3,640,222 | 291,936 | 8.02 | |
| 1996 | 3,886,687 | 312,745 | 8.05 | |
| 1997 | 3,928,767 | 315,441 | 8.03 | |
| 1998 | 4,162,607 | 303,175 | 7.28 | |
| 1999 | 4,163,824 | 304,747 | 7.32 | |
| 2000 | 4,424,768 | 366,028 | 8.27 | 7.79 |
| 2001 | 4,494,199 | 304,067 | 6.77 | 7.53 |
| 2002 | 4,566,262 | 334,287 | 7.32 | 7.39 |
| 2003 | 4,594,856 | 347,676 | 7.57 | 7.45 |
| 2004 | 4,628,759 | 338,035 | 7.30 | 7.45 |
| 2005 | 4,923,486 | 361,858 | 7.35 | 7.26 |
| 2006 | 5,049,599 | 273,483 | 5.42 | 6.99 |
| 2007 | 5,118,460 | 356,396 | 6.96 | 6.92 |
| 2008 | 5,124,277 | 353,204 | 6.89 | 6.78 |

¹² Management Applications Consulting, Inc. “2008 Analysis of System Losses,” October 2009.

6.2 Smart Grid

In March 2010, Empire assembled a team to develop a pilot program that would research and test the available metering products and technologies for an advanced metering infrastructure system such as would be required for Smart Grid. The main benefits of such a system are automated meter reading, on-demand meter reads, and instant outage notification.

The team determined it would first need to visit with and learn from a number of manufacturers, vendors, and other utility companies. It was also necessary to identify the required interfaces and to then define the corporate resources needed to ensure a successful pilot implementation.

The proposed pilot program will include residential, commercial, and industrial customers, and will cover single-phase and three-phase applications. The plan is for the pilot program to implement two different communication technologies via two separate phases. The scale, location, and timeline are pending completion as of September 2010.


7.0 Screening Analysis

Two sets of screening cost curves were developed: one for base environmental costs and one for probable environmental costs. The costs are expressed in nominal dollars. The cost curves presented are for 2015 as that is roughly the first year that Empire needs to consider new supply-side resources. The supply-side alternatives have been ranked using a spreadsheet model that computes levelized busbar costs. The levelized busbar costs considers capital, fuel and operating and maintenance costs for each technology and calculates costs for a range of capacity factors for each technology. These costs do not reflect how a specific technology would operate within the Empire generating system but instead is a stand-alone per unit cost calculated on a cents per kWh basis.

7.1 Base Environmental Costs

The first series of screening curves assumed base environmental costs. Screening curves are presented for baseload resources, intermediate resources, intermittent resources, and peaking resources. Rankings can be deduced by examining the curves at a specific capacity factor.


Base Load Resources: Figure 7-1 shows the screening curve for baseload resources over the range of 50% to 100% capacity factor. Technologies considered included coal, landfill gas, nuclear, IGCC and biomass.



Source: Venytx

Intermediate Load Resources: The cost curve for the intermediate load resources shown on Figure 7-2 considers a capacity factor range of 15% to 40%. The technologies considered were a 1 x 1 combined cycle and wind.


**Figure 7-2
Intermediate Screening Curves – Base Environmental**



Source: Venytx

Intermittent Load Resources: The screening curves for the intermittent load resources shown on Figure 7-3 include solar thermal and wind.


**Figure 7-3
Intermittent Screening Curves – Base Environmental**



Source: Venytx

Peaking Load Resources: The screening curves for the peaking load resources shown in Figure 7-4 include combustion turbines and distributed generation.

**Figure 7-4
Peaking Screening Curves – Base Environmental**




Source: Venytx

7.2 Probable Environmental Costs

The second series of screening curves assumed probable environmental costs. Screening curves are presented for baseload resources, intermediate resources, intermittent resources, and peaking resources. Rankings can be determined through an examination of the relative values of the cost curves.

Ventyx used the non-zero probabilities for each scenario shown in Figure 7-5 to “weight rank” the supply-side alternatives when considering probable environmental costs. The cost of fuel was correlated to the emission costs for each of the scenarios.


**Figure 7-5
Critical Uncertain Factors**



Source: Venytx

Base Load Resources: Figure 7-6 shows the cost curves for baseload resources over the range of 50%-100% capacity factor using the probable environmental costs. Technologies considered included coal, landfill gas, nuclear, IGCC and biomass.


**Figure 7-6
Baseload Screening Curves – Probable Environmental**



Source: Venytx

Intermediate Load Resources: The cost curve for the intermediate load resources shown on Figure 7-7 considers a capacity factor range of 15% to 40%. The technologies considered were combined cycle and wind.


Figure 7-7
Intermediate Screening Curves – Probable Environmental



Source: Venytx

Intermittent Load Resources: The screening curves for the intermittent load resources shown on Figure 7-8 include solar thermal and wind.

Figure 7-8
Intermittent Screening Curves – Probable Environmental




Source: Venytx

Peaking Load Resources: The screening curves for the peaking load resources shown in Figure 7-9 include combustion turbines and distributed generation.

Figure 7-9
Peaking Screening Curves – Probable Environmental

Comparison of Peaking Resources
 Based on 2015 In-Service Date (Probable Environmental)



Source: Venytx

SPP Board of Directors Approved Appendix A projects January 26, 2010

| Project ID | Year | Category | Description | Estimated Cost | Funding Source | Start Date | End Date | Status | Location / Notes | Substation | Priority | |
|------------|-------|---------------------------------|---|---|----------------|------------|----------|----------------------------------|---|---|----------------------------------|---|
| 10560 | 723 | transmission service | Upgrade line to 240 MVA for WE2C | \$8,437,500 | NPPD | 06/01/10 | M | | Sutton 115 kv | Whelan Energy Center 115 kv | 1 | |
| 20252 | 20240 | regional reliability | Install 9 Mvar capacitor bank at Cushing Oil 69kv bus. | \$360,000 | OGFE | 06/01/10 | M | NTC | Cushing Oil 69kv | Tiger Creek 69kv | 1 | |
| 50233 | 30240 | regional reliability | Install 6 Mvar capacitor bank at Tiger Creek 69kv bus. | \$240,000 | OGFE | 06/01/10 | M | NTC | Tiger Creek 69kv | Northwest 345 kv | 1 | |
| 10787 | 614 | sponsored | Install 120 mile 345 kv 2000 amp capacity line from new OG&E Woodward District EHV substation to Northwest substation | | OGFE | 03/30/10 | M | | Woodward District EHV 345 kv | Woodward 345 kv | 1 | |
| 10715 | 614 | sponsored | At Northwest substation, install 3 3000 amp 345 kv breaker and new line terminal. Relocate Spring Creek Line to new sub way, terminate line from Talatoga. Install line relays and coordinate all relays at Northwest Substation. | | OGFE | 03/30/10 | M | | Woodward 345 kv | Woodward 345 kv | 1 | |
| 10789 | 614 | sponsored | Install 345/138 kv transformer. | \$218,000,000 | OGFE | 03/30/10 | M | | Woodward District EHV 345 kv | Woodward EHV 138 kv | 1 | |
| 10790 | 614 | sponsored | Build 5 miles of 138 kv and install terminal equipment. | | OGFE | 03/30/10 | M | | Woodward EHV 138 kv | Woodward EHV 138 kv | 2 | |
| 10791 | 614 | sponsored | Build 5 miles of 138 kv and install terminal equipment. | | OGFE | 03/30/10 | M | | Woodward EHV 138 kv | Woodward EHV 138 kv | 2 | |
| 11132 | 852 | regional reliability | Install Canadian River 345 kv terminal equipment at new Canadian River substation tapoima the Pittsboro-Muskogee line. | \$5,500,000 | OGFE | 06/01/10 | M | NTC | Canadian River 345 kv | Canadian River 345 kv | 1 | |
| 10331 | 310 | zonal - sponsored | Conversion from 69kv to 161kv. | \$1,400,000 | OGFE | 06/01/10 | M | | Fitzhugh 161 kv | Hilbrand 161 kv | 1 | |
| 10393 | 310 | zonal - sponsored | Conversion from 69kv to 161kv. | \$660,000 | OGFE | 12/31/10 | M | | Attus 161 kv | Fitzhugh 161 kv | 1 | |
| 10395 | 310 | zonal - sponsored | Conversion from 69kv to 161kv. | \$2,112,000 | OGFE | 06/01/10 | M | | Little Spadra 161 kv | Attus 161 kv | 1 | |
| 10397 | 309 | zonal - sponsored | Relay upgrade. | \$90,000 | OGFE | 06/01/10 | M | | Park Lane 69 kv | Attus 161 kv | 1 | |
| 10399 | 310 | zonal - sponsored | Conversion from 69kv to 161kv. | \$2,973,000 | OGFE | 10/01/10 | M | | Attus 161 kv | Razorback 161 kv | 1 | |
| 10399 | 310 | zonal - sponsored | Conversion from 69kv to 161kv. | \$500,000 | OGFE | 06/01/10 | M | | Attus 161 kv | Razorback 161 kv | 1 | |
| 10400 | 310 | zonal - sponsored | Conversion from 69kv to 161kv. | \$3,231,000 | OGFE | 10/01/10 | M | | Attus 161 kv | Razorback 161 kv | 1 | |
| 20029 | 10463 | regional reliability | Upgrade wavetrap and switches to 800 A at 3rd St. substation. | \$100,000 | OGFE | 06/01/10 | M | NTC-Modifv Scope | 3rd St 69 kv | 3rd St 69 kv | 1 | |
| 20002 | 10513 | regional reliability | Replace a wave trap, breaker, and increase CT ratio. | \$347,073 | OGFE | 06/01/10 | M | | Russell 138 kv | Russell 138 kv | 1 | |
| 11001 | 758 | zonal - sponsored | Rebuild Sub 902 - Sub 983 69 kv. The purpose of this project is to address maintenance-related issues, not to address violations of reliability criteria. | \$2,500,000 | OPPD | 02/26/10 | M | | SUB 902 69 kv | SUB 983 69 kv | 1 | |
| 50246 | 20234 | regional reliability | Install 12 Mvar capacitor bank at Johnson Corner 115 kv substation. | \$1,000,000 | SEPC | 06/01/10 | M | NTC | Johnson Corner 115 kv | Johnson Corner 115 kv | 1 | |
| 10336 | 296 | regional reliability | Convert Johnson Corner - Pioneer line from 69 kv to 115 kv. | \$10,650,000 | SEPC | 06/01/10 | M | NTC | Johnson 115 kv | Pioneer 115 kv | 1 | |
| 50217 | 30213 | regional reliability | Install 50 Mvar capacitor bank at East Plant 115 kv bus configured as two blocks of 25 Mvar. | \$2,025,000 | SPS | 06/01/10 | M | NTC | East Plant 115 kv | East Plant 115 kv | 1 | |
| 50285 | 30250 | zonal - sponsored | Install 1 stage of 7.2 Mvar | \$238,000 | SPS | 06/01/10 | M | | Perryton Interchange 69 kv | Perryton Interchange 69 kv | 1 | |
| 50289 | 30251 | zonal - sponsored | Install a 7.2 Mvar cap at Castro County 69 kv | \$238,000 | SPS | 06/01/10 | M | | Castro County Interchange 69 kv | Castro County Interchange 69 kv | 1 | |
| 50287 | 30264 | regional reliability | Replace 802A wave trap with 1200A. | \$65,000 | SPS | 06/01/10 | M | | Harrington Station 140 Bus 230 kv | Harrington Station 140 Bus 230 kv | 1 | |
| 10407 | 315 | regional reliability | Upgrade terminal equipment, Rate A & B 185 MVA | \$200,000 | SPS | 06/01/10 | M | NTC | Roosevelt County Interchange 115 kv | Roosevelt County Interchange 115 kv | 1 | |
| 20004 | 10317 | 248 | regional reliability | Install 115/69 kv Graves transformer. | \$10,985,000 | SPS | 06/01/10 | M | | Graves Sub 69 kv | Graves Sub 69 kv | 1 |
| 20004 | 10318 | 248 | regional reliability | Install new 220/115 kv transformer at Wheeler Co (near State Line of Oklahoma and Texas) | \$10,985,000 | SPS | 06/01/10 | M | | Wheeler Interchange 230 kv | Wheeler Interchange 115 kv | 1 |
| 20004 | 10319 | 248 | regional reliability | Build new 17 mile Wheeler Co to Graves 115 kv and modify 69 kv bus. | \$2,000,000 | SPS | 06/01/10 | M | | Wheeler Interchange 115 kv | Wheeler Interchange 230 kv | 1 |
| 20004 | 10300 | 248 | regional reliability | Wheeler County tap. | \$1,000,000 | SPS | 06/01/10 | M | | Wheeler Interchange 230 kv | Wheeler Interchange 230 kv | 1 |
| 20004 | 10801 | 248 | regional reliability | Wheeler County tap. | \$1,000,000 | SPS | 06/01/10 | M | | Wheeler Interchange 230 kv | Wheeler Interchange 230 kv | 1 |
| 20031 | 10335 | 156 | regional reliability | Build new 50 mile Moore County - Hitchland 230 kv rated at 541 MVA. | \$15,094,371 | SPS | 12/31/10 | M | | Moore Co 230 kv | Hitchland 230 kv | 1 |
| 20037 | 10337 | 156 | regional reliability | Add 2-Winding 345/230 kv transformer at Hitchland - 660 MVA. | \$12,877,500 | SPS | 06/01/10 | M | | Hitchland 345 kv | Hitchland 345 kv | 1 |
| 20004 | 10328 | 156 | regional reliability | Build new 24 mile Hitchland - Sherman Tap 115 kv rated at 161 MVA. | \$6,545,000 | SPS | 06/01/10 | M | | Sherman Tap 115 kv | Hitchland 115 kv | 1 |
| 20004 | 10329 | 156 | regional reliability | Add 115 kv line from Sherman to Dallam - 161 MVA. | \$10,771,825 | SPS | 06/01/10 | M | NTC-Modifv Scope | Dallam County Interchange 115 kv | Dallam County Interchange 115 kv | 1 |
| 20004 | 10200 | 156 | regional reliability | Build new 9 mile Hitchland - Texas Co 115 kv rated at 161 MVA. | \$5,132,829 | SPS | 06/01/10 | M | | Texas County Interchange 115 kv | Hitchland 115 kv | 1 |
| 20004 | 10401 | 156 | regional reliability | Add 2-Winding 230/115 kv transformer at Hitchland - 252 MVA. | \$3,915,701 | SPS | 06/01/10 | M | | Hitchland 115 kv | Hitchland 115 kv | 1 |
| 20004 | 10802 | 156 | regional reliability | Tap the Texas County to Hansford line. | \$1,000,000 | SPS | 06/01/10 | M | | Hansford 315 kv | Hansford 315 kv | 1 |
| 20004 | 10805 | 156 | regional reliability | Tap the Texas County to Hansford line. | \$1,000,000 | SPS | 06/01/10 | M | | Texas County Interchange 115 kv | Hitchland 115 kv | 1 |
| 20031 | 10704 | 554 | regional reliability | Build new 35 mile Dallam - Channing 115 kv using 795 ACSR. | \$27,452,677 | SPS | 12/31/10 | M | | Dallam County Interchange 115 kv | Channing 115 kv | 1 |
| 20031 | 10705 | 554 | regional reliability | Convert 15 mile Channing - Tabasco line from 69 kv to 115 kv with 795 ACSR. | \$1,987,500 | SPS | 12/31/10 | M | | Channing 115 kv | Tabasco 115 kv | 1 |
| 20031 | 10706 | 554 | regional reliability | Convert 30 mile Tabasco - Northwest Interchange line from 69 kv to 115 kv with 795 ACSR. | \$5,600,000 | SPS | 12/31/10 | M | | Tabasco 115 kv | Northwest Interchange 115 kv | 1 |
| 20031 | 11018 | 773 | regional reliability | Add 2nd 230/115 kv transformer at Roosevelt. | \$5,670,000 | SPS | 06/01/10 | NTC | Roosevelt County Interchange 115 kv | Roosevelt County Interchange 230 kv | 2 | |
| 11026 | 776 | regional reliability | Build new 1 mile Deaf Smith to Panola 115 kv line. | \$600,000 | SPS | 06/01/10 | M | NTC | Panola Energy Substation, Hansford 115 kv | Panola Energy Substation, Hansford 115 kv | 1 | |
| 11027 | 778 | regional reliability | Reconductor 2.24 mile East Plant - Manhattan 115 kv line. | \$1,100,000 | SPS | 06/01/10 | M | NTC | East Plant Interchange 115 kv | Manhattan 115 kv | 1 | |
| 11032 | 782 | regional reliability | Rebuild 4 mile Osage Switching Station - South Georgia Interchange 115 kv with 795 ACSR. | \$1,897,500 | SPS | 06/01/10 | NTC | South Georgia Interchange 115 kv | Osage Switching Station 115 kv | 1 | | |
| 11034 | 821 | regional reliability | Reconductor 2 mile Osage Switching Station - Randall County Interchange 115 kv line with 795 ACSR. | \$1,145,000 | SPS | 06/01/10 | NTC | Osage Switching Station 115 kv | Randall County Interchange 115 kv | 1 | | |
| 11097 | 830 | regional reliability | Reconductor 1.6 mile Manhattan - Randall County Interchange 115 kv line with 795 ACSR. | \$900,000 | SPS | 06/01/10 | NTC | Manhattan Tap 115 kv | Randall County Interchange 115 kv | 1 | | |
| 11121 | 851 | regional reliability | Replace existing wavetrap with 1200 A unit. | \$225,000 | SPS | 06/01/10 | NTC | Harrington Mio 230 kv | Randall Co 230 kv | 1 | | |
| 10439 | 342 | regional reliability - non OATT | Upgrade the bus to 1200 amp and reconect CT ratios to 1200's. | \$2,200,000 | SWPPA | 01/01/10 | 06/01/10 | | Bull Shoals 161 kv | Bull Shoals 161 kv | 1 | |
| 10725 | 101 | regional reliability - non OATT | Replace Bufalua 15/138 kv transformer with 200 MVA unit. | \$3,000,000 | SWPPA | 10/01/10 | M | | Bufalua 161 kv | Bufalua 138 kv | 1 | |
| 20003 | 20265 | 30079 | regional reliability | Install 12 Mvar capacitor at Carter Jct which makes a total of 24 Mvar. | \$334,000 | WFEC | 06/01/10 | M | 02/13/08 | Carter 69 kv | Carter 69 kv | 1 |
| 20030 | 30180 | 30172 | regional reliability | Install 12 Mvar capacitor at Eagle Chief Southwest 69 kv bus. | \$330,000 | WFEC | 06/01/10 | M | 01/27/09 | Eagle Chief 69 kv | Eagle Chief 69 kv | 1 |
| 20003 | 13176 | 138 | regional reliability | Upgrade WFEC Woodward sub to 1200 A and reconductor from 336.4 ACSR to 795 ACSR, new rating 5/11/10 MVA. | \$1,650,000 | WFEC | 06/01/10 | M | 02/13/08 | OGF Woodward 69 kv | WFEC Woodward 69kv | 1 |
| 20030 | 10305 | 239 | regional reliability | Build new 4 mile AEP Snyder - WFEC Snyder 138 kv. | \$3,373,000 | WFEC | 12/31/10 | M | 01/27/09 | AEP Snyder 138 kv | WFEC Snyder 138 kv | 1 |
| 20003 | 10307 | 241 | regional reliability | Rebuild 2 mile Anadarko - Georgia 138 kv line from 556 to 1113 ACSR. | \$1,145,000 | WFEC | 06/01/10 | M | 01/13/09 | Anadarko 138 kv | Georgia 138 kv | 1 |
| 20003 | 10308 | 242 | regional reliability | Elmore - Panol Rebuild 3/0 to 336 ACSR - 10.8 miles. | \$3,240,000 | WFEC | 06/01/10 | M | 01/13/08 | Elmore 69 kv | Panola 69 kv | 1 |
| 20003 | 10309 | 243 | regional reliability | Convert 5 mile Oklahoma University (OU) Switch - Godsoy from 69 kv to 138 kv. | \$2,153,000 | WFEC | 06/01/10 | M | 01/13/08 | OU Switchyard 138 kv | Godsoy 138 kv | 1 |
| 20003 | 10310 | 243 | regional reliability | Convert 5 mile Godsoy - Canadian Switch from 69 kv to 138 kv. | \$2,250,000 | WFEC | 06/01/10 | M | 01/13/08 | Godsoy 138 kv | Canadian SW 138 kv | 1 |
| 20003 | 10311 | 243 | regional reliability | Install 135/62 kv transformer at Oklahoma University. | \$5,000,000 | WFEC | 06/01/10 | M | 01/13/08 | OU Switchyard 138 kv | OU Switchyard 69 kv | 1 |
| 20003 | 10174 | 136 | regional reliability | Build new 10 mile Meeker - Hammett 138 kv and install terminal equipment. | \$6,674,000 | WFEC | 06/01/10 | M | 01/13/08 | Meeker 138 kv | Hammett 138 kv | 1 |
| 20003 | 10175 | 137 | regional reliability | Reconductor 16.9 mile Wixom - Hazleton Junction 69 kv from 110 ACSR to 336.4 ACSR for new rating of 5/365 MVA. | \$5,379,750 | WFEC | 06/01/10 | M | 01/13/08 | Wixom 69 kv | Hazleton 69 kv | 1 |
| 20003 | 10401 | 311 | regional reliability | Convert 5 mile Acme - Franklin from 69 kv to 138 kv. | \$2,065,000 | WFEC | 06/01/10 | M | 01/13/08 | Franklin SW 138 kv | ACME SW 138 kv | 1 |
| 20003 | 10402 | 311 | regional reliability | Convert 4 mile West Norman - Acme from 69 kv to 138 kv. | \$1,601,000 | WFEC | 06/01/10 | M | 01/13/08 | ACME 138 kv | West Norman 138 kv | 1 |
| 20003 | 10403 | 311 | regional reliability | Convert 5 mile OU - West Norman from 69 kv to 138 kv. | \$1,677,000 | WFEC | 06/01/10 | M | 01/13/08 | West Norman 138 kv | OU SW 138 kv | 1 |
| 20030 | 10794 | 616 | regional reliability | Convert 11 mile Dover Southwest - Dover from 69 kv to 138 kv and install terminal equipment at Dover Southwest. | \$5,765,600 | WFEC | 06/01/10 | M | 01/27/09 | Dover SW 138 kv | Dover 138 kv | 1 |
| 20030 | 10795 | 616 | regional reliability | Convert 16.5 mile Dover - Twin Lakes from 69 kv to 138 kv. | \$5,315,750 | WFEC | 06/01/10 | M | 01/27/09 | Dover 138 kv | Twin Lakes 138 kv | 1 |
| 20030 | 10796 | 616 | regional reliability | Convert 7.5 mile Twin Lakes - Cashion from 69 kv to 138 kv. | \$3,164,000 | WFEC | 06/01/10 | M | 01/27/09 | Twin Lakes 138 kv | Cashion 138 kv | 1 |
| 20030 | 10797 | 616 | regional reliability | Build new 7 mile WFEC Twin Lakes - OG&E Crescent 138 kv. | \$3,937,500 | WFEC | 06/01/10 | M | 01/27/09 | Twin Lakes 138 kv | Crescent 138 kv | 1 |
| 20030 | 10798 | 617 | regional reliability | Upgrade CT's at Lake Creek Carter Branch to 600's. | \$120,000 | WFEC | 06/01/10 | M | 01/27/09 | Carter Jct 69 kv | Lake Creek 69 kv | 1 |
| 20030 | 10799 | 136 | regional reliability | Reconductor 3.7 miles of 10 ACSR to 556.5 ACSR from Lindsay to Lindsay Southwest 69 kv. | \$1,149,750 | WFEC | 06/01/10 | M | 01/27/09 | Lindsay 69 kv | Lindsay SW 69 kv | 1 |
| 20030 | 10173 | 136 | regional reliability | Reconductor 6.9 miles from 3/0 ACSR to 336.4 ACSR from Bradley to Rush Springs 69 kv. | \$2,128,750 | WFEC | 06/01/10 | M | 01/27/09 | Bradley 69 kv | Rush Springs 69 kv | 1 |
| 19989 | 10179 | 140 | regional reliability | Reconductor 3.8 miles from 3/0 ACSR to 795 ACSR, Rate A=51MVA, Rate B=106MVA. | \$912,000 | WFEC | 06/01/10 | M | 02/02/07 | ACME 69 kv | W Norman 69 kv | 1 |
| 20006 | 10220 | 171 | regional reliability | Rebuild Weaver-Rose Hill 69 kv. | \$2,242,500 | WR | 12/01/10 | M | 01/13/08 | Weaver 69 kv | Rose Hill 69 kv | 1 |
| 20006 | 20005 | 20005 | regional reliability | Add 10.7 Mvar capacitor bank at Trans Canada 115 kv instead of Seneca. | \$658,600 | WR | 06/01/10 | 06/01/10 | NTC-Modifv Timing & Scope | Seneca 115 kv | Seneca 115 kv | 1 |
| 19986 | 50583 | 30252 | zonal - sponsored | Add 76.8 Mvar bank at Benton | \$3,072,000 | WR | 12/01/10 | M | | Benton 138 kv | Benton 138 kv | 1 |
| 19986 | 50585 | 30082 | zonal reliability | Install switched capacitor bank | \$500,000 | WR | 6/1/2010 | M | 02/02/07 | 3rd & VanBuren 115 kv | Nortonville 115 kv | 1 |
| 19986 | 50583 | 30057 | zonal reliability | Install 15 Mvar capacitor at Nortonville 69 kv (bus #533451). | \$715,000 | WR | 6/1/2010 | M | 02/02/07 | Nortonville 69 kv | Nortonville 69 kv | 1 |
| 20059 | 10231 | 182 | regional reliability | Rebuild approximately 7.5 miles Chase - White Junction 69 kv line. Replace existing 2/0 copper conductor to achieve a minimum 600 amp emergency rating. | \$5,184,701 | WR | 06/01/10 | M | 09/18/09 | Chase 69 kv | | |

SPP Board of Directors Approved Appendix A projects January 26, 2010

| | | | | | | | | | | | |
|------------------|-------|-------|-------------------------|--|--------------|-------|----------|----------|----------------------------------|----------------------------------|-------|
| | 10425 | 328 | zonal - sponsored | Install New 2nd 138/115 KV transformer at Moundridge (57429/57013). Operate both 138/115 KV transformers normal closed. | \$1,700,000 | WR | 06/01/10 | | Moundridge 138 kv | Moundridge 115 kv | 2 |
| 20006 | 10219 | 170 | regional reliability | 3.53 miles Arno - Ford Junction Substation 115 kv. | \$3,639,977 | WR | 06/01/10 | | Arno 115 kv | Ford Junction | 1 |
| 20033 | 10809 | 621 | regional reliability | Upgrade JE-C - E Mannheim 230 kv line to 100 deg C operation by raising structures. | \$17,095,938 | WR | 06/01/10 | | E Mannheim 230 kv | JEC 230 kv | 1 |
| 20033 | 10613 | 625 | regional reliability | Rebuild the 2.37 mile Chishom - Ripley 69 kv line using single 1192.5 ACSR. | \$2,255,250 | WR | 06/01/10 | | Chishom 69 kv | Ripley 69 kv | 1 |
| 20019 | 10739 | 578 | regional reliability | New 115 kv Line from Knob Hill to Kansas/Nebraska state line | \$25,751,000 | WR | 06/01/10 | | Knob Hill 115 kv | Shree City 115 kv | 1 |
| 20019 | 10738 | 577 | regional reliability | Rebuild 10.3 mile line between Kelly and South Geneva. | \$5,925,000 | WR | 12/31/10 | | Kelly 115 kv | South Geneva 115 kv | 1 |
| 20033 | 10765 | 599 | regional reliability | Year down and rebuild the 2.72 mile Tecumseh Hill - 27th & Croco 115 kv line as a single circuit. | \$3,860,000 | WR | 12/31/10 | | Tecumseh Hill 115 kv | 27th & Crocos 115 kv | 1 |
| 20059 | 50235 | 30228 | transmission service | Replace Jumpers to achieve a minimum 600 amp emergency rating. | \$115,000 | WR | 06/01/10 | | Toga 69 kv | Chanute TAP 69 kv | 1 |
| 20059 | 50237 | 30229 | transmission service | Replace Disconnect Switches, WaveTrap, Breaker, Jumpers with a minimum 2000 amp emergency rating equipment | \$600,000 | WR | 06/01/10 | | Coffeyville Tap 138 kv | Clearing 138 kv | 1 |
| 20059 | 50238 | 30224 | transmission service | Rebuild approximately 7 miles of line with 954 kcmil ACSR to achieve a minimum 1200 amp emergency rating. | \$3,335,500 | WR | 07/01/10 | | Green 69 kv | Coffey County No. 4 Vernon 69 kv | 1 |
| 20059 | 10711 | 561 | transmission service | Replace Disconnect Switches, WaveTrap, Breaker, Jumpers a minimum 2000 amp emergency rating. | \$5,613,000 | WR | 06/01/10 | | Evans Energy Center South 138 kv | Lakeridge 138 kv | 1 |
| Year 2011 | | | | | | | | | | | |
| | 10367 | 283 | Inter-regional | The proposed line connects to the Morgan - Neosho 345kv line near the Kansas border - This is the proposed Blackberry sub. From Blackberry the 108 mile 345kv line connects to Chouteau 345 kv bus which connects via a 5 mile 345kv circuit to GRDA 1 bus (GRDA 2 gen). At the Chouteau 345kv bus a 345/161 transformer connects to Chouteau 161kv sub. | | AECI | 06/01/12 | | Blackberry 345 kv | Sportsman Acres 345 | 1 |
| | 10368 | 283 | Inter-regional | The proposed line connects to the Morgan - Neosho 345kv line near the Kansas border - This is the proposed Blackberry sub. From Blackberry the 108 mile 345kv line connects to Sportsman Acres 345 kv bus which connects via a 5 mile 345kv circuit to GRDA 1 bus (GRDA 2 gen). At the Sportsman Acres 345kv bus a 345/161 transformer 161 kv line connects to Chouteau 161kv sub. | | AECI | 02/01/11 | | Sportsman Acres 345 | GRDA 1 345 kv | 1 |
| | 10369 | 283 | Inter-regional | The proposed line connects to the Morgan - Neosho 345kv line near the Kansas border - This is the proposed Blackberry sub. From Blackberry the 108 mile 345kv line connects to Sportsman Acres 345 kv bus which connects via a 5 mile 345kv circuit to GRDA 1 bus (GRDA 2 gen). At the Sportsman Acres 345kv bus a 345/161 transformer 161 kv line connects to Chouteau 161kv sub. | \$57,000,000 | AECI | 02/01/11 | | Sportsman Acres 345 kv | Sportsman Acres 161 kv | 1 |
| | 10916 | 283 | Inter-regional | The proposed line connects to the Morgan - Neosho 345kv line near the Kansas border - This is the proposed Blackberry sub. From Blackberry the 108 mile 345kv line connects to Sportsman Acres 345 kv bus which connects via a 5 mile 345kv circuit to GRDA 1 bus (GRDA 2 gen). At the Sportsman Acres 345kv bus a 345/161 transformer 161 kv line connects to Chouteau 161kv sub. | | AECI | 02/01/11 | | Sportsman Acres 345 kv | Sportsman Acres 161 kv | 2 |
| | 10781 | 283 | Inter-regional | The proposed line connects to the Morgan - Neosho 345kv line near the Kansas border - This is the proposed Blackberry sub. From Blackberry the 108 mile 345kv line connects to Sportsman Acres 345 kv bus which connects via a 5 mile 345kv circuit to GRDA 1 bus (GRDA 2 gen). At the Sportsman Acres 345kv bus a 345/161 transformer 161 kv line connects to Chouteau 161kv sub. | | AECI | 02/01/11 | | Sportsman Acres 161kv | Chouteau 161 kv | |
| | 10459 | 349 | Generation interconnect | Replace breaker 3310. | \$277,000 | AEP | 12/31/11 | | Bann 138 kv | Red Springs REC 138 kv | 1 |
| | 10446 | 349 | Generation interconnect | Reconductor and convert line to 138 kv and replace switches at Ashdown REC | \$7,610,000 | AEP | 06/01/11 | | Ashdown REC Millwood 138 kv | Okay 138 kv | 1 |
| | 10447 | 349 | Generation interconnect | Reconductor line and convert line to 138 kv. Convert Patterson station to breaker-and-a-half configuration. | \$11,431,000 | AEP | 12/31/11 | | Ashdown REC Millwood 138 kv | Patterson 138 kv | 1 |
| | 10448 | 349 | Generation interconnect | Build new McNab-Turk 115 kv line. | \$1,773,000 | AEP | 12/31/11 | | McNab REC 115 kv | Turk 115 kv | 1 |
| | 10451 | 349 | Generation interconnect | Convert 115-69 kv station to 138-69 kv. | \$3,266,000 | AEP | 12/31/11 | | Okay 69 kv | Okay 138 kv | 1 |
| | 10452 | 349 | Generation interconnect | Build two mile, 138 kv, 1590ACSR line section from Turk Sub to existing Okay-Hope 115 kv line and rebuild twelve miles of 115 kv line to Okay Sub to 138 kv, 1590 ACSR, to form a Turk-Okay 138 kv line. | \$8,170,000 | AEP | 12/31/11 | | Okay 138 kv | Turk 138 kv | 1 |
| | 10457 | 349 | Generation interconnect | Build Turk 138-115 kv station and relocate autotransformer (and spare) from Patterson to this new Turk station. | \$7,806,000 | AEP | 12/31/11 | | Turk 115 kv | Turk 138 kv | 1 |
| 20027 | 10586 | 452 | regional reliability | Replace one breaker and four switches. | \$390,000 | AEP | 06/01/11 | | Whitney 138 kv | Whitney 69 kv | 1 & 2 |
| 20016 | 10449 | 349 | transmission service | Reconductor about 0.5 miles of 666 ACSR with 1590 ACSR | \$540,000 | AEP | 12/31/11 | | McNab REC 115 kv | Turk 115 kv | 1 |
| 20016 | 10450 | 349 | transmission service | Reconductor 3.35 miles of 666 ACSR with 1590 ACSR | \$2,170,000 | AEP | 12/31/11 | | McNab REC 115 kv | Hoge 115 kv | 1 |
| 20048 | 10579 | 446 | transmission service | Rebuild approximately 13 miles of line with 1590 ACSR to achieve a minimum 2000 Amp emergency rating | \$13,100,000 | AEP | 06/01/11 | | North Bartlesville 138 kv | Coffeyville Tap 138 kv | 1 |
| 20048 | 10588 | 454 | transmission service | Rebuild approximately 8.5 miles of line with 1590 ACSR to achieve a minimum 2000 Amp emergency rating & reset relays at Bartlesville southeast accordingly. | \$8,400,000 | AEP | 06/01/11 | | Bartlesville Southeast 138 kv | North Bartlesville 138 kv | 1 |
| 19970 | 10373 | 287 | zonal - sponsored | Build 12 miles of 138 kv from Elotte - Chireno | \$11,299,000 | DETEC | 06/01/11 | | Elotte 138 kv | Chireno 138 kv | 1 |
| 19970 | 10544 | 459 | transmission service | Replace Auto transformer at Oronogo 115 with 150 MVA rated Auto transformer due to increased generation available | \$6,600,000 | EDE | 06/01/11 | | ORC110.5 181 kv | ORC110.5 69 kv | 1 |
| 19970 | 10730 | 352 | transmission service | Reconductor 11.9 miles of Oronogo Jct. to Riverton 151kv Ckt. 1 from 556 ACSR to 795 ACSR, change CT settings @ Oronogo, and replace wave trap. | \$5,750,000 | EDE | 06/01/11 | | Sub 110 - Oronogo Jct. | Sub 167 - Riverton | 1 |
| | 10370 | 284 | Inter-regional | Entergy Planning has identified this proposed project as installing a new switching station, Grandview, on the existing 161 kv line between Table Rock Dam and Eureka Springs substation and constructing a new 161 kv line between Grandview and the existing Osage Creek substation. | \$6,000,000 | EES | 06/01/11 | 06/01/10 | Grandview 161 kv | Osage 161 kv | 1 |
| 20034 | 10830 | 634 | regional reliability | Tap the Montrose - LomaVista 161 kv Line into KC South 161 kv substation. This project is an alternative to replace the reconductor project of the Duncan Rd - Blue Spring East and Martin City - Grandview East 161 kv lines. | \$2,369,625 | GMO | 11/01/11 | | Loma Vista 161 kv | KC South 161 kv | 1 |
| | 10431 | 334 | zonal - sponsored | Radial Line From Greenwood to a new distribution sub at Lone Jack | \$7,096,402 | GMO | 06/01/11 | | Lone Jack 161 kv | Greenwood 161 kv | 1 |
| | 10428 | 331 | zonal - sponsored | Tap Clinton AECI 1300071 to Clinton MIPU 1541242) with new Clinton bus and tie in existing Clinton transformer into new bus. | \$2,418,750 | GMO | 06/01/11 | | Clinton 161 kv | Clinton 161 kv | 1 |
| 20034 | 10854 | 650 | regional reliability | Tap Stilwell - Archie Junction 161 kv line into South Harper 161 kv sub and make it two new 161 kv sections. Stilwell - South Harper and Archie Junction - South Harper. | \$2,259,673 | GMO | 06/01/11 | | Stilwell 161 kv | Archie 161 kv | 1 |
| | 50194 | 30187 | regional reliability | Add 20 Mvar capacitor bank at Adrian 161 kv. | \$810,000 | GMO | 06/01/11 | 06/01/11 | Adrian 161kv | NTC | |
| | 50224 | 30220 | regional reliability | Add 50 Mvar cap bank at Blue Springs East | \$1,400,000 | GMO | 06/01/11 | | Blue Springs East 161 kv | | |
| 20053 | 10361 | 278 | zonal - sponsored | 161KV Tap of Grandview to Grandview East | \$963,668 | GMO | 06/01/11 | | Grandview 161 kv | Sampson 161 kv | 1 |
| | 10366 | 278 | zonal - sponsored | 161KV Tap of Conover to Grandview East | \$0 | GMO | 06/01/11 | | Grandview 161 kv | Grandview East 161 kv | 1 |
| | 10355 | 273 | zonal - sponsored | 161KV Tap of Nashua to Liberty West | \$1,350,000 | GMO | 06/01/11 | | Liberty West 161 kv | Liberty West 161 kv | 1 |
| | 10357 | 273 | zonal - sponsored | 161KV Tap of Nashua to Liberty West | \$0 | GMO | 06/01/11 | | Nashua 161 kv | Cookingham 161 kv | 1 |
| 20056 | 50227 | 30223 | transmission service | Reconductor line from 1192 ACSR to 1192 ACSS and rebuild the line terminals to 2000 amp capacity | \$4,400,000 | GMO | 06/01/11 | | ST Joe 161 kv | Cook 161 kv | 1 |
| 20001 | 50292 | 30096 | regional reliability | Install 21's Mvar capacitor at Jay 69 kv substation. | \$930,000 | GRDA | 06/01/11 | | Jay 69 kv | NTC-Modify Timing | 1 |
| | 10390 | 302 | zonal - sponsored | Tap the GRDA 1-Flint Creek 345 kv line and build a 345/161 transformer. Then build a 161 kv line down to Sloom Springs. | \$8,019,000 | GRDA | 12/01/11 | | Sloom Springs Tap 345 kv | Sloom Springs Tap 161 kv | 1 |
| 20050 | 10512 | 354 | regional reliability | Rebuild approximately 22 miles of line with 795 ACSR. | \$10,450,000 | GRDA | 06/01/11 | | Kerr 161 kv | Penasco 115 kv | 1 |
| 20051 | 50221 | 30217 | transmission service | Add 20 Mvar cap bank to make a total of 70 Mvar at Crane 161kv | \$50,000 | KCPD | 06/01/11 | | Crane 161 kv | | |
| 20051 | 50222 | 30218 | transmission service | Reconductor line and upgrade terminal equipment for 2000 amps | \$2,200,000 | KCPD | 06/01/11 | | Stilwell 161 kv | Rede 161 kv | 1 |
| 20032 | 50184 | 30176 | regional reliability | Install 5 Mvar Cap at Kinsey 115 kv. | \$300,000 | MIDW | 06/01/11 | 06/01/11 | Kinsey 115 kv | NTC-Modify Scope | |
| | 50197 | 30190 | regional reliability | Install 5 Mvar capacitor bank at Pawnee 115 kv. | \$300,000 | MIDW | 06/01/11 | | Pawnee 115 kv | | |
| 20027 | 50296 | 30096 | regional reliability | Add 5 Mvar capacitor at Russell 115 kv. | \$1,350,000 | MWAC | 06/01/11 | | Russell 115 kv | NTC | 1 |
| | 50211 | 30204 | regional reliability | Install 10.8 Mvar capacitor bank at Valentine 115 kv. | \$3,000,000 | NPPD | 06/01/11 | 06/01/11 | Valentine 115 kv | NTC | |
| | 10924 | 609 | regional reliability | Build new 161-kv substation Sub 1341. Remove 0.06 mile of 161 kv line from Sub 1251- Sub 1305. | | OPPD | 12/31/11 | | Sub 1341 161 kv | Sub 1251 161 kv | 1 |
| | 10925 | 609 | regional reliability | Tap 161-kv line from Sub 1251 to Sub 1305 and route it into and out of new 161-kv substation Sub 1341. | \$16,300,000 | OPPD | 12/31/11 | | Sub 1341 161 kv | Sub 1305 161 kv | 1 |
| | 10926 | 609 | regional reliability | Tap 161-kv line from Sub 1251 to Sub 1305 and route it into and out of new 161-kv substation Sub 1341. | | OPPD | 12/31/11 | | Sub 1341 161 kv | | 1 |
| | 50145 | 304 | zonal - sponsored | Add 9 Mvar of emergency capacitors | \$584,000 | OGE | 03/01/11 | | Nicol industries 138 kv | | |
| | 10382 | 310 | zonal - sponsored | Conversion from 69kv to 161kv | \$254,000 | OGE | 03/31/11 | | Great Lakes Carbon 161 kv | Altus 161 kv | 1 |
| | 10384 | 310 | zonal - sponsored | Conversion from 69kv to 161kv | \$2,944,000 | OGE | 03/31/11 | | ago 161 kv | Naok 161 kv | 1 |
| | 10395 | 310 | zonal - sponsored | Conversion from 69kv to 161kv | \$624,000 | OGE | 03/31/11 | | Naok 161 kv | Great Lakes Carbon 161 kv | 1 |
| | 11190 | 865 | zonal - sponsored | Three terminals line will be upgraded to 2000A with breakers. Limiting equipment will be 795A/33 conductor | \$1,300,000 | OGE | 04/01/11 | | Remington 138 kv | Remington Park 138 kv | 1 |
| 20017 | 50166 | 30158 | transmission service | Replace 4.85 miles of line with 477A/33 | \$1,400,000 | OGE | 06/01/11 | | Rocky Point 69 kv | Armore 69 kv | 1 |
| 20017 | 50179 | 30162 | transmission service | Replace wave trap 80GA at Lintray | \$50,000 | OGE | 06/01/11 | | Sunshine 138 kv | Lintray 138 kv | 1 |
| 20017 | 50167 | 30159 | transmission service | Replace Differential Relaying | \$300,000 | OGE | 06/01/11 | | Llano 138 kv | Heaton Tap 138 kv | 1 |

SPP Board of Directors Approved Appendix A Projects January 26, 2010

| | | | | | | | | | | | | |
|-------|---------------|---------------------------------|---------------------------------|---|--------------|------|----------|----------|-------------------|---|---|-------|
| 20029 | 10792 & 10793 | 615 | regional reliability | Convert 13.64 miles of 69 kv to 138 kv from Crescent to Cottonwood Creek and install terminal equipment at Cottonwood Creek, completing loop from Crescent to Twin Lakes (WFEC). | \$5,404,250 | OGE | 06/01/11 | M | 01/27/09 | Crescent 138 kv | Cottonwood Creek 138 kv | 1 |
| 11188 | 896 | zonal - sponsored | zonal - sponsored | Bell Cow Sub is Cleared until 2011. Install Bell Cow sub and associated lines, remove changer sub. | | OGE | 06/30/11 | M | | Keystone West 138 kv | Bell Cow 138 kv | 1 |
| 11189 | 896 | zonal - sponsored | zonal - sponsored | Bell Cow Sub is Cleared until 2011. Install Bell Cow sub and associated lines, remove changer sub. | | OGE | 05/30/11 | M | | Warner 138 kv | Bell Cow 138 kv | 1 |
| 10731 | 304 | zonal - sponsored | zonal - sponsored | At Caney Creek remove 2 existing line terminals to the north and expand the 138 kv bus north into a ring bus | | OGE | 06/01/11 | M | | Caney Creek 138 kv | Caney Creek 138 kv | 1 |
| 10732 | 304 | zonal - sponsored | zonal - sponsored | Construct 2.5 miles of 138 kv of 75FA533 line from the new Johnson County sub to Caney Creek. | | OGE | 06/01/11 | M | | Johnson County 138 kv | Caney Creek 138 kv | 1 |
| 10733 | 304 | zonal - sponsored | zonal - sponsored | Build a new 345 kv substation in the Sunnyside to Pittsburg line. Install a 400 MVA transformer with 3-345kv breakers in a ring bus and 4-138kv breakers in a ring bus at new Johnson County sub. | | OGE | 06/01/11 | M | | Johnson County 345 kv | Johnson County 138 kv | 1 |
| 10734 | 304 | zonal - sponsored | zonal - sponsored | Replace relays at Sunnyside 345 kv | \$32,975,000 | OGE | 06/01/11 | M | | Sunnyside 345 kv | Johnson County 345 kv | 1 |
| 10735 | 304 | zonal - sponsored | zonal - sponsored | Replace relays at Pittsburg 345 kv | | OGE | 06/01/11 | M | | Johnson County 345 kv | Pittsburg 345 kv | 1 |
| 10820 | 304 | zonal - sponsored | zonal - sponsored | Tap the MillCreek to Russell 138 kv into the new Johnson County substation | | OGE | 06/01/13 | M | | Johnson County 138 kv | MillCreek | 1 |
| 10821 | 304 | zonal - sponsored | zonal - sponsored | Tap the MillCreek to Russell 138 kv into the new Johnson County substation and reconductor Jonson County to Russell Sub with 795 FA533 | | OGE | 06/01/13 | M | | Johnson County 138 kv | Russelt 138 kv 138 kv | 1 |
| 10747 | 582 | zonal - sponsored | zonal - sponsored | Install Terminal equipment to remove Three terminal line | \$1,900,000 | OGE | 06/01/11 | M | | Cottonwood Creek 138 kv | Arcadia 138 kv | 1 |
| 10748 | 582 | zonal - sponsored | zonal - sponsored | Install Terminal equipment to remove Three terminal line | | OGE | 06/01/11 | M | | Arcadia 138 kv | Garber 138 kv | 1 |
| 20041 | 10946 | 709 | Balanced Portfolio | Tap Lawton East Side to Cimarron 345 kv line at Anoaiko and build substation. Install a 345/138 kv transformer in substation. | \$15,000,000 | OGE | 12/31/11 | M | 06/19/09 | Anoaiko (Graecmont) 345 kv | Graecmont 138 kv | 1 |
| 20002 | 10514 | 396 | regional reliability | Install a 138 kv breaker at Boodle to close the normally open switch. Breaker connects 515155 Boodle 138 kv to 515156 Boodle 138 kv. | \$1,000,000 | OGE | 10/01/11 | M | 02/13/08 | Boodle 138 kv | Boodle 138 kv | 1 |
| 50247 | 30235 | regional reliability | regional reliability | Install 2nd 115 kv 12 Mvar cap bank at Johnson corner substation. | \$650,000 | SEPC | | 06/01/11 | NTC | Johnson Corner 115 kv | | 1 |
| 10214 | 165 | zonal - sponsored | zonal - sponsored | Build new 35 mile Phillipsburg - Rhoades 115 kv. | \$10,500,000 | SEPC | 09/01/11 | M | | Phillipsburg 115 kv | Rhoades 115 kv | 1 |
| 20007 | 10215 | 166 | regional reliability | Rebuild 12 mile Holcomb - Plymouth 115 kv | \$3,650,000 | SEPC | 09/01/11 | M | 02/13/08 | Holcomb 115 kv | Plymouth 115 kv | 1 |
| 10480 | 357 | regional reliability | regional reliability | Rebuild 15 mile Holcomb - Pioneer Tap 115kv | \$3,250,000 | SEPC | 09/01/11 | M | 09/18/08 | Pioneer Tap 115 kv | | 1 |
| 50259 | 30246 | regional reliability | regional reliability | Install 2 blocks of 7.2 Mvar capacitor bank at Kress 69 kv | \$883,300 | SPS | | 06/01/11 | NTC | Kress Rural 69 kv | | 1 |
| 11040 | 791 | regional reliability | regional reliability | Tap the Potter interchance - Plant X Station 230 kv line from new Newhart Substation Install 230/115 kv 150/173 MVA transformer. | \$11,280,000 | SPS | 12/22/11 | 06/01/10 | NTC | Newhart 230 kv | Newhart 115 kv | 1 |
| 11090 | 824 | regional reliability | regional reliability | New 345/230 kv transformer rated 515/560 MVA at Hobbs interchange. | \$11,280,000 | SPS | 12/22/11 | 06/01/10 | NTC | Hobbs interchange 230 kv | Hobbs interchange 345 kv | 1 |
| 11091 | 824 | regional reliability | regional reliability | New 345/138 kv transformer rated 400/445 MVA at Midland. | \$11,280,000 | SPS | 12/22/11 | 06/01/10 | NTC | Midland 345 kv | Midland 138 kv | 1 |
| 11029 | 719 | regional reliability | regional reliability | Reconductor 6.15 mile Madsco - Sawyer Switching Station 115kv line for 225/239 MVA rating. | \$3,320,000 | SPS | 08/25/11 | 06/01/10 | NTC | Madsco Station 115 kv | Sawyer Switching Station 115 kv | 1 |
| 11019 | 774 | regional reliability | regional reliability | New Tap to new Cherry 230/115 kv Transformer. | \$1,112,500 | SPS | 08/24/11 | 06/01/10 | NTC | Cherry Sub 230 kv | Potter county interchance 230 kv | 1 |
| 11020 | 774 | regional reliability | regional reliability | New 230/115 kv Auto/transformer at Cherry Substation. | \$4,505,000 | SPS | 08/24/11 | 06/01/10 | NTC | Cherry Sub 230 kv | Cherry Sub 115 kv | 1 |
| 20031 | 10787 | 590 | regional reliability | Convert 8 miles of 69 kv to 115 kv from Carlisbad interchance - Coofillo. Convert Coofillo substation to 115 kv. | \$1,222,843 | SPS | 06/01/11 | 06/01/10 | 01/27/09 | Carlisbad interchance 115 kv | Coofillo Sub 115 kv | 1 |
| 20004 | 10365 | 196 | zonal - sponsored | Add 230 kv line from Pinhook to Hitchland - 541 MVA. | \$11,922,643 | SPS | 06/01/11 | M | 02/13/08 | Pinhook interchance 230 kv | Hitchland 230 kv | 1 |
| 20004 | 10330 | 196 | regional reliability | Add 230 kv line from Hitchland to Ochiltree - 541 MVA. | \$10,756,250 | SPS | 06/01/11 | M | 02/13/08 | Hitchland 230 kv | Ochiltree 230 kv | 1 |
| 20004 | 10331 | 196 | regional reliability | Add 2-Winding 230/115 kv transformer at Ochiltree - 172.5 MVA. | \$6,846,295 | SPS | 06/01/11 | M | 02/13/08 | Perryton interchance 115 kv | Ochiltree 230 kv | 1 |
| 11033 | 783 | regional reliability | regional reliability | Install second 230/115 kv transformer in Randall substation. | \$11,280,000 | SPS | 08/24/11 | 06/01/10 | NTC | Randall County Interchance 230 kv | Randall County Interchance 115 kv | 2 |
| 20031 | 10822 | 632 | regional reliability | Tap line from Teneco - Boardman Tap 69 kv and add new 75/75 MVA 115/69 kv transformer at new Legacy interchance substation. | \$3,937,600 | SPS | 06/01/11 | M | 01/27/09 | Legacy interchance 115 kv (new interchance) | Boardman Tap 69 kv | 1 |
| 20031 | 10823 | 632 | regional reliability | Build new 6 mile 115 kv line from Doss interchance - Legacy interchance. | \$3,375,000 | SPS | 06/01/11 | M | 01/27/09 | Doss interchance 115 kv | Legacy interchance 115 kv (new interchance and sub) | 1 |
| 20031 | 10824 | 632 | regional reliability | Build new 5.5 mile 115 kv line from Gaines County interchance - Legacy interchance. | \$3,083,750 | SPS | 06/01/11 | M | 01/27/09 | Gaines County Interchance 115 kv | Legacy interchance 115 kv (new interchance and sub) | 1 |
| 20031 | 10825 | 633 | regional reliability | Tap line 69 kv from Navajo No. 2 - Navajo No. 4, tap line 115 kv from Navajo No. 3 - Navajo No. 4, and install Eagle Creek Substation and 115/69 kv transformer. | \$3,265,000 | SPS | 04/15/11 | M | 01/27/09 | Eagle Creek 69 kv (new sub) | Eagle Creek 115 kv (new sub) | 1 |
| 20031 | 10826 | 633 | regional reliability | Build new 0.5 mile 115 kv line from new Navajo No. 5 substation - Navajo No. 4 substation 115 kv. | \$281,250 | SPS | 04/15/11 | M | 01/27/09 | Navajo No. 5 Sub 115 kv (new sub) | Navajo No. 4 Sub 115 kv | 1 |
| 20031 | 10827 | 633 | regional reliability | Build new 0.5 mile 115 kv line from new Navajo No. 5 substation - Navajo No. 3 substation 115 kv. | \$281,250 | SPS | 04/15/11 | M | 01/27/09 | Navajo No. 5 Sub 115 kv (new sub) | Navajo No. 3 Sub 115 kv | 1 |
| 20031 | 10829 | 633 | regional reliability | Build new 3 mile 69 kv line from Artesia Town - Artesia South Rural 69 kv. | \$1,350,000 | SPS | 04/15/11 | M | 01/27/09 | Artesia Town Sub 69 kv | Artesia South Rural Sub 69 kv | 1 |
| 20031 | 10829 | 696 | regional reliability | Convert 11.8 miles of 69 kv line to 115 kv from Chaves County - Price - Central Valley REC-Pine Lodge - Capitan - Roswell. SPS-provided mitigation was verified by SPP staff until 12/01/12 when the conversion will be completed. | \$4,716,600 | SPS | 06/01/11 | 06/01/11 | 01/27/09 | Chaves County interchance 115 kv | Roswell interchance 115 kv | 1 |
| 11036 | 786 | regional reliability | regional reliability | Reconductor 3.36 mile Madsco - Monument CKT 1 115 kv with 795 ACSR. | \$1,417,500 | SPS | 06/25/11 | 06/01/11 | NTC | Madsco Station 115 kv | Monument Sub 115 kv | 1 |
| 11096 | 829 | regional reliability | regional reliability | Install second 115/69 kv transformer rated 75/86 MVA at Kingsmill. | \$1,938,000 | SPS | 12/22/11 | 06/01/11 | NTC | Kingsmill 69 kv | Monument 115 kv | 2 |
| 19987 | 10194 | 150 | regional reliability | Upgrade #2 Transformer | \$1,250,000 | SPS | - | 06/01/11 | NTC | Kress 69 kv | Kress 115 kv | 2 |
| 11196 | 857 | regional reliability | regional reliability | Reconductor EAST PLANT-PIERCE 1.06 mile 115 kv to 795 ACSR line | \$696,250 | SPS | | 06/01/11 | NTC | East Plant 115 kv | Pierce 115 kv | 2 |
| 10741 | 690 | regional reliability - non OATT | regional reliability - non OATT | Replace Paragallo auto transformers 1 and 2 with 70 MVA units. | \$3,350,000 | SWPA | 12/01/11 | | | Paragallo 115 kv | Paragallo 69 kv | 1,8,2 |
| 10944 | 612 | regional reliability - non OATT | regional reliability - non OATT | Replace wave trap, disconnect switches, current transformers, and breaker at Dardanelle | \$165,000 | SWPA | 06/01/11 | 06/01/10 | | Dardanelle 161 kv | Russellville South 161 kv | 1 |
| 20044 | 10938 | 705 | Balanced Portfolio | Tap the existing WFEC Anadarko - Wachita 138 kv line into the new Graecmont 345 kv substation. | \$200,000 | WFEC | 12/31/11 | M | 06/19/09 | Anadarko (Graecmont) Tap 138 kv | | 1 |
| 19951 | 10467 | 357 | transmission service | Install 2nd 112 MVA auto In parallel with existing unit | \$2,000,000 | WFEC | 06/01/11 | M | 01/02/07 | Anadarko 138 kv | Anadarko 69 kv | 2 |
| 20003 | 10471 | 361 | regional reliability | Upgrade 7 miles to 795 ACSR from Fletcher SW to Marlow Junction 69 kv. | \$2,000,000 | WFEC | 06/01/11 | M | 02/13/08 | Fletcher 69 kv | Marlow Jct 69 kv | 1 |
| 11114 | 842 | regional reliability | regional reliability | Upgrade Snyder CTS from 400A to 500A. | \$225,000 | WFEC | | 06/01/11 | NTC | Snyder 69 kv | Tipton 69 kv | 1 |
| 20003 | 10303 | 236 | regional reliability | WFEC will build a double circuit 138 kv line, approximately 6.5 miles long, from AEP's Atoka substation to the south and looping into the WFEC Tupelo-Lane 138 kv line - Atoka to Tupelo line. | \$8,265,000 | WFEC | 01/01/11 | M | 02/13/08 | Atoka West 138 kv | Tupelo (WFEC) 138 kv | 1 |
| 20003 | 10304 | 238 | regional reliability | WFEC will build a double circuit 138 kv line, approximately 6.5 miles long, from AEP's Atoka substation to the south and looping into the WFEC Tupelo-Lane 138 kv line - Atoka to Lane line. | | WFEC | 01/01/11 | M | 02/13/08 | Atoka East 138 kv | Lane (WFEC) 138 kv | 1 |
| 20056 | 50243 | 30232 | transmission service | Add 138 kv 30 Mvar Cap bank at Timber | \$1,215,000 | WR | 06/01/11 | | 09/18/09 | Timber 138 kv | | 1 |
| 20056 | 50244 | 30233 | transmission service | Add 69 kv 15 Mvar Cap bank at Tiooa | \$607,500 | WR | 06/01/11 | | 09/18/09 | Tiooa 69 kv | | 1 |
| 50291 | 30253 | zonal - sponsored | zonal - sponsored | one stage of 9.6 Mvar | \$354,000 | WR | 06/01/11 | M | | Riley 115 kv | | 1 |
| 50292 | 30254 | zonal - sponsored | zonal - sponsored | Install 2nd block of 76.8 Mvar | \$3,072,000 | WR | 12/01/11 | M | | Rose Hill 138 kv | | 1 |
| 50293 | 30255 | zonal - sponsored | zonal - sponsored | one stage of 10.8 Mvar | \$432,000 | WR | 06/01/11 | M | | Butler County No. 5-Furley 69 kv | | 1 |
| 20033 | 10349 | 266 | regional reliability | Rebuild 0.23 mile Circle - HEC GT 115 kv line | \$710,000 | WR | 06/01/11 | | 01/27/09 | Hutchinson Gas Turbine Station 115 kv | Circle 115 kv | 1 |
| 20033 | 10635 | 491 | regional reliability | Rebuild 2.9 mile Bernard - Farmer's Consumer Co-op 115 kv. | \$2,055,000 | WR | 06/01/11 | 06/01/11 | NTC-Modify Timing | Bernard 115 kv | Farmer's Consumer Co-op 115 kv | 1 |
| 20006 | 10482 | 369 | regional reliability | Rebuild SW Lawrence - Wakarusa 115 kv line | \$2,000,000 | WR | 06/01/11 | M | 02/13/08 | SW Lawrence 115 kv | Wakarusa 115 kv | 1 |
| 20006 | 10483 | 370 | regional reliability | Rebuild 1.53 miles Co-op-Wakarusa 115 kv line | \$760,000 | WR | 06/01/11 | M | 02/13/08 | Farmer's Consumer Co-op 115 kv | Wakarusa 115 kv | 1 |
| 10666 | 660 | regional reliability | regional reliability | Tear down and rebuild 7.8 mile Gill - Clearwater 138 kv | \$53,224,375 | WR | 06/01/11 | | NTC | Gill 138 kv | Clearwater 138 kv | 1 |
| 20033 | 10639 | 493 | regional reliability | Rebuild Jarrabo - Stranger CKT 2, 7.1 miles of 115 kv line and tap the existing Jarrabo - Northwest Leavenworth line into Stranger. | \$8,050,000 | WR | 06/01/11 | M | 01/27/09 | Jarrabo 115 kv | Stranger Creek 115 | 2 |
| 20033 | 10639 | 493 | regional reliability | Rebuild Stranger - Northwest Leavenworth 6.5 miles of 115 kv and tap existing Jarrabo - Northwest Leavenworth line into Stranger. | | WR | 06/01/11 | M | 01/27/09 | Stranger Creek 115 | NW Leavenworth | 1 |
| 20033 | 10606 | 618 | regional reliability | Tap KSU - Wilcox 115 kv into Northwest Manhattan. | \$17,437,500 | WR | 12/01/11 | M | 01/27/09 | KSU Campus 115 kv | Wilcox 115 kv | 1 |
| 20033 | 10608 | 618 | regional reliability | Tap the Concordia - East Manhattan 230 kv line and build new Northwest Manhattan 230/115 kv substation. | \$11,250,000 | WR | 06/01/11 | M | 01/27/09 | Concordia 230 kv | East Manhattan 230 kv | 1 |
| 20059 | 50239 | 30224 | transmission service | Rebuild approximately 5.5 miles of line with 954-kcmv ACSR to achieve a minimum 500 amp emergency rating. | \$3,811,500 | WR | 12/01/11 | 06/01/11 | | Jeniah Tap 69 kv | Old Creek 69 kv | 1 |
| 20059 | 50232 | 30224 | transmission service | Rebuild approximately 3 miles of line with 954 kcmv ACSR to achieve a minimum 500 amp emergency rating. | \$1,418,500 | WR | 04/01/11 | | 09/18/09 | Athens Switching Station 69 kv | Old Creek 69 kv | 1 |
| 20059 | 50241 | 30230 | transmission service | Replace bus and Jumpers at NE Parsons 138 kv substation | \$250,000 | WR | 06/01/11 | | 09/18/09 | Northeast Parsons 138 kv | | 1 |
| 20059 | 50242 | 30231 | Zonal Reliability | Tap Delta Plane-Cardo 138 kv line, build a 3-breaker ring bus switching station, build approximately 12 miles 138 kv line from Gunter County 138 kv to Timber Junction 138 kv and install Timber Junction 138-69 kv 100 MVA transformer with LTC. | \$9,360,000 | WR | 06/01/11 | | 09/18/09 | Timber Junction 138 kv | Summer County Tap 138 kv | 1 |
| 20059 | 50245 | 30224 | transmission service | Rebuild approximately 5 miles of line with 954-kcmv ACSR to achieve a minimum 1200 amp emergency rating. | \$2,426,500 | WR | 01/01/11 | | 09/18/09 | Coffey County No. 4 Vernon 69 kv | Athens Switching Station 69 kv | 1 |
| 20059 | 10610 | 622 | Zonal Reliability | Rebuild approximately 5.5 mile Rose Hill Junction-Richland | \$2,815,000 | WR | 06/01/11 | | 09/18/09 | Rose Hill Junction 69 kv | Richland 69 kv | 1 |
| 20033 | 10767 | 600 | regional reliability | Tear down and rebuild the 3.43 mile 27th & Croco - 41st & California 115 kv line as a single circuit. | \$3,227,500 | WR | 12/31/11 | | 01/27/09 | 27TH & Croco Junction 115 kv | 41ST & California 115 kv | 1 |
| 20006 | 10417 | 321 | regional reliability | Tear down/rebuild 1.91-miles of Oaklawn - Oliver 69 kv line replacing 477 kcmil ACSR conductor with 954 kcmil ACSR conductor. Limit section to 0.2-mile 750 kcmil CU underground cable. | \$1,292,500 | WR | 06/01/11 | M | 02/13/08 | Oaklawn 69 kv | Oliver 69 kv | 1 |
| 20033 | 10380 | 267 | regional reliability | Rebuild 1.0 mile Mud Creek Junction - Mid-American Junction 69 kv line. Replace 336.4 kcmil ACSR conductor with 954 kcmil | \$2,500,000 | WR | 06/01/11 | 06/01/11 | NTC-Modify Timing | Mud Creek Junction 69 kv | Mud Creek Junction 69 kv | 1 |
| 20033 | 10381 | | | | | | | | | | | |

SPP Board of Directors Approved Appendix A Projects January 26, 2010

| Year | Project ID | Priority | Category | Description | Cost | Priority | Start | End | Notes | Start | End | Status | | | |
|-----------|------------|----------|---------------------------------|---|---------------|----------|-----------|----------|-------------------|----------|-----|-----------------------------|------------------------------------|-------------------------|---|
| 20033 | 10362 | 267 | regional reliability | Rebuild 3.9 mile Mid-American Junction - Newton 69 kv line. Replace 336.4 kcmil ACSR conductor with 954 kcmil ACSR conductor and replace terminal equipment at substations. | \$1,300,000 | WR | 06/01/11 | 06/01/11 | NTC-Modify Timing | 01/27/09 | | Mid-American Junction 69 kv | Newton 69 kv | 1 | |
| Year 2012 | | | | | | | | | | | | | | | |
| 20015 | 50181 | 30143 | transmission service | Upgrade to McNab Substation | \$165,000 | AEEC | 04/01/12 | | | 01/16/09 | | Turk 115 | McNab REC 115 kv | 1 | |
| 20015 | 10460 | 351 | transmission service | Reconductor line to 1550 ACSR line Hope-Fulton line. Build at 138 and operate at 115 kv. | \$1,512,000 | AEEC | 04/01/12 | | | 01/16/09 | | Fulton 115 kv | Hope 115 kv | 1 | |
| 20015 | 10461 | 351 | transmission service | Upgrade Fulton Switching Station | \$340,000 | AEEC | 04/01/12 | | | 01/16/09 | | Fulton 115 kv | | 1 | |
| 20015 | 50076 | 30070 | zonal - sponsored | Add pad and switches for new delivery point along 69 kv line from 507187 Molano to old 507185 Excelsior station site. | \$500,000 | AEP | 12/1/2012 | | | | | Sugar Loaf 69 kv | | | |
| 20016 | 50165 | 30157 | transmission service | Rebuild 5.92 miles of 266 ACSR with 795 ACSR. Replace 69 kv switches, jumpers, and reset CTS and relays at Texarkana plant. | \$8,193,000 | AEP | 04/01/12 | | | 01/16/09 | | Texarkana Plant 69 kv | South Texarkana REC 69 kv | 1 | |
| 20016 | 50164 | 30156 | transmission service | Change out the two CTS jumpers at Texarkana plant. | \$129,000 | AEP | 04/01/12 | | | 01/16/09 | | SE Texarkana 69 kv | Texarkana Plant 69 kv | 1 | |
| 20016 | 50163 | 30155 | transmission service | Replace 69 kv switches | \$400,000 | AEP | 04/01/12 | | | 01/16/09 | | Chow 69 kv | Trotter 69 kv | 1 | |
| 20048 | 50186 | 30148 | transmission service | Replace 69 kv switch at Lone Star Ordinance Tap with a minimum 800 amp emergency rating | \$273,400 | AEP | 06/01/12 | | | 09/18/09 | | Bann 69 kv | Lone Star Ordinance Tap 69 kv | 1 | |
| 20016 | 50180 | 30152 | transmission service | Replace 135 kv breaker, switches, and jumpers at Linwood. Replace circuit switcher at Powell Street | \$456,000 | AEP | 06/01/12 | | | 01/16/09 | | Powell Street 138 kv | Linwood 138 kv | 1 | |
| 20016 | 50148 | 30142 | transmission service | Build approximately 3.3 miles of 2-954 ACSR from Turk to NW Texarkana | \$45,580,000 | AEP | 04/01/12 | | | 01/16/09 | | Turk 345 kv | NW Texarkana 345 kv | 1 | |
| 20016 | 50149 | 30142 | transmission service | Add 345 kv terminal at NW Texarkana | \$1,000,000 | AEP | 04/01/12 | | | 01/16/09 | | Turk 345 kv | NW Texarkana 345 kv | 1 | |
| 20016 | 50150 | 30142 | transmission service | Add 345 kv terminal at Turk (Hamstead) | \$1,000,000 | AEP | 04/01/12 | | | 01/16/09 | | Turk 345 kv | NW Texarkana 345 kv | 1 | |
| 20016.1 | 10426 | 342 | transmission service | Add Turk 345/138 kv transformer | \$7,310,000 | AEP | 04/01/12 | | | 09/18/09 | | Turk 138 kv | Turk 345 kv | 1 | |
| 20016 | 10374 | 288 | transmission service | Install 345 kv terminal equipment at Vallant Substation | \$3,840,000 | AEP | 04/01/12 | | | 01/16/09 | | Hugo Power Plant 345 kv | Vallant 345 kv | 1 | |
| 20016 | 11165 | 673 | regional reliability | Replace 69 kv switch 11665 and 1033 AAC jumpers at Sugar Hill | \$100,000 | AEP | 04/01/12 | | D401/12 | NTC | | Sugar Hill 69 kv | | 1 | |
| 20027 | 10510 | 392 | regional reliability | Rebuild 3.45 miles of Howell - Kilgore 69 kv 4/0 ACSR with 795 ACSR | \$3,285,000 | AEP | 06/01/12 | | | 01/27/09 | | Howell 69 kv | Kilgore 69 kv | 1 | |
| 20000 | 10505 | 387 | regional reliability | Replace wave trap at Okmulgee | \$125,000 | AEP | 06/01/12 | | | 02/13/08 | | Riverside Station 138 kv | Okmulgee 138 kv | 1 | |
| 20000 | 10508 | 388 | regional reliability | Replace 2 sets of New Boston switches on terminal to North New Boston | \$100,000 | AEP | 06/01/12 | | | 02/13/08 | | North New Boston 69 kv | New Boston 69 kv | 1 | |
| 20000 | 10509 | 391 | regional reliability | Replace 135 kv switch at both ends. Reset CTS at Lone Star South. Replace 135 kv switches & reset relays at Pittsburg | \$300,000 | AEP | 06/01/12 | | | 02/13/08 | | Lone Star South 138 kv | Pittsburg 138 kv | 1 | |
| 20000 | 10140 | 113 | regional reliability | Convert Red Point-Haughton to 138 kv. 1550 ACSR (includes Red Point terminal & Haughton station conversion). | \$9,480,000 | AEP | 06/01/12 | | | 02/13/08 | | Haughton 138 kv | Red Point 138 kv | 1 | |
| 20000 | 10141 | 113 | regional reliability | Convert Haughton-McDade to 138 kv. 1550 ACSR (includes McDade station conversion). | \$16,482,000 | AEP | 06/01/12 | | | 02/13/08 | | McDade 138 kv | Haughton 138 kv | 1 | |
| 20000 | 10798 | 113 | regional reliability | Build new Capri-McDade 138 kv. 1550 ACSR line | \$11,989,400 | AEP | 06/01/12 | | | 02/13/08 | | McDade 138 kv | Capri 138 kv | 1 | |
| 20036 | 10534 | 636 | zonal - sponsored | Install new 138 kv line from Clarendon to Martinsville | \$2,617,000 | DETEC | 06/01/12 | | | | | Chicago 138 kv | Martinsville 138 kv | 1 | |
| 20036 | 10539 | 638 | regional reliability | Reconductor 8.92 mile Nichols - Secoria 69 kv with 556 ACSR and upgrade CTS. | \$3,520,000 | EDC | 06/01/12 | | NTC-Modify Timing | 01/27/09 | | SUB 170 - Nichols 5T. 69 kv | Secoria 69 kv | 1 | |
| 20036 | 10546 | 620 | regional reliability | Replace jumpers on breaker #5650 at Blackhawk junction with 556 ACSR for rates 73/69 MVA. | \$50,000 | EDC | 06/01/12 | | | 01/27/09 | | Jamesville 69 kv | SUB 215 - Blackhawk Junction 69 kv | 1 | |
| 20028 | 50080 | 30074 | regional reliability | Install (3) 7.2 Mvar capacitors for a total of 21.6 Mvar at Tanlequah West 69 kv | \$779,000 | GRDA | 07/01/12 | | | 01/27/09 | | Tanlequah West 69 kv | | 1 | |
| 20040 | 10627 | 698 | Balanced Portfolio | Install terminal equipment at Cleveland Substation | \$1,605,000 | GRDA | 12/31/12 | | | 06/19/09 | | Sooner 345 kv | Cleveland 345 kv | 1 | |
| 20021 | 10365 | 225 | regional reliability | Reconductor line to 1550 ACSR. A = 347, B = 403. \$255K/mile @ 4.2 mi | \$6,212,500 | GRDA | 06/01/12 | | | 01/16/09 | | Kansas Tap 161 kv | Vallant 345 kv | 1 | |
| 20021 | 10366 | 226 | regional reliability | Reconductor line to 1550 ACSR. A = 347, B = 403. \$255K/mile @ 4.2 mi | \$1,700,000 | GRDA | 06/01/12 | | | 01/16/09 | | W Sloan Springs 161 kv | Sloan City 161 kv | 1 | |
| 20021 | 10595 | 718 | regional reliability - non OATT | Upgrade 115 kv line from Sub F - Liberty. City of Grand Island Owned Transmission Facility that is NOT under SPP OATT | \$3,937,500 | GRIS | 12/01/12 | | | | | SUB-F 7 115 kv | SUB-F 7 115 kv | 1 | |
| 20021 | 10596 | 719 | regional reliability - non OATT | Upgrade line to 179 MVA. City of Grand Island Owned Transmission Facility that is NOT under SPP OATT. | \$500,000 | GRIS | 04/01/12 | | | | | SUB H 115 kv | SUB H 115 kv | 1 | |
| 20018 | 10405 | 313 | transmission service | Install new line from Vallant 345 kv to Hugo Power Plant. with 19 miles of bundled 795 ACSR conductor | \$11,989,400 | ITGSP | 04/01/12 | | | 01/16/09 | | Hugo Power Plant 345 kv | Vallant 345 kv | 1 | |
| 20042 | 10534 | 702 | Balanced Portfolio | West Gardner 345kv bus out-in to Swissvale-Stillwell 345 kv line | \$2,000,000 | KCPL | 06/01/12 | | | 06/19/09 | | West Gardner 345 kv | West Gardner 345 kv | 1 | |
| 20042 | 10460 | 377 | zonal - sponsored | New Middle Creek sub and Spania/Middle Creek 161kv line | \$6,622,650 | KCPL | 06/01/12 | | | | | Papa 161 kv | Middle Creek 161 kv | 1 | |
| 20042 | 10461 | 378 | zonal - sponsored | New North Louisiana-Middle Creek 161kv line | \$12,179,000 | KCPL | 06/01/12 | | | | | North Louisiana 161 kv | Middle Creek 161 kv | 1 | |
| 20042 | 10540 | 414 | zonal - sponsored | New Cedar Niles-Claire 161 kv Line & Claire substation | \$3,756,500 | KCPL | 06/01/12 | | | | | Cedar Niles | Claire 161 kv | 1 | |
| 20009 | 10543 | 417 | regional reliability | Upgrade wave trap at Gladstone from 800 A to 1200 A | \$13,000 | KCPL | 06/01/12 | | | 02/13/08 | | Avonlea 161 kv | Gladstone 161 kv | 1 | |
| 20011 | 11086 | 823 | regional reliability - non OATT | New substation and transformer 116/69 kv 44 MVA | \$1,000,000 | LEA | 06/01/12 | | | | | LE-ERF 115 kv | LE-ERF 115 kv | 1 | |
| 20011 | 11087 | 823 | regional reliability - non OATT | New Line 69 kv | \$1,000,000 | LEA | 06/01/12 | | | | | LE-ERF 69 kv | LE-ERF 69 kv | 1 | |
| 20011 | 11088 | 823 | regional reliability - non OATT | New Line 69 kv | \$1,000,000 | LEA | 06/01/12 | | | | | LE-ERF 69 kv | LEA-Gales 69 kv | 1 | |
| 20046 | 10541 | 707 | Balanced Portfolio | Install new 345/230 kv transformer at Wolf | \$3,000,000 | MIDW | 06/01/12 | | | 06/19/09 | | Wolf 345 kv | wolf 230 | 1 | |
| 20007 | 50104 | 30098 | regional reliability | Install 20 Mvar capacitor bank at Plamille 115 kv. | \$1,500,000 | MDEC | 06/01/12 | | | 02/13/08 | | Plamille 115 kv | | 1 | |
| 20048 | 50248 | 30236 | regional reliability | Install 36 Mvar capacitor bank at Keamey 115 kv. | \$1,000,000 | NPPD | 06/01/12 | | NTC | | | Keamey 115 kv | | 1 | |
| 20048 | 50207 | 30200 | regional reliability | Add one 15 Mvar cap at Petersburg | \$600,000 | NPPD | 11/01/12 | | NTC | | | Petersburg 115 kv | | 1 | |
| 20048 | 50208 | 30201 | regional reliability | Add one 15 Mvar cap at Clarks 7. | \$725,000 | NPPD | 11/01/12 | | NTC | | | Clarks 115 kv | | 1 | |
| 20048 | 50209 | 30202 | regional reliability | Expand existing 9 Mvar cap to 15 Mvar cap at Ainsworth | \$50,000 | NPPD | 11/01/12 | | NTC | | | Ainsworth 115 kv | | 1 | |
| 20048 | 50206 | 30199 | zonal - sponsored | Add one 9 Mvar cap at Onell 69 kv | \$364,500 | NPPD | 11/01/12 | | NTC | | | Onell 69 kv | | 1 | |
| 20048 | 50210 | 30203 | regional reliability | Add one 15 Mvar cap at Onell 115 | \$729,000 | NPPD | 11/01/12 | | NTC | | | Onell 115 kv | | 1 | |
| 20048 | 10964 | 711 | zonal - sponsored | Tap CEN-CNTY - Silver Creek 115 kv at CLARKS7. Build new 115 kv line from CLARKS7 - CEN.C.N7. Radial 115 kv line for TransCanada Keystone XL project. | \$5,625,000 | NPPD | 11/01/12 | | | | | | Clarks 115 kv | CEN.C.N7 115 kv | 1 |
| 20048 | 10969 | 732 | zonal - sponsored | Build new line from Onell to new STUART97. Radial 115 kv line for TransCanada Keystone XL project. | \$16,031,250 | NPPD | 11/01/12 | | | | | | Onell 115 kv | Sturts 115 kv | 1 |
| 20048 | 10975 | 738 | zonal - sponsored | Build new line from Petersburg to new ERICSON7. Radial 115 kv line for TransCanada Keystone XL project. | \$19,687,500 | NPPD | 11/01/12 | | | | | | Petersburg 115 kv | Erison 115 kv | 1 |
| 20048 | 10986 | 749 | regional reliability | Upgrade conductor and terminal equipment to 100 Deg Rating by 2012. 155 MVA normal continuous rating. 155 MVA 4-hour emergency rating. | \$2,000,000 | NPPD | 06/01/12 | | NTC | | | | Matney 115 kv | North Platte 115 kv | 1 |
| 20048 | 11080 | 818 | regional reliability | Upgrade conductor and terminal equipment to 150 Deg Rating by 2012. 137 MVA normal continuous rating. 137 MVA 4-hour emergency rating. | \$1,000,000 | NPPD | 06/01/12 | | NTC | | | | Loup City 115 kv | North Loup 115 kv | 1 |
| 20048 | 11151 | 629 | regional reliability | Build new 5.5 miles double circuit line from Twin Ch- new South Sioux City sub. Includes rebuild of Twin Church sub and new South Sioux City sub. | | NPPD | 06/01/12 | | NTC | | | | Twin Church 115 kv | South Sioux City 115 kv | 1 |
| 20048 | 11206 | 629 | zonal - sponsored | Build new 5.5 miles double circuit line from Twin Ch- new South Sioux City sub. Includes rebuild of Twin Church sub and new South Sioux City sub. | \$33,000,000 | NPPD | 12/31/08 | | | | | Twin Church 115 kv | Beiden 115 kv | 1 | |
| 20048 | 11162 | 629 | regional reliability | Build new 5.5 miles double circuit line from Twin Ch- new South Sioux City sub. Includes rebuild of Twin Church sub and new South Sioux City sub. | | NPPD | 06/01/12 | | NTC | | | Twin Church 115 kv | South Sioux City 115 kv | 2 | |
| 20029 | 10749 | 883 | regional reliability | Install new tap for Adabel substation. | \$4,972,000 | OGE | 03/31/12 | | | 01/27/09 | | VBI 161 kv | Adabel 161 kv | 1 | |
| 20029 | 10749 | 883 | regional reliability | Install new tap for Adabel substation. | \$4,972,000 | OGE | 03/31/12 | | | 01/27/09 | | Adabel 161 kv | Adabel 161 kv | 1 | |
| 20041 | 10529 | 699 | Balanced Portfolio | New 345 kv line from Sooner to Oklahoma/Kansas State line or the interface with the Westar Energy line segment to achieve 3000 | \$45,000,000 | OGE | 06/01/12 | | | 06/19/09 | | Sooner 345 kv | Rose Hill 345 kv | 1 | |
| 20041 | 10529 | 699 | Balanced Portfolio | Build new 345 kv line from Sooner to Cleveland. Install terminal equipment at Sooner | \$47,200,000 | OGE | 12/31/12 | | | | | | Cleveland 345 kv | | 1 |
| 20017 | 50169 | 30161 | transmission service | Add 345 kv line from Sunnyside to WFEC interception of 345 kv line from Hugo. Install 345 kv breaker, switches, and relays at Sunnyside. | \$200,000,000 | OGE | 04/01/12 | | | 01/16/09 | | Hugo 345 kv | Sunnyside 345 kv | 1 | |
| 20017 | 50171 | 30163 | transmission service | Add 2nd 345/138 kv Auto Transformer | \$10,000,000 | OGE | 04/01/12 | | | 01/16/09 | | Sunniside 345 kv | Sunny6138 kv | 2 | |
| 20017 | 10537 | 551 | regional reliability | Install 2 miles of 161 kv from Johnson to Oak Park and install terminal equipment at Oak Park | \$3,200,000 | OGE | 06/01/12 | | NTC | | | Oak Park 161 kv | Johnson 161 kv | 1 | |
| 20017 | 10701 | 551 | regional reliability | Convert 5.6 miles of 69 kv to 161 kv. | \$5,500,000 | OGE | 06/01/12 | | NTC | | | Johnson 161 kv | Massard 161 kv | 1 | |
| 20017 | 11002 | 759 | zonal - sponsored | Replace terminal equipment so that the overall fault rating is 352 MVA. | \$665,000 | OPPD | 11/10/12 | | | | | SUB 1221 161 kv | S1255 161 kv | 1 | |
| 20058 | 50110 | 30134 | regional reliability | Add 2nd Mvar cap bank at North Cimarron | \$2,500,000 | SEPC | 06/01/12 | | | 06/19/09 | | North Cimarron 115 kv | | 1 | |
| 20045 | 10539 | 706 | Balanced Portfolio | Build new 345 kv line from Spearville to interception point of Spearville to Knoll line. | \$54,000,000 | SEPC | 06/01/12 | | | 06/19/09 | | Wor 345 kv | Spearville 345 kv | 1 | |
| 20045 | 11102 | 835 | regional reliability | Move load from 69 to 115 kv bus | \$16,245,000 | SPS | 11/17/12 | | 06/01/14 | | | EOT Clarks 69 kv | E Clarks 115 kv | 1 | |
| 20045 | 11103 | 835 | regional reliability | Reconductor 5.35 mile FE-Clovis to Curry Ckt 1 with 397.5 ACSR | \$2,287,031 | SPS | 12/17/12 | | 06/01/14 | | | FE-Clovis 115 kv | FE-Holand 115 kv | 1 | |
| 20045 | 11056 | 797 | regional reliability | Add second 230/138kv transformer at Borden County by moving old from Moland when retired. | \$11,280,000 | SPS | 03/21/12 | | 06/01/10 | NTC | | Caprock REC-Vealmoor 138 kv | B | | |

SPP Board of Directors Approved Appendix A Projects January 26, 2010

| Project ID | Year | Category | Description | Amount | Source | Start | End | Notes | Location | Status | Priority | |
|------------------|---------------|---------------------------------|---|--|---------------|----------|----------|----------|--------------------|---------------------------------------|-------------------------------------|---|
| 11054 | 795 | regional reliability | Build new 20 mile Frio-Draw - Roosevelt County 230kV line | \$21,937,500 | SPS | 11/17/12 | 06/01/11 | NTC | Frio-Draw 230kV | Roosevelt County Interchange 230 kV | 1 | |
| 11175 | 687 | regional reliability | Build new 9 mile Canyon West - Spring Draw 115 kV line | \$7,762,500 | SPS | 12/16/12 | 6/1/2010 | NTC | Canyon West 115 kV | Spring Draw 115 kV | 1 | |
| 11177 | 688 | regional reliability | Build new 20 mile Ranchal Co - Amarillo South 230 kV line | \$27,450,000 | SPS | 12/16/12 | 6/1/2010 | NTC | Ranchal Co 230 kV | Amarillo South 230 kV | 1 | |
| 10835 | 102 | regional reliability - non OATT | Upgrade Nixa #2 transformer to 70 MVA | \$1,575,000 | SWPA | 06/01/12 | 06/01/12 | | Nixa 161 kV | Nixa 55 kV | 2 | |
| 50294 | 30257 | regional reliability - non OATT | 10 Mvar cap at Gregory WAPA | \$405,000 | WAPA | 06/01/12 | | | Gregory 115 kV | | 1 | |
| 50296 | 30258 | regional reliability - non OATT | 21.6 Mvar cap at Martin WAPA | \$874,800 | WAPA | 06/01/12 | | | Martin 115 kV | | 1 | |
| 50297 | 30259 | regional reliability - non OATT | 30 Mvar cap bank at Phil Lee WAPA | \$1,215,000 | WAPA | 06/01/12 | | | Phillips 115 kV | | 1 | |
| 19985 | 50047 | 30041 | regional reliability | Install 12 Mvar capacitor at Comanche 138 kv bus | \$350,000 | WFEC | 06/01/12 | M | 02/20/07 | Comanche 138 kV | | 1 |
| 20003 | 50299 | 30093 | regional reliability | Install 12 Mvar capacitor at Latta Junction 138 kV | \$324,000 | WFEC | 06/01/12 | M | 02/13/08 | Latta Junction 138 kV | | 1 |
| 20018 | 50173 | 30165 | transmission service | Install 345 kV breaker at Hugo | \$2,000,000 | WFEC | 04/01/12 | M | 01/16/09 | Hugo 345 kV | | 1 |
| 20003 | 10929 | 402 | regional reliability | Convert 3 miles of 69 kV to 138 kV from Indianola to Grandfield | \$1,125,000 | WFEC | 06/01/12 | M | 02/13/08 | Grandfield 138 kV | | 1 |
| 20003 | 10923 | 402 | regional reliability | Tap Cache to Paradise 138 kV and Install 13.7 miles of 138 kV from Cache to Indianola | \$7,305,000 | WFEC | 06/01/12 | M | 02/13/08 | Cache SW 138 kV | | 1 |
| 20003 | 10924 | 402 | regional reliability | Install new 138/69 kV transformer at Grandfield | \$5,000,000 | WFEC | 06/01/12 | M | 02/13/08 | Grandfield 138 kV | | 1 |
| 20003 | 10919 | 399 | regional reliability | Upgrade line from 110 to 236.4, 4.85 miles | \$1,341,000 | WFEC | 06/01/12 | M | 02/13/08 | Walville 69 kV | | 1 |
| 20003 | 10920 | 400 | regional reliability | WFEC will upgrade 800 A CTS, new CT limit will be 1200 A at Pharaoh | \$225,000 | WFEC | 06/01/12 | M | 02/13/08 | Pharaoh 138 kV | | 1 |
| 20003 | 10921 | 401 | regional reliability | Replace CT at WFEC Russel | \$50,000 | WFEC | 06/01/12 | M | 02/13/08 | WFEC Russel 138 kV | | 1 |
| 10878 | 672 | regional reliability | Reconductor 6.5 miles of 110 conductor with 336.4 ACSR | \$1,950,000 | WFEC | 06/01/12 | 06/01/12 | NTC | EI Reno 69 kV | EI Reno SW 69 kV | 1 | |
| 50102 | 30096 | regional reliability | Install 20 Mvar capacitor bank at Eudora 115 kV | \$590,000 | WR | 06/01/12 | M | 02/13/08 | Eudora 115 kV | | 1 | |
| 50229 | 30225 | transmission service | Add 15 Mvar Cap bank at Allen | \$607,500 | WR | 06/01/12 | M | 09/18/09 | Allen 69 kV | | 1 | |
| 50295 | 30256 | zonal - sponsored | Install 2nd block of 14.4 Mvar | \$1,120,000 | WR | 06/01/12 | M | | Clearwater 138 kV | | 1 | |
| 20033 | 10902 | 463 | regional reliability | The East Manhattan-McDowell 115 kV is built as a 230 kV line but is operated at 115 kV. Substation work will have to be performed in order to convert this line to 230 kV operation. | \$4,100,000 | WR | 06/01/12 | M | 01/27/09 | East Manhattan 230kV | McDowell 230kV | 1 |
| 10995 | 754 | zonal - sponsored | Build a new 138kV line from Clearwater and a new 138kV line from Evans to serve the new Goodland substation | \$8,625,000 | WR | 06/01/12 | M | | Clearwater 138 kV | Goodland 138 kV | 1 | |
| 10995 | 754 | zonal - sponsored | Build a new 138kV line from Clearwater and a new 138kV line from Evans to serve the new Goodland substation | \$5,525,000 | WR | 06/01/12 | M | | Goodland 138 kV | Goodland 138 kV | 1 | |
| 20059 | 50229 | 30224 | transmission service | Rebuild approximately 6 miles of line with 954-KCM ACSR to achieve a minimum 600 amp emergency rating | \$2,660,500 | WR | 06/01/12 | M | 09/18/09 | Allen 69 kV | Lenah Tap 69 kV | 1 |
| 20006 | 10921 | 172 | regional reliability | Convert TECT-Midland from 161 kV to 115 kV | \$2,100,000 | WR | 06/01/12 | M | 02/13/08 | McCumbers Energy Center 115 kV | Midland 115 kV | 1 |
| 19964 | 10488 | 374 | transmission service | Install 3rd Rose Hill 345/138 kV TRANSFORMER | \$8,100,000 | WR | 06/01/12 | M | 05/27/07 | Rose Hill 345 kV | Rose Hill 138 kV | 3 |
| 20053 | 10879 | 664 | regional reliability | Tear down and rebuild 1.8 mile Gill Energy Center West - Waco 138 kV with bundled 1192.5 ACSR conductor | \$1,000,000 | WR | 06/01/12 | 06/01/13 | 11/02/09 | Gill Energy Center West 138 kV | Waco 138 kV | 1 |
| Year 2013 | | | | | | | | | | | | |
| 20027 | 10975 | 443 | regional reliability | Tap the South Springsdale-East Fayetteville 161 kV line and build 1.5 miles of 161 kV to new Cisbourne station | \$2,000,000 | AEP | 06/01/13 | M | 01/27/09 | Cisbourne 161 kV | Cisbourne Tap 161 kV | 1 |
| | 10695 | 546 | regional reliability | Rebuild the 26.2 mi Carnegie - Hobart Jct. 138 kV line from 39T ACSR to 1272 ACSR. Replace 3 switches, wave traps and jumpers. Reset CTs and relays. | \$28,150,000 | AEP | 06/01/13 | NTC | | Hobart Junction 138 kV | Carnegie 138 kV | 1 |
| | 10696 & 10697 | 546 | regional reliability | Reconductor the 14.37 mile Southwest Station - Carnegie 138 kV line from 795 ACSR to 1272 ACSR. Replace wave traps and jumpers. | \$11,030,000 | AEP | 06/01/13 | NTC | | Carnegie 138 kV | Southwest Station 138 kV | 1 |
| 20064 | 11015 | 770 | regional reliability | Rebuild 2.45 miles of 795 ACSR with 1590 ACSR and reset relays | \$2,500,000 | AEP | 06/01/13 | NTC | 11/02/09 | Ashtown 138 kV | Craig Junction 138 kV | 1 |
| 20057 | 10887 | 539 | transmission service | Brookline: Replace 1,200 amp switches with 2,000 amp units and replace metering CT's. Junction: Replace 1,200 amp switches with | \$120,000 | CUS | 06/01/13 | 06/01/19 | 09/18/09 | Brookline 161 kV | Junction 161 kV | 1 |
| 20034 | 10847 | 645 | regional reliability | Rebuild Clinton 161/69 kv transformer #1 with new 100/125 MVA to match transformer #2 | \$2,000,000 | GMO | 06/01/13 | M | 01/27/09 | Clinton 69 kV | Clinton 161 kV | 1 |
| | 10430 | 333 | zonal - sponsored | 16 kV Tap of Hallmark to Sibley | \$302,795 | GMO | 06/01/13 | M | | Hallmark 161 kV | Sibley 161 kV | 1 |
| | 10432 | 336 | zonal - sponsored | 16 kV Tap of Hallmark to Sibley | \$9 | GMO | 06/01/13 | M | | Hallmark 161 kV | Sibley 161 kV | 1 |
| | 10941 | 414 | zonal - sponsored | New Quarry/Clare 161 kV line | \$1,385,000 | KCPCL | 06/01/13 | M | | Quarry 161 kV | Clare 161 kV | 1 |
| | 10944 | 418 | zonal - sponsored | New Wadon sub out-lin | \$1,632,300 | KCPCL | 06/01/13 | M | | Wadon 161 kV | Mawood 161 kV | 1 |
| | 10945 | 418 | zonal - sponsored | New Wadon sub out-lin | \$250,000 | KCPCL | 06/01/13 | M | | Wadon 161 kV | Washburn 161 kV | 1 |
| | 10952 | 715 | regional reliability | Reconductor Clark portion of Glenora - Liberty 69 kV for 767.5 MVA rating | \$200,000 | KCPCL | 06/01/13 | NTC | | Clare 69 kV | Clare 69 kV | 1 |
| | 10948 | 711 | zonal - sponsored | ADD NWE68 Holdridge 345/115kV Transformer 2nd. Driven by NERC Category C (TPL-003) - prior outage of one 345/115kV transformer, followed by an outage of a second 345/115kV transformer. | \$11,250,000 | LES | 05/31/13 | M | | NW68 & HOLDRIDGE 115 kV | NWE6 & Holdridge 345 kV | 1 |
| 20046 | 10940 | 707 | Balanced Portfolio | Build new 345 kV line from Knoll to Intersection point of Spearville to Knoll line | \$42,000,000 | MIDW | 06/01/13 | M | 06/19/09 | SPEARVILLE 345 kV | Wolf 345 kV | 1 |
| 20046 | 10943 | 707 | Balanced Portfolio | Build new 345 kV line from Knoll to Intersection point of Axtel to Knoll line | \$66,000,000 | MIDW | 06/01/13 | M | 06/19/09 | Wolf 345 kV | Wolf 345 kV | 1 |
| 20039 | 10914 | 697 | regional reliability | Rebuild 21.1 mile HE-C - Humboldt 115 kV line and replace CT, wave trap and relays. | \$8,293,000 | MIDW | 06/01/13 | NTC | 01/27/09 | Humboldt Energy Center 115 kV | Humboldt 115 kV | 1 |
| | 10958 | 653 | regional reliability | Rebuild 21.5 mile St. John - Pratt 115 kV line with 795 ACSR conductor. | \$9,639,000 | MWEC | 06/01/13 | NTC | | St. John 115 kV | Pratt 115 kV | 1 |
| | 50213 | 30206 | regional reliability | Install 9 Mvar capacitor bank at Gordon 115 kV | \$1,000,000 | NPPD | 06/01/12 | 06/01/13 | NTC | Gordon 138 kV | | 1 |
| 20047 | 10942 | 708 | Balanced Portfolio | Build new 345 kV line from Axtel to Intersection point of Axtel to Wolf line (Kansas Border). Includes substation expansion at Axtel and line regrade. | \$76,000,000 | NPPD | 06/01/13 | M | 06/19/09 | Axtel 345 kV | Wolf 345 kV | 1 |
| | 11079 | 817 | regional reliability | Uprate line and substation equipment to 100 Deg C Rating by 2013. 174 MVA Normal Continuous Rating. 174 MVA 4-Hour Emergency Rating. | \$1,000,000 | NPPD | 06/01/13 | 06/01/13 | NTC | Ablon 115 kV | Spalding 115 kV | 1 |
| 20029 | 10843 | 642 | regional reliability | Remove wavetrp at VBI. | \$10,000 | OGE | 06/01/13 | M | 01/27/09 | Kigore 69 kV | VBI 69 kV | 1 |
| | 10300 | 235 | regional reliability | Reconductor 2.2 miles to 1590 kcmcm ACSR and change terminal equipment at Fl. Smith and Colory substations to 2000A. | \$2,500,000 | OGE | 06/01/13 | 06/01/13 | NTC | Fort Smith 161 kV | Colony 161 kV | 1 |
| 20041 | 10930 | 700 | Balanced Portfolio | Build new 345 kV line from Muskogee to Muskogee | \$131,000,000 | OGE | 12/31/13 | M | 06/19/09 | Seminole 345 kV | Muskogee 345 kV | 1 |
| 20041 | 10931 | 700 | Balanced Portfolio | Install 3rd 345/138 kv transformer at Seminole | \$4,000,000 | OGE | 12/31/13 | M | 06/19/09 | Seminole 345 kV | Seminole 138 kV | 3 |
| | 11139 | 862 | regional reliability | Rebuild 2 mile Sup 906 Norm - Sup 929 line. Change CT tap settings, and replace line jumpers for 110 MVA rating. | \$4,638,000 | ORPD | 06/01/13 | NTC | | SUB 906 norm 69 kV | SUB 929 69 kV | 1 |
| | 11141 | 864 | regional reliability | Increase line clearances to allow the use of a higher conductor rating. | \$372,000 | ORPD | 06/01/13 | NTC | | SUB 907 69 kV | Sub 919 69 kV | 1 |
| | 11044 | 791 | regional reliability | Build new 4 mile Hart Industrial Substation - Newhart Substation 115 kV line. | \$2,250,000 | SPS | 03/16/13 | 06/01/10 | NTC | Hart Industrial 115 kV | Newhart 115 kV | 1 |
| | 11023 | 774 | regional reliability | Build new 3.7 mile Hastings - East Plant 115kV line. | \$1,700,000 | SPS | 03/16/13 | 06/01/10 | NTC | Hastings Sub 69 kV | East Plant Interchange 115 kV | 1 |
| | 11047 | 793 | regional reliability | Reconductor 5.5 mile Gains County Interchange - Legacy 115 kV line. | \$2,320,300 | SPS | 06/01/13 | NTC | | Gaines County Interchange 115 kV | Legacy 115 kV | 1 |
| | 11050 | 795 | regional reliability | Build new 130 mile 345 kV line from Potter to new Frio-Draw substation at Roosevelt | \$146,250,000 | SPS | 12/31/13 | 06/01/13 | NTC | Frio-Draw 345kV | Potter County Interchange 345 kV | 1 |
| | 11051 | 795 | regional reliability | Build new Frio-Draw substation with 345/230 kV transformer. | \$11,250,000 | SPS | 12/31/13 | 06/01/13 | NTC | Frio-Draw 345 kV | Frio-Draw 330kV | 1 |
| | 11049 | 794 | regional reliability | Add a second Grove 115/69 kv transformer. | \$600,000 | SPS | 06/01/13 | 06/01/13 | NTC | GRAVE 3 115 kV | Grove 69 kV | 2 |
| | 11101 | 834 | regional reliability | Convert existing 3 mile Portales Interchange - Zodiak 69 kV line to operate at 115 kV. | \$3,487,500 | SPS | 05/21/13 | 06/01/13 | NTC | Portales Interchange 115 kV | Zodiak 115 kV | 1 |
| | 10841 | 640 | regional reliability - non OATT | Resao conductor and replace some structures. | \$50,000 | SWPA | M | | | Malden 69 kV | New Madiso 55 kV | 1 |
| | 11012 | 799 | regional reliability - non OATT | Replace bus and CT's at Norton | \$112,500 | SWPA | 06/01/13 | 06/01/11 | NTC-Modify Timing | Norton 69 kV | Southland 161 kV | 1 |
| 20030 | 50186 | 30178 | regional reliability | Install 6 Mvar capacitor bank at Electra 69 kV bus for a total of 18 Mvar at this location. | \$240,000 | WFEC | 06/01/13 | 06/01/11 | NTC | Electra 69 kV | | 1 |
| | 11115 | 846 | regional reliability | Rebuild 25.2 mile Anadarko - Blanchard 69 kv as 138 kv. | \$14,737,500 | WFEC | 06/01/13 | NTC | | Anadarko 138 kV | Blanchard 138 kV | 1 |
| | 11116 | 846 | regional reliability | Rebuild 2 mile Blanchard - OU Switchyard 69 kv as 138 kv. | \$1,125,000 | WFEC | 06/01/13 | NTC | | Blanchard 138 kV | OU Switchyard 138 kV | 1 |
| | 50311 | 30105 | regional reliability - non OATT | Install 30 Mvar capacitor at Springhill 115 kV. | \$1,000,000 | WR | 06/01/13 | M | 02/13/08 | Springhill 115 kV | | 1 |
| 20059 | 50231 | 30227 | transmission service | Add 15 Mvar Cap bank at Athens | \$607,500 | WR | 06/01/13 | M | 09/18/09 | Athens 69 kV | | 1 |
| | 50298 | 30260 | zonal - sponsored | 1 stage of 10.8 Mvar | \$432,000 | WR | 06/01/13 | M | | Shawnee 115 kV | | 1 |
| | 50299 | 30261 | zonal - sponsored | 1 stage of 10.8 Mvar | \$432,000 | WR | 06/01/13 | M | | Shawnee Heights 115 kV | | 1 |
| 20033 | 10803 | 467 | regional reliability | Replace wave traps on Gill - Interstate 138 kV line for a new rating of 232/256 MVA. | \$50,000 | WR | 06/01/13 | NTC | | Gill Energy Center East 138 kV | Interstate 138 kV | 1 |
| | 10844 | 643 | regional reliability | Tap the Neosho - Twin Valley line into Alamogordo | \$4,000,000 | WR | 06/01/13 | M | 01/27/09 | TWIN VALLEY NO. 1 MOUND VALLEY 138 kV | Neosho 138 kV | 1 |
| | 10846 | 646 | regional reliability | Anti-sagcoo transformer in 17th Street substation | \$2,480,000 | WR | 06/01/12 | M | 11/02/09 | 17TH STREET 138 kV | 17TH Street 2.69 kv | 1 |
| 20033 | 10879 | 533 | regional reliability | Install second Auburn Road 230/115 kV transformer | \$19,620,000 | WR | 06/01/15 | 06/01/11 | NTC-Modify Timing | Auburn 230 kV | Auburn 115 kV | 2 |
| | 11082 | 819 | regional reliability | Rebuild 5.6 mile Gill Energy Center East - MacArthur 60 kv line. Replace substation bus and jumpers at MacArthur 69 kv. | \$3,127,500 | WR | 06/01/13 | NTC | | Gill Energy Center East 69 kV | MacArthur 69 kV | 1 |
| 20059 | 50333 | 30224 | transmission service | Rebuild approximately 7 miles of line with 954 kcmil ACSR to achieve a minimum 1200 amp emergency rating. | \$3,340,000 | WR | 07/01/13 | M | 09/18/09 | Burlington Junction 69 kV | Coffey County No. 3 Westhalla 69 kV | 1 |
| | 50334 | 30224 | transmission service | Rebuild approximately 4 miles of line with 954 kcmil ACSR to achieve a minimum 1200 amp emergency rating. | \$1,945,000 | WR | 01/01/13 | M | 09/18/09 | Burlington Junction 69 kV | Wolf Creek 69 kV | 1 |
| | 50340 | 30224 | | | | | | | | | | |

SPP Board of Directors Approved Appendix A Projects January 26, 2010

| Year | Item ID | Account ID | Reliability | Description | Cost (\$) | Agency | Start Date | End Date | Priority | Location / Notes | Benefit / Notes | Count | | |
|------|---------|------------|---------------------------------|---|---|---|------------------|----------|----------|----------------------------------|-------------------------------------|-----------------------------------|---------------------|-------|
| 2009 | 10577 | 445 | regional reliability | Rebuild 5.4 mile Big Sandy - Perdue 69 kV line from 477 ACSSR to 1272 ACSSR. | \$5,400,000 | AEP | 06/01/14 | 06/01/15 | | Big Sandy 69 kV | Perdue 69 kV | 1 | | |
| | 11153 | 873 | regional reliability | Upgrade 600 A breaker and two switches at Texasiana Plant. | \$230,000 | AEP | 06/01/14 | 06/01/14 | | 3E Texasiana 69 kV | Texasiana 69 kV | 1 | | |
| | 11169 | 890 | regional reliability | Upgrade 2 sets of switches at Rock Hill and 1 set of switches at Beckville bus. | \$200,000 | AEP | 06/01/14 | 06/01/14 | | Beckville 69 kV | Rock Hill 69 kV | 1 | | |
| | 10849 | 548 | regional - sponsored | Convert from 59 kV to 138 kV. | \$3,837,000 | DETEC | 06/01/14 | 06/01/14 | | Marlinville 138 kV | Shady Grove 138 kV | 1 | | |
| | 10850 | 548 | regional - sponsored | Convert from 59 kV to 138 kV. | \$3,837,000 | DETEC | 06/01/14 | 06/01/14 | | Snoddy Grove 138 kV | Central Heights 138 kV | 1 | | |
| | 10851 | 548 | regional - sponsored | Convert from 59 kV to 138 kV. | \$3,837,000 | DETEC | 06/01/14 | 06/01/14 | | Central Heights 138 kV | Filze 138 kV | 1 | | |
| | 10852 | 548 | regional - sponsored | Convert from 59 kV to 138 kV. | \$3,837,000 | DETEC | 06/01/14 | 06/01/14 | | Filze 138 kV | Tempsion 138 kV | 1 | | |
| | 11074 | 812 | regional reliability | Replace jumpers. | \$100,000 | EDF | 06/01/14 | 06/01/14 | | SUB 203 - Jasper West Tap 69 kV | SUB 209 - Boston East 69 kV | 1 | | |
| | 11073 | 811 | regional reliability | Raise structures on Diamond Jct - Sarcosie Southwest 69 kV line to achieve a new rating of 44 MVA. | \$30,000 | EDF | 06/01/14 | 06/01/14 | | SUB 151 - Campion Junction 69 kV | SUB 362 - Sarcosie Southwest 69 kV | 1 | | |
| | 10567 | 637 | regional reliability | Replace switch on transformer at Subst 167 for Rate B - 91 MVA. | \$75,000 | EDF | 06/01/14 | 06/01/15 | | Sub 157 - Riverton 69 kV | SUB 278 - Galena Northeast 69 kV | 1 | | |
| | 20036 | 10236 | 202 | regional reliability | Reconductor 1.0 mile of 40 ACSSR with 336 ACSSR for 55 MVA Rate B | \$400,000 | EDF | 06/01/14 | 06/01/14 | | SUB 436 - vrabo City Carolina 69 kV | SUB 110 - Oronogo Junction 69 kV | 1 | |
| | 10560 | 3024 | regional reliability | Install 7.2 Mvar capacitor bank at Washer 69 kV. | \$299,600 | GRCA | 06/01/14 | 06/01/14 | 01/27/09 | Washer 69 kV | | 1 | | |
| | 10533 | 489 | regional reliability | Rebuild 29.55 mile Huntsville - St. John 115 kV line and replace CT, waverlap, breakers, and relays. | \$5,100,000 | MIDW | 06/01/14 | 06/01/14 | | Huntsville 115 kV | | 1 | | |
| | 30049 | 30037 | regional reliability | Install 18 Mvar capacitor bank at Hootledge 115 kV. | \$1,000,000 | NPPD | 06/01/14 | 06/01/14 | | Hootledge 115 kV | | 1 | | |
| | 2010 | 11078 | 816 | regional reliability | Uprate line and substation equipment to effect 100 Deg C Rating by 2014. 137 MVA Normal Continuous Rating; 137 MVA 4-Hour Emergency Rating. | \$1,000,000 | NPPD | 06/01/14 | 06/01/14 | | Albon 115 kV | Genoa 115 kV | 1 | |
| | | 11143 | 899 | regional reliability | Increase line clearances to allow the use of a higher conductor rating. Change CT tap settings. | \$261,000 | ORPD | 06/01/14 | 06/01/14 | | Sub 921 69 kV | Sub 942 69 kV | 1 | |
| | | 11137 | 860 | regional reliability | Increase line clearances to allow the use of a higher conductor rating. | \$105,000 | ORPD | 06/01/14 | 06/01/14 | | SUB 901 69 kV | Junction 205 69 kV | 1 | |
| | | 11138 | 861 | regional reliability | Increase line clearances to allow the use of a higher conductor rating. | \$261,000 | ORPD | 06/01/14 | 06/01/14 | | SUB 910 69 kV | Junction 205 69 kV | 1 | |
| | | 11142 | 865 | regional reliability | Increase line clearances to allow the use of a higher conductor rating. | \$263,000 | ORPD | 06/01/14 | 06/01/14 | | Sub 917 69 kV | Sub 918 69 kV | 1 | |
| | | 11191 | 897 | regional - sponsored | New Distribution Sub - WR Airport | \$ | OGE | 06/01/14 | M | | 35 & Meridian 138 kV | WRAirport 138 kV | 1 | |
| | | 11192 | 897 | regional - sponsored | New Distribution Sub - WR Airport | \$ | OGE | 06/01/14 | M | | WRAirport 138 kV | Pennsylvania 138 kV | 1 | |
| | | 20041 | 10532 | 701 | Balanced Portfolio | Build new 345 kV line from Woodward EHV to Borer | \$108,000,000 | OGE | 05/19/14 | M | 06/19/09 | Stalene 345 kV | Woodward EHV 345kV | 1 |
| | | 20041 | 10533 | 701 | Balanced Portfolio | Install 2nd 345/138 kV transformer at Woodward EHV | \$15,000,000 | OGE | 05/19/14 | M | 06/19/09 | Woodward EHV 138 kV | Woodward EHV 345 kV | 2 |
| | | 30275 | 30262 | regional reliability | Install 7.2 Mvar at Canadian Sub | \$291,600 | SPS | 06/01/14 | 06/01/14 | | Canadian 115 kV | | 1 | |
| | | 11055 | 796 | regional reliability | Add second 230/115 kV transformer at Grassland interchange. | \$11,290,000 | SPS | 06/01/14 | 06/01/14 | | Grassland interchange 115 kV | Grassland Interchange 230 kV | 2 | |
| | | 20043 | 10535 | 704 | Balanced Portfolio | Build new 345 kV line from Tupo to Borer | \$102,500,000 | SPS | 05/19/14 | M | 06/19/09 | Tupo interchange 345 kV | Stalene 345 kV | 1 |
| | | 20043 | 10537 | 704 | Balanced Portfolio | Build Borer at Intersection point of Woodward to Tupo line. | \$14,880,000 | SPS | 05/19/14 | M | 06/19/09 | Stalene 345 kV | Stalene 345 kV | 1 |
| | | 11007 | 764 | regional reliability | Upgrade both Happy County 115/69 kV transformers to 84 MVA. | \$1,890,000 | SPS | 06/01/14 | 06/01/14 | | Happy Interchange 115 kV | Happy Interchange 69 kV | 1 | |
| | | 11009 | 764 | regional reliability | Upgrade both Happy County 115/69 kV transformers to 84 MVA. | \$1,890,000 | SPS | 06/01/14 | 06/01/14 | | Happy Interchange 115 kV | Happy Interchange 69 kV | 2 | |
| | | 11093 | 826 | regional reliability | Replace existing 149/171 MVA Chaves 230/115 kV transformer with 225 MVA transformer. | \$11,250,000 | SPS | 06/01/14 | 06/01/14 | | Chaves 230 kV | Chaves 230 kV | 2 | |
| | | 11104 | 836 | regional reliability | Move load from Mustanghoe 59 kV to Mustanghoe 115 kV. | \$3,319,750 | SPS | 06/01/14 | 06/01/14 | | Mustanghoe 59 kV | Mustanghoe 115 kV | 1 | |
| | | 11107 | 539 | regional reliability | Build new 22.2 mile Kress Interchange - Plainview County 115 kV. | \$14,737,500 | SPS | 06/01/14 | 06/01/14 | | Kress Int 115 kV | Plainview County 115 kV | 1 | |
| | | 11108 | 839 | regional reliability | Add new Plainview County 115/69 kV transformer with 44/65 MVA ratings. | \$990,000 | SPS | 06/01/14 | 06/01/14 | NTC | Plainview Co 69 kV | Plainview County 115 kV | 1 | |
| | | 11109 | 840 | regional reliability | Build new 9.8 mile Cox - Plainview 115 kV line unit. | \$7,765,500 | SPS | 06/01/15 | 06/01/14 | NTC | Cox 115 kV | Plainview County 115 kV | 1 | |
| | | 11122 | 852 | regional reliability | Replace wave trap with 1200 A minimum. | \$245,000 | SPS | 06/01/14 | 06/01/14 | | Jones 230 kV | Grassland 230 kV | 1 | |
| | | 11172 | 863 | regional reliability | Build new second Jones - Grassland 230 kV line. | \$36,338,000 | SPS | 05/16/14 | 06/01/11 | NTC | Jones 230 kV | Grassland 230 kV | 2 | |
| | | 11187 | 860 | regional reliability | Reconductor FRIQ-ORAW 0.55 miles 115 kV to 795 ACSSR line. | \$915,000 | SPS | 06/01/14 | 06/01/14 | | Friq Drw 115 kV | Grassland 230 kV | 1 | |
| | | 50119 | 30113 | regional reliability - non OATT | Install 30 Mvar capacitor at Glencoe 161 kV substation. | \$1,218,000 | SWPA | 06/01/14 | 06/01/14 | | Glencoe 161 kV | Farmers Electric REC-Crows 115 kV | 1 | |
| | | 10819 | 531 | regional reliability - non OATT | Reconductor line to 335/335 MVA. | \$10,096,750 | SWPA | 06/01/14 | 06/01/14 | | Ashville 161 kV | Idalia 161 kV | 1 | |
| | | 10820 | 461 | regional reliability - non OATT | Replace both Carbath and transformers with larger units. | \$8,626,000 | SWPA | 06/01/14 | 06/01/14 | | Carbath 161 kV | Carbath 69 kV | 1 | |
| | | 20003 | 10539 | 30039 | regional reliability | Install 6 Mvar capacitor at Escalante 69 kV. | \$240,000 | WPEC | 06/01/14 | 06/01/14 | | Escalante 69 kV | Carbath 69 kV | 1 & 2 |
| | | 10669 | 534 | regional reliability | Reconductor 3 mile Cypsum - Russel 69 kV line from 110 to 336 4 ACSSR | \$900,000 | WPEC | 06/01/14 | 06/01/14 | | Cypsum 69 kV | Russel 69 kV | 1 | |
| | | 20059 | 30330 | 30226 | transmission service | Add 6 Mvar Cap bank at Allona East. | \$607,500 | WR | 06/01/14 | | Altona East 69 kV | Altona East 69 kV | 1 | |
| | | 10713 | 563 | regional reliability | Replace 69 kV recombed switches at Aquarius with a minimum 800 amp emergency rating. | \$75,000 | WR | 06/01/13 | M | | Acropolis 69 kV | Aquarius 69 kV | 1 | |
| | | 20033 | 10679 | 534 | regional reliability | Replace Halstead 138/69/12 kV transformer with 100/110 MVA unit. | \$1,400,000 | WR | 06/01/14 | 06/01/11 | NTC-Modify Timing | Halstead South 138 kV | Aquarius 69 kV | 1 |
| | | 10605 | 469 | regional - sponsored | Reset CTs on Moundridge - Newton 69 kV line (multiple rating changes). | \$20,000 | WR | 06/01/14 | 06/01/14 | | Galtz 69 kV | Newton 69 kV | 1 | |
| | | 10957 | 755 | regional reliability | Tear down and rebuild 6.6 mile County Line - Goodwater Junction 115 kV line. | \$3,712,500 | WR | 06/01/14 | 06/01/14 | | County Line 115 kV | Goodwater Junction 115 kV | 1 | |
| | | 20059 | 30236 | 30224 | transmission service | Rebuild approximately 9 miles of line with 954 kcmil ACSSR to achieve a minimum 1200 amp emergency rating. | \$4,249,000 | WR | 04/01/14 | | Green 69 kV | Coffey County No. 3 Weonaha 69 kV | 1 | |
| | | | | | | | Year 2015 | | | | | | | |
| 2016 | | 11156 | 876 | regional reliability | Rebuild 0.8 mile Weatherford - Thomas Tap 69 kV line from 40 ACSSR with 795 ACSSR. Replace Weatherford waverlap. | \$1,000,000 | AEP | 06/01/15 | 06/01/15 | | Weatherford 69 kV | Thomas Tap 69 kV | 1 | |
| | | 20036 | 10685 | 537 | regional reliability | Build new 9.2 mile Substation 383 - Monett 5.161 kV line. | \$7,369,319 | EDF | 06/01/15 | 06/01/19 | NTC-Modify Timing | SUB 383 - Monett 161 kV | South Monett 161 kV | 1 |
| | | 20036 | 10686 | 537 | regional reliability | Install 3-winding transformer connecting new 161 kV bus to Monett City South 69 kV. | \$8,000,000 | EDF | 06/01/15 | 06/01/19 | NTC-Modify Timing | SUB 376 - Monett City South 69 kV | South Monett 161 kV | 1 |
| | | 10681 | 536 | regional reliability | Reconductor 1.2 mi with 336 ACSSR. | \$275,000 | EDF | 06/01/15 | 06/01/15 | | Monett City South Jct 69 kV | Monett City East 69 kV | 1 | |
| | | 20042 | 10635 | 703 | Balanced Portfolio | Tap Nashua 345kV bus in Hartstrom - St. Joseph 345 kV line. Build new 345 kV line from Hartstrom to Nashua. | \$54,444,000 | KOPL | 06/01/15 | 06/01/15 | | Hartstrom 345 kV | Nashua 345 kV | 1 |
| | | 20042 | 10945 | 703 | Balanced Portfolio | Install new 345/161 kV transformer at Nashua. | \$4,620,000 | KOPL | 06/01/15 | M | 06/19/09 | Nashua 345 kV | Nashua 161 kV | 1 |
| | | 30198 | 30192 | regional reliability | Install 3 additional Mvar cap at Kinsey 115 kV for a total 8 Mvar | \$180,000 | MIDW | 06/01/15 | 06/01/15 | | Kinsey 115 kV | | 1 | |
| | | 11060 | 757 | regional reliability | Reconductor 12.66 mile PRC - Station to Woodcove district line to 1590 ACSSR | \$4,200,000 | OGE | 06/01/15 | 06/01/15 | | Pawnee 115 kV | Woodcove District 138 kV | 1 | |
| | | 10876 | 670 | regional reliability | Install third Arcadia 345/138 kV autotransformer. | \$14,000,000 | OGE | 06/01/15 | 06/01/15 | | Arcadia 345 kV | Arcadia 138 kV | 3 | |
| | | 11129 | 856 | regional reliability | Convert 14 mile Mehan - Cushing 69 kV line to 138 kV. | \$ | OGE | 06/01/15 | 06/01/15 | | Mehan 138 kV | Cushing 138 kV | 1 | |
| | | 11130 | 856 | regional reliability | Convert 6 mile Stillwater - Spring Valley 69 kV line to 138 kV. | \$ | OGE | 06/01/15 | 06/01/15 | | Stillwater 138 kV | Spring Valley 138 kV | 1 | |
| | | 11131 | 858 | regional reliability | Convert 3 mile Spring Valley - Mehan 69 kV line to 138 kV. | \$ | OGE | 06/01/15 | 06/01/15 | | Spring Valley 138 kV | Mehan 138 kV | 1 | |
| | | 11132 | 858 | regional reliability | Convert 8.7 mile Sprno Valley - Krippe 69 kV line to 138 kV. | \$16,000,000 | OGE | 06/01/15 | 06/01/15 | | Spring Valley 138 kV | Krippe 138 kV | 1 | |
| | 11133 | 856 | regional reliability | Tap existing Cushing - Bristol 138 kV line into new Greenwood Sub 138 kV transformer bus and add new Greenwood 138/69/13.8 transformer. | \$ | OGE | 06/01/15 | 06/01/15 | | Cushing 138 kV | Bristol 138 kV | 1 | | |
| | 11134 | 856 | regional reliability | Tap existing Oak Grove - Hwy 99 Tap 69 kV circuit into new Greenwood Sub 69 kV transformer bus. | \$ | OGE | 06/01/15 | 06/01/15 | | Oak Grove 69 kV | Hwy 99 Tap 69 kV | 1 | | |
| | 11195 | 869 | regional reliability | Rebuild 11.1 miles with 954 ACSSR Cardinal. | \$4,000,000 | SEPCO | 06/01/15 | 06/01/15 | | Holcomb 115 kV | Fletcher 115 kV | 1 | | |
| | 50215 | 766 | regional reliability | Add 28.8 Mvar capacitor at Swisher 115 kV bus. | \$1,166,400 | SPS | 06/01/15 | 06/01/15 | | Swisher 115 kV | | 1 | | |
| | 50216 | 766 | regional reliability | Add 28.8 Mvar capacitor at Swisher 115 kV bus. | \$1,166,400 | SPS | 06/01/15 | 06/01/15 | | Swisher 115 kV | | 1 | | |
| | 50300 | 30253 | regional reliability | Install 2 Blocks of 7.2 Mvar. | \$593,200 | SPS | 06/01/15 | 06/01/15 | | LaJ 138 kV | | 1 | | |
| | 50301 | 30254 | regional reliability | Install 2 Blocks of 14.4 Mvar. | \$1,166,400 | SPS | 06/01/15 | 06/01/15 | | LaJ Road 138 kV | | 1 | | |
| | 11010 | 766 | regional reliability | Add second Newhart 230/115 kV transformer. | \$3,892,500 | SPS | 06/01/15 | 06/01/15 | | Newhart 3115 kV | Newhart 6 230 kV | 2 | | |
| | 11057 | 798 | regional reliability | Reconductor Amantio - Farmers 115 kV Circuit 2.35 miles with 795 kcmil conductor | \$992,000 | SPS | 06/01/15 | 06/01/15 | | Amantio South Interchange 115 kV | Farmers Sub 115 kV | 1 | | |
| | 11060 | 801 | regional reliability | Build new 8.5 mile Lea County Ancei - Gaines 69kV line. | \$3,828,000 | SPS | 06/01/15 | 06/01/15 | | Lea County REC-Ancei 69 kV | Lea County REC-Gaines 69 kV | 1 | | |
| | 11061 | 801 | regional reliability | Build new 9 mile Lea County TP-91 - Garby 69kV line. | \$4,050,000 | SPS | 06/01/15 | 06/01/15 | | Lea County REC-TP91 69 kV | Lea County REC-Garby 69 kV | 1 | | |
| | 11062 | 801 | regional reliability | Build new ERP3 substation with new 44MVA 115/69kV transformer. | \$11,250,000 | SPS | 06/01/15 | 06/01/15 | | New ERP3 115 kV | Lea County ERP 69 kV | 1 | | |
| | 11175 | 886 | regional reliability | Add second Swisher 230/115 kV transformer. | \$6,350,000 | SPS | 06/01/15 | 6/1/2015 | | Swisher 230 kV | Swisher 115 kV | 2 | | |
| | 20004 | 10186 | 145 | regional reliability | Add 230 kV line from Hobbs to Seminole - 541 MVA. | \$8,920,699 | SPD | 06/01/15 | M | 02/13/08 | Hobbs 230 kV | Seminole 230 kV | 1 | |
| | 10536 | 694 | regional reliability - non OATT | Replace disconnect switches, replace some structures and reset line. | \$167,500 | SWPA | 06/01/15 | 06/01/15 | | Ashville 161 kV | Poplar Bluff 161 kV | 1 | | |
| | 10575 | 444 | regional reliability - non OATT | Reconductor 12.2 mi line with 795 ACSSR. | \$650,000 | SWPA | 06/01/15 | 06/01/15 | | Nixa 69 kV | Nixa DT 69 kV | 1 | | |
| | 50285 | 30272 | regional reliability | Install 6 Mvar capacitor at Cole 69 kV bus. | \$300,000 | WPEC | 06/01/15 | 06/01/15 | | Cole 69 k | | | | |

SPB Board of Directors Approved Appendix A Projects January 26, 2010

Table with columns for project ID, year, priority, category, description, cost, agency, start date, end date, and location. The table lists various utility projects from 2000 to 2019, including reconductors, transformers, and line upgrades across different regions like Rock Hill, Carthage, and various counties in North Carolina.

SPP Board of Directors Approved Appendix A Projects January 26, 2010

| | | | | | | | | | | | | |
|-----------------|-------|---------------------------------|--|-------------|-------|----------|---|--------------|-----------|--|-----------------------------------|---|
| 10977 | 671 | regional reliability | Increase CT ratio at both Chickasaw and Ardmore. Also possibly change out relay | \$450,000 | OGE | 06/01/19 | | | | Ardmore 69 kv | Chickasaw 69 kv | 1 |
| 10999 | 30212 | regional reliability | Replace Jones Tap bus 1200A switch with 2000A switch | \$420,000 | OGE | 06/01/19 | | | | Jones Tap 138 kv | Shawnt 138 kv | 1 |
| 11119 | 849 | regional reliability | Upgrade the existing 550 amp 69 kv switches in Kentucky Sub to 1200 amp | \$60,000 | OGE | 06/01/19 | | | | Kentucky 69 kv | Kentucky Tap 69 kv | 1 |
| 11207 | 916 | regional reliability | Replace wavetrapp | \$225,000 | OGE | 06/01/19 | | | | Bryant 138 kv | Memorial 138 kv | 1 |
| 10906 | 669 | regional reliability | Replace South Waverly 161/69kv transformer with larger 30/33MVA model; interim mitigation is to move 20% of load off S Waverly 161kv bus starting in 2010 | \$2,000,000 | KCPCL | 06/01/19 | | | | South Waverly 161kv | South Waverly 69kv | 1 |
| 11135 | 859 | regional reliability | Reconductor Hawthorn - Birmingham 16 kv | \$1,670,625 | KCPCL | 06/01/19 | | | | Birmingham 161kv | Hawthorn 161kv | 1 |
| 10994 | 30211 | regional reliability | Replace Medicine Lodge 138/115 kv transformer with a larger 147/170 MVA transformer | \$3,825,000 | MKEC | 06/01/19 | | | | Medicine Lodge 138 kv | Medicine Lodge 115 kv | 1 |
| 10991 | 30208 | regional reliability | Rebuild MKEC portion of the Clearwater-Milan tap 115 kv with bundled 1192.5 kcmil ACSR conductor (Burling) | \$3,150,000 | MKEC | 06/01/19 | | | | Clearwater 138 kv | Milan Tap 138 kv | 1 |
| 10993 | 30210 | regional reliability | Replace Wave Trap at Harrier Substation | \$225,000 | MKEC | 06/01/19 | | | | Harper 138 kv | Milan Tap 138 kv | 1 |
| 10990 | 753 | regional reliability | Reconductor and upgrade terminal equipment to effect higher rating by 2015: 240 MVA Normal Continuous Rating: 240 MVA 4-Hour Emergency Rating | \$6,000,000 | NPPD | 06/01/19 | | | | Beatrice 115 kv | Harbine 115 kv | 1 |
| 20254 | 30241 | regional reliability | Install 21.6 Mvar capacitor bank | \$2,213,000 | OPPD | 06/01/19 | | | | Neb City U Sub 903 69 kv | | |
| 50306 | 30269 | regional reliability | Install 2 Blocks of 14.4 Mvar | \$1,186,400 | SPS | 06/01/19 | | | | Lamb Co 115 kv | | |
| 50307 | 30270 | regional reliability | Install min. 2 Blocks 14.4 Mvar | \$1,186,400 | SPS | 06/01/19 | | | | Deaf Smith 115 kv | | |
| 20031 | 10195 | regional reliability | Add third Tupo 115/69 kv auto transformer with 84/84 MVA rating | \$1,260,000 | SPS | 06/01/19 | | 01/27/09 | | Tupo 69 kv | Tupo 115 kv | 1 |
| 20031 | 10197 | regional reliability | Add third Polash Junction Interchange 115/69 kv transformer | \$600,000 | SPS | 06/01/19 | | 01/27/09 | | Polash Junc 69 kv | Polash Junc 115 kv | 1 |
| 11092 | 825 | regional reliability | Reconductor 0.45 miles 69 kv from 4/0 to 357.5 ACSR | \$225,000 | SPS | 06/01/19 | | | | Artesia 69 kv | CV-Artesia 69 kv | 1 |
| 11094 | 827 | regional reliability | Reconductor 5.34 miles 115 kv from 397.5 to 750 ACSR | \$3,518,426 | SPS | 06/01/19 | | | | Cherny 115 kv | Northwest 115 kv | 1 |
| 11099 | 832 | regional reliability | Add 2nd transformer 115/69 kv 54/96 MVA C&T 2 | \$1,890,000 | SPS | 06/01/19 | | | | Northwest 69 kv | Northwest 115 kv | 2 |
| 11105 | 838 | regional reliability | Add new 115 kv CKL Hookley Co-E Leveland Co | \$3,037,500 | SPS | 06/01/19 | | | | Hookley Co 115 kv | E Leveland 115 kv | 1 |
| 11126 | 858 | regional reliability | convert 69 kv load onto 115 kv | 65375 | SPS | 06/01/19 | | | | Stanton 69 kv | Stanton 69 kv | 1 |
| 11199 | 901 | regional reliability | Replace NICHOLS Line Trap with 1200 Amp B unit 230 kv | 4450,000 | SPS | 06/01/19 | | | | Nichols Station 230 kv | Amarillo South Interchange 230 kv | 1 |
| 10850 | 855 | regional reliability - non CATT | Replace Springfield transformer #1 three winding transformer with 70 MVA auto transformer | \$225,000 | SWPA | 06/01/19 | | | | Springfield 69 kv | Springfield 69 kv | 1 |
| 11193 | 869 | zonal - sponsored | convert County Line - Arnold to 115 kv. Valley Falls sub converted to 115 | \$6,651,575 | WR | 06/01/19 | | M | | County Line 115 kv | Valley Falls 115 kv | 1 |
| 11194 | 868 | zonal - sponsored | convert County Line - Arnold to 115 kv. Valley Falls sub converted to 115 | \$9,534,375 | WR | 06/01/19 | | M | | Arnold 115 kv | Valley Falls 115 kv | 1 |
| 10992 | 30209 | regional reliability | Rebuild Westar portion of the Clearwater-Milan tap 115 kv with bundled 1192.5 kcmil ACSR conductor (Burling) | \$3,431,250 | WR | 06/01/19 | | | | Clearwater 138 kv | Milan Tap 138 kv | 1 |
| Withdraw | | | | | | | | | | | | |
| 20000 | 10444 | 347 | Reconductor with 2.7 miles 477 ACSR 69 kv Woodlawn-Baldwin. Reset relays | \$2,000,000 | AEP | 06/01/11 | D | NTC-Withdraw | 02/13/08 | Baldwin 69 kv | Woodlawn 69 kv | 1 |
| 20027 | 10614 | 477 | Reconductor 5.2 miles with 477 ACSR 69 kv from Baldwin - Kamacka Tap | \$6,500,000 | AEP | 06/01/13 | D | NTC-Withdraw | 01/27/09 | Baldwin 69 kv | Kamacka Tap 69 kv | 1 |
| 20016 | 10440 | 345 | Replace 69 kv switch at Maxvilia tap for new emergency limit 85 MVA | \$125,000 | AEP | 06/01/10 | D | NTC-Withdraw | 01/16/09 | Quilman-Maxvilia 69 kv | Forest Hills REC 69 kv | 1 |
| 20011 | 10572 | 441 | Reconductor 69kv line from 636 ACSR to 752.8 ACSR/TW | \$905,000 | CUS | 06/01/12 | D | NTC-Withdraw | 02/13/08 | Kokopoo 69 kv | Sunset 69 kv | 1 |
| 20034 | 50182 | 30174 | Install 5 Mvar capacitor at Crain 69 kv bus | \$355,000 | GMO | | D | NTC-Withdraw | 01/27/09 | Crain 69 kv | | |
| 20034 | 50182 | 30076 | Install 12 Mvar capacitor at Warsaw 69 kv bus | 1409,900 | GMO | | D | NTC-Withdraw | 01/27/09 | Warsaw 69 kv | | |
| 20028 | 50185 | 30177 | Add additional 7.2 Mvar capacitor at Tahlequah West, for a 28.8 Mvar total | \$291,600 | GRDA | | D | NTC-Withdraw | 1/27/2009 | Tahlequah West 69 kv | | |
| 20009 | 10492 | 379 | New Hilldale-Cedar Niles 161 kv Line and Cedar Niles ring bus | \$5,418,700 | KCPCL | 06/01/15 | D | NTC-Withdraw | 02/13/08 | Hilldale 161 kv | Cedar Niles 161 kv | 1 |
| 20002 | 10515 | 397 | Convert 7 mile Mustang - Yukon 65 kv line to 135 kv | \$6,850,000 | OGE | 06/01/12 | D | NTC-Withdraw | 02/13/08 | Mustang 135 kv | Yukon 135 kv | 1 |
| 20002 | 10516 | 397 | Convert 3 mile Yukon - Cimarron 69 kv line to 135 kv | \$3,000,000 | OGE | 06/01/12 | D | NTC-Withdraw | 02/13/08 | Yukon 135 kv | Cimarron 135 kv | 1 |
| 20003 | 20100 | 30094 | Install 6 Mvar capacitor at Mustang 69 kv | \$152,000 | WFEC | | D | NTC-Withdraw | 02/13/08 | Mustang 69 kv | | |
| 20033 | 10811 | 623 | Rebuild the 14.63 miles of 69 kv line from Timber Junction - Winfield | \$7,415,000 | WR | 12/31/10 | D | NTC-Withdraw | 01/27/09 | Timber Junction 69 kv | City Of Winfield 69 kv | 1 |
| 20033 | 10812 | 624 | Build new 8.76 mile Fort Junction - West Junction City 115 kv line that follows the path of the JEC - Summit 345 kv line. Remove old double circuit and West Junction City Junction (East) - West Junction City 115 kv line. | \$4,527,500 | WR | 06/01/11 | D | NTC-Withdraw | 01/27/09 | Fort Junction Switching Station 115 kv | West Junction City 115 kv | 1 |
| 20006 | 10638 | 410 | Rebuild Ark Valley Tower 33 115 kv | \$3,206,200 | WR | | D | NTC-Withdraw | 02/13/08 | Ark Valley 115 kv | Tower 33 115 kv | 1 |
| 20033 | 10640 | 495 | Rebuild the 5.49 mile Lawrence Hill to Mockingbird Hill 115 kv line | \$2,377,445 | WR | | D | NTC-Withdraw | 01/27/09 | Lawrence Hill 115kv | Mockingbird Hill 115 kv | 1 |
| 20033 | 10218 | 169 | Upgrade CT ratio on Chapman - Clay Center 115 kv line | \$10,000 | WR | 06/01/17 | D | NTC-Withdraw | 01/27/09 | Chapman 115 kv | Clay Center Junction 115 kv | 1 |

Appendix B – Empire District STEP Projects

| SPP Board Of Directors Approved Transmission Expansion Projects 1-26-10 - Empire District Electric Projects Only | | | | | |
|--|---|---------------|--|-------------------------------------|---------|
| Project Type | Project Description/Comments | Cost Estimate | From Bus Name | To Bus Name | Circuit |
| YEAR 2010 | | | | | |
| Zonal Reliability | Install (3) 22 Mvar capacitor banks for a total of 66 Mvar at Riverside Sub #438 | \$2,600,000 | SUB 438 - Riverside 161 kV | | |
| regional reliability | Change CT setting on Breaker #6973 at Baxter #271 to 800/5 ratio | \$50,000 | SUB 404 - Hockerville 69 kV | SUB 271 - Baxter Springs West 69 kV | 1 |
| regional reliability | Change CT ratio on breaker #6936 at Aurora Substation 124 | \$5,000 | SUB 124 - Aurora H.T. 69 kV | SUB 152 - Monett H.T. 69 kV | 1 |
| transmission service | Rebuild 1.7 mile Neosho South Jct. - Neosho SPA 161 kV from 336 ACSR to 795 ACSR and replace terminal equipment | \$1,215,000 | SUB 184 - Neosho South Junction 161 kV | Neosho (SWPA) 161 kV | 1 |
| regional reliability | Replace 600 amp disconnect switches with a minimum 1,2300 amp units and replace leads on Breaker #6965 at Sub #64 and #6932 at Sub #145 | \$55,000 | SUB 145 - Joplin West 7th 69 kV | Sub 64 - Joplin 10th ST 69 kV | 1 |
| YEAR 2011 | | | | | |
| transmission service | Replace auto transformer at ORONOGO 110 with 150 MVA rated auto transformer due to increased generation available | \$4,000,000 | ORO110 5 161 kV | ORO110 2 69 kV | 1 |
| transmission service | Reconductor 11.9 miles of Oronogo Jct. to Riverton 161 kV Ckt. 1 from 556 ACSR to 795 ACSR, change CT settings @ Oronogo, and replace wavetrap. | \$5,750,000 | Sub 110 - Oronogo Jct. | Sub 167 - Riverton | 1 |
| YEAR 2012 | | | | | |
| regional reliability | Reconductor 8.92 miles Nichols-Sedalis 69 kV with 556 ACSR and upgrade CTs | \$3,520,000 | SUB 170 - Nichols St 69 kV | Sedalia 69 kV | 1 |
| regional reliability | Replace jumpers on breaker #6950 at Blackhawk Junction with 556 ACSR for rates 73/89 MVA | \$50,000 | Jamesville 69 kV | SUB 415 - Blackhawk Junction 69 kV | 1 |
| YEAR 2013 | | | | | |
| NONE | | | | | |
| YEAR 2014 | | | | | |
| regional reliability | Replace jumpers | \$100,000 | SUB 403 - Jasper West Tap 69 kV | SUB 249 - Boston East 69 kV | 1 |
| regional reliability | Raise structures on Diamond Jct. - Sarcoxie Southwest 69 kV line to achieve a new rating B of 44 MVA | \$50,000 | SUB 131 - Diamond Junction 69 kV | SUB 362 - Sarcoxie Southwest 69 kV | 1 |
| regional reliability | Replace switch on transfer bus at Sub #167 for Rate B = 91 MVA | \$75,000 | Sub 167 - Riverton 69 kV | SUB 278 - Galena Northeast 69 kV | 1 |
| regional reliability | Reconductor 1.0 Mile of 4/0 ACSR with 336 ACSR for 65 MVA Rate B | \$400,000 | SUB 436 - Webb City Cardinal 69 kV | SUB 110 - Oronogo Junction 69 kV | 1 |
| YEAR 2015 | | | | | |
| regional reliability | Build new 9.2 mile Substation 383 - Monett 5 161 kV line | \$7,389,319 | SUB 383 - Monett 161 kV | South Monett 161 kV | 1 |
| regional reliability | Install 3-winding transformer connecting new 161 kv line to Monett City South 69 kV | \$8,000,000 | South Monett 161 kV | SUB 376 - Monett City South 69 kV | 1 |
| regional reliability | Reconductor 1.2 mi with 336 ACSR | \$275,000 | Monett City South Jct. 69 kV | Monett City East 69 kV | 1 |
| YEAR 2016 | | | | | |
| zonal - sponsored | Convert 27 mi of 34.5 kV to 69 kV in the Baxter Springs area | \$12,375,000 | | | |

| SPP Board Of Directors Approved Transmission Expansion Projects 1-26-10 - Empire District Electric Projects Only (continued) | | | | | |
|--|--|-------------|----------------------------------|------------------------------------|---|
| YEAR 2017 | | | | | |
| regional reliability | Reconductor 7.55 miles Diamond-Jct - Sarcoxie Southwest 69 kV lines from 1/0 Cu to 336 ACSR | \$2,274,000 | SUB 131 - Diamond Junction 69 kV | SUB 362 - Sarcoxie Southwest 69 kV | 1 |
| regional reliability | Tear down the Riverton to Joplin 59 69 kV line, rebuilding the line to 161 kV from Stateline to outside Joplin sub. Tear down and rebuild Joplin 59 to Gateway to Pillsbury to Reinmiller, converting those 69 kV lines to 161 kV. Tap the 161 kV line between Joplin 59 and Gateway at Joplin 422 | | SUB 439 - Stateline 161 kV | Joplin 59 161 kV | 1 |
| regional reliability | | | Joplin 59 161 kV | Gateway 161 kV | 1 |
| regional reliability | | | Gateway 161 kV | Pillsbury 161 kV | 1 |
| regional reliability | | | Pillsbury 161 kV | Reinmiller 161 kV | 1 |
| regional reliability | Reconductor 3.5 miles Atlas Jct - Carthage Northwest 69 kV lines from 4/0 ACSR for 65 MVA Rate B | \$1,277,935 | SUB 109 - Atlas Junction 69 kV | SUB 108 - Carthage Northwest 69 kV | 1 |
| YEAR 2018 | | | | | |
| | | NONE | | | |
| YEAR 2019 | | | | | |
| | | NONE | | | |

Appendix C
Empire 2010-2014 Transmission and Distribution Construction Budget **Highly Confidential in its Entirety******

****Highly Confidential in its Entirety****

****Highly Confidential in its Entirety****

****Highly Confidential in its Entirety****

****Highly Confidential in its Entirety****

****Highly Confidential in its Entirety****

****Highly Confidential in its Entirety****

****Highly Confidential in its Entirety****

****Highly Confidential in its Entirety****

****Highly Confidential in its Entirety****

****Highly Confidential in its Entirety****

****Highly Confidential in its Entirety****

Abbreviations

ACFB – Atmospheric Circulating Fluidized Bed
 AECI – Associated Electric Cooperative
 AEP – American Electric Power
 AFUDC – Allowance for Funds Used During Construction
 AMI – Advanced Metering Infrastructure
 AQCS – Air Quality Control Systems
 AWEA – American Wind Energy Association
 BNSF – Burlington Northern Santa Fe Railroad
 Btu – British Thermal Unit
 CAES – Compressed Air Energy Storage
 CAIR – Clean Air Interstate Rule
 CAMR – Clean Air Mercury Rule
 CC – Combined cycle
 CCS – Carbon capture and sequestration
 CFB – Circulating Fluidized Bed
 CO₂ – Carbon dioxide
 CSP – Concentrating solar power
 CT – Combustion turbine
 DOE – Department of Energy
 EIA – Energy Information Administration
 EPA – U.S. Environmental Protection Agency
 ESBWR – Economic simplified boiling-water reactor
 FERC – Federal Energy Regulatory Commission
 GDP – Gross Domestic Product
 Hg – Mercury
 HRSG – Heat recovery steam generator
 IGCC – Integrated Gasification Combined Cycle
 IRP – Integrated Resource Plan or integrated resource planning
 ITP – Integrated Transmission Planning
 KCP&L – Kansas City Power & Light
 kV – kilovolt
 kW – kilowatt
 kWh – kilowatthour
 MCSP – Missouri Carbon Sequestration Project
 MMBtu- Millions of British Thermal Units
 MPSC – Missouri Public Service Commission
 MW – Megawatt
 MWh – Megawatthour
 NO_x – Nitrous oxides
 NRC – U.S. Nuclear Regulatory Commission
 NYMEX – New York Mercantile Exchange
 NSI – Net System Input
 O&M – Operating and Maintenance
 OG&E – Oklahoma Gas & Electric

OMS – Outage Management System
PPA – Power Purchase Agreement
PRB – Power River Basin
PV - Photovoltaics
PVRR – Present Value of Revenue Requirements
REC – Renewable Energy Credit
RMP – Risk Management Policy
RPS – Renewable Portfolio Standard
SCR – Selective catalytic reduction
SLCC – State Line Combined Cycle
SMR – Small modular reactor
SO₂ – Sulfur dioxide
SPP – Southwest Power Pool
SPP RTO – Southwest Power Pool Regional Transmission Organization
STEP – SPP Transmission Expansion Plan
VOC – Volatile Organic Compounds
WTI – West Texas Intermediate