

DATA INFORMATION REQUEST
Missouri-American Water Company
WU-2017-0296

Requested From: Tim Luft
Date Requested: 8/9/17

Information Requested:

Referencing OPC DR-2009, does the Company believe it must take any and all steps to address possible sources of lead contamination from customer-owned property or just service lines and goose necks to remain in compliance with applicable drinking water regulation? If no, please provide a narrative explanation as to what possible sources of lead contamination are not the Company's responsibility in order to remain in compliance with applicable drinking water regulation.

Requested By: Geoff Marke – Office of Public Counsel – geoff.marke@ded.mo.gov

Information Provided:

The Company takes many actions to maintain compliance with the Lead and Copper Rule to protect the health and safety of our customers. We are currently in compliance with LCR requirements without replacing any portion of the service lines and our goal is to maintain compliance. Currently, MAWC actions include source water assessments, treatment optimization, water quality monitoring at the treatment plants and distribution system, inventorying service lines, replacing lead service lines and goosenecks when encountered during construction, evaluating changes to treatment and supplies, and public education. Current drinking water regulations do not require actions "to address possible sources of lead contamination from customer-owned property" beyond what has been historically practiced by the Company. The USEPA is considering a household action level for lead; however, the revisions to the LCR have not been released as of August 21, 2017.

Responsible witness: Bruce Aiton

OPC Exhibit No. 30
Date 9/27/17 Reporter *ML*
File No. WU-2017-0296