

# LOG OF BORING NO. 5-2

OWNER ST. JOSEPH WATER WORKS	ARCHITECT-ENGINEER AMERICAN WATER WORKS
SITE ST. JOSEPH, MISSOURI	PROJECT NAME PROPOSED CHEMICAL PLANT

DEPTH ELEVATION	SAMPLE NO.	TYPE SAMPLE	SAMPLE DIST.	RECOVERY	DESCRIPTION OF MATERIAL	UNIT DRY WT. LBS./FT. 3	UNCONFINED COMPRESSIVE STRENGTH TONS/FT. 2
							<div> 12345 </div> <div> PLASTIC LIMIT %      WATER CONTENT %      LIQUID LIMIT % </div> <div> X      ●      ▲ </div> <div> STANDARD "N" PENETRATION (BLOWS/FT.) </div> <div> 1020304050 </div>
×					SURFACE ELEVATION → 321.9		
	1	ST			"A"	93	
	2	ST			SILTY CLAY - GRAY AND BROWN - VERY TOUGH (CL-CH)	87	
	3	ST			SILT, TRACE CLAY AND FINE SAND - GRAY AND BROWN -	86	
10.0	4	ST			LOOSE (ML)	91	
	5	ST			SILTY CLAY - DARK BROWN - TOUGH (CL)	93	
20.0	6	3" ST					
	7	3" ST					
	8	ST					
30.0	8A				SANDY CLAYEY SILT WITH PIECES OF BROKEN LIMESTONE - BROWN MOTTLED WITH YELLOW - MEDIUM DENSE (SC-SM)	107	
	9	ST					
40.0	10	ST				90	
	11	SS			SILTY CLAY, TRACE SAND AND GRAVEL - GRAY AND BROWN - VERY TOUGH (CL)		
49.5	12	SS			END OF BORING		
					"A": FILL, CLAYEY SILT, TRACE SAND, CINDERS, AND RUBBLE - DARK BROWN		

WATER LEVEL OBSERVATIONS			
W.L.	11.5'	W.S. OR W.D.	
W.L.	B.C.R.	A.C.R.	
W.L.	11.0' A.B.		

**SOIL TESTING SERVICES**  
INC.  
111 PFINGSTEN ROAD  
NORTHBROOK, ILLINOIS

BORING STARTED	11/28/67
BORING COMPLETED	11/28/67
RIG	FOREMAN
DRAWN MP	APPROVED CNE
JOB #	8908-0
SHEET	1 OF 1

# LOG OF BORING NO. B-3

OWNER						ARCHITECT-ENGINEER					
ST. JOSEPH WATER WORKS						AMERICAN WATER WORKS					
SITE						PROJECT NAME					
ST. JOSEPH, MISSOURI						PROPOSED CHEMICAL PLANT					
DEPTH ELEVATION	SAMPLE NO.	TYPE SAMPLE	SAMPLE DIST.	RECOVERY	DESCRIPTION OF MATERIAL	UNIT DRY WT. LBS./FT. 3	UNCONFINED COMPRESSIVE STRENGTH TONS/FT. 2				
							PLASTIC LIMIT %	WATER CONTENT %	LIQUID LIMIT %		
SURFACE ELEVATION → 82.4						STANDARD "N" PENETRATION (BLOWS/FT.)					
							10	20	30	40	50
	1	ST			FILL, CLAYEY SILT, TRACE SAND, CINDERS AND RUBBLE - DARK BROWN (FILL)						
	2	ST			SILT, TRACE CLAY AND FINE SAND - GRAY AND BROWN - LOOSE (ML)	87					
10.0	3	ST				85					
	4	ST									
	4A	ST									
					CLAYEY SILT WITH PIECES OF BROKEN LIMESTONE - GRAY - LOOSE TO MEDIUM DENSE (ML-CL)	84					
20.0	5	ST				91					
	6	ST				91					
30.0	7	ST				94					
					SANDY CLAYEY SILT WITH PIECES OF BROKEN LIMESTONE - BROWN, MOTTLED WITH YELLOW - MEDIUM DENSE TO DENSE (SC-SM)	97					
40.0	9	ST				107					
	10	ST									
50.0	11	ST			SILTY CLAY, TRACE SAND - GRAY AND BROWN - VERY TOUGH TO HARD (CL)	109					
	12	ST			GRAY SHALE						
CONTINUED ON PAGE 2											

CONTINUED ON PAGE 2

LOG OF BORING NO. B-3 (CONTINUED)										
OWNER ST. JOSEPH WATER WORKS					ARCHITECT-ENGINEER AMERICAN WATER WORKS					
SITE ST. JOSEPH, MISSOURI					PROJECT NAME PROPOSED CHEMICAL PLANT					
DEPTH ELEVATION	SAMPLE NO.	TYPE SAMPLE	SAMPLE DIST. RECOVERY	DESCRIPTION OF MATERIAL	UNIT DRY WT. LBS./FT. 3	UNCONFINED COMPRESSIVE STRENGTH TONS/FT. 2				
						1	2	3	4	5
						PLASTIC LIMIT % X		WATER CONTENT % ●		LIQUID LIMIT % △
						STANDARD "N" PENETRATION (BLOWS/FT.)				
						10	20	30	40	50
				CONTINUED FROM PAGE 1						
				GRAY SHALE						
60.0										
67.0										
				END OF BORING POWER AUGER REFUSAL AT 67.0'		*CALIBRATED PENETROMETER				

## WATER LEVEL OBSERVATIONS

W.L.	W.S. OR W.D.	
W.L.	B.C.R.	A.C.R.
W.L.		

BORING STARTED 11/29/67

**BORING COMPLETED** 11/29/67

<b>RIG</b>	<b>FOREMAN</b>
------------	----------------

DRAWN	MP	APPROVED CNE
-------	----	--------------

JOB # 8002-D SHEET 1 OF 1

## CONSOLIDATION TEST

Void Ratio vs. Pressure

Job Name:

Job No.: 8908-1

Boring: B-1

Sample: S-4-2

Depth: B-10

## TEST DATA

Sample Initial Height = 1 in.

Sample Diameter = 2.5 in.

Dry Density

Initial = 85.5 pcf

After Rebound =

Moisture Content

Initial = 38.4%

After Rebound =

Atterburg

LL = 63%

PL = 27%

PI = 46%

Soil Testing Services, Inc.  
111 Pfingsten Road  
Northbrook, Illinois

By: JPS Checked by: CMB

# CONSOLIDATION TEST

Void Ratio vs. Pressure

Job Name:  
 Job No.: 8908-0  
 Boring: B-1  
 Sample: S-3-3  
 Depth: 113-115'


## TEST DATA

Sample initial height = 1 in.  
 Sample Diameter = 2.5 in.

Dry Density  
 Initial = 95.4 pcf  
 After Rebound = 111.3 pcf

Moisture Content  
 Initial = 29.02  
 After Rebound = 21%

Atterburg Limits  
 LL = 26%  
 PL = 21%  
 PI = 15%





Electrical -	\$ 2,425,000
HVAC -	776,000
Plumbing -	505,000
Instrumentation	1,550,000

Site Work:

Tank & Fdn.	1,940,000
Bldg. Fdns.	2,910,000
Raw Water Main & Meters	190,000
Settled Water	285,000
Transfer Pipe/H.S. Suction	402,000
H.S. Discharge	52,000
Waste water Line	102,000
Overflow	37,000
Sanitary Facilities	24,000
Pulsator Drain lines/valves	122,000
Pre Sed Basin Mads.	58,000
Chem feed lines to intake	92,000
Spill Containment System	15,000
Storm Water System	43,000
Soil Erosion & Control	19,000
Utility Relocations	48,000
Paving	37,000
Curbs	10,000
Sidewalks	7,000
Structural Excavation/Backfill	182,000
Demolition - Basin # 1, 2, 3 + Filtr. Bldg.	493,000
Topsoil Seeding	10,000
Landscaping	48,000
Site Dewatering - Well Pts	194,000
Puls. temp flame	25,000

7,350,000

1. Pulsators

Concrete	1,273,000
Superstructure	754,000
Process	1,600,000
	<hr/>
	* 3,627,000

2. Chemical Bldg

Concrete	836,000
Superstructure	1,051,000
Process	2,448,000
	<hr/>
	* 4,335,000

3. Filter Bldg / Clearwell

Concrete	1,288,000
Superstructure	665,000
Process	2,540,000
	<hr/>
	* 4,493,000

4. Transfer / H.S Pump Station

Concrete	305,000
Superstructure	365,000
Process	899,000
	<hr/>
	* 1,569,000

Total This Page: \$ 14,024,000

GRAND TOTAL \* 26,630,000





Summary of Unit Prices

Concrete	CY	450.7
D.I. Fittings	LB	2.00
48" DIP	LF	200.
42" DIP	LF	175
36" DIP	LF	137
Bit. Paving	SY	25.7
Conc. Curbs	LF	20
Conc. Sidewalks	SY	25
Structural Excavation	CY	10
Structural Backfill	CY	15
Superstructure - Pulsators	SF	60
- Filters	SF	60
- Chem. Bldg	SF	80
- Pump Sta	SF	80



# Process Breakdown By Est Sheet #

Sheet #	(1) Pulsators	(2) Chem	(3) F. ltr	(4) Pmp Sk	I Instrum.	pg total
1	—	9,000	—	456,000	—	465,000
2	—	—	—	—	316,000	316,000
3	—	115,000	—	—	—	115,000
4	1,360,000	110,000	4,000	—	—	1,474,000
5	—	401,000	—	—	—	401,000
6	—	549,000	—	—	—	549,000
7	—	105,000	1,698,000	—	—	1,803,000
8	—	373,000	—	32,000	—	405,000
9	74,000	99,000	554,000	320,000	—	1,047,000
10	74,000	—	—	—	—	74,000
11	27,000	400,000	210,000	78,000	—	715,000
12	—	—	—	—	657,000	657,000
13	—	—	—	—	280,000	280,000
14	—	—	—	—	345,000	345,000
15	44,000	30,000	94,000	5,000	—	173,000
16	7,000	162,000	4,000	—	—	173,000
17	54,000	46,000	—	—	—	100,000
18	—	25,000	—	—	—	25,000
19	10,000	100,000	54,000	36,000	—	200,000
	1,650,000	2,524,000	2,618,000	927,000	1,598,000	9,317,000
X.97						
=	1,600,000	2,448,000	2,540,000	899,000	1,550,000	

\*

Division 11000

11160 Dock Leveler & Bumpers

$$H. 5488 \times 1.38 = 7573 + 1.15 = 8700$$

$$B. 7000 \times 1.265 = 8855$$

$$F. 10,750 \times 1.3225 = 14,200$$

use \$9,000 - (

~~11202 Sluice Gates~~ see next sheet

11214 Vertical Turbine Pumps

5.0 MGD Transfer Pump @ 75HP	\$33,000
10.0 " " " @ 125HP	\$50,000
15.0 " " " @ 200HP	\$65,000
15.0 " " " @ 200HP	\$65,000

6 MGD VFD High Service Pumps.

Can Pump 600HP  
VFD

\$70,000  
\$43,000

326,000  
+ 1.4  
\$456,800 (4)

\$465,000

# Sluice Gates

Assume

6 Filter Influent Gates 3'x3' @ \$15,000 = 90,000  
w/ Motor Oper

6 Filter Waste Gates 2'x3' @ 14,000 = 84,000  
w/ Motor Oper


2 Clearwell Gates @ 4'x4' @ 10,000 = 20,000  
w/ Floor Stand

1 Clearwell Gate @ 3'x3' @ 15,000 = 15,000  
w/ Floor Stand

226,000

+ 1.4%

\$ 316,000



Transfer Pump Sump

11214 Vertical Turbine Pumps

Transfer Pumps

5 MGD

10 "

15 "

15 "

see first sheet

High Service Pumps w/VFD

6 MGD

112

Chemical Transfer Pumps

2 C.S.

2 F

2 A

2 CA

2 Water Water

10 Pumps @ \$11,500 = \$115,000

$$F \quad 7900.00 \times 1.3225 = 10,450$$

$$B \quad 41,000 (4) \times 1.265 = 13,000 \quad \text{also } 11,500$$

\$115,000 (2)

13 18,000

11218 Sample Pumps

Pre Sed Basin Effluent

Mixed Water

Filter Influent

Filter Effluent 4 @ 2000

8000

4K (1)  
4K (3)

11223 Fiberglass Stop Gate and Weir Plates

Slow Mix. Basin

3 @ 5' x 3'

2 @ 5' x 5'

Pulsator Effluent

3 @ 7' x 2'

3 @ 7' x 4'

11 @ \$2,000 w/frame

\$22,000

10K (3)  
12K (1)

11224 Pulsator Units

3 @ 460,000 x 1.4

= 1,344,000

11225

Mixer Equipment

1 Rapid Mixer @

1 Slow Mixer @

Mixer + VFD

\$33,600 + 9,500 = 43,100

\$24,303 + 4,500 = 28,803

\$71,903

plus

\$100,660

1,474,000



11241 Polymer Feed Pumps

4 @ \$8,000 x 1.4 =

\$45,000

11242 Chemical Feed Pumps

4 Series 43 @ 7,000 = 28,000

16 Series 44 @ 5,500 88,000

1 Series 45 @ 2,000 2,000

85,000 x 1.4 = 120,000

11244 Chlorination Feed System

2 Pre Cl<sub>2</sub>

13 49,000

4 (15,000 + 7,000) x 1.15 = 94,000 = 138,000

2 Pos Cl<sub>2</sub>

8 105,000 x 1.3225 =

138,

2 Evaporators

say \$142,000

11245 Cross Linked High Density Polyethylene Tanks  
w/ Site Gages

4 - 10,000 Gal Alum x \$1.10 =

\$44,000

1 - 6,000 Gal Fluoride

6,600

1 - 6,000 Gal Coagulant Aid

6,600

1 - 6,000 Gal Spar Tank

6,600

1 - 400 Gal Alum Tank

440

1 Gal Coag Aid

440

2 Gal KMnO<sub>4</sub>

880

2 Gal Filter Aid

880

2 800 Gal Polymer Batch Tanks

1760

1 400 Gal Lab Wastewater Tank

440

68,640 x 1.4 = 96,100  
94,010

11246 Botel Tank Mixers

F 23500 3,100

2 KMnO<sub>4</sub>

2 Polymer Tanks

4 @ 3,100

2 \$12,000

11247 Bulk Chemical Feed System w/

Lime Silo & Feeders B 172,000

Add Weight Transmitter H 23,000 + 32,000

180,000 x 1.4 = 252,000

Carbon Silo & Feeders

Add Weight Transmitter 130,000 x 1.4 = 182,000

11248 Steel Tanks w/ Site Gage & Heat System

B 34,000

6000 Gal Caustic Soda Tank 15,000 +

400 Gal Caustic Soda Day Tank

w/ Heat System + Insul. H (1700 + 1000) H. 15 = 14,600

say 25,000

11250 Chemical Feed System Accessories

~~4~~ Cl<sub>2</sub> Scales

2 Cl<sub>2</sub> Gas Detectors + 1500 3,000

1 Fluoride Scale + 400

1 SBP Scale 400

1 Atom Scale 400

1 C.A. Scale 4,000

1 RH Scale 400

2 KMnO<sub>4</sub> Scales 8,000

Misc. Equip say 25,000

56,000 x 1.4 = 78,000

548,000



11311 Air Compressor & Related Equipment

$$B 27,250 \times 1.265 = 34,471$$

$$F 23,650 \times 1.3225 = 31,277$$

use 33,000 (2)

11373 Centrifugal Blower B 70,000 (2)

$$40,000 \times 1.4 = 56,000 (3)$$

11450 Kitchanette Unit 46200 + 300

10,000 (2)

13410 Spill Containment Tank F 31,250 + 11,000 +

$$B 42,000 = 54,000 (2)$$

Spill Containment Tank

Spill Containment Valve Manhole 8,000 (2)

13521 (a) Filter Underdrain System

13522 (b) Filter Media  $\frac{38 \times 15.33 + 34 \times 12 + 30 \times 12}{12} \times 1.0 \times 1.25 = 742,000 (3)$

13524 (c) Fiberglass Wastewater Troughs

(d) Air Lateral & Distribution System

$$a+c+d = \frac{835,000}{10 \times 34 \times 12} = 144.44/SF \times 12 \times 15.33 \times 34 = 903,560$$

say \$900,000 (1)

\$1,807,000



Elevator B  $20,000 \times 1.265 =$  \$101,000 (2)

14300 Hoist & Crane

2 - 2 Ton Chlorine Cylinder Hoist

2 @ 6000 = \$12,000 (2)

1 - 7 1/2 Ton Pump truck Crane

\$32,000 (4)

H  $18,000 \times 1.15 = 20,700 \times 1.38 = 28,566$

+ 1.15

larger Unit = 32,850

14510 Truck & Lift

1 - Fork Lift

1 - High Lift Pallet Truck

1 - Drum Handler

10,000 (2)

B 6000  $\times 1.265$

H 8500

12600 Laboratory

B  $70,000 \times 1.265 = 88,550$

H  $65,000 \times 1.15 \times 1.32 = 103,000$

use \$105,000 (2)

Scrubber System B  $105,000 \times 1.4$

\$145,000 (2)

\$405,000



15100 Process Piping

Pre-sedimentation Basin Effluent D

Pulsator Influent Piping D

Process to Filter Piping & Valves L

Raw Water Vent Pipe? 5000 (2)

Pulsator Blow-off Piping L 74,000 (1)

Raw Water Main in Plant 37,721' @ 2" 94,300 (2)

Pulsator Drain Piping D

Filter Air Wash Piping say 50' @ 1" 15,000 (3)

Filter Face Piping 76,173' @ 4" 305,000 (3)

Wastewater Piping 39,821' @ 3" 120,000 (3)  
+ 2,828 @ 3" 8,500 (3)

Clearwell Interconnection Piping

1 4" B.F.V. = 24,500

1 36 B.R.V. 11,200

R.H. & Pipe say 27,995,250 = 69,990 105,700 (3)

Transfer Pump Discharge Piping

93,925 @ 2" = 235,000 (1)

High Service Section Piping


High Service Discharge Piping  
Valves

85,000 (1)

1,947,500




# Pulsator Blow-off Piping



4 Valve / Pulsator  
x 3

12 - 6"  $\phi$  Plug Valve @ 3,500 = \$42,000  
x 1.4



58,800 (1)

6 6" 90° @ 65 = 390  
3 6" Tees @ 95 = 285

20' 6"  $\phi$  x 22" / 1 = 440  
8 6"  $\phi$  Flg. x 17" / 4 = 136

1251 x 3 = 3753 @ 40 = \$15,012 (1)  
74,000

Plant Service Piping 10,430' @ 42 - \$42,000  
Valves 18,100  
\$60,000 (2)

Carbon Removal System Piping  
250' @ \$40. \$10,000 (3)

Chemical Feed Piping &  
Chemical Feed Connection 200,000 (2)

Pipe Supports & Hangers say 100,000 20k (2)  
50k (3)  
20k (4)

Piping Insulation  
Both 212,000 x 1.265 = 268,000 say \$250,000 75 (2)  
125 (3)  
50 (4)

Modular Seals 50,000 9 (2)  
15 (3)  
20 (4)  
6 (5)

Pipe Trays 10,000 4K (2)  
4K (3)

Pressure Gauge say 20 @ 400 8000 5K (2)  
1K (3)  
2K (4)

Truck Hose Adapters & Vents @ 11 @ \$800 8800 (2)

Water Spray Piping System for Pulsatone Flow  
3 @ say \$600 18,000 (2)

\$714,800

511  
1.64  
1.05  
1.56  
1.52  
1.64  
1.6

## Instrumentation

1.	<del>2</del>	<del>36" <math>\phi</math> Magmeters</del>		
2.	6	18" $\phi$ Filter Effluent Flow Tubes @ SS25	33,150	
3.	1	24" $\phi$ Wastewater Flow Tube	18,250	
4.	1	42" $\phi$ Transfer Pump Discharge	30,960	
5.	1	48" $\phi$ High Service Pump Section	33,000	
6.	1	12" Pitot Tube	2000	
7.	2	6" Plant Service Turbine Meters	3000	6000
8.	1	2" Batol Tank Meter	5000	5000
9.	16	Differential Pressure Transmitters	2000	32,000
10.	3	Pulsator Conductive Level Probes	1000	3000
11.	6	Filter Conductive Level Probes	2000	12000
12.	2	Clearwell Conductive Level Probes	1000	2000
13.	1	Rapid Mix Level Probe		1000
14.	1	Filter Influent Level Transmitter	4000	4000
15.	2	Pump Section & Discharge Pressure Transmitters	2000	4000
16.	8	Tank Capacitance Level Transmitters	4000	32,000
17.	4	Batol Tank Capacitance Level Probes	1500	6000
18.	4	Day Tank Capacitance Level Probes	1500	6000
19.	10	Spill Containment Probes	1500	15000
20.	1	Sump Alarm		1000
21.	2	High Range Turb.	3000	6000
22.	7	Low Range Turb.	4000	28,000
23.	6	Backwash Turb @ 2500		15000
24.	3	pH Meters @ 3000		9000
25.	1	SCD		10,000
26.	3	Chlorine Residual Analyzers	8500	25,500
27.	6	Dual FCC w/ DPC @ 45,000		270,000
28.	1	Chemical Storage Room DPC @		10,000
29.	1	Chemical Feed Room DPC		10,000
30.	1	Pump Room DPC		10,000
31.	1	RW/HS Pump Room DPC		10,000
32.	1	UPS system		8,000
33.	5	Pump Pressure Switches		3000
34.	12	Solenoid Valves 500		6000
35.	7	2" Motor Operated Ball Valves 1000		7000
36.	1	Temp Transmitter	(1) 30,000	30,000



**Gannett Fleming**  
ENGINEERS AND PLANNERS

SUBJECT

SHEET NO. 13 OF

JOB NO.

BY

DATE

CHKD. BY

DATE

Main Control Console 15,000  
Unloading Dock Panel (High Level) 10,000

Computers 2 @ 5000 10,000  
Printers 2 @ 2000 4,000  
CRT 2 @ 5000 10,000

49,000

Labor 3900 hours @ \$65/hr 195,000

30 day field @ 1000 30,000

6 Trips @ 1000 6,000

231,000

280,000 (E)



Butterfly Valve

2 - 36" Raw Water Control Valve	x 15,000	=	30,000
12 - 18" Filter Effluent Valve	x 4,600	=	55,200
12 - 12" Air-wash Valve	x 4,000	=	48,000
6 - 24" Wash Valves	x 6,500	=	39,000
6 - 18" Filter Effluent Flow Control Valve	x 5,600	=	33,600
6 - 16" Filter Rinse Flow Control Valve	x 5,400	=	32,400
1 - 24" Wash Water Flow Control Valve	x 800	=	800

246,200

x 1.4

\$344,680 (I)



*Accum Hatels*

1	Rapid Mix		
1	Slow Mix		
4	Split Box		
6	Pulsator		
3	Vacuum Box		
1	Pipe Gallery		
2	Clearwell		
1	Pump Pipe Gallery		
<u>19</u>	@ \$3000	=	\$57,000
Manway to Pulsator			27K (
			18K (
			9K (
			3K

2 @ end of Flumes + 3 = 6 x \$3000 9,000 (

1 @ 8'-c-c 10 x 3 = 30 along inflow flume @ 2000 \$60,000 (

4 into clearwell sections @ 3000 12,000 (

*Ladders @ \$65/l.f.*

1	Rapid Mix	22
1	Slow Mix	22
4	Split Boxes	88
12	Pulsators	192
1	Pump room	15
2	Clearwell	40
2	Roof	<u>30</u>

\$09 x 65 = 26,585

Add for safety Clim L

say

\$35,000 } 17  
82  
5  
2

173,000



## M. Grating

2' x 7' for 3 pulsators = 42 SF @ \$48/SF  
 2 x 1.5 SF for Sluice Room 45  
 87 x 48 = 4176

Mixer Stand 4 @ 2000

say \$6000 3K (1)  
 8,000 (2)

## RRP Grating

CL 60 SF  
 SBP/A = 360 SF  
 CA 360 SF  
 IC 225 SF  
 RA 225 SF  
 F 150 SF  
 CS 150 SF

1530 SF @ \$72/SF = 110,160

110,000 (1)

## RRP Star

Flooring Room

say \$5,000 (1)

## M. Stair & Platforms

CS		say 4000	(1)
Polymer		4000	(1)
Polymer Mix System		8000	(1)
Chemical / Admin Bldg	2 Towers	23R x 2270/R = 12420	(1)
End of Rilla Bldg	1 Tower	14R x 270 = 4000	(1)
End of Process Bldg	1 Tower	14R x 270 = 4000	(1)
Scrubber Room		4000 4000	(1)
Unloading Dock		4000 4000	(1)

\$157,000 + 173

\* Not in orig total



**Gannett Fleming**  
ENGINEERS AND PLANNERS

SUBJECT \_\_\_\_\_

SHEET NO. 17 OF \_\_\_\_\_

BY \_\_\_\_\_

DATE \_\_\_\_\_

CHKD. BY \_\_\_\_\_

DATE \_\_\_\_\_


JOB NO. \_\_\_\_\_

*Aluminum Handrail*

*Process Room*

*40'*


*87'*



$$6 \times 87 = 522$$

$$2 \times 120 = 240$$

*Filter*



$$2 \times 12 \times 26 = 624$$

$$2 \times 12 \times 12 = \underline{288}$$

*1674 l.f. @ 60¢*

*= 100,000:46:54*



## Containment Area Liners

### Reed Area

H	18 x 20	=	360
CA	18 x 20	=	360
K	13 x 15	=	195
PA	13 x 15	=	195
Fot.	10 x 15	=	150

### Storage Area

A	67 x 20	1340
F	19 x 15	361
CS	15 x 12	342
Scrub	19 x 25	475
Sp	18 x 15	342
Lab/Waste	10 x 8	80

4200 SF x 4.00

16,800

57,170.00

Mats	A	67 x 8	=	536
	F	19 x 8	=	152
	CS	15 x 8	=	152
	Scrub	19 x 8	=	152
	Sp	19 x 8	=	152
	Lab/W	10 x 8	=	80

1224 x 6.00 = 7344

57,800.00

325,000



**Gannett Fleming**  
ENGINEERS AND PLANNERS

SUBJECT

SHEET NO. 15 OF

JOB NO.

BY

DATE

CHKD. BY

DATE

Structural Steel say part of unit  
price per sq foot of  
superstructure

Painting

say

200,000

10 (1)  
100 (2)  
54 (3)  
36 (4)



**MISSOURI-AMERICAN WATER COMPANY  
ST. JOSEPH DISTRICT  
ST. JOSEPH WATER TREATMENT PLANT  
IMPROVEMENTS**

**GEOTECHNICAL DESIGN MEMORANDUM**

**APRIL 1993**

Prepared by

**Gannett Fleming, Inc.  
Harrisburg, Pennsylvania**

**SCHEDULE  
JSY-6**

MISSOURI-AMERICAN WATER COMPANY  
ST. JOSEPH DISTRICT  
ST. JOSEPH WATER TREATMENT PLANT IMPROVEMENTS

GEOTECHNICAL DESIGN MEMORANDUM

INTRODUCTION

This memorandum summarizes the geotechnical investigation and preliminary analyses performed for the proposed facility improvements of the St. Joseph, Missouri Water Treatment Plant. The proposed plant improvements consist of a Process Building, Filter Building, Chemical Building, and Pumping Station to be located within the footprint of existing Sediment Basin No. 1. An additional storage tank will be located north of existing Sediment Basin No. 2, and a garage to the east of existing Sediment Basin No. 2. The results of the subsurface investigation and laboratory testing are summarized below. Preliminary design analyses and recommendations are also presented for the proposed facility improvements.

The plant site is located on the east shore of the Missouri River, approximately two miles upstream of the city of St. Joseph, Missouri. The site is situated within the flood plain of the river, and terrain surrounding the plant is relatively flat. Existing ground elevation at the site varies from approximately 820 to 836 feet. The topographic relief indicated by these ground elevations is primarily the result of 10 to 15 foot earthen embankments surrounding most of the existing plant structures. These embankments were placed as part of the original plant construction.

It is noted that several alternates are currently under consideration with regard to the precise locations and elevations of proposed structures. Once established, final foundation design and recommendations will be made with regard to the proposed plant improvements. It is the intent of this memorandum to present the results of the current subsurface investigations and laboratory testing, and discuss their relevance with regard to the feasible foundation types



anticipated for the proposed structures. The analyses upon which the recommendations presented herein are based were performed using preliminary structure location and loading information. As process and structural design progresses and more precise information is made available, additional geotechnical analyses will be performed as warranted.

#### **SUBSURFACE INVESTIGATION**

Subsurface conditions in the general vicinity of the proposed facilities were evaluated by performance of seven Standard Penetration Test (SPT) borings, identified as Borings GF-1, 2, 3, 5, 7, 8 and 9. These borings were located in accessible areas around the perimeter of the existing sediment basins. Proposed Borings GF-4 and GF-6 were deleted from the boring program when it was determined their proposed locations were not accessible. In general, subsurface information directly beneath the proposed structures was not obtained since their locations were within the existing sediment basins, which are currently in service. The locations of the borings are shown on the Site Plans of Figures 1 and 2. The locations of available borings performed during earlier phases of plant development in areas adjacent to the currently proposed facilities are also shown on the Site Plans. Subsurface conditions encountered in these borings were also reviewed as part of the current evaluation. Logs of all borings shown on Figures 1 and 2 are attached as Appendix A.

Alpha-Omega Geotech, Inc. of Kansas City, Kansas, performed the current borings in December of 1992. Gannett Fleming, Inc., provided a geotechnical engineer to inspect and supervise boring and sampling operations during the subsurface investigation. Standard split-spoon samples were taken continuously in the upper ten feet of each boring with sampling intervals of five feet thereafter to bedrock. With the exception of Boring GF-7, bedrock was cored in all borings. Cores were obtained in order to determine the condition and engineering qualities of site bedrock. In addition, undisturbed tube samples were taken for the purpose of classification, consolidation and strength testing.

## **Gannett Fleming**

Classification tests were also performed on soil samples taken from the split-spoon.

### **LABORATORY TESTING**

Samples collected from the subsurface investigation were tested to confirm visual classifications obtained in the field and to determine other relevant engineering properties of the soils. All laboratory testing was performed in Gannett Fleming's Geotechnical Laboratory. Laboratory testing included determinations of natural moisture content, dry density, Atterberg limits, and gradation analyses. A consolidation test and triaxial compression test were also performed on undisturbed samples. Copies of laboratory testing results are attached as Appendix B.

### **SUBSURFACE CONDITIONS**

Existing ground surface at current boring locations varied from approximately Elevation 820 at Boring GF-1 to Elevation 823 at Boring GF-9. In general, borings performed at the eastern side of the plant encountered significantly different soil conditions than those borings located to the west. Boring information indicates that the western portion of the site is underlain by silty sands and sandy silts, whereas the eastern side is underlain by moderate to highly plastic clays. It is not presently known with any certainty where the boundary between these two differing soil profiles occurs. Because the central portion of the site was inaccessible due to the existing basins it was not possible to perform intermediate borings to better define the limits of the two different soil strata.

In the western portion of the site, Borings GF-1, GF-3 and GF-5 encountered a layer of silt and sandy silt overlying sandy material. The silt was approximately 20 feet thick and classifies as an "ML" (low plasticity silt) in the Unified Soil Classification System (USCS). The sandy material consisted of an upper layer of loose to medium dense silty sand and a lower strata of much

## Gonnett Fleming

denser sand with some gravel content. The upper sands exhibited SPT N-values (blows per foot of penetration) ranging from 5 to 13 blows per foot, with an average value of 9 blows per foot. The underlying dense to very dense poorly graded sand exhibited N-values ranging from 19 to 121 blows per foot, with an average value of 34 blows per foot. Laboratory tests performed on the sands indicate USCS classifications of SP (poorly graded sand) and SP-SM (poorly graded, to silty, sand) for these materials. Gravel content of the sands increased with depth, and the sand stratum was typically underlain by a 2 to 6 foot thick layer of boulders and cobbles overlying bedrock.

The clay strata encountered in the easternmost borings contained an upper zone of soft to medium stiff, highly plastic clay. N-values for this material ranged between 2 and 19 blows per foot, with an average value of 8 blows per foot. This upper clay strata extended to depths between 30 and 35 feet, and was underlain by a layer of medium to stiff highly plastic clay containing some gravel. This clay strata exhibited N-values ranging between 12 and 49 blows per foot, with an average value of 25 blows per foot. This stratum extended to bedrock, and varied in thickness from 18 to 26 feet. Laboratory tests performed on the clay soils indicate a USCS classification of CH (highly plastic clay).

An unconsolidated-undrained (UU) strength test was performed on a tube sample representative of the softer clay soils present at the site. That test obtained an unconfined compressive strength of 0.8 ksf, which is indicative of a relatively weak material. A consolidation test was also performed, which indicated the clays had been subjected at some point in the past to vertical pressures greater than those presently existing. Such soils are categorized as "overconsolidated", and typically experience lesser settlement than would otherwise occur under application of a vertical load. The results of strength and consolidation testing were incorporated into the geotechnical analyses discussed later in this memorandum.

## **Gannett Fleming**

Bedrock was encountered at depths ranging from 56 to 89 feet at the boring locations, corresponding to top of rock elevations of about 766 to 733 feet. In general, bedrock slopes downward from east to west at the site.

Bedrock at the water treatment plant consists of gray shale, which is soft and highly weathered to a depth of approximately 5 feet below the top of rock. Bedrock was sampled to depths of 3 to 10 feet below the point of split spoon or auger refusal. Recovery of rock cores ranged from 87 to 100 percent and rock quality designation (RQD) varied from 0 to 86 percent.

Measurements taken during the course of drilling indicated groundwater levels varied between Elevation 800 and Elevation 810 across the site. It is believed likely that groundwater levels at the site will vary with seasonal fluctuations of the Missouri River.

Subsurface profiles depicting representative conditions across the area of proposed construction are presented in Appendix C. These profiles were used in evaluating the probable performance of several foundation types, as discussed in the following section of this report.

### **PRELIMINARY ANALYSES**

The feasibility and performance of both shallow and deep foundation systems was evaluated using the preliminary structure loads and foundation elevations currently available. Given the presence of competent bedrock at moderate depth, and the fact that several of the existing plant structures are supported on deep foundations, it is assumed that caisson or driven pile foundations could be successfully used if warranted. The analyses performed for preparation of this report therefore dealt primarily with the feasibility of shallow foundations. It was also assumed that the characteristics of the soft clays present at the site would control allowable bearing capacity and settlement analyses.

## Gannett Fleming

Bearing capacity and settlement of shallow structural slab foundations were evaluated using the strength and consolidation characteristics obtained from current laboratory testing. The relevant strength and consolidation parameters obtained from the testing are:

Unconfined Compressive Strength,  $q_u = 0.8$  ksf

Compression Index,  $C_c = 0.47$

Re-Compression Index,  $C_r = 0.05$

Pre-Consolidation Pressure,  $P_p = 2.8$  ksf

A preliminary estimate of the bearing pressures associated with the proposed structures was also required to perform the analyses. An estimated bearing pressure of 2.5 ksf was provided by the project structural designers as representative of a typical process structure loading.

Using the Terzaghi bearing capacity equation, an ultimate bearing capacity of 2.5 ksf was calculated for the soft to medium clays present at the site. If typical safety factors of 2.5 to 3 are applied to this value, an allowable bearing capacity ranging from 0.8 to 1.0 ksf is thereby obtained. In light of the estimated 2.5 ksf which will be applied by the proposed structures, bearing capacity of the clay soils present beneath the eastern portion of the site will not be adequate for support of anticipated structure loads.

The magnitude of anticipated consolidation settlements associated with shallow foundations on clay soils was calculated, assuming that bearing capacity deficiencies could somehow be mitigated. Using the re-compression index to calculate settlement (i.e., making the "best case" assumption that only re-compression, rather than virgin consolidation, would occur), consolidation settlements on the order of 2 to 3 inches were obtained. If any virgin consolidation were to occur, the magnitude of observed settlement would likely increase several fold. In addition, because of the difference in soil conditions across the site it is expected that significant differential settlements would occur beneath any structure spanning the juncture of the clay soils to the east

of the site and the sands to the west. The sandy soils would not be expected to experience any appreciable consolidation settlement, and therefore virtually all consolidation settlement occurring in clay soils would be expressed as differential settlement across the structure.

#### CONCLUSIONS AND DISCUSSION

Based on the results of the analyses discussed above, it is concluded that the use of shallow foundations will probably not be feasible for any structure founded in or above the clay soils present at the site. It is anticipated that some form of deep foundation bearing on bedrock will be required for those structures. As mentioned previously, it is anticipated that either caissons or driven pile foundations could be utilized to support proposed structures. Subsequent foundation design will consider which of these foundation types, as well as other possible types, will provide the most cost effective foundation system for the proposed facilities.

It is possible that some structures, such as the garage building being considered, may be relatively lightly loaded as well as relatively insensitive to post-construction settlements. If the garage building is retained in its current location to the east of the existing plant, it may therefore be feasible to found it on shallow foundations bearing on clays. If so, it is likely a significant cost savings could be achieved by avoiding installation of a relatively expensive deep foundation system for this, or any similar, structure.


In order to better delineate the limits and properties of the sandy soils and clay soils in the areas of proposed structures it is recommended that additional borings and laboratory testing be performed. Because the area in question is within the limits of existing Sediment Basin No. 1, it will be necessary to drain the basin and remove any significant sediment deposits to allow performance of the borings. While it is recognized that performing additional borings and testing will entail additional expense, it is believed the potential cost savings associated with utilization of shallow foundations for

## **Gannett Fleming**


even one of the proposed structures would more than offset that expense. Specific recommendations regarding boring locations and laboratory testing will be submitted to Missouri-American in the immediate future.

In the event it can be determined that one or more of the proposed structures will be underlain entirely by sands, it is possible that such structures may be founded on shallow foundations without adverse consequences. A critical consideration in such cases will be the potential for differential movements between adjacent structures on dissimilar foundation types. These situations will be evaluated following final location of the proposed facilities.

Additional items to be addressed during subsequent design work include support and stability of required excavations, dewatering of excavations, flotation resistance, and protection of existing facilities during construction of adjacent structures. A final geotechnical report addressing these issues will be provided during the latter stages of facilities design.







## **APPENDIX A**

### **• BORING LOGS •**

Date Started	12/7/92	<b>DRILLING LOG</b>  <b>GANNETT FLEMING, INC.</b> Harrisburg, PA 17105	Hole No.	GF-1
Date Finished	12/8/92		Sheet	1 of 3
Soil Sampling	64 Ft.		Line & Station	-
Rock Sampling	10 Ft.		Offset	-
Total Depth of Hole	74 Ft.	Project	St. Joseph Water Treatment Plant	
No. of Undist. Sample	0	Drilling Agency	Layne Western	
Total Number of Core Boxes	1	Driller	Randy Crowl	
Groundwater Observations At 26.7 Ft. After 0 Hrs. At 20.2 Ft. After 36 Hrs. Elev. 800.5 After 36 Hrs.	Size and Bit Type NX Casing Size Hollow-Stem 6" O.D. Drilling Fluid		Spoon Size 2" O.D. Hammer Wt. 140# Hammer Drop 30"	
	Inspector T. L. Dreese		Direction of Hole x Vertical      _ Inclined	
			Deg. From Vertical	

Elev. Depth	Legend	Description of Materials	Sample Depth	Blows or RQD	Recovery	Box or Sample No.	Remarks
4.2		Dark Brown Lean CLAY; Medium; Moist.	0.0-2.0	2-4			PPR = 0.85 tsf
				4-4	0.8	S-1	
			2.0-4.0	3-3			
				4-4	0.8	S-2	
5		Gray SILT with Sand; Damp. (ML)	4.0-6.0	3-3			
				4-3	N.R.	S-3	
			6.0-8.0	4-4			
				4-5	2.0	S-4	
			8.0-10.0	4-3			
				4-4	2.0	S-5	
			14.0-16.0	5-8			
				7-6	1.8	S-6	
			19.0-21.0	3-3			
20.0				2-4	2.0	S-7	
			24.0-26.0	4-4			
25		Gray Poorly Graded Fine SAND with Silt; Loose to Medium Dense, Wet.		4-6	1.9	S-8	

**REMARKS:**

Water Table encountered at 20'.  
 Drilled through thin clay seam at = 12.5' (return on augers).

DRILLING LOG (Continuation Sheet)		GANNETT FLEMING, INC.			Hole No. GF-1		
		Project St. Joseph Water Treatment Plant			Sheet 2 of 3		
					Elev. Top of Hole 820.72		
Elev. Depth	Legend	Description of Materials	Sample Depth	Blows or RQD	Recovery	Box or Sample No.	Remarks
		Gray Poorly Graded Fine SAND with Silt; Loose to Medium Dense; Wet.					
			29.0-31.0	4-4			
30				5-12	2.0	S-9	
			34.0-36.0	2-4			
				9-11	2.0	S-10	
35							
			39.0-41.0	4-8			
40				13-19		S-11	
			44.0-46.0	5-7			
45				13-22		S-12	Sand ran into augers to #42' on first attempt for S-12
			49.0-51.0	17-11			
50				12-14		S-13	
			54.0-56.0	16-12			
55				7-10		S-14	Augers bouncing from 56.0' to 59.0'
			59.0-60.5	20-48			
60				60/0.5		S-15	

[illegible]

Date Started	12/10/92	<b>DRILLING LOG</b> <b>GANNETT FLEMING, INC.</b> <b>Harrisburg, PA 17105</b>	Hole No.	GF-2
Date Finished	12/11/92		Sheet	1 of 3
Soil Sampling	55 Ft.		Line & Station	-
Rock Sampling	10 Ft.		Offset	-
Total Depth of Hole	65 Ft.	Project	St. Joseph Water Treatment Plant	
No. of Undist. Sample	1	Drilling Agency	Layne Western	
Total Number of Core Boxes	1	Driller	Randy Crowl	
Groundwater Observations		Size and Bit Type	NX	
At 31 Ft. After 0 Hrs.		Casing Size	Spoon Size 2" O.D.	
At Ft. After Hrs.		Hollow-Stem 6" O.D.	Hammer Wt. 140#	
		Drilling Fluid	Hammer Drop 30"	
Elev.	After Hrs.	Inspector	T. L. Dreese	
			Direction of Hole	
			<input checked="" type="checkbox"/> Vertical <input type="checkbox"/> Inclined	
			_____ Deg. From Vertical	

Elev. Depth	Legend	Description of Materials	Sample Depth	Blows or ROD	Recovery	Box or Sample No.	Remarks
5 8.0		Dark Brown Fat CLAY; Moist; Very Soft to Soft.	0.0-2.0	3-3			PPR = 1.9 tsf
				3-5	0.3	S-1	
			2.0-4.0	4-9			
				7-9	0.7	S-2	
			4.0-6.0	4-3			
				3-4	1.4	S-3	
			6.0-8.0	3-6			
10 15		Brown Fat CLAY with Sand; Very Soft to Medium; Moist to Wet.		5-7	1.3	S-4	PPR = 0.2 tsf
			8.0-10.0	2-3			
				3-4		S-5	
			10.0-12.0	-	1.3/2.0	U-1	
			14.0-16.0	1-1			
				1-2	1.5	S-6	
20 25		Same except Wet.					PPR = 0.2 tsf
			19.0-21.0	8-2			
				1-2	1.7	S-7	
		Gravel Chip caught in spoon.	24.0-26.0	2-2			PPR = 0.25 tsf
				4-27	1.0	S-8	

REMARKS:

DRILLING LOG (Continuation Sheet)		GANNETT FLEMING, INC.			Hole No. GF-2		
		Project St. Joseph Water Treatment Plant			Sheet 2 of 3		
					Elev. Top of Hole 821.15		
Elev. Depth	Legend	Description of Materials	Sample Depth	Blows or RQD	Recovery	Box or Sample No.	Remarks
26.0		Brown Fat CLAY with Gravel; Soft to Medium; Wet.  Boulder or Cobble from 32.0' - 32.5'					Auger Jumping 26.0' - 27.0'
			29.0-31.0	6-5			
				7-33	1.3	S-9	PPR = 0.5 tsf
30							
			34.0-36.0	5-8			PPR = 1.0 tsf
				9-23	0.8	S-10	
35							
37.0							
			39.0-39.8	7-50/0.3	0.7	S-11	Gravel caught in spoon
40		Brown Gravelly Fat CLAY; Medium to Stiff; Wet.					
			44.0-46.0	13-12			PPR = 0.8 tsf
				15-13		S-12	
45							
			49.0-51.0	12-18			PPR = 1.2 tsf
				13-21	0.4	S-13	
50							
53.0							
			54.0-54.75	44-50/0.25		S-14	Augered to 55.0'
55		Gray SHALE; Very Soft to Soft; Highly Weathered; Intensely to Very Intensely Bedded, RD 0°-5°; Very Widely Spaced Fractures, RD 35°-40°.	55.0-65.0	79%	100%	R-1	
60							

[illegible]





DRILLING LOG (Continuation Sheet)		GANNETT FLEMING, INC.		Hole No. GF-3			
		Project St. Joseph Water Treatment Plant		Sheet 2 of 3			
				Elev. Top of Hole 822.07			
Elev. Depth	Legend	Description of Materials	Sample Depth	Blows or RQD	Recovery	Box or Sample No.	Remarks
38.0		Gray Poorly Graded Fine SAND with Silt; Loose to Medium Dense; Wet.					
			29.0-31.0	3-3			
				5-8			S-9
			34.0-36.0	6-6			
				7-14			S-10
		Gray Poorly Graded Fine SAND; Dense to Very Dense; Wet.					
		Gray Poorly Graded SAND; Wet. (SP)	39.0-41.0	11-19			
				20-20	1.5		S-11
			44.0-46.0	14-19			
				19-25	1.0		S-12
			49.0-51.0	20-29			
				27-35	1.7		S-13
			54.0-56.0	17-24			
				32-43	1.0		S-14
			59.0-61.0	49-60			
				61-57	1.1		S-15