

Missouri Public Service Commission
Public Comments Report

Date : 07/12/2005

Utility Type : Water

Company Name : Stockton Hills Water Company-(Water)

Public Comment ID.	First Name	Last Name	City	State	Public Comments	Office	Staff Person	Resolution
P200500224	Earl	Cox	Stockton	MO	Customer opposed to rate increase. No water pressure, water smells. Senior citizens and can't afford any increases.	PSC	BN	Pressure tested 80 psi on 6/2/05. They do have 1/2" pipe that could cause a problem with pressure when watering.
P200500251	Kathleen	Haley	Stockton	MO	Poor service & low water pressure until 2 mos. ago. Now have wonderful water pressure. Worried after rate increase water pressure will go down. Notice went out 5/4 but did not receive until 6/4/05. Co. supposedly put in new pump.	PSC	BN & JM	Site visit on 7/11/05. Pressure tested at 36 psi. They were informed to contact our office if the pressure decreases.
P200500255	david	Haley	Stockton	MO	High elevation, pressure inadequate if co doesn't operate the tank at full level. It is full now, but follow up on operations. Also just got rate case notice, supposed to be mailed May4 and most were, but theirs is post marked Jun3, rcd Jun4.	PSC	BN & JM	Site visit on 7/11/05. Pressure tested at 36 psi. They were informed to contact our office if the pressure decreases.

Total Public Comments(s) : 3