

Exhibit No.:
Issues: Energy Efficient CHP and Obligation
to Serve
Witness: Jane E. Epperson
Sponsoring Party: Missouri Department of Economic
Development, Division of Energy
Type of Exhibit: Direct Testimony
Case Nos.: ER-2018-0145
ER-2018-0146

MISSOURI PUBLIC SERVICE COMMISSION

KANSAS CITY POWER & LIGHT COMPANY

AND

KCP&L GREATER MISSOURI OPERATIONS COMPANY

CASE Nos. ER-2018-0145 and ER-2018-0146

DIRECT TESTIMONY

OF

JANE E. EPPERSON

ON

BEHALF OF

MISSOURI DEPARTMENT OF ECONOMIC DEVELOPMENT

DVISION OF ENERGY

Jefferson City, Missouri

July 6, 2018

**BEFORE THE PUBLIC SERVICE COMMISSION
OF THE STATE OF MISSOURI**

In The Matter of Kansas City Power & Light)
Company's Request for Authority to Implement) Case No. ER-2018-Q145
a General Rate Increase for Electric Service)


In The Matter of KCP&L Greater Missouri)
Operations Company's Request for Authority to) Case No. ER-2018-0146
Implement a General Rate Increase for)
Electric Service)

AFFIDAVIT OF JANE E. EPPERSON

STATE OF MISSOURI)
) **SS**
COUNTY OF COLE)


Jane E. Epperson, of lawful age, being duly sworn on her oath, deposes and states:


1. My name is Jane E. Epperson. I work in the City of Jefferson, Missouri, and I am employed by the Missouri Department of Economic Development, Division of Energy as an Energy Policy Analyst.
2. Attached hereto and made a part hereof for all purposes is my Direct Testimony on behalf of the Missouri Department of Economic Development, Division of Energy.
3. I hereby swear and affirm that my answers contained in the attached testimony to the questions therein propounded are true and correct to the best of my knowledge.



Jane E. Epperson

Subscribed and sworn to before me this 6th day of July, 2018.





Notary Public

My commission expires: 4/26/20

TABLE OF CONTENTS

| | |
|---|----|
| I. INTRODUCTION AND PURPOSE OF TESTIMONY..... | 1 |
| II. OBLIGATION TO SERVE..... | 3 |
| III. ENERGY EFFICIENT COMBINED HEAT AND POWER | 4 |
| IV. CRITERIA FOR EVALUATING STANDBY SERVICE RIDERS..... | 25 |
| V. RECOMMENDATION | 28 |

LIST OF TABLES, FIGURES, AND SCHEDULES

TABLE 1. U.S. Installed CHP Sites and Capacity by Prime Mover

TABLE 2. Comparison of CHP Technology Sizing, Cost, and Performance Parameters

TABLE 3. Combined Heat and Power Installations in Missouri

TABLE 4. Ameren Missouri SSR Workshop Model Outage Profile

FIGURE 1. Energy Efficiency Comparison of CHP versus Separate Heat and Power Production

FIGURE 2. CHP System Schematic

FIGURE 3. CHP Designed to Meet Total Electricity Requirement

FIGURE 4. Thermal Load Following CHP Application

FIGURE 5. CHP Installations Nationwide

SCHEDULE 1. Minnesota's Standby Service Tariff

SCHEDULE 2. Iowa's Standby Service Tariff

SCHEDULE 3. Ameren Missouri's Standby Service Tariff

1 **I. INTRODUCTION AND PURPOSE OF TESTIMONY**

2 **Q. Please state your name and business address.**

3 A. My name is Jane E. Epperson. My business address is 301 West High Street,
4 Suite 720, PO Box 1766, Jefferson City, Missouri 65102.

5 **Q. By whom and in what capacity are you employed?**

6 A. I am employed by the Missouri Department of Economic Development (“DED”),
7 Division of Energy (“DE”) as an Energy Policy Analyst.

8 **Q. On whose behalf are you testifying?**

9 A. I am testifying on behalf of the Missouri Department of Economic Development,
10 Division of Energy.

11 **Q. Please describe your educational background and employment experience.**

12 A. I received my Masters of Science in Geology from the University of Missouri –
13 Columbia and my Bachelor of Arts degree in Geology from Stephens College,
14 Columbia, Missouri. I began work with DE in 2014 as an Energy Policy Analyst.
15 In that capacity I have filed testimony in prior cases (ER-2014-0370, ER-2014-
16 0351, ER-2014-0258, ER-2016-0179), participated in Missouri Energy Efficiency
17 Investment Act (“MEEIA”) rule revision dockets and various electric and gas
18 collaboratives, contributed to development of the Comprehensive State Energy
19 Plan and provided project management for development of Missouri’s first,
20 statewide Technical Reference Manual. Prior to working with DE, I was employed
21 by the Missouri Department of Conservation as Supervisor of the Policy
22 Coordination Unit, which was responsible for statewide, regional, and
23 Conservation Area planning; statewide compliance with environmental and cultural

1 resource laws; Missouri River, Mississippi River and White River basin interstate
2 coordination; and human dimensions (survey) research. Prior to working with the
3 Missouri Department of Conservation, I was employed as a Hydrologist III with the
4 Missouri Department of Natural Resources – Director’s Office, focusing on
5 interstate water policy and management issues.

6 **Q. What is the purpose of your testimony?**

7 A. DE offers direct testimony to provide the Commission with facts on Combined Heat
8 and Power (“CHP”) that may be relevant to its decisions in this case. As the
9 Commission considers the standby service rider (“SR”) proposed by Kansas City
10 Power & Light Company (“KCPL”) in this case, DE strongly encourages the
11 Commission to create a regulatory environment that is conducive to CHP and to
12 avoid rate designs and tariffs that would hinder a customer from utilizing CHP to
13 improve their process or business. Specifically, my direct testimony will a) clarify
14 the obligation for utilities to provide cost-based standby service to customers who
15 choose to self-generate a portion of their energy requirement, b) describe CHP
16 technology and associated energy efficiency benefits to the customers, c)
17 summarize results of the collaborative Workshop to develop a standby service
18 rider in Ameren Case No. ER-2014-0258, and d) provide components and
19 characteristics of a standby service rider that is not discriminatory. I will provide
20 recommendations specific to KCPL’s proposed standby service rider in rebuttal
21 testimony.

1 **Q. What information did you review in preparing this testimony?**

2 A. In preparation of this testimony I reviewed reports and publications about CHP
3 technology, best practices literature, and standby service riders of other states;
4 Direct, Rebuttal and Surrebuttal Testimony by DE on the Standby Service Rider
5 issue in previous rate cases (Case Nos ER-2014-0258, and ER-2016-0179); Direct
6 Testimony filed by Kansas City Power & Light Company by Bradley D. Lutz; and
7 Kansas City Power & Light Company’s responses to my Data Request Numbers
8 300-312 in this case.

9 **II. OBLIGATION TO SERVE**

10 **Q. Is a customer’s choice to generate a portion of their own energy on-site at
11 the discretion of a Missouri regulated utility?**

12 A. No. Missouri Public Service Commission rules specify an electric utility “obligation”
13 to purchase from, sell to, and interconnect with customer generators—specifically
14 called “qualifying facilities”¹. This obligation is consistent with the federal Public
15 Utility Regulatory Policy Act of 1978 (PURPA), which defines two distinct types of
16 “qualifying facilities”²: small power production facilities³ (customer generated
17 renewable energy sources) and cogeneration facilities⁴ (customer combined heat
18 and power or CHP systems). Missouri regulation requires that rates,

19 “... shall be just and reasonable and in the public interest and shall not
20 discriminate against any qualifying facility in comparison to rates for sales

¹ 4 CSR 240-20.060(3)(A),(B),(C)

² 18 C.F.R. 292.207

³ 18 C.F.R. 292.203c, 292.204

⁴ 18 C.F.R. 292.203b, 292.205

1 to other customers served by the electric utility. Rates for sales which are
2 based on *accurate data and consistent system-wide costing principles* shall
3 not be considered to discriminate against any qualifying facility to the extent
4 that those rates apply to the utility's *other customers with similar load or*
5 *other cost-related characteristics*"⁵ (emphasis added).

6 **III. ENERGY EFFICIENT COMBINED HEAT AND POWER**


7 **Q. What is CHP?**

8 A. CHP refers to an array of proven technologies that concurrently generate electricity
9 and useful thermal energy from the same fuel source (conventional or renewable).
10 A simple illustration of a separate heat and power system is a typical commercial
11 or industrial building that purchases electricity generated by a utility but has a
12 natural gas-fired boiler in the basement that makes hot water to heat the building.
13 Thus, supply of the building's electric and thermal energy requirements
14 necessitates the use of two separate fuel sources. In contrast, CHP systems utilize
15 one fuel to make both electric and thermal energy. This is done by recovering the
16 otherwise wasted heat from the electric generation process and using it to meet
17 the thermal needs of the building. Figure 1 illustrates how CHP uses one source
18 of fuel (100 units) as opposed to two sources of fuel (150 units) in a more efficient
19 (75% vs 50%) way than separate heat and power systems.

⁵ 4 CSR 240-20.060(5)(A)

1 **FIGURE 1. ENERGY EFFICIENCY COMPARISON OF CHP VERSUS SEPARATE HEAT AND POWER PRODUCTION⁶**

CHP Recaptures Heat of Generation, Increasing Energy Efficiency, and Reducing GHGs




2 Fuel drives the prime mover, which converts the fuel into other forms of energy
3 that are useful to a device or process. For example, in a car, the engine (prime
4 mover) burns gasoline (fuel) to produce the energy required to move the car. The
5 conversion of fuel to useful energy to move the car also produces heat that is not
6 usable to the car. The car's radiator releases unusable heat to the atmosphere.
7 Hence, a portion of the energy contained in the gasoline was wasted. In CHP
8 systems, a heat exchanger converts waste heat created by the prime mover into

⁶ U.S. Department of Energy Central CHP Technical Assistance Partnership, 2018.

1 thermal energy that is useful for onsite applications. Figure 2 is a schematic that
2 summarizes the basic elements of a typical CHP system. The diversity of fuel
3 sources, prime movers, and thermal applications underscores the incredible
4 potential application of CHP.

5 **FIGURE 2. CHP System Schematic⁷**



⁷ U.S. Department of Energy Central CHP Technical Assistance Partnership, Cliff Haefke, June, 2018.

1 **Q. Are there benefits associated with CHP for customers and the utilities that**
2 **serve them?**

3 A. Yes. Reduced overall energy consumption attributable to the increased efficiency
4 of CHP systems creates cost savings, translating into increased availability of
5 funds for capital investment, business expansion or other purposes. When
6 properly configured and maintained, CHP systems operate very reliably,
7 enhancing the customer's ability to maintain normal business operations at all
8 times (increased resiliency). The utility may benefit from a customer with a CHP
9 system when the CHP system contributes to reducing load during peak periods,
10 thus benefiting all utility customers, and particularly when the CHP system is sited
11 in an area of localized grid congestion.

12 **Q. What is a Distributed Energy Resource ("DER")?**

13 A. A DER is a generation source located near the point of energy consumption by a
14 customer-user. The location of DERs near customer-users results in generation
15 sources distributed throughout the grid, separate from centralized utility generation
16 infrastructure. Examples of DERs include, but are not limited to, microgrids,
17 combined heat and power, solar photovoltaic, wind, and energy storage.

18 **Q. Has the Missouri Public Service Commission ordered a workshop on DERs?**

19 A. Yes, the Commission opened working docket EW-2017-0245 seeking responses
20 to nine questions.

21 **Q. How did the EW-2017-0245 docket address CHP?**

22 A. In my opinion, inadequately. While the proposed definition of DER included
23 combined heat and power specifically, the overall effort focused on utility DERs.

1 The following is an excerpt from DE's formal comments on the proposed revision
2 to the rule:

3 "... a regulated utility is obligated to provide non-discriminatory
4 interconnection services, so it is important for, and incumbent upon,
5 regulated utilities and regulators to remove impediments to the customer
6 use of DERs. ... the failure to adequately address customer-owned DERs
7 could undervalue customer-owned DERs in the context of utility planning."

8 **Q. What is the link between DE, CHP and Missouri economic development?**

9 A. The Division of Energy assists, educates, and encourages Missourians to advance
10 the efficient use of diverse energy resources to drive economic growth, provide for
11 a healthier environment, and achieve greater energy security for future
12 generations. CHP contributes to all three areas of DE's role in support of economic
13 development.

14 **Q. Is CHP addressed in the Missouri Comprehensive State Energy Plan?**

15 A. Yes. The following are recommendations from the Missouri Comprehensive State
16 Energy Plan that address combined heat and power.

17 1.1: Modifying the Missouri Energy Efficiency Investment Act.

- 18 • Allow electric utilities to treat combined heat and power in the same
19 manner as other energy efficiency measures⁸.

⁸ <https://energy.mo.gov/sites/energy/files/MCSEP.pdf> (page 213)

1 2.6: Maintaining Business Affordability and Competitiveness.

- 2 • Continue to review and recommend revisions to regulated utility tariffs
3 to eliminate barriers or incent on-site customer generation of electricity
4 for businesses⁹.
- 5 • Continue to identify and encourage opportunities for large commercial
6 and industrial customers for cost-effective energy efficiency, demand
7 response programs and on-site generation to help them reduce their
8 energy consumption and resources use and manage their peak energy
9 usage¹⁰.

10 3.6: Expanding Combined Heat and Power Applications.

- 11 • Establish cost-based stand-by rates and interconnection practices that
12 reflect best practices.¹¹

13 **Q. Is CHP the same as a microgrid?**

14 A. No. A microgrid is "... a group of interconnected loads and distributed energy
15 resources within clearly defined electrical boundaries that act as a single
16 controllable entity with respect to the grid."¹² Microgrids typically consist of a)
17 generator units located at one or more locations within the defined electrical
18 boundary that use the power, b) electrical distribution infrastructure (wires, conduit,
19 transfer switches, etc.) to distribute the electricity from the generator units to
20 multiple locations within the boundary and, c) interconnections with the local

⁹ Ibid. (page 226)

¹⁰ Ibid. (page 227)

¹¹ Ibid. (page 232)

¹² Sandia National Laboratories, 2014, *The Advanced Microgrid: Integration and Interoperability*,
https://energy.gov/sites/prod/files/2014/f19/AdvancedMicrogrid_Integration-Interoperability_March2014.pdf.

1 utility's distribution system, which allows the microgrid to both receive electricity
2 from the utility system, and to export electricity from the microgrid system¹³. In the
3 case of a utility system power outage, the microgrid is capable of disconnecting
4 (islanding) itself from the utility distribution system so the microgrid can continue
5 to function without exporting power to the utility system that may injure workers
6 who may be working on its' repair. Once the utility system is re-energized after its
7 outage, the microgrid is capable of re-synchronizing with it. While each microgrid
8 is unique, all microgrids need a strong, stable source of baseload power, or
9 "anchor", and CHP is often the technology that provides it¹⁴. So, a microgrid may
10 include CHP but CHP alone is not a microgrid.

11 **Q. Is CHP generally designed to meet or exceed the total energy needs of a**
12 **customer/facility?**

13 A. No. CHP systems are typically sized and designed around the thermal
14 requirement of a customer's facility. While unique to each customer application, a
15 CHP system sized and designed around the thermal requirements of a facility
16 typically will generate only a portion of the electrical energy requirements of the
17 facility. Thus, a significant portion of the total electrical energy requirements is
18 purchased from the utility, with the customer being subject to full service tariffs as
19 well as a standby service rider.

¹³ Baier, Martin, Bhavaraju, Vijay, Murch, William, and SercanTleke, 2017, "Making Microgrids Work: Practical and technical considerations to advance power resiliency."

<http://www.eaton.com/ecm/public/@pub/@electrical/documents/content/wp027009en.pdf>.


¹⁴ <https://www.districtenergy.org/HigherLogic/System/DownloadDocumentFile.ashx?DocumentFileKey=fce6cd6d-0896-b77b-97ce-ab5baae5124c>

1 **Q. Why would a customer choose to generate only a portion of their total energy**
2 **needs through CHP?**


3 A. CHP system's energy efficiency and economic advantage is maximized when
4 100% of the thermal energy produced is utilized in a productive way. A CHP
5 system sized to meet the total electricity requirement commonly creates thermal
6 energy exceeding that which can be productively used, and the excess thermal
7 energy must be "dumped" or wasted. It is not economical to purchase and operate
8 a CHP system to meet the total electrical energy requirement of a customer's
9 facility unless all of the thermal energy from the CHP system is also productively
10 used. Figure 3 illustrates the unrealistic scenario in which the CHP system
11 generates the majority (about 90%) of the annual facility electricity energy
12 requirements, resulting in a significant amount of unused (wasted) thermal energy.
13 The CHP system efficiency would average less than 60% and, during off-peak
14 thermal periods (summer), its efficiency would fall below 50%.

1

FIGURE 3. CHP Designed to Meet Total Electricity Requirement¹⁵.



2




¹⁵ U.S. Department of Energy, Central CHP Technical Assistance Partnership. David Baker, June 2018.

1 **Q. What is “thermal load following” and its implication on rate design?**

2 A. Most CHP systems are designed and operated to “follow the thermal load,”
3 meaning the generation is actively managed to satisfy the thermal energy needs
4 of the customer, which may vary significantly depending upon the specific
5 application. Figure 4 illustrates a realistic scenario in which the CHP generator is
6 sized to meet the thermal load and is operated to follow that load. The CHP system
7 supplies about 50% of the annual facility electrical energy requirements and the
8 CHP system efficiency is maximized since all of the heat is being utilized on-site.
9 The implication of thermal load following on SSR rate design is to ensure that the
10 utility does not penalize the customer for operating their CHP system in the way it
11 was designed, which is to maximize efficiency.

1

FIGURE 4. THERMAL LOAD FOLLOWING CHP APPLICATION¹⁶.



¹⁶ U.S. Department of Energy, Central CHP Technical Assistance Partnership, David Baker, June, 2018.

1 **Q. Provide examples of thermal applications for which a CHP system may be**
2 **beneficial.**

3 A. Thermal energy requirements that can be satisfied by a CHP system include steam
4 for sterilization, domestic hot water heating, space heating, process heating, space
5 cooling, process cooling, refrigeration and dehumidification. CHP can also anchor
6 a district energy system, which is a highly efficient way to heat and cool many
7 buildings from a central plant. District energy systems distribute energy, commonly
8 thermal energy in the form of steam, hot water or chilled water, to multiple buildings
9 within a defined geographic vicinity served by the district system. Heating and
10 cooling using a central plant is more efficient, eliminating the need to install and
11 maintain boilers and chillers at each building. In Missouri, Veolia Energy and the
12 Ashley Plant utilize CHP as the anchor for district energy systems in Kansas City
13 and St. Louis, respectively, and are included in Table 3.

14 **Q. Is CHP an established and commercially available technology?**

15 A. Yes. Figure 5 and Table 1 show that CHP is not new, as there are over 4,000 CHP
16 systems that generate over 83,000 megawatts of energy nationally. Gas turbines
17 (64 percent), followed by boiler/steam turbines (32 percent), account for the
18 greatest share of total capacity; however, over half of the total number of CHP
19 applications use reciprocating engines, though they represent only 2.7% share of
20 total capacity.

1

FIGURE 5. CHP INSTALLATIONS NATIONWIDE¹⁷.

CHP Is Used Nationwide In Several Types of Buildings/Facilities



Slide prepared on 5-30-17



¹⁷ U.S. Department of Energy, Central CHP Technical Assistance Partnership

1 **TABLE 1: U.S. Installed CHP Sites and Capacity by Prime Mover**¹⁸.

| Prime Mover | Sites | Share of | Capacity (MW) | Share |
|----------------------|--------------|-----------------|----------------------|---------------|
| Reciprocating Engine | 2,194 | 51.9% | 2,288 | 2.7% |
| Gas Turbine | 667 | 15.8% | 53,320 | 64.0% |
| Boiler/Steam Turbine | 734 | 17.4% | 26,741 | 32.1% |
| Microturbine | 355 | 8.4% | 78 | 0.1% |
| Fuel Cell | 155 | 3.7% | 84 | 0.1% |
| Other | 121 | 2.9% | 806 | 1.0% |
| Total | 4,226 | 100.0% | 83,317 | 100.0% |

2 **Q. How are the different kinds of CHP technologies categorized?**

3 A. All CHP systems possess a number of basic components: a prime mover (heat
4 engine), a generator, heat recovery equipment, and an electrical interconnection.
5 CHP systems are categorized primarily by the type of prime mover. Table 1 lists
6 prime mover types and provides national statistics regarding the number of sites
7 and capacity, by prime mover. Table 2 provides detailed characteristics of each
8 prime mover, illustrating the large size range of potential applications as well as
9 the technical performance parameters. Table 3 lists CHP installations in Missouri,
10 illustrating the range of size, fuel, and application.

¹⁸ Catalog of CHP Technologies, U.S. Environmental Protection Agency Combined Heat and Power Partnership Program, 2017, Table 1-1.

1 **TABLE 2. COMPARISON OF CHP TECHNOLOGY SIZING, COST, AND PERFORMANCE PARAMETERS¹⁹.**

| Technology | Recip. Engine | Steam Turbine | Gas Turbine | Microturbine | Fuel Cell |
|---|--|---|---|-------------------------------------|--|
| Electric efficiency (HHV) | 27-41% | 5-40+ ² | 24-36% | 22-28% | 30-63% |
| Overall CHP efficiency (HHV) | 77-80% | near 80% | 66-71% | 63-70% | 55-80% |
| Effective electrical efficiency | 75-80% | 75-77% | 50-62% | 49-57% | 55-80% |
| Typical capacity (MWe) | .005-10 | 0.5-several hundred MW | 0.5-300 | 0.03-1.0 | 200-2.8 commercial CHP |
| Typical power to heat ratio | 0.5-1.2 | 0.07-0.1 | 0.6-1.1 | 0.5-0.7 | 1-2 |
| Part-load | ok | ok | poor | ok | good |
| CHP Installed costs (\$/kWe) | 1,500-2,900 | \$670-1,100 | 1,200-3,300 (5-40 MW) | 2,500-4,300 | 5,000-6,500 |
| Non-fuel O&M costs (\$/kWh) | 0.009-0.025 | 0.006 to 0.01 | 0.009-0.013 | 0.009-.013 | 0.032-0.038 |
| Availability | 96-98% | 72-99% | 93-96% | 98-99% | >95% |
| Hours to overhauls | 30,000-60,000 | >50,000 | 25,000-50,000 | 40,000-80,000 | 32,000-64,000 |
| Start-up time | 10 sec | 1 hr -1 day | 10 min -1 hr | 60 sec | 3 hrs -2 days |
| Fuel pressure (psig) | 1-75 | n/a | 100-500 (compressor) | 50-140 (compressor) | 0.5-45 |
| Fuels | natural gas, biogas, LPG, sour gas, industrial waste gas, manufactured gas | all | natural gas, synthetic gas, landfill gas, and fuel oils | natural gas, sour gas, liquid fuels | hydrogen, natural gas, propane, methanol |
| Uses for thermal output | space heating, hot water, cooling, LP steam | process steam, district heating, hot water, chilled water | heat, hot water, LP-HP steam | hot water, chiller, heating | hot water, LP-HP steam |
| Power Density (kW/m ²) | 35-50 | >100 | 20-500 | 5-70 | 5-20 |
| NO _x (lb/MMBtu) (not including SCR) | 0.013 rich burn 3-way cat. 0.17 lean burn | Gas 0.1-.2 Wood 0.2-.5 Coal 0.3-1.2 | 0.036-0.05 | 0.015-0.036 | 0.0025-.0040 |
| NO _x (lb/MWhTotalOutput) (not including SCR) | 0.06 rich burn 3-way cat. 0.8 lean burn | Gas 0.4-0.8 Wood 0.9-1.4 Coal 1.2-5.0. | 0.52-1.31 | 0.14-0.49 | 0.011-0.016 |

¹⁹ U.S. Environmental Protection Agency Combined Heat and Power Partnership, 2017. Catalog of CHP Technologies, p 1-6.

1

TABLE 3. Combined Heat and Power Installations in Missouri²⁰.

| City | Facility Name | Application | Op Year | Prime Mover | Capacity (KW) | Fuel Class-Primary Fuel |
|-----------|----------------|------------------|---------|-------------|---------------|-------------------------|
| Butler | Butler | District Energy | 1946 | ERENG | 13,100 | Oil-Distillate Fuel |
| Columbia | University Of | Colleges / Univ. | 1961 | B/ST | 99,500 | BIOMASS - Biomass |
| Columbia | Columbia | Solid Waste | 2015 | ERENG | 3,000 | BIOMASS - LFG |
| Hannibal | Clemmons | Hotels | 1990 | ERENG | 150 | NG - NG |
| Jefferson | Jefferson City | Justice / Public | 2009 | ERENG | 3,200 | BIOMASS - LFG |
| Kansas | Bolling GSA | General Gov't. | 2000 | BPST | 100 | WAST - Steam |
| Kansas | Veolia Energy | District Energy | 2012 | B/ST | 5,000 | BIOMASS - Biomass |
| Kansas | Trigen-Kansas | District Energy | 1990 | B/ST | 6,000 | COAL - Coal |
| Ladonia | POET | Chemicals | 2007 | CT | 13,000 | NG - NG |
| Lewistown | Lewistown | Schools | 2003 | MT | 60 | NG - NG |
| Macon | Northeast | Chemicals | 2003 | CT | 10,000 | NG - NG |
| Mountain | Smith | Wood Products | 1989 | B/ST | 500 | WOOD - Wood |
| Neosho | La-Z-Boy | Furniture | 1984 | B/ST | 750 | WOOD - Wood |
| North | North Kansas | Agriculture | 1987 | CC | 4,000 | NG - NG |
| St. Louis | Anheuser- | Food Processing | 1939 | B/ST | 26,100 | NG - NG |
| St. Louis | Ashley Plant | District Energy | 2000 | CT | 15,000 | NG - NG |
| St. Louis | Southwestern | Communications | 1992 | ERENG | 6,000 | OIL - Distillate Fuel |
| St. Louis | Brandonview | Office Building | 1969 | ERENG | 4,300 | NG - NG |
| | Agricultural | Agriculture | 2014 | ERENG | 800 | BIOMASS - Digester G |

2

Q. What are some examples of facilities that are good candidates for CHP?

3

A. Customers whose facility has an ongoing requirement for both thermal and electrical energy throughout the year are prime candidates for utilization of CHP generation. Commercial sector candidates include hospitals and nursing homes, public water and wastewater treatment facilities, data centers, hotels, government facilities (federal, state, county and city), and universities and colleges. Industrial sector candidates include food/beverage manufacturers and distributors as well as manufacturers of chemical, wood, agricultural and furniture products.

4

5

6

7

8

9

²⁰ U.S. DOE Combined Heat and Power Installation Database, accessed June, 2018.
<https://doe.icfwebservices.com/chpdb/state/MO>

1 **Q. When should CHP be considered?**

2 A. New facilities offer the most economical opportunity to implement a CHP system.
3 Existing facilities should consider a CHP system during an expansion, or when a
4 boiler, chiller or emergency generator requires replacement. In addition, CHP
5 should be considered for existing facilities when manufacturing processes produce
6 a significant amount of heat that is currently being wasted. The U.S. Department
7 of Energy estimates that between 20 – 50% of industrial energy input is lost as
8 waste heat in the form of hot exhaust gases, cooling water, and heat lost from hot
9 equipment surfaces and heated products²¹. The recovery and use of wasted heat
10 could result in higher productivity and lower operating costs, which contribute to
11 economic competitiveness. This type of CHP application is referred to as
12 “bottoming cycle” because waste heat is converted to electrical energy, whereas
13 with the more common “topping cycle” heat resulting from electricity generation is
14 recovered and used as thermal energy²².

15 **IV. BACKGROUND ON STANDBY SERVICE RIDERS IN MISSOURI**

16 **Q. What are standby service riders?**

17 A. Standby service riders are charges that a utility levies upon customers who
18 choose to generate a portion of their own electrical requirements. Fees may
19 include a) a capacity (reservation) charge to stand ready to provide electricity
20 during customer-generator outages, and b) charges for actual electricity supplied

²¹ U.S Department of Energy, Office of Energy Efficiency & Renewable Energy, Waste Heat Recovery Resource Page, January, 2017. <https://www.energy.gov/eere/amo/articles/waste-heat-recovery-resource-page>

²² U.S. Environmental Protection Agency Combined Heat and Power Partnership, Waste Heat to Power Systems. https://www.epa.gov/sites/production/files/2015-07/documents/waste_heat_to_power_systems.pdf

1 during temporary customer-generator outages (planned maintenance or
2 unplanned outage).

3 **Q. What is the purpose of an SSR?**

4 A. The basic purpose of an SSR is for the electric utility to recover the fully allocated
5 embedded costs associated with providing backup service—no more and no less.
6 Like any other group of customers with similar cost-related characteristics, rates
7 for services provided to customers with CHP should be based on accurate data
8 and consistent system-wide costing principles. A customer with CHP should not
9 pay for costs that they do not cause to be incurred. Missouri regulation requires
10 that costs shall not discriminate against any qualifying facility in comparison to
11 rates for sales to other customers served by the electric utility²³.

12 **Q. Why are SSR's important?**

13 A. Standby service riders have been generally recognized as a barrier to CHP
14 implementation.^{24, 25, 26, 27} As regulated utilities have an obligation to serve
15 qualifying facilities in a nondiscriminatory way, SSR proposals warrant thorough
16 consideration.

²³ 4 CSR 240-20.060(5)(A)

²⁴ American Council for an Energy Efficient Economy, 2011. Chittum, Anna, and Nate Kaufman, *Challenges Facing Combined Heat and Power Today: A State by State Assessment*, Report Number IE111. Pages 22, 51.

²⁵ American Council for an Energy Efficient Economy, 2013. Chittum, Anna and Kate Farley, *Utilities and the CHP Value Proposition*, Report Number IE134. Page 4.

²⁶ [EPA] Environmental Protection Agency. 2009. *Standby Rates for Customer-Sited Resources: Issues, Considerations, and the Elements of Model Tariffs*. Washington, D.C.: US Environmental Protection Agency.

²⁷ Casten, S. and M. Karegianes. 2007. "The Legal Case Against Standby Rates." *The Electricity Journal* 20 (9): 37-46.

1 **Q. Have SSRs been addressed in recent PSC cases?**

2 A. Yes. DE filed testimony in Case No. ER-2014-0258 entitled, “CHP and Ameren
3 Missouri’s Rider E.” In this testimony, DE described CHP, explained the economic,
4 security, and environmental benefits associated with CHP and documented the
5 absence of cost-causation and non-discriminatory rate principles reflected in
6 Ameren Missouri Rider E²⁸. The issue was addressed through a Nonunanimous
7 Stipulation and Agreement Regarding Supplemental Service Issues in which
8 Ameren Missouri committed to develop and file, in collaboration with the
9 signatories, a Standby Service Rider by December 31, 2015.²⁹ On behalf of DE, I
10 participated in all the SSR collaborative Workshop meetings initiated by Ameren,
11 pursuant to the Nonunanimous Stipulation and Agreement.

12 **Q. What were the results of the PSC-ordered Ameren SSR collaborative**
13 **Workshop effort?**

14 A. The SSR collaborative Workshop resulted in productive dialogue. Specifically, the
15 workshop led to the following outcomes:

- 16 • A clear definition of terms.
- 17 • A tariff structure that provides transparency regarding fixed charges
18 (administrative, generation and transmission access and seasonal facilities
19 charges); seasonal daily demand charges for back up and maintenance
20 service; seasonal energy charges for back up service on and off peak.

²⁸ Direct Testimony of Alex Schroeder on Behalf of Missouri Department of Economic Development-Division of Energy, Missouri Public Service Commission Case No. ER-2014-0258, December 19, 2014.

²⁹ Nonunanimous Stipulation and Agreement Regarding Supplemental Service Issues. ER-2014-0258.

- 1 • Stakeholders learned that an important concept for evaluating the treatment of
2 onsite generation is the avoided cost percentage (“ACP”). The ACP reflects a
3 comparison of the value of avoided purchases to the value of the full
4 requirements of electricity on a per kWh basis. Ideally, the reduction in
5 electricity costs should be commensurate with the reduction in purchased
6 electricity.³⁰ If the onsite system reduces consumption by 80 percent, the cost
7 of electricity purchases would also be reduced by 80 percent. The economics
8 are severely impacted if partial requirement rates are structured so that only a
9 small portion of the electricity price can be avoided. The higher the ratio of
10 avoided costs to the full retail average price, the higher the user’s savings. An
11 ACP above 90 percent generally provides savings supportive of customer
12 investment in onsite generation³¹.
- 13 • The SSR Workshop process led to the development of an annual load profile
14 based upon average customer class data for each of the three classes of
15 service intended to be addressed by the draft SSR. A consistent set of
16 guidelines was established to create CHP generation and outage profiles for
17 each class to use for evaluation. The generation profile nominally represented
18 40 percent of the total customer load. Outage rates, intended to represent
19 reasonable levels for common CHP technologies, were assumed at
20 approximately 2 percent for maintenance service and 2 percent for backup
21 service. Maintenance service was planned to occur during one continuous time

³⁰ U.S Environmental Protection Agency, 2009 Standby Rates for Customer-Sited Resources, Issues, Considerations, and Elements of Model Tariffs.

³¹ Ibid.

1 during an off-peak period (November). Backup service was allocated to
2 multiple forced outages occurring during different months, time of day periods,
3 and was assumed to occur for differing durations of time, as would reasonably
4 be expected in reality. The details of the forced outage (FO) occurrences were
5 left to the discretion of Ameren and are depicted in Table 4.

6 **TABLE 4. AMEREN MISSOURI SSR WORKSHOP MODEL OUTAGE PROFILE.**

| Outages | Additional Purchases | | Maint. hours | FO hours |
|------------------------------------|----------------------|-------------|--------------|-------------|
| November 22-28 | 121275 | Maintenance | 168 | |
| January 17 for 42 hours | 33201 | FO | | 42 |
| June 20 for 42 hours | 30940 | FO | | 42 |
| February 17 for 24 hours | 18873 | FO | | 24 |
| July 17 for 22 hours | 17540 | Maintenance | 22 | |
| March 28 @ hour ending 4, 7 | 4815 | FO | | 7 |
| August 28 @ hour ending 11, 7 | 6020 | FO | | 7 |
| October 28 @ hour ending 11, 7 | 5796 | FO | | 7 |
| April 3, @12:00 24@3:00 3 hours | 4239 | FO | | 6 |
| May 2, @12:00 24@3:00 3 hours | 4239 | FO | | 6 |
| August 3, @ 12, 3 hours (off peak) | 2580 | FO | | 3 |
| September 24@3:00 3 hours | 1710 | FO | | 3 |
| December 12@1:00 3 hours | 2133 | FO | | 3 |
| Totals | 253361 | | 190 | 150 |
| Percentage of Annual Hours | | | 2.2% | 1.7% |

7 The annual load profiles that were developed by Ameren and based upon average
8 customer class data for each of the three applicable customer classes were then

1 used to evaluate and compare avoided cost percentages for each of the classes
2 on a consistent basis. This evaluation method resulted in an ACP of 84 percent
3 for Large General Service (LGS), 85 percent for Small Primary Service (SPS), and
4 86 percent for Large Primary Service (SPS), all of which fall below the 90 percent
5 threshold. These below-threshold ACP values suggest that the SSR rate design
6 does not recognize the low probability that CHP customers will experience an
7 outage during peak period.

- 8 • The SSR Workshop also resulted in the review of standby service riders from
9 other states, including Minnesota (Schedule 1) and Iowa (Schedule 2).
- 10 • While progress was made during the SSR Workshop regarding the definitions
11 and overall structure, a significant impasse occurred regarding the specific rate
12 charges. Schedule 3 is the current SSR for Ameren Missouri.
- 13 • An SSR study tool was developed and made available on the Ameren website³²
14 to educate and inform how a customer's bill may be impacted given various
15 usage and generation assumptions under the SSR.

16 **Q. Did KCPL participate in the Ameren SSR collaborative Workshop effort?**

17 A. Yes.

18 **IV. CRITERIA FOR EVALUATING STANDBY SERVICE RIDERS**

19 **Q. What services should CHP customers be charged for in a SSR?**

20 A. A SSR should reflect the cost of 1) the reservation of the generation, transmission,
21 and distribution services needed to provide power when the customer's generator

³² <https://www.ameren.com/missouri/business/rates/electric-rates/rider-ssr>

1 is not producing due to an unplanned (emergency) energy failure/outage, and 2)
2 energy charges for the incremental amount of electricity provided by the utility
3 resulting from the customer-generator outage.

4 **Q. By what evaluative criteria should standby service rider proposals be**
5 **considered?**

6 A. Standby service rate design should follow the same rate-making objectives that
7 are applied to full requirements customers. Of the generally accepted Bonbright
8 Principles for Rate Structure, four stand out as particularly important in the
9 development and approval of a SSR: 1) simplicity, understandability, public
10 acceptability, and feasibility of application; 2) fairness of the specific rates in the
11 appointment of total cost of service among the different consumers; 3) avoidance
12 of undue discrimination in rate relationships, and 4) promoting efficient use of
13 energy and competing products and services.³³

14 The first principle of simplicity, understandability, public acceptability, and
15 feasibility of application cannot be overstated. Definitions should be clear, rate
16 calculations transparent, and the customer should be able to understand what they
17 are being charged for and how the SSR will impact their bill. The concepts and
18 definitions developed through the Ameren SSR collaborative Workshop should be
19 utilized.

³³ Bonbright, James, C., 1961. Principles of Public Utility Rates, Columbia University Press, New York.

1 Regarding the second principle of fairness of the specific rates, I offer the following
2 metrics for evaluating proposed SSR rates:

- 3 • Annual ACP should be 90 percent or more for all classes of service. This
4 means that ACP will be above 90 percent for months when there is no
5 outage and likely less than 90 percent for months where there is an outage.
- 6 • Fixed monthly charges for generation, transmission, and distribution should
7 not be higher than the demand charge on the otherwise applicable tariff.
- 8 • Generation reservation demand charges should be based on the utility's
9 cost and the forced outage rate, as identified in RAP³⁴.
- 10 • No additional demand charges or higher energy rates should apply to
11 standby customers in conjunction with scheduled maintenance service
12 unless actual demand, including scheduled maintenance, exceeds the
13 supplementary contract capacity.
- 14 • No additional demand charges or higher energy rates should apply to
15 standby customers in conjunction with backup service unless actual
16 demand, including backup service, exceeds a supplementary contract
17 capacity.
- 18 • There should be a reasonable balance between fixed and variable charges.
19 As an example, with lower fixed costs, higher variable costs may be
20 justified.

³⁴ <http://raponline.org/documents/download/id/7020> (Standby Generation Reservation Charge, page 13)

- 1 • An average load profile for each eligible class of the SSR should be
2 developed for study to provide billing examples necessary to analyze rider
3 impact.

4 Regarding the third principle of particular importance, avoidance of undue
5 discrimination, Missouri regulation is specific:

6 “...Rates for sales which are based on accurate data and consistent
7 system-wide costing principles shall not be considered to discriminate
8 against any qualifying facility to the extent that those rates apply to the
9 utility’s other customers with similar load or other cost-related
10 characteristics”³⁵.

11 The Commission should be confident that undue discrimination against customers
12 who choose to utilize CHP will not occur through the rates charged in standby
13 service riders.

14 Regarding the fourth rate structure principle, promoting efficient use of energy and
15 competing products and services, CHP provides a distinct opportunity/potential.

16 **V. RECOMMENDATION**

17 **Q. What is DE’s recommendation to the Missouri Public Service Commission**
18 **regarding the development of SSRs?**

19 A. DE offers the above CHP testimony to provide the Commission with facts on CHP
20 that may be relevant to its decisions in this case. As the Commission considers
21 stand by service riders and other rate design issues in this case, DE strongly

³⁵ 4 CSR 240-20.060(5)(A)

1 encourages the Commission to create a regulatory environment that is conducive
2 to CHP and to avoid rates designs and charges that would hinder a customer from
3 utilizing CHP to improve their process or business. As the Commission evaluates
4 the merits of KCPL's proposed Standby Service Rider in this case, DE
5 recommends consideration of a) the practical tariff rate attributes of simplicity,
6 understandability, and feasibility of application, b) the progress made on the issue
7 from the Ameren case no. ER-2014-0258 (concepts, definitions, structure,
8 transparency, study tool), c) the utility obligation to base rates on accurate data
9 and consistent system-wide costing principles, d) the responsibility to ensure
10 avoidance of undue discrimination, and e) the role CHP plays in promoting the
11 efficient use of energy, reducing emissions, and increasing resiliency. Any SSR
12 proposal should, at a minimum, be based on specific model profiles (for each class
13 of service applicable), and a realistic, consistent set of generation and outage
14 scenarios for evaluation in this case.

15 **Q. Does this conclude your testimony?**

16 A. Yes.