

Missouri-American Water Company
Name of Issuing Corporation

For

Missouri Service Area
Community, Town or City

Rules And Regulations Governing The Rendering of
Water Service

7. A cross connection is specifically identified; or
8. Due to proprietary or classified restrictions the Company is not permitted to enter upon the premises to inspect plumbing and water using equipment.
- E. When a premises is served by multiple service lines, wherever backflow protection is determined to be required on the Customer's premises, all such water supply lines from the Company's mains entering such premises shall be protected by an approved backflow prevention assembly of a proper type.
- F. Temporary connections to the public water supply are prohibited unless authorized by the Company in writing. This includes the use of fire hydrants. If a temporary connection is permitted the proper metering and backflow prevention assembly, as approved by the Company, will be required. The backflow device shall be an RP, and it shall be tested each time it is placed into service.
- G. Backflow protection on private fire protection systems shall be as required by the Company, and applicable state and local regulations. +
- H. The type of protection that shall be required to prevent backflow into the public potable water supply shall be commensurate with the degree of hazard (either actual or potential) that exists on the Customer's premises, and subject to the reasonably exercised judgment of the Company. +
- I. The St. Louis County Department of Public Works administers a cross connection control (CCC) program in St. Louis County. This Rule applies in St. Louis County, however the Company does not directly manage the CCC program.

* Indicates new rate or text

+ Indicates change

DATE OF ISSUE: November 20, 2013DATE EFFECTIVE: December 20, 2013ISSUED BY: Frank Kartmann
name of officerPresident
title727 Craig Road, St. Louis, MO 63141
address