## P.S.C. MO. No. 5 Consolidated Second Revised Sheet No. R-46-b CANCELLING P.S.C. MO. No. 5 Consolidated, First Revised Sheet R-46-b Schedules

Laclede Gas Company

For

Refer to Sheet No. R-1

Name of Issuing Corporation or Municipality Community, Town or City

## **RULES AND REGULATIONS**

## 35. Conservation and Energy Efficiency Programs (continued)

<b>Equipment or Service</b>	Rated	Rebate
Gas space heating hot water boiler less than 300 MBH input	Greater than or equal to 85% and less than 92% AFUE*	\$2.50 per MBH
Gas space heating hot water boiler from 300 MBH to 2,500 MBH input	Greater than or equal to 85% and less than 92% TE**	
Gas space heating hot water boiler greater than 2,500 MBH to 5,000 MBH input	Greater than or equal to 85% and less than 92% CE***	
Gas space heating hot water boiler less than 300 MBH input	Greater than or equal to 92% AFUE*	\$3.00 per MBH
Gas space heating hot water boiler from 300 MBH to 2,500 MBH input	Greater than or equal to 92% TE**	
Gas space heating hot water boiler greater than 2,500 MBH to 5,000 MBH input	Greater than or equal to 92% CE***	
Gas space heating steam boiler less than 300 MBH input	Greater than or equal to 82% AFUE*	\$1.75 per MBH
Gas space heating steam boiler from 300 MBH to 5,000 MBH input	Greater than or equal to 82% TE**	
Space Heating steam trap replacement or rebuild	Steam trap replacement or rebuild of failed trap considered efficiency improvement	50% of the equipment cost for trap replacement or rebuild kit, up to \$100 per steam trap
Process and/or industrial steam trap replacement or rebuild	Steam trap replacement or rebuild of failed trap considered efficiency improvement	50% of the equipment cost for trap replacement or rebuild kit, up to \$200 per steam trap
Vent damper	Damper installation considered efficiency improvement	50% of equipment cost or \$500 cap per boiler, whichever is lower
Primary air damper	Damper installation considered efficiency improvement.	50% of equipment cost or \$500 cap per boiler, whichever is lower
Gas Instantaneous Water Heater < 2 gallon	Greater than or equal to 0.82 EF***	\$300
Condensing Storage Water Heater Greater than 75,000 and less than or equal to 500,000 BTU/hour input	Greater than or equal to 90% TE**	\$450

\*Annual Fuel Utilization Efficiency (AFUE)

\*\*\*Combustion Efficiency (CE)

\*\*\*Energy Factor (EF)

MBH is a thousand BTUs per hour