

Name of Issuing Corporation or Municipality

Community, Town or City

RULES AND REGULATIONS

35. Conservation and Energy Efficiency Programs (continued)

Equipment or Service	Rated	Rebate
Gas space heating hot water boiler less than 300 MBH input	Greater than or equal to 85% and less than 92% AFUE*	\$2.50 per MBH
Gas space heating hot water boiler from 300 MBH to 2,500 MBH input	Greater than or equal to 85% and less than 92% TE**	
Gas space heating hot water boiler greater than 2,500 MBH to 5,000 MBH input	Greater than or equal to 85% and less than 92% CE***	
Gas space heating hot water boiler less than 300 MBH input	Greater than or equal to 92% AFUE*	\$3.00 per MBH
Gas space heating hot water boiler from 300 MBH to 2,500 MBH input	Greater than or equal to 92% TE**	
Gas space heating hot water boiler greater than 2,500 MBH to 5,000 MBH input	Greater than or equal to 92% CE***	
Gas space heating steam boiler less than 300 MBH input	Greater than or equal to 82% AFUE*	\$1.75 per MBH
Gas space heating steam boiler from 300 MBH to 5,000 MBH input	Greater than or equal to 82% TE**	
Space Heating steam trap replacement or rebuild	Steam trap replacement or rebuild of failed trap considered efficiency improvement	50% of the equipment cost for trap replacement or rebuild kit, up to \$100 per steam trap
Process and/or industrial steam trap replacement or rebuild	Steam trap replacement or rebuild of failed trap considered efficiency improvement	50% of the equipment cost for trap replacement or rebuild kit, up to \$200 per steam trap
Vent damper	Damper installation considered efficiency improvement	50% of equipment cost or \$500 cap per boiler, whichever is lower
Primary air damper	Damper installation considered efficiency improvement.	50% of equipment cost or \$500 cap per boiler, whichever is lower
Gas Instantaneous Water Heater < 2 gallon	Greater than or equal to 0.82 EF****	\$300
Gas storage water heater greater than or equal to 20 gallons and less than or equal to 55 gallons	Greater than or equal to 0.67 EF****	\$200
Condensing Storage Water Heater Greater than 75,000 and less than or equal to 500,000 BTU/hour input	Greater than or equal to 90% TE**	\$450

*Annual Fuel Utilization Efficiency (AFUE) ** Thermal Efficiency (TE)
 Combustion Efficiency (CE) *Energy Factor (EF)
 MBH is a thousand BTUs per hour

DATE OF ISSUE	January 23, 2017	DATE EFFECTIVE	February 22, 2017
	Month Day Year		Month Day Year
ISSUED BY	C. Eric Lobser, VP - Regulatory and Governmental Affairs, 700 Market, St. Louis, Mo. 63101		
	Name of Officer	Title	Address