

SESSION1 - EXTRA! Enterprise

File Edit View Tools Session Options Help



RICHARD D SMITH
12787 JOHN SMITH RD

CUSTOMER OUTAGE HISTORY
12 KV DISTRIBUTION CUSTOMER
METERS: 1 TRANSFORMERS

DATE	TIME	HR/MIN	TYPE	CAUSE/ACTION
08/06/06	16:34	0 49	DEVICE	OVERHD EQUIP MALFUNC
07/24/06	05:42	56 38	DEVICE	TREE CONTACT
07/13/06	12:30	0 01	FEEDER	DROPPED FOR SAFETY
04/02/06	16:56	50 41	GROUPED	TREE LIMB BROKEN
03/11/06	21:45	16 15	DEVICE	TREE CONTACT
12/07/05	20:33	2 22	MAINTAIN	DROPPED FOR SAFETY
09/29/05	04:52	5 53	DEVICE	TREE CONTACT
09/28/05	17:30	9 16	GROUPED	OVERHD EQUIP MALFUNC
08/26/05	13:34	1 26	DEVICE	TREE CONTACT
04/21/05	00:06	3 17	DEVICE	OVERHD EQUIP MALFUNC
08/25/04	15:59	0 51	DEVICE	TREE LIMB BROKEN
08/17/03	21:33	4 14	GROUPED	OVERHD EQUIP MALFUNC
12/01/02	12:00		ACTION>>	** TREE TRIMMING **
11/07/02	10:15	1 14	DEVICE	TREE TRIMMERS
09/24/02	20:20	0 34	MAINTAIN	DROPPED FOR SAFETY
09/19/02	08:57	2 28	DEVICE	OVERHD EQUIP MALFUNC
PF1=HELP PF2=TOP PF8=SCROLL FORWARD PF9=FULL HISTO				
TROCH05 ***** MORE OUTAGES PRESENT - PF8 FOR NEX				

10/20/2006 10:00.5

Connected to host:

