

DATA INFORMATION REQUEST
ST. JOSEPH LIGHT & POWER COMPANY
CASE NO. EO-2000-845

FILE COPY

REQUESTED FROM: Tim Rush

DATE REQUESTED: October 5, 2000

INFORMATION REQUESTED:

Please refer to the "Possible Contributing Factors" documented dated July 13 provided in response to Staff Data Request No. 4102 in Case No. ES-2001-28.

1. What was the significance of the factor "DC pump availability and operation not checked during start-up on 6/2/00"? Was this a routine/scheduled/required check and who was responsible for its completion?
2. What was the significance of the factor "Routine check of pump readiness not performed at shift changes"? Were these routine checks scheduled and/or required and who was responsible for their completion?

REQUESTED BY: Bill Harris

INFORMATION PROVIDED

1. This is a routine check that verifies the proper operation of the DC oil pump prior to starting the unit. It is listed on the start up procedure. This is the responsibility of the outside operator. Start up of 4/6 unit is a very busy and very physical time for the outside operator. Not doing this test does not prevent successful start up of the unit.
2. These checks are the responsibility of the Head Operator following shift change. Based on feedback from the head operators following the incident, it appears that the checks were made, but misunderstood. The only place to do this was on the DCS control screen. The head operators said that they did indeed check this screen, but that the "local" indication on the screen was what they had been seeing for the past 5 years when the pump was in ready mode. Of course, with the pistol grip switch removed, there was no "local" control to be in auto mode.

The attached information provided to the Missouri Public Service Commission Staff in response to the above data information request is accurate and complete, and contains no material misrepresentations or omissions, based upon present facts of which the undersigned has knowledge, information or belief. The undersigned agrees to immediately inform the Missouri Public Service Commission Staff if, during the pendency of Case No. EO-2000-845 before the Commission, any matters are discovered which would materially affect the accuracy or completeness of the attached information.

Exhibit No. 22
Date 10-26-00 Case No. EO-2000-845
Reporter JY OCT 11 2000

If these data are voluminous, please (1) identify the relevant documents and their location (2) make arrangements with requestor to have documents available for inspection in the St. Joseph Light and Power Co. office, or other location mutually agreeable. Where identification of a document is requested, briefly describe the document (e.g. book, letter, memorandum, report) and state the following information as applicable for the particular document: name, title number, author, date of publication and publisher, addresses, date written, and the name and address of the person(s) having possession of the document. As used in this data request the term "document(s)" includes publication of any format, workpapers, letters, memoranda, notes, reports, analyses, computer analyses, test results, studies or data, recordings, transcription and printed, typed or written materials of every kind of your possession, custody or control or within your knowledge. The pronoun "you" or "your" refers to St. Joseph Light and Power and its employees, contractors, agents or others employed by or acting in its behalf.

Date Response Received: _____ Signed by: _____

Prepared by: Jane Parker