



Kennett Board Of Public Works

P.O. BOX 40 • KENNETT, MISSOURI 63857-0040 • (573) 888-5366 • FAX (573) 888-3312

RECEIVED²

JUL 18 2014

*Records
Public Service Commission*

July 15, 2014

Mr. Morris Woodruff
Secretary/General Council
Missouri Public Service Commission
200 Madison Street, Suite 100
P.O. Box 360
Jefferson City, MO 65102

Mr. Woodruff,

Enclosed is our annual report for the Three Rivers Community College (formerly Emerson Electric) yard line.

We are providing this report pursuant to Missouri Public Service Commission Case No. GE-2003-0503.

Sincerely,

George Anderson
Gas Department Superintendent
Kennett Board of Public Works
Kennett, MO 63857

cc: Mr. Bob Leonberger
Missouri Public Service Commission
P.O. Box 360
Jefferson City MO 65102

**Annual Report for Three Rivers Community College Yard Line
(Formerly Emerson Electric Yard Line)**

Date: July 15, 2014

Yard Line leak survey results on 6" line: Leaks Found: Yes ☐ No ☒

If leaks found, what was done: _____

Cathodic protection readings on 6" line:

Test Point #1: -1.46v Test Point #2: -1.45v Test Point #3: -1.53v Test Point #4: -1.51v

Work performed by: Bill Heinen

A handwritten signature in blue ink, appearing to read "Bill Heinen", with a long horizontal stroke extending to the right.

(Pursuant to Missouri Public Service Commission Case No. GE-2003-0503)