1	
2	Missouri Public Service Commission
3	
4	Case Nos. WC-2006-0082 & WO-2007-0277
5	
6	
7	Big Island Sewer and Water Systems
8	
9	Rebuttal Testimony
10	
11	Of
12	
13	Benjamin D. Pugh
14	
15	
16	
17	Roach, Missouri
18	
19	February 2007
20	
21	
22	
23	

## 1 2 Q. PLEASE STATE YOUR NAME AND ADDRESS. 3 A. Benjamin D. Pugh, 1780 Big Island Drive, Roach, Missouri 65787 4 Q. **BRIEFLY, WHAT IS YOUR EMPLOYMENT BACKGROUND?** 5 Α. 4 years in the US Navy and 33 years with Trans World Airlines (Lead Electrician) 6 WHAT IS YOUR INTEREST IN BIG ISLAND? Q. 7 My wife and I have been property owners on Big Island for 44 years. We have been full time A. 8 residents since my retirement. In 1986. I am very concerned that the growth of Big Island be a 9 responsible and safe growth for its residents. Since Folsom Ridge came in 1998 there has been 10 little consideration for the existing resident of Big Island or their health risks. 11 WHAT IS THE PURPOSE OF THIS REBUTTAL TESTIMONY? Q. 12 A. I filed a formal complaint case # WC 2006 0090 along with 8 others, against Folsom Ridge LLC 13 owning and operating Big Island Home Owners Association (BIHOA) The Big Island Sewer and 14 Water Systems need to be regulated by the Public Service Commission as each user is a customer 15 only and it requires no membership for the homeowners. A regulated system is the best solution to the membership problem. A 393 Not for Profit Corp. as proposed by many Big Island 16 17 homeowners does not address the membership problem as stated in my testimony, and could 18 create some possible litigation which I'm sure would not be advantageous to anyone. This rebuttal 19 will be primarily to answer Mr. Krehbeils questions . 2

### 1 Q. KREHBEIL ENGINEERING WAS THE CONSULTANT FOR THE THE OFF 2 ISLAND EXTENSION. DO YOU MR. PUGH HAVE ANY COMMENTS ABOUT 3 EXTENSIONS TO THE PHASE ONE SYSTEMS? 4 Α. We have documented commitments by signatures of Golden, Rusaw and Lees that there would be 5 no extensions off the island pertaining to Folsom Ridges off the island 160 acres. This extension 6 apparently goes to 12 lots which are on that land parcel which connect into the Phase One 7 system. 8 Q. THE WATER MAIN IS POSITIONED BELOW A SEWER MAIN ON AN INCLINE. 9 THE LOCATION OF SEWER MAIN POSE A DOES THE RISK OF 10 **CONTAMINATION OF THE WATER SUPPLY?** 11 Α. I will stick to what is logical to me. Anytime a drinking water line is below the elevation of the 12 sewer line there is a added risk for water contamination. An ideal situation according to the DNR regulations is a separation by a minimum of 10 foot separation; separated by virgin undisturbed 13 14

14 soil. On the causeway the separation of the two lines has disturbed soil where the service lines 15 extend to the lower level road which contains the main water line. This disturbed soil presents a 16 path for liquids to pass to the lower level which contains the drinking water line. These liquids could 17 well be waste water. I have discussed this situation with the DNR in meetings about the water 18 main being on the lower level of the causeway. The DNR engineers agreed that it would be 19 preferable to have relocated the sewer main to the lower level road.. I agree with Mr. Krehbeil that sometimes things are much easier on paper than in the field; but I see no reason that it would
have been an impractical problem to have relocated the sewer line to the lower level. I am
reminded of a discussion related to this subject by another Engineer, Mr. Jim Jackson (Folsom
Ridge Project Engineer) who in 1998 pleaded with the DNR for permission to install both water
and sewer lines in the same trench as it was impractical to install the lines in separate trenches.
Folsom Ridge and Mr. Jackson chose to install the sewer and water lines in the same trench as it
was the practical thing to do.

# Q. WERE THE BIG ISLAND WATER WELL AND WASTEWATER TREATMENT PLANT DESIGNED, CONSTRUCTED AND SEPARATED IN ACCORDANCE WITH REGULATION?

11 Α. I agree with Mr. Krehbeil's regulation quoted. The DNR regulation 10 CSR 20-8.020 (11) (A) 3 12 does state that the DNR will accept a minimum of 100 feet of separation but goes on to say that it 13 is preferable to have a separation of 300 feet between the waste water facilities at any well or 14 water supply structure. In 1998 Mr. Jim Jackson as Folsom Ridges project engineer in a letter and 15 drawing asked Folsom Ridge that the water well be a minimum of 300 feet separation. My 16 question to Mr. Krehbeil and Folsom Ridge would be: why is it that this system was not installed according to Missouri state preferred standards and regulations? Do not the residents of Big 17 18 Island deserve a system installed better than the minimum standards? Is it no wonder that Folsom 19 Ridge would like to transfer the potential liabilities to the homeowners "AS IS"? Many of the Big

 1
 Island residents want the "State of the Art" system that was promised, not a sewer & water

 2
 system "AS IS".

#### 3 INSPECTION WALK THROUGH WAS MADE BY SOME FOLSOM Q. А OF 4 RIDGE'S EMPLOYEES AND 393 SUPPORTERS. DO YOU HAVE ANY 5 COMMENTS REGARDING THE WALK THROUGH?

6 A. A walk through is commendable; but my complaints are with the installation under the ground. A 7 little tough to see on a walk through. A walk through will not show water lines lying perpendicular to sewer lines in close proximity, without sleeving, or sewer valves in the same upright with water 8 9 valves. It will not show sewer and water lines still in the same trench. Because these problems 10 are out of the jurisdiction of the DNR doesn't in my opinion make it a safe installation. Again, you 11 can get drinking water contamination from service lines in close proximity just the same as you can with main lines. The DNR does state in their writings that any service lines without jurisdiction 12 should come under the National codes which are as stringent as the DNR codes. Some Big 13 14 Islands service lines do not conform to National codes.

# Q MR. PUGH, DO YOU HAVE DOCUMENTATION TO SUPPORT THIS REBUTTAL TESTIMONY?

17 A. Yes

18 Q. ARE THERE ANY OTHER COMPLAINANTS GIVING REBUTTALS?

19 A, Yes, Ms. Cathy Orler.

2/16/2007 10:14 AM

# **1** Q. DOES THIS COMPLETE YOUR REBUTTAL ?

- 2 A. Yes.
- 3