



Kennett Board Of Public Works

P.O. BOX 40 • KENNETT, MISSOURI 63857-0040 • (573) 888-5366 • FAX (573) 888-3312

RECEIVED²

OCT 17 2013

*Records
Public Service Commission*

October 11, 2013

Mr. Steven C. Reed
Secretary/General Council
Missouri Public Service Commission
200 Madison Street, Suite 100
P.O. Box 360
Jefferson City, MO 65102

Mr. Reed,

Enclosed is our annual report for the Three Rivers Community College (formerly Emerson Electric) yard line.

We are providing this report pursuant to Missouri Public Service Commission Case No. GE-2003-0503.

Sincerely,

George Anderson
Gas Department Superintendent
Kennett Board of Public Works
Kennett, MO 63857

cc: Mr. Bob Leonberger
Missouri Public Service Commission
P.O. Box 360
Jefferson City MO 65102

**Annual Report for Three Rivers Community College Yard Line
(Formerly Emerson Electric Yard Line)**

Date: October 11, 2013

Yard Line leak survey results on 6" line: Leaks Found: Yes ☐ No ☒

If leaks found, what was done: _____

Cathodic protection readings on 6" line:

Test Point #1: -1.40v Test Point #2: -1.40v Test Point #3: -1.50v Test Point #4: -1.41v

Work performed by: Bill Heinen

(Pursuant to Missouri Public Service Commission Case No. GE-2003-0503)