



Kennett Board Of Public Works

P.O. BOX 40 • KENNETT, MISSOURI 63857-0040 • (573) 888-5366 • FAX (573) 888-3312

*RECEIVED*⁵

NOV 21 2016

*Records
Public Service Commission*

November 16, 2016

Mr. Morris Woodruff
Secretary/General Council
Missouri Public Service Commission
200 Madison Street, Suite 100
P.O. Box 360
Jefferson City, MO 65102

Mr. Woodruff,

Enclosed is our annual report for the Three Rivers Community College (formerly Emerson Electric) yard line.

We are providing this report pursuant to Missouri Public Service Commission Case No. GE-2003-0503.

Sincerely,

George Anderson
Gas Department Superintendent
Kennett Board of Public Works
303 S Anthony St
Kennett, MO 63857

cc: Ms. Kathleen McNelis
Missouri Public Service Commission
P.O. Box 360
Jefferson City MO, 65102

**Annual Report for Three Rivers Community College Yard Line
(Formerly Emerson Electric Yard Line)**

Date: Nov. 16, 2016

Yard Line leak survey results on 6" line: Leaks Found: Yes ☐ No ☒

If leaks found, what was done: _____

Cathodic protection readings on 6" line:

Test Point #1: -1.40v Test Point #2: -1.35v Test Point #3: -1.42v Test Point #4: -1.39v

Work performed by: Bill Heinen

(Pursuant to Missouri Public Service Commission Case No. GE-2003-0503)