

Exhibit No.:
Issues: Transmission Planning/
Need for the Proposed
Callaway-Franks Line
Witness: Charles E. Mitchell
Type of Exhibit: Direct Testimony
Sponsoring Party: AmerenUE
Case No.: EO-2002-351
Date Testimony Prepared: July 11, 2002

FILED²

JUL 11 2002

MISSOURI PUBLIC SERVICE COMMISSION

CASE NO. EO-2002-351

**Missouri Public
Service Commission**

DIRECT TESTIMONY

OF

CHARLES E. MITCHELL

**** Contains Proprietary Information ****

**St. Louis, Missouri
July 11, 2002**

**BEFORE THE PUBLIC SERVICE COMMISSION
OF THE STATE OF MISSOURI**


Application of Union Electric Company)
for Permission and Authority to Construct,)
Operate, Own and Maintain a 345 kilovolt) Case No. EO-2002-351
Transmission Line in Maries, Osage and)
Pulaski Counties, Missouri)
("Callaway-Franks Line"))

AFFIDAVIT OF CHARLES E. MITCHELL

STATE OF MISSOURI)
)**ss**
CITY OF ST. LOUIS)

Charles E. Mitchell, being first duly sworn on his oath, states:

1. My name is Charles E. Mitchell. I work in St. Louis, Missouri and I am employed by Ameren Services Company as Consulting Transmission Planning Engineer of the Transmission Planning and Services Group.
2. Attached hereto and made a part hereof for all purposes is my Testimony on behalf of Union Electric Company d/b/a AmerenUE consisting of 26 pages, which has been prepared in written form for introduction into evidence in the above-referenced docket.
3. I hereby swear and affirm that my answers contained in the attached testimony to the questions therein propounded are true and correct.


Charles E. Mitchell

Subscribed and sworn to before me this 10th day of July, 2002.


Notary Public

My commission expires:




TABLE OF CONTENTS

I.	INTRODUCTION
II.	BACKGROUND INFORMATION ABOUT THE COMPANY'S ELECTRICAL SYSTEM AND NEIGHBORING SYSTEMS
	A. Description of the Company's Electrical System
	B. Interconnections With Other Electrical Systems
	C. Requirements of Regional and National Organizations
	D. Requirements of Federal and State Laws
III.	NEED FOR THE PROPOSED LINE
IV.	DATA SHOWING OVERLOADS
V.	CONSEQUENCES OF OVERLOADINGS
VI.	JOINT STUDY WITH AECI
VII.	ALTERNATIVES EXAMINED
VIII.	CONCLUSION
Schedule 1	Diagram of Electrical System
Schedule 2	Map Showing Proposed Callaway-Franks Line
Schedule 3	Graph Showing Overloadings on Bland-Franks Line
Schedule 4	UE-AECI Joint Study and Related Documents

1 DIRECT TESTIMONY
2 OF
3 CHARLES E. MITCHELL
4 AMERENUE
5 CASE NO. EO-2002-351

6 I. INTRODUCTION

7
8 Q. Please state your name and address.

9 A. Charles E. Mitchell, 1901 Chouteau Avenue, P.O. Box 66149,
10 St. Louis, Missouri, 63166-6149.

11 Q. By whom are you employed and in what capacity?

12 A. I am employed by Ameren Services Company (Ameren Services)
13 as a Consulting Transmission Planning Engineer in the Transmission
14 Planning and Services Department of Energy Delivery Technical
15 Services. Ameren Services performs various technical and
16 administrative services for Union Electric Company (the Company),
17 doing business as AmerenUE, and other subsidiaries of Ameren
18 Corporation (Ameren).

19 Q. What are your responsibilities in that position?

20 A. My responsibilities include planning the development of
21 the Union Electric transmission system to ensure that it is capable
22 of transmitting the required electrical loads in an economical, safe,
23 and reliable manner. I also work on other special projects as
24 needed.

25 Q. How long have you been employed by Union Electric Company?

26 A. I have been employed full time at Union Electric Company
27 since June 1971. Since January of 1998 when the UE-CIPSCO merger
28 took effect, I became an employee of Ameren Services. My entire stay

1 at Union Electric and later at Ameren Services up to the present has
2 been with Transmission Planning. I have held the positions of
3 Assistant Engineer and Engineer in the Transmission and
4 Interconnections Group of Planning. In 1981 I accepted the position
5 of Supervising Engineer of the Transmission and Interconnections
6 Group. In 1985 I became Supervising Engineer of the Bulk Substation
7 and Subtransmission Group for all districts. In 1989 I became
8 Supervising Engineer of the Bulk Substation and Subtransmission Group
9 for the Missouri operating districts. In 1992, I accepted the
10 position of Staff Engineer, and in 2001 I accepted my present
11 position of Consulting Transmission Planning Engineer.

12 Q. What is your educational background?

13 A. I received a Liberal Arts and Science degree in Physics
14 and Mathematics from Southern Illinois University, Carbondale,
15 Illinois, in 1964. I also received a BS degree in Electrical
16 Engineering from the University of Missouri-Rolla in 1971, and an MS
17 degree in Electrical Engineering from the same school in 1978.

18 Q. Are you a registered professional engineer?

19 A. I am a registered professional engineer in the states of
20 Missouri and Illinois.

21 Q. What is the purpose of your testimony?

22 A. I will show that the proposed Callaway-Franks 345 kilovolt
23 (kV) transmission line is necessary to provide reliable service to
24 the public in Missouri, including the retail electric customers of
25 AmerenUE.

26 Q. Are you familiar with the subject matter of this case?

27 A. Yes. AmerenUE is seeking permission and authority to
28 construct, own, operate, and maintain a 345 kV transmission line in

1 Osage, Maries, and Pulaski Counties, to be known as the Callaway-
2 Franks line. As I discuss further below, AmerenUE needs to construct
3 this line to address an electrical overloading condition we
4 currently have on our existing electrical facilities and to otherwise
5 improve the reliability of the transmission system in Missouri. This
6 new 345 kV transmission line will connect UE's Callaway 345 kV
7 Substation to Associated Electric Cooperative, Inc.'s (AECI) Franks
8 Substation and will roughly parallel the Company's existing Bland-
9 Franks line located to the East. The construction for this new line
10 will be about 54 miles in length.

11 Q. Were you personally involved in any of the analyses or
12 studies which the Company performed to assess the need for the
13 proposed line?

14 A. Yes. I was involved in both the analyses and studies
15 performed to assess the need for the proposed line. In particular, I
16 performed load flow analyses on existing facilities and shared this
17 information with my counterparts from AECI. Further, I was involved
18 in drafting a joint study report with AECI referred to later in my
19 testimony.

20 **II. BACKGROUND INFORMATION ABOUT THE COMPANY'S ELECTRICAL SYSTEM AND**
21 **NEIGHBORING SYSTEMS**

22
23 **A. Description of the Company's Electrical System**

24 Q. Have you supplied a diagram to illustrate how electricity
25 flows on the Company's facilities, starting from the power plants and
26 ending up at a customer's premises?

27 A. Yes. Attached at the end of my testimony and marked as
28 Schedule 1 is a diagram showing the facilities that an electric
29 utility uses for the generation, transmission, and distribution of

1 electricity. The Company's request in this case pertains to the
2 transmission portion of its system.

3 **Q. Please describe, in more detail, how the Company's**
4 **electrical system operates.**

5 A. As illustrated on Schedule 1, electrical power is produced
6 at the Company's generating stations at voltage levels ranging from
7 11,000 to about 24,000 volts, or 11 kV to 24 kV. To achieve
8 transmission operating economies, this voltage is raised, or stepped
9 up, by power transformers at the generating station sites to voltages
10 generally ranging from 138 kV to 345 kV for transmission to the
11 Company's bulk substations that are strategically located throughout
12 its service area.

13 **Q. What is the function of the Company's bulk substations?**

14 A. Bulk substations receive electrical power at transmission
15 voltage levels. They then lower, or step-down, this power to other
16 transmission or distribution voltages generally ranging from 138 kV
17 to 34.5 or 69 kV. Such power is then distributed over the Company's
18 34.5 or 69 kV distribution lines to distribution substations located
19 throughout the Company's service area.

20 **Q. What function do distribution substations perform?**

21 A. Distribution substations, which are far more numerous than
22 bulk substations, provide a further reduction in the electrical power
23 voltage to a range of 4 to 13.8 kV within various portions of the
24 Company's service area. Such power is then distributed over the
25 Company's 4 to 13.8 kV distribution lines to points at or near the
26 premises of the Company's customers.

1 Q. After electrical power at 4,160 to 13,800 volts is
2 delivered to a point at or near a customer's premises, do any further
3 reductions in voltage take place?

4 A. Yes, in most instances. While approximately 650 of the
5 Company's largest industrial and commercial customers take service at
6 the 4,160 to 13,800 volt range or higher in Missouri, the majority of
7 the Company's customers are served at lower voltages, ranging from
8 120 to 480 volts. Such lower voltages are achieved through the use
9 of numerous line transformers located at or near a customer's
10 premises. This low voltage electrical power from the line
11 transformer is delivered to a customer's premises over low voltage
12 lines referred to as "secondary" and "service" lines.

13 Q. What voltages are utilized in providing electric service
14 to residential customers?

15 A. Residential customers are served at either 120 or 240
16 volts depending upon the customer's service entrance panel size and
17 connected appliances.

18 Q. What voltages are utilized to serve non-residential
19 customers?

20 A. Non-residential customers on the Company's Small and Large
21 General Service Rates are served at voltages from 120 to 480 volts
22 due to the wide variety of electrical consuming devices utilized by
23 such customers. Customers in the latter voltage range are often
24 referred to as "secondary" voltage customers. Other larger non-
25 residential customers receiving service at 4,160 to 13,800 volts are
26 referred to as "primary" voltage customers. The Company also serves
27 approximately 50 customers in Missouri at voltages above the 13,800
28 volt level. These are referred to as "high voltage" customers.

1 Q. In your description of the Company's generation,
2 transmission and distribution system are you using the term "lines"
3 in a general sense?

4 A. Yes. Such lines may be overhead conductors or underground
5 cables. Overhead lines include all poles, towers, insulators,
6 crossarms and all other hardware associated with such installations.
7 Underground "lines" include direct buried cable as well as that
8 installed in single or multi-duct conduit, and other associated
9 hardware.

10 B. Interconnections With Other Electrical Systems

11 Q. Is the Company's electrical system connected with the
12 systems of other electrical suppliers?

13 A. Yes. Although not illustrated on Schedule 1, the
14 Company's electrical system is interconnected with many other
15 electrical systems in the Midwest. These other systems include the
16 following: AECI, Kansas City Power and Light, Aquila (formerly
17 Utilicorp), Illinois Power, AmerenCIPS (an affiliate of AmerenUE) and
18 MidAmerican, and many other systems as well. The Company's
19 interconnections with these electrical systems provide great benefits
20 to the Company's customers in terms of reliability and efficiency,
21 and allow the Company to access power from other systems when
22 necessary, in case of an emergency, or when it is economically
23 desirable, when cheaper power is available from sources other than
24 the Company's generating units.

25 C. Requirements of Regional and National Organizations

26 Q. Is AmerenUE a member of any regional or national
27 organizations which impose requirements for operating and maintaining
28 an electrical system?

1 A. Yes. The Company is a member of the Mid-America
2 Interconnected Network, Inc. (MAIN). MAIN is one of several regional
3 reliability organizations operating under the auspices of the North
4 American Electric Reliability Council (NERC). Through MAIN, the
5 Company is also a member of NERC.

6 **Q. Please discuss the origins of NERC.**

7 A. NERC was formed after the Northeastern blackout in the mid
8 1960s when the northeastern part of the United States experienced
9 widespread outages and loss of power in the New York and New England
10 areas. NERC was formed to ensure that such a widespread event would
11 not occur again, and also to prescribe good utility practices for
12 reliable service by electrical systems operating throughout the
13 United States. NERC is divided into different regions, which have
14 authority over the systems within a particular region of the country.

15 **Q. Please discuss MAIN and AmerenUE's membership in it.**

16 A. AmerenUE, like all prudent operators of electric
17 transmission systems, is a member of a regional electric reliability
18 council. In AmerenUE's case, the regional council is MAIN. MAIN
19 serves as the regional reliability authority, which is charged with
20 ensuring reliable service in the Midwestern areas, including all of
21 AmerenUE's Missouri service area.

22 **Q. Please provide an example of what MAIN will do to ensure**
23 **reliable service by its members.**

24 A. The example most relevant to this case involves
25 Transmission Loading Relief (TLR) procedures developed by NERC and
26 administered by each reliability authority, such as MAIN. In
27 particular, when MAIN believes that loadings on the transmission

1 lines of its member companies are too high, it will invoke NERC's TLR
2 procedures.

3 Q. Please describe these TLR procedures.

4 A. There are 7 levels (2, 3a, 3b, 4, 5a, 5b, and 6) of TLR
5 that call for changes in transmission transactions, in generation,
6 and in native load to maintain reliable service to as many users of
7 the interconnected grid as possible. Level 2 holds transactions
8 between neighboring systems at the current level. Levels 3a and 3b
9 reallocate and/or curtail non-firm transactions. Level 4
10 reconfigures a transmission system. Level 5a reallocates firm
11 transactions. Level 5b involves pro rata curtailment of firm
12 transactions, network integrated transmission service, and native
13 load. Level 6, Emergency Action, includes demand-side management,
14 redispatch, voltage reductions, interruptible, and firm load
15 shedding.

16 By way of analogy, TLR procedures are similar to "rules of
17 the road" which govern traffic on an interstate highway. At the
18 lowest and least serious level, a highway controller might issue a
19 warning that traffic will be heavy at a particular time. At the next
20 higher level, when traffic congestion becomes a more serious issue,
21 the highway controller might take action to prevent any new cars from
22 entering the highway. Next, the controller might take action to
23 require that some cars leave the highway. (This would be analogous
24 to a requirement to interrupt transmission service to users on a non-
25 firm rate.) Next, the controller might require the payment of a
26 higher toll on the road to attempt to further ease congestion. (This
27 would be analogous to using a more expensive power plant, through
28 redispatch, that could relieve some of the congestion.) Finally, at

1 the most serious level, congestion might be so intense that local
2 traffic might be required to exit the highway. (This would be
3 analogous to interrupting service to the utility's retail customers
4 who are served on a firm, non-interruptible basis.)

5 In addition to TLRs, MAIN imposes numerous requirements on
6 AmerenUE and the other members of MAIN in terms of how they plan and
7 operate their systems, including how much generating reserves a
8 system must have.

9 D. Requirements of Federal and State Law

10 Q. In addition to the requirements of MAIN and NERC, is the
11 Company subject to other requirements as to how it should operate and
12 maintain its electrical system?

13 A. Yes. Federal regulations require that AmerenUE and other
14 owners of transmission systems make their systems available to
15 eligible users on a non-discriminatory, open-access basis. This
16 means that the Company must allow a variety of transmission
17 customers--such as Independent Power Producers (IPPs), municipal
18 systems, cooperatives, wholesale transmission customers and eligible
19 retail customers--to use its transmission system, and must expand
20 that system as necessary to accommodate their requests for
21 transmission service. These regulations have been imposed since 1997
22 by the Federal Energy Regulatory Commission (FERC). More recently,
23 the FERC has strongly encouraged owners of transmission systems such
24 as AmerenUE to join Regional Transmission Organizations (RTOs) to
25 allow for the coordinated operation of multiple transmission systems
26 on a regional basis. AmerenUE is in the process of complying with
27 FERC's requirements to join an RTO. As I understand it, this is

1 consistent with orders and recommendations of the Missouri Public
2 Service Commission and its Staff.

3 In addition to requirements of the FERC, AmerenUE is
4 required to comply with numerous requirements and regulations imposed
5 by its state commissions, not only the Missouri Commission but also
6 the Illinois Commerce Commission. Generally, the state commissions
7 require that AmerenUE and other electrical suppliers subject to state
8 authority operate and maintain their electrical systems in a
9 reliable, efficient, and safe manner.

10 **III. NEED FOR THE PROPOSED LINE**

11 **Q. Have you supplied a map showing the location of the**
12 **proposed line?**

13 **A. Yes.** Attached to my testimony and marked as Schedule 2 is
14 a map showing the location of the existing Bland-Franks 345 kV line
15 and the proposed Callaway-Franks 345 kV line. The purpose of this
16 map is to show the approximate location of the Company's existing
17 Bland-Franks 345 kV line and the location of the proposed Callaway-
18 Franks 345 kV line.

19 **Q. Please discuss why AmerenUE decided to build the proposed**
20 **Callaway-Franks 345 kV transmission line.**

21 **A.** AmerenUE concluded that the proposed line was essential to
22 provide reliable and safe electric service to its Missouri customers.
23 In particular, the proposed line is necessary 1) to avoid electric
24 service interruptions, 2) to avoid safety related problems and
25 hazards for employees and members of the public, and 3) to avoid
26 damage to existing electrical facilities and to other property. If
27 the proposed line is not built, it will compromise AmerenUE's ability
28 to provide reliable service and will increase the likelihood that

1 there will be unsafe conditions and damage to persons and to
2 property.

3 **Q. Is the proposed line necessary to provide reliable and**
4 **safe service to Missouri customers on electrical systems other than**
5 **AmerenUE's?**

6 **A. Yes. The proposed line is necessary to provide reliable**
7 **and safe electric service to retail customers served by AECI and its**
8 **distribution cooperatives. As discussed more fully below, the need**
9 **for the proposed line was determined from a joint planning effort**
10 **undertaken by AmerenUE and AECI to coordinate their transmission**
11 **planning efforts for their customers and to minimize the potential**
12 **for conflicting and duplicative facilities.**

13 For many years, AmerenUE's electrical system has been
14 connected at numerous locations with AECI's electrical systems.
15 Because of these interconnections, AmerenUE and AECI have engaged in
16 joint efforts on previous occasions to coordinate their transmission
17 planning efforts for the benefit of their Missouri customers.

18 **Q. Please explain why the proposed line is needed to provide**
19 **reliable service to the public in Missouri.**

20 **A. Reliable electrical service is service that is provided on**
21 **a continuous basis with a minimum number of interruptions and that is**
22 **within acceptable electrical parameters such as voltage and current.**
23 **AmerenUE can not guarantee that there will never be any interruptions**
24 **because of forces outside of AmerenUE's control, for example weather**
25 **conditions (e.g. thunderstorms and tornadoes). However, AmerenUE**
26 **does strive to minimize the number of interruptions by taking steps**
27 **that are within its control. This includes steps to ensure that the**
28 **existing electrical facilities are operating within their specified**

1 electrical limits. If any particular transmission line becomes too
2 heavily loaded--that is, loaded beyond its rated electrical
3 capability--it will increase the risk of failure of that line and
4 neighboring lines. It can even affect the entire interconnected
5 transmission system, including as noted above AECI's system and that
6 of its member cooperatives. This means that a line that is too
7 heavily loaded can increase the frequency and likelihood of service
8 interruptions to AmerenUE's and AECI's customers in Missouri.

9 Therefore, loading above a line's capability could
10 jeopardize the integrity of the line and impact the reliability of
11 the transmission system. This in turn could negatively impact both
12 AmerenUE's customers and customers of others who depend upon the line
13 (including the cooperatives) in a variety of ways. Furthermore, if a
14 line were to experience an outage--that is, if it were opened, or
15 tripped out of service--when its loading is above its capability, the
16 impact could be felt on other area facilities.

17 **Q. Please explain why the proposed line is needed to avoid**
18 **safety related problems.**

19 A. A loading above a line's electrical rating may cause the
20 line to violate minimum ground clearances as specified by the
21 National Electric Safety Code. When those clearances are violated,
22 the risk of harm to persons, to third-party property, and to the line
23 itself increases. Among the increased risks are of course possible
24 direct contact with the line including electrocution or fire risks.
25 As I discuss throughout my testimony, the overloading conditions we
26 have seen in this area are increasing the risk of these safety
27 concerns which we can alleviate with this new line.

1 Q. It seems obvious how inadequate line clearances can damage
2 persons or property, but how does that affect the line itself?

3 A. Because the transmission system is interconnected,
4 transmission facilities share in the division of power. All
5 transmission facilities carry power (current) according to the laws
6 of physics. As the loading on the existing Bland-Franks 345 kV line
7 loading increases, other facilities experience an increase or
8 decrease in power flow as well, but not in the same proportion. If
9 the overloading results in an outage on the Bland-Franks 345 kV line--
10 -that is, if the line is not able to carry any power--then several
11 transmission facilities in the mid-Missouri area will experience
12 loading changes, and some of those other facilities may themselves
13 become overloaded. For transformers, such overloads decrease the
14 life of the transformer by weakening its insulation, thereby
15 advancing the failure of a key facility such as a transformer. For
16 line conductors, such overloads result in reduced strength and
17 conductor sag. If transformers and conductors fail, service
18 interruptions can occur, and of course the cost to operate and
19 maintain the entire system increases. Those costs are ultimately
20 borne by AmerenUE's customers as determined by the Commission's
21 ratemaking process. Similar costs would be borne by customers of the
22 cooperatives.

23 IV. DATA SHOWING OVERLOADINGS

24 Q. Please discuss the recent history concerning the use of
25 electricity on existing lines in the area.

26 A. In 1997, AmerenUE's existing Bland-Franks 345 kV line
27 loading began to experience loadings in excess of its summer normal
28 rating. In 1998, 1999, and 2000 the loading on the Bland-Franks 345

1 kV line continued to get higher and higher with more frequent
2 excursions above the normal rating. At times the loading was such
3 that there was a potential to exceed its summer emergency rating if
4 an outage on the parallel Rush Island 345 kV line outage were to
5 occur. Additionally, transmission service requested by several open
6 access transmission customers, including an IPP owning a generating
7 plant in Missouri, was refused because of the Bland-Franks 345 kV
8 line constraint. The addition of Callaway-Franks 345 kV line would
9 allow the granting of transmission service associated with these
10 requests. This type of transmission service has the ability to allow
11 access to additional electric generation that, if needed, can be
12 utilized by utilities such as AmerenUE or AECI.

13 Q. Do you have any data showing these overloading problems?

14 A. Yes, attached at the end of my testimony as Schedule 3 is
15 a frequency plot of the loading on the Bland-Franks 345 kV line
16 during the period 1998 through 2001 normalized to the summer rating
17 of 949 MVA. The intent of the frequency plot is to help visualize
18 the Bland-Franks 345 kV line loading for the last four years. Note
19 that the Bland-Franks 345 kV line loading has been increasing from
20 1998 through 2000 and that loading in 2001 was higher than 1998 and
21 1999. For the year 2000, the Bland-Franks 345 kV line loading
22 pattern was the highest when compared to the other years. The
23 "Percent of Time" versus the "Percent of Rating" 2001 plot is less
24 than that for 2000 because some local generation plants connecting to
25 the 345 kV transmission system were out of service for refueling,
26 maintenance and/or overhaul, and there was improved coordination of
27 transmission service, and there were changes in weather and market
28 activity. Even with these factors, the 2001 patterns are still

1 unacceptable from a reliability, safety and property damage
2 perspective.

3 Q. Do you expect this high loading pattern to continue on the
4 Bland-Franks 345 kV line if the Callaway-Franks 345 kV line were not
5 built?

6 A. Yes, I do expect the high loading pattern on the Bland-
7 Franks 345 kV line to continue into the future. The line loading
8 will continue because of increases in the electrical requirements of
9 AmerenUE's Missouri retail customers, and in the requirements of the
10 cooperatives, and also because of long term power scheduling
11 commitments and transmission service reservations. Based on the
12 federal regulations of the FERC referenced above, the Company must
13 make its transmission system available to all eligible customers such
14 as IPPs, which want to build power plants in AmerenUE's service area,
15 and also to Power Marketers, which want to schedule power across or
16 into or out of AmerenUE's transmission system. These multi-purpose
17 uses of the transmission system will result in continued exposure to
18 high loading patterns.

19 Q. Have you obtained the input of the Commission's Staff
20 regarding the need for the line?

21 A. Yes. The Staff has requested and obtained data, both
22 historical and engineering, that we relied upon to demonstrate the
23 overloadings on existing facilities. It is my understanding that the
24 Staff concurs in our conclusions regarding the need for the proposed
25 line as evidenced by its conditional recommendation for Commission
26 approval as set forth in the Staff's report dated April 29th filed in
27 this case.

1 V. CONSEQUENCES OF HIGH LOADINGS

2 Q. What happens if loadings on existing facilities become too
3 high?

4 A. As referenced above (in Section II.C.), if loadings
5 become too high, MAIN will invoke TLR procedures. It is important
6 to understand that having to call TLR on any facility at all is never
7 a good thing. Calling a TLR means that some facility is overloaded
8 for normal conditions (i.e., when there are no outages) or has the
9 potential to overload if there is an outage of some specific
10 facilities resulting in emergency conditions.

11 Q. Did MAIN call TLR when the Bland-Franks 345 kV line was
12 operating above its normal rating and/or when it was projected to
13 operate above its emergency rating for the outage of a critical
14 element?

15 A. Yes. TLR was called several times to reduce line flows
16 that were above, or were projected to be above, a line's rating.
17 TLRs were called by the MAIN reliability authority as a tool to
18 reduce the heavy flows on facilities of member companies. These TLRs
19 are also reported to the NERC.

20 As pointed out above, TLRs are very undesirable and should
21 occur rarely, or not at all, if the existing transmission system is
22 adequate. If conditions lead to a TLR being called, then
23 transactions will be interrupted, and thus some customers may have to
24 be interrupted. The first customers to be interrupted are those who
25 subscribe to interruptible power, but other customers also may be
26 affected. AmerenUE and surrounding utilities may also be forced to
27 rely upon more expensive generation options so that the loading of
28 the affected part of the transmission system can be reduced.

1 Thus, the proposed line is needed to provide adequate transmission
2 capacity and to reduce the need for TLRs.

3 Q. Mr. Mitchell, how many times were TLRs called on the
4 Bland-Franks 345 kV line in the last several years?

5 A. In 1997, 18 TLRs were called on Bland-Franks 345 kV line.
6 In 1998, 15 TLRs were called on Bland-Franks 345 kV line. In 1999, 21
7 TLRs were called on Bland-Franks 345 kV line. In 2000, 124 TLRs were
8 called on Bland-Franks 345 kV line. In 2001, 13 TLRs were called on
9 Bland-Franks 345 kV line.

10 Q. Can you help us understand the reasons for the reduction
11 in the TLRs called on Bland-Franks during 2001?

12 A. Yes. One of the major reasons for fewer TLRs called on
13 the Bland-Franks 345 kV line in 2001 was the temporary unavailability
14 of local generation. There were several generator unit outages the
15 result of which was a decrease in the loading on the Bland-Franks 345
16 kV line. AmerenUE's Callaway Power Plant was out of service for
17 about a month because of its refueling and associated standard
18 maintenance schedule needs. Also, its Labadie Power Plant and Rush
19 Island Power Plant experienced outages some of which were coincident
20 during the spring and fall of 2001 because of forced outages. These
21 outages were more numerous in 2001 than those in 2000. Other than the
22 regular scheduled maintenance outages, the major units were available
23 for operation during 2000. Another major reason was improved
24 interregional coordination of the use of the transmission system.
25 Also, there have been major variations in weather patterns and energy
26 market conditions. In any case, the number of TLRs was still
27 unacceptable, as previously discussed.

28 Q. What type of TLRs were called on Bland-Franks 345 kV line?

1 A. TLRs called on the Bland-Franks 345 kV line involved Level
2 3a.

3 Q. Did NERC identify the Bland-Franks 345 kV line as a
4 significant constraint to power transfers to MAIN in their 2002
5 Summer Assessment?

6 A. Yes, in the NERC's 2002 Summer Assessment, the Bland-
7 Franks 345 kV line as one of the two facilities in the MAIN region,
8 that includes Wisconsin, Illinois, and AmerenUE's service territory
9 in Missouri that were identified as restricting MAIN power transfers
10 in 2001. In addition, the Bland-Franks 345 kV line has been
11 identified by NERC as one of the primary causes of congestion in the
12 entire interconnected transmission system (basically the electric
13 transmission system from the Rocky Mountains to the East Coast,
14 excluding parts of Texas).

15 VI. JOINT STUDY WITH AECI

16 Q. You previously mentioned a joint planning effort with
17 AECI. Please discuss this joint study in more detail.

18 A. Attached at the end of my testimony as Schedule 4 is a
19 report of the joint study performed by AECI and Ameren Services,
20 together with related documents. First of all, please note that this
21 report and the related documents contain information about other
22 proposed lines, in addition to Callaway-Franks, that are under
23 consideration by both AmerenUE and AECI. This information is
24 sensitive and confidential from a commercial and business standpoint
25 and if disclosed to the public, or to segments of the public, it
26 could compromise the ability of AmerenUE and AECI to buy and sell
27 electricity, and to provide transmission service, at reasonable
28 prices. In particular, if these documents were obtained by IPPs or

1 other users of the transmission system it would provide to them
2 valuable information about the development of the AmerenUE and AECI
3 transmission systems which might allow them to game the system to the
4 detriment of AmerenUE and AECI and their customers. For example, if
5 such IPPs and transmission users knew the location of a proposed line
6 that had not been disclosed to the public it might allow them to
7 build their generating facilities in a certain location, or to choose
8 transmission service on certain paths, ahead of other users,
9 including the Company and AECI, to their detriment. It could also be
10 in conflict with FERC's regulations to provide non-discriminatory
11 open-access transmission service.

12 **Q. Please provide some background on the joint study.**

13 A. In the spring of 2000, AECI and AmerenUE agreed to perform
14 a joint study to investigate the high loading being experienced on
15 some of AECI's transmission facilities and on some of AmerenUE's
16 transmission facilities. As the result of the joint study, the best
17 plan to mitigate these heavy loading was to build a Rush Island-St.
18 Francois 345 kV line, a Callaway-Franks 345 kV line, and install a
19 larger Franks 345/161 kV transformer. Though this study is labeled as
20 a draft, it is complete in all significant respects. In particular,
21 both AECI and Ameren have agreed with the report contents and with
22 the conclusions. The report has not yet been finalized because of
23 time constraints, including the need to move forward with work needed
24 to get the proposed line built as soon as possible. The report is
25 complete except for certain minor tasks, consisting of the writing
26 the Executive Summary, making a few editorial changes, and
27 reformatting the report to improve its appearance. All of the
28 analyses and conclusions of the report have been completed.

1 Q. Was power flow analysis performed as part of the joint
2 study?

3 A. Yes, I performed a power flow analysis as part of the
4 joint study.

5 Q. As a result of your power flow analysis, what overloads or
6 voltage problems were identified assuming the Callaway-Franks 345 kV
7 line was not built?

8 A. For the system conditions modeled in the study, several
9 AmerenUE facilities would be overloaded in the event of the loss of,
10 or outage of, the Bland-Franks 345 kV line. These overloaded
11 facilities include the Overton 345/161 kV transformer, the St.
12 Francois-Esther-Rivermines 138 kV line, the St. Francois-Rivermines
13 138 kV line, the Selma-Rivermines 138 kV line, and the Clark-Viburnum
14 161 kV line. Overloading these facilities could create the kinds of
15 problems for Missouri customers discussed above. AECI's Maries
16 138/161 kV transformer could also overload negatively impacting
17 cooperative customers. Low voltage was identified at the AECI Franks
18 161 kV Substation during heavy loading on the Bland-Franks 345 kV
19 line. Low voltage situations reduce the service that the electric
20 provider (in that case, the cooperatives) can provide to its
21 customers.

22 Q. What is the significance of transmission line outages?

23 A. Each transmission line outage impacts other facilities.
24 The 345 kV transmission system generally carries more power as
25 compared to the parallel lower voltage lines, thereby relieving the
26 lower voltage facilities of the burden of carrying large quantities
27 of power. When 345 kV facilities suffer an outage, the impact on the
28 lower voltage facilities is generally increased loading. This

1 increased loading can be such that the facilities are overloaded as
2 was identified above. When a facility experiences an overload
3 condition, it could become damaged or it could result in an outage of
4 its own. In short, the present overloading of the Bland-Franks line
5 and outages thereon expose facilities throughout the system,
6 including other 345 kV and 161 kV lines, to potential overloads. As
7 such, this increases the frequency and likelihood of the problems
8 discussed earlier in my testimony.

9 Q. If the Callaway-Franks 345 kV line is built, would these
10 overloads that you have been discussing be eliminated when there is
11 an outage of the Bland-Franks 345 kV line?

12 A. Yes. Once the Callaway-Franks line is in service, the
13 other facilities would not be overloaded if the Bland-Franks line
14 experienced a forced outage (that is, forced out of service) due to
15 weather related damage or other accident, or is out of service for
16 maintenance, because the newly upgraded system could handle the
17 displaced loads.

18 Q. Please help us understand your statement in a previous
19 answer that low voltage was experienced in the power flow analysis at
20 AECl's Franks Substation.

21 A. Voltage is another transmission system characteristic. As
22 noted above, the Franks Substation 345 kV and 161 kV voltages are
23 reduced as the Bland-Franks line loading increases to at or above the
24 circuit rating. Low voltages can adversely impact reliability to area
25 customers.

26 VII. ALTERNATIVES EXAMINED

27 Q. Were alternatives to building the Callaway-Franks 345 kV
28 line investigated?

1 A. Yes, several alternatives were investigated. None of them
2 were acceptable as compared to the construction of the Callaway-
3 Franks line.

4 Q. Please tell us what alternatives were investigated.

5 A. In general, the joint study investigated the option of
6 placing a series inductor in the Bland-Franks 345 kV line or building
7 one of several other 345 kV lines. Though various series inductor
8 impedance sizes were modeled, the end result was to push the power to
9 other parts of the transmission system, which could then cause
10 overloads on those parts of the transmission system. Thus, relying
11 on series inductors to reduce loading alone simply solved one problem
12 but created another equally unacceptable problem. We also considered
13 building a 345 kV line from Overton to Franks, from Pleasant Hill to
14 Morgan, and from Callaway to Jefferson City to Franks. None of these
15 lines performed as well as the Callaway-Franks 345 kV line to relieve
16 Bland-Franks loading.

17 Q. Why was the proposed Callaway to Franks 345 kV line
18 considered as a possible solution?

19 A. There were two primary reasons to consider a 345 kV line
20 from Callaway to Franks. First, it would represent a line in
21 parallel with the Bland-Franks 345 kV line. Such a new line,
22 operating in parallel with Bland-Franks, would share the loading that
23 Bland-Franks now carries thus reducing the flows (and overloading)
24 that Bland-Franks now experiences. A good analogy to what we are
25 doing is to take the case where a bypass highway is built to take
26 some of the traffic off of an overloaded existing road. The power
27 (traffic) still needs to go to and from the same places so it makes
28 sense to build the second line (road) parallel to the existing road.

1 Secondly, AECI already held a significant amount of the easements
2 needed for such a line because the proposed Callaway-Franks line is
3 designed to serve much the same purpose for which AECI originally
4 obtained the easements. As I discuss below, the need for a line from
5 Callaway to Franks was able to be deferred for a number of years in
6 part because of joint cooperation between AmerenUE and AECI, but
7 changed circumstances have simply brought an end to that deferral
8 period.

9 Q. Why did AECI hold these easements?

10 A. As I alluded to above, it is my understanding that AECI,
11 as part of the addition of generating capacity at its Thomas Hill
12 Power Plant in the 1980s planned to build 345 kV transmission from
13 Thomas Hill to Franks via their Chamois Power Plant. Much of that
14 line would have essentially taken the same route as our proposed
15 Callaway-Franks line. To this end AECI began to secure right of way
16 (ROW) for that project in the late 1970s and earlier 1980s. The 345
17 kV line was ultimately terminated at Kingdom City as the result of a
18 joint study between AmerenUE and AECI. The study developed a
19 mutually beneficial plan that allowed AECI and AmerenUE to provide
20 reliable service to the mid-Missouri area without the need to extend
21 the 345 kV line to Franks at that time. As a result, AECI "banked"
22 the ROW against future needs.

23 Q. So the proposed line is not a new project?

24 A. Correct. AECI originally intended to build, at their
25 expense, a similar line from Chamois to Franks. The earlier joint
26 study conducted in the 1980s allowed for a deferral of the project.
27 Current conditions have revived the need for the line, which was part
28 of a joint effort between AmerenUE and AECI to improve the

1 transmission system in the Mid-Missouri area. Because this line
2 benefits AECI and cooperative customers, AECI is contributing ROW
3 easements as part of the project. They are also contributing a new
4 345/161 kV, 625 MVA transformer, a 345 kV breaker position, and
5 associated relay equipment at their Franks Substation for this
6 project. For its part, AmerenUE is making substation changes at
7 Callaway, building a substation near Loose Creek, and building the
8 line. AECI will realize improved system reliability as a result of
9 this project plus AECI has the right to install a 345/161 kV
10 transformer at AmerenUE's Loose Creek Substation supplied by this
11 line that will support Central Electric Cooperative's, a member of
12 AECI, transmission system in the Mid-Missouri area. Central Electric
13 supplies power to the local distribution cooperatives that serve
14 individual customers in Mid-Missouri. In short, this is a win-win
15 for both AmerenUE and the cooperatives and their customers.

16 Q. What are the major benefits to be derived by AmerenUE from
17 this proposed Callaway-Franks 345 kV line?

18 A. The major benefits are to relieve loading on the Bland-
19 Franks 345 kV line, to ensure that existing facilities are safe, to
20 keep from overloading and possibly damaging the Bland-Franks line and
21 other transmission facilities if there are outages on the Bland-
22 Franks 345 kV line, and to maintain a reliable transmission system
23 for our customers.

24 Q. You discussed before that AECI has contributed to this
25 project because of benefits it also realizes from it and have touched
26 on some of the benefits AECI and the cooperatives will realize. Can
27 you please summarize those benefits?

1 A. The main benefits of which I am aware will be as follows:

2 1) an improvement of the voltage available to AECI at its Franks
3 substation, 2) avoiding overloading of cooperative facilities if
4 outage conditions on the Bland-Franks line "push" loads onto these
5 other facilities, 3) the cooperatives' ability to use the connection
6 they will have at the new Loose Creek Substation to enhance service
7 to their customers in the area, and 4) the access the new line gives
8 the cooperatives to the wholesale power markets in times when they
9 may need more power, or can buy it in the market more cheaply.

10 Q. One final topic that has been raised. Can the Callaway-
11 Franks 345 kV line be placed on towers with the existing Central
12 Electric Chamois-Maries 161 kV line?

13 A. No. To do so would require that the entire existing
14 Chamois-Maries 161 kV line be taken out of service for approximately
15 two years. The Chamois-Maries 161 kV line is one of three 161 kV
16 outlet lines for Chamois Power Plant. The Chamois-Maries 161 kV line
17 is an integral part of the cooperatives' transmission system. With
18 the long-term outage of the Chamois-Maries 161 kV line, the Sullivan
19 161 kV Substation will be unable to support its load for a Chamois-
20 Big Springs 161 kV line outage.

21 Therefore, having the existing Chamois-Maries 161 kV line
22 out of service for an extended period of time is not an acceptable
23 engineering solution as it would significantly impair the reliability
24 of the cooperatives' systems. It would be like shutting down a major
25 highway for a period of two years where there exists no acceptable
26 detour to handle the traffic.

27 Q. Why couldn't the line be taken out of service in stages?

1 A. Power must be moved on a transmission line from point to
2 point - substation to substation. You simply can not shut down a
3 "piece" of a line because the power can not get from point A to point
4 B where it needs to go. Once any part of the line is removed from
5 service, the entire line is outaged and no power can flow from one
6 terminal to the other terminal.


7 **VIII. CONCLUSION**

8 Q. Please summarize your testimony.


9 A. The Callaway-Franks 345 kV line is the result of a joint
10 project with AECI that will enhance AmerenUE's and AECI's
11 transmission systems, which in turn will allow AmerenUE and the
12 cooperatives to more reliably serve their customers. Without this
13 project, the Bland-Franks 345 kV line will continue to experience
14 overloads and will thereby adversely impact transmission system
15 reliability, will increase safety related problems, and will also
16 increase the potential to damage transmission system equipment and
17 other property. The proposed line is the best way to address these
18 problems and is the most feasible and economical of all of the
19 alternatives studied.

20 Q. Does this conclude your testimony?


21 A. Yes, it does.



Callaway-Loose Creek-Franks 345kV Transmission Line



Bland-Franks 345 kV Line
% of Time Above Summer Normal Rating
For Years 1998, 1999, 2000, and 2001



% of Rating
949 MVA Summer Rating