

Exhibit No.:14  
Witness: Greg Elam  
Type of Exhibit: Direct  
Sponsor: Boulevard Brewing Company  
Case No.: EC-2006-0332

Subj: **RE: FW: dwf file**  
Date: 3/2/2006 4:41:11 PM Eastern Standard Time  
From: [Carl.privitera@markone.com](mailto:Carl.privitera@markone.com)  
To: [Elam2000@aol.com](mailto:Elam2000@aol.com)  
*Sent from the Internet ([Details](#))*

If we are only working on Bellview. All cable to be furnished and installed within a ductbank provided by others. All transformer pads, vaults, and switchgear pads by others. We will provide only the cable, installation, and termination.

Assume 500 mcm 15KV shielded cable. EPR. 1045 lf of 3 cond cable for Bellview and Alley. \$59,000.

If we are only doing Bellview we anticipate 572 LF. \$45,000.

Please note we do not include any permit, engineering, maintenance, testing, or theft if left non energized. This area has a high steal appeal rating. Known to steal copper if not energized. Copper is at \$2.18 per pound today.

Hope this helps.