



Work with S/O

Premise 350185083 32 Crabapple CT

Account 649266 Dzhurninskaya, Zhinaida

All Times Central Open Only  Yes  No

Position to order number

S/O Number	Scheduled	All Day	Type	Account	Closed	Close Date	Appt	Crew	Sts
5079426	12/21/2009	All Day	MTRCH	649266	Y	12/17/2009	N	35C14	
5075734	12/17/2009	All Day	CKMTR	649266	Y	12/17/2009	Y	35C14	
5067636	12/10/2009	All Day	CKMTR	649266	C	12/09/2009	N	35C14	
5061110	12/04/2009	All Day	HILDW	649266	Y	12/04/2009	N	35C14	
3465331	03/01/2006	12:31 PM	DIST	649266	Y	03/02/2006	N	35C02	
3464102	02/28/2006	08:00 AM	MTRCH	649266	Y	02/28/2006	N	35C02	
3461794	02/28/2006	All Day	CKMTR	649266	Y	02/28/2006	N	35C02	

New S/O  Select  S/O Log



Path \_\_\_\_\_ Account # 649266-4 Name Dzhurinskaya, Zinaida

Misc Chrg List | Fixed Chrg List | Contract Entry | Billed Svc List |

Work with S/O | New/Edit S/O | S/O Acct Info | Premises Addtl | S/O Predet Cmnt | S/O Comments | S/O Services |

Service Order Type HILDW RefRead and/or Inspect for Leak Service Order Number 5061110

Comment Lines

Comment Lines	Type
Re-read/inspect meter and check for leaks; customer has high bill. Customer wishes to be present for inspection.	S
Customer had used kit online, believes that something is wrong with the meter because it is always moving. Advised that that would show a leak. Wants meter checked. Issued a HILDW.	S
W001 Meter reading: 93.	S
timed mtr 15 min mtr shows 7 tenths of a cubic ft loss can not detect leak at mtr and yoke i am sending two man crew to pump out box to the bottom to check for service line leak customers stop and waste will not shut off completely to test between mtr and shut off valve and	S
Verified read OK	S

FoldUnfold

E-CIS V597M8

OK

Cancel

