

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

McClannahan, Governor • Stephen W. Mahles, Jr., Director

DIVISION OF ENVIRONMENTAL QUALITY

Jefferson City Regional Office
 210 Hoover Road P.O. Box 176 Jefferson City, MO 65102-0176
 (573) 751-2729
 FAX (573) 751-0011

May 25, 1999

CO Schedule
 1

CERTIFIED MAIL # Z 290 136 189
 RETURN RECEIPT REQUESTED

Fulsum Ridgelle dba Big Island
 c/o David Lee, Management
 HCR 67, Box 680
 Roach, MO 65787

Dear Mr. Lee:

Enclosed is a Notice of Violation number 1315 JC being issued to Fulsum Ridgelle dba Big Island for failure to construct water lines and sewer lines in accordance with approved plans. On April 23, 1999, inspection of work being conducted on the water and wastewater lines for the Big Island in Camden County found illegal water and sewer mains being constructed. Instead of constructing individual one-inch PVC service lines for water and wastewater to each home, one inch lines were being placed to serve up to three homes. This would make the lines by definition water and wastewater mains, which have to be at least two-inch PVC and receive prior approval by the Department.

You stated at the time of my inspection that the change from single service lines to lines serving up to three homes was a misunderstanding of the requirements and what was approved. You have since stated to me that all work has been corrected. To resolve this matter, written certification needs to be submitted by your engineer verifying that all water and wastewater construction was corrected /completed in conformance with approved plans. Also, I noted that the water and wastewater service lines were being placed in the same trench. Separation of water and sewer service lines should meet national plumbing code standards.