

## Marke, Geoff

**From:** Weckenborg, Scott  
**Sent:** Friday, November 3, 2023 12:25 PM  
**To:** Marke, Geoff  
**Subject:** RE: question on monthly water testing

Good afternoon Geoff,

Even though Raytown Water Company purchases water from Kansas City PWS, Raytown Water Company also meets the definition of a public water system. Since Raytown Water Company is a consecutive system and does not treat drinking water, they are responsible for meeting the following distribution system monitoring requirements:

15 Routine bacteriological (Total Coliform/E. coli) samples every month.

2 Routine disinfection byproducts [total trihalomethanes (TTHM) and haloacetic acids (HAA5)] samples every quarter.

30 Lead and Copper samples every 3 years.

These schedules can be accessed along with more information about Raytown Water Company on Missouri Drinking Water Watch. <https://www.dnr.mo.gov/DWW/JSP/SearchDispatch>

Then type in the water system name or PWS ID number you are interested in searching. Then click on the Water System number like highlighted yellow below.

Missouri Department of  
**Natural Resources**

Search

Programs   Forms and Permits   Publications   Laws and Regulations   Online Data   Calendar of Events

---

**Find Water Systems: Search Results**   **Program Links**

1 Records Found	Search Date: 11/3/2023	Home
Water System Number: <b>MO1010676</b>	Fed Type: C	Glossary of Terms
RAYTOWN WATER COMPANY <a href="#">Fact Sheet</a>	Status: A	Water System Search
	County: JACKSON	User Login
	Water Type: SWP	County Map Search
		Contact Us

Then click on [Sample Schedules/FANLs/Plans](#) link in yellow font on the top left of the Water System Detail Page to view the active sample schedules for Raytown.

I hope this helps and if you have any more questions, please let me know.

Thanks,

Scott Weckenborg  
Missouri Department of Natural Resources  
Public Drinking Water Monitoring Section  
Bacteriological & Chemical Monitoring Unit  
P.O. Box 176, Jefferson City, MO 65102-0176  
Phone: 573-526-1124 Fax: 573-751-3110  
[scott.weckenborg@dnr.mo.gov](mailto:scott.weckenborg@dnr.mo.gov)

*We'd like your feedback on the service you received from the Missouri Department of Natural Resources. Please consider taking a few minutes to complete the department's Customer Satisfaction Survey at <https://www.surveymonkey.com/r/MoDNRsurvey>. Thank you.*

**From:** Marke, Geoff <Geoff.Marke@opc.mo.gov>  
**Sent:** Thursday, November 2, 2023 3:22 PM  
**To:** Weckenborg, Scott <scott.weckenborg@dnr.mo.gov>  
**Subject:** question on monthly water testing

Scott,

Your name has been forwarded to me as somebody who could answer some questions I have about DNR's requirements regarding water testing. The specific question I have has to do with the Raytown Water Company, a distribution only company that buys its water from the City of Kansas City. In this example, who tests the water? Is it Raytown, KC, or both? Any insight would be greatly appreciated.

Best regards,

Geoff Marke  
Chief Economist  
Missouri Office of the Public Counsel  
(314) 956-4487 cell  
(573 751-5563 office