



**Planning Year
2022-2023
Loss of Load
Expectation
Study Report**

Loss of Load
Expectation Working
Group

Contents

1	Executive Summary	5
2	LOLE Study Process Overview	7
2.1	Future Study Improvement Considerations	8
3	Transfer Analysis	8
3.1	Calculation Methodology and Process Description.....	8
3.1.1	Generation pools	8
3.1.2	Redispatch.....	9
3.1.3	Generation Limited Transfer for CIL/CEL and ZIA/ZEA.....	9
3.1.4	Voltage Limited Transfer for CIL/CEL and ZIA/ZEA	10
3.2	Powerflow Models and Assumptions.....	10
3.2.1	Tools used	10
3.2.2	Inputs required.....	10
3.2.3	Powerflow Modeling.....	10
3.2.4	General Assumptions.....	11
3.3	Results for CIL/CEL and ZIA/ZEA	12
3.3.1	Out-Year Analysis.....	16
4	Loss of Load Expectation Analysis.....	17
4.1	LOLE Modeling Input Data and Assumptions.....	17
4.2	MISO Generation	17
4.2.1	Thermal Units	17
4.2.2	Behind-the-Meter Generation.....	19
4.2.3	Sales	19
4.2.4	Attachment Y	19
4.2.5	Future Generation.....	19
4.2.6	Intermittent Resources.....	19
4.2.7	Demand Response	20
4.3	MISO Load Data	20
4.3.1	Weather Uncertainty	20
4.3.2	Economic Load Uncertainty	21
4.4	External System.....	22
4.5	Loss of Load Expectation Analysis and Metric Calculations	22
4.5.1	MISO-Wide LOLE Analysis and PRM Calculation.....	22

4.5.2	LRZ LOLE Analysis and Local Reliability Requirement Calculation.....	23
5	MISO System Planning Reserve Margin Results	24
5.1	Planning Year 2022-2023 MISO Planning Reserve Margin Results	24
5.1.1	LOLE Results Statistics	24
5.2	Comparison of PRM Targets Across 10 Years.....	25
5.3	Future Years 2022 through 2031 Planning Reserve Margins	25
6	Local Resource Zone Analysis – LRR Results	26
6.1	Planning Year 2022-2023 Local Resource Zone Analysis.....	26
Appendix A: Comparison of Planning Year 2021 to 2022.....		31
A.1	Waterfall Chart Details	31
A.1.1	Load	31
A.1.2	Units	32
Appendix B: Capacity Import Limit Tier 1 & 2 Source Subsystem Definitions		33
Appendix C: Compliance Conformance Table.....		37
Appendix D: Acronyms List Table		41

Tables

Table 1-1: Initial Planning Resource Auction Deliverables	6
Table 2-1: Example LRZ Calculation	8
Table 3-1: Model assumptions	10
Table 3-2: Example subsystem	12
Table 3-3: Planning Year 2022–2023 Import Limits	13
Table 3-4: Planning Year 2022–2023 Export Limits	15
Table 4-1: Historical Class Average Forced Outage Rates	18
Table 4-2: Economic Uncertainty	21
Table 4-3: 2021 Planning Year Firm Imports and Exports	22
Table 5-1: Planning Year 2022-2023 MISO System Planning Reserve Margins.....	24
Table 5-2: MISO Probabilistic Model Statistics	24
Table 5-3: Future Planning Year MISO System Planning Reserve Margins	26
Table 5-4: MISO System Planning Reserve Margins 2022 through 2031	26
Table 6-1: Planning Year 2022-2023 LRZ Local Reliability Requirements.....	27
Table 6-2: Planning Year 2025-2026 LRZ Local Reliability Requirements.....	27
Table 6-3: Planning Year 2027-2028 LRZ Local Reliability Requirements.....	28
Table 6-4: Time of Peak Demand for all 30 weather years.....	30

Figures

Figure 1-1: Local Resource Zones (LRZ)	6
Figure 3-1: Planning Year 2022-23 Import Constraint Map	14
Figure 3-2: Planning Year 2022-23 Export Constraint Map	16
Figure 4-1: Monthly Average Wind ELCC.....	20
Figure 5-1: Comparison of PRM targets across ten years	25
Figure A-1: Waterfall Chart of 2021 PRM UCAP to 2022 PRM UCAP	31

Equations

Equation 3-1: Total Transfer Capability	11
Equation 3-2: Machine 1 dispatch calculation for 100 MW transfer	12
Equation 3-3: Zonal Import Ability (ZIA) Calculation	12

Revision History

Reason for Revision	Revised by:	Date:
Draft Posted	MISO	10/15/2021
Final Posted	MISO	11/1/2021
Correction to Planning Years referenced in Appendix C	MISO	12/6/2021

1 Executive Summary

Midcontinent Independent System Operator (MISO) conducts an annual Loss of Load Expectation (LOLE) study to determine a Planning Reserve Margin Unforced Capacity (PRM UCAP), zonal per-unit Local Reliability Requirements (LRR), Zonal Import Ability (ZIA), Zonal Export Ability (ZEA), Capacity Import Limits (CIL) and Capacity Export Limits (CEL). The results of the study and its deliverables supply inputs to the MISO Planning Resource Auction (PRA).

The 2022-2023 Planning Year LOLE Study:

- Establishes a PRM UCAP of 8.7 percent to be applied to the Load Serving Entity (LSE) coincident peaks for the planning year starting June 2022 and ending May 2023.
- Uses the Strategic Energy Risk Valuation Model (SERVM) software for Loss of Load analysis to provide results applicable across the MISO market footprint.
- Provides initial zonal ZIA, ZEA, CIL and CEL for each Local Resource Zone (LRZ) (Figure 1-1). These values may be adjusted in March 2022 based on changes to MISO units with firm capacity commitments to non-MISO load, and equipment rating changes since the LOLE analysis. The Simultaneous Feasibility Test (SFT) process can further adjust CIL and CEL to ensure the resources cleared in the auction are simultaneously reliable.
- Determines a minimum planning reserve margin that would result in the MISO system experiencing a less than one-day loss of load event every 10 years, as per the MISO Tariff.¹ The MISO analysis shows that the system would achieve this reliability level when the amount of installed capacity available (considering external support) is 1.179 times that of the MISO system coincident peak.
- Sets forth initial zonal-based (Table 1-1) PRA deliverables in the [LOLE charter](#).


The stakeholder review process played an integral role in this study. The MISO staff would like to thank the Loss of Load Expectation Working Group (LOLEWG) for its assistance and input. Stakeholder feedback led to revisions in LOLE results, including updated transfer limits due to improved redispatch, use of existing Op Guides, and constraint invalidation, and one major LOLE modeling enhancement regarding planned outage scheduling to better reflect some flexibility for generators to reschedule planned outages as needed throughout the year. MISO implemented the new flexible planned outage methodology for both PRM and LRR determination in this year's LOLE study.

¹ A one-day loss of load in 10 years (0.1 day/year) is not necessarily equal to 24 hours loss of load in 10 years (2.4 hours/year).

² "No Limit Found" reflects no valid constraint identified.

PRA and LOLE Metrics	LRZ 1	LRZ 2	LRZ 3	LRZ 4	LRZ 5	LRZ 6	LRZ 7	LRZ 8	LRZ 9	LRZ 10
PRM UCAP	8.7%	8.7%	8.7%	8.7%	8.7%	8.7%	8.7%	8.7%	8.7%	8.7%
LRR UCAP per-unit of LRZ Peak Demand	1.121	1.140	1.164	1.332	1.365	1.175	1.194	1.350	1.179	1.595
Capacity Import Limit (CIL) (MW)	4,629	1,923	5,626	10,224	6,072	7,352	3,749	4,037	4,201	3,033
Capacity Export Limit (CEL) (MW)	2,273	2,246	3,777	No Limit Found ²	No Limit Found ²	7,231	2,392	4,705	1,501	842
Zonal Import Ability (ZIA) (MW)	4,627	1,923	5,561	9,332	6,072	6,952	3,749	3,989	3,389	3,033
Zonal Export Ability (ZEA) (MW)	3,275	2,246	3,842	No Limit Found ²	No Limit Found ²	7,631	2,392	4,705	1,501	1,842

Table 1-1: Initial Planning Resource Auction Deliverables



Local Resource Zone	Local Balancing Authorities
1	DPC, GRE, MDU, MP, NSP, OTP, SMP
2	ALTE, MGE, MIUP, UPPC, WEC, WPS
3	ALTW, MEC, MPW
4	AMIL, CWLP, GLH, SIPC
5	AMMO, CWLD
6	BREC, CIN, HE, HMPL, IPL, NIPS, SIGE
7	CONS, DECO
8	EAI
9	CLEC, EES, LAFA, LAGN, LEPA
10	EMBA, SME

Figure 1-1: Local Resource Zones (LRZ)

2 LOLE Study Process Overview

In compliance with Module E-1 of the MISO Tariff, MISO performed its annual LOLE study to determine the 2022-2023 PY MISO system unforced capacity (UCAP) Planning Reserve Margin (PRM) and the per-unit Local Reliability Requirements (LRR) of Local Resource Zone (LRZ) Peak Demand.

In addition to the LOLE analysis, MISO performed transfer analysis to determine initial Zonal Import Ability (ZIA), Zonal Export Ability (ZEA), Capacity Import Limits (CIL) and Capacity Export Limits (CEL). CIL, CEL, and ZIA are used, in conjunction with the LOLE analysis results, in the Planning Resource Auction (PRA). ZEA is informational and not used in the PRA.

The 2022-2023 per-unit LRR UCAP multiplied by the updated LRZ Peak Demand forecasts submitted for the 2022-2023 PRA determines each LRZ's LRR. Once the LRR is determined, the ZIA values and non-pseudo tied exports are subtracted from the LRR to determine each LRZ's Local Clearing Requirement (LCR) consistent with Section 68A.6² of Module E-1. An example calculation pursuant to Section 68A.6 of the current effective Module E-1³ shows how these values are reached (Table 2-1).

The actual effective PRM Requirement (PRMR) will be determined after the updated LRZ Peak Demand forecasts are submitted by November 1, 2021, for the 2022-2023 PRA. The ZIA, ZEA, CIL and CEL values are subject to updates in March 2022 based on changes to exports of MISO resources to non-MISO load, changes to pseudo tied commitments, and updates to facility ratings following the completion of the LOLE study.

Finally, the simultaneous feasibility test (SFT) is performed as part of the PRA to ensure reliability and is maintained by adjusting CIL and CEL values as needed.

Local Resource Zone (LRZ) EXAMPLE	Example LRZ	Formula Key
Installed Capacity (ICAP)	17,442	[A]
Unforced Capacity (UCAP)	16,326	[B]
Adjustment to UCAP (1d in 10yr)	50	[C]
Local Reliability Requirement (LRR) (UCAP)	16,376	[D]=[B]+[C]
LRZ Peak Demand	14,270	[E]
LRR UCAP per-unit of LRZ Peak Demand	114.8%	[F]=[D]/[E]
Zonal Import Ability (ZIA)	3,469	[G]
Zonal Export Ability (ZEA)	2,317	[H]
Proposed PRA (UCAP) EXAMPLE	Example LRZ	Formula Key
Forecasted LRZ Peak Demand	14,270	[I]
Forecasted LRZ Coincident Peak Demand	13,939	[J]
Non-Pseudo Tied Exports UCAP	150	[K]
Local Reliability Requirement (LRR) UCAP	16,376	[L]=[F]x[I]
Local Clearing Requirement (LCR)	12,757	[M]=[L]-[G]-[K]
Planning Reserve Margin (PRM)	8.7%	[N]
Zone's System Wide PRMR	15,152	[O]=[1.087]x[J]
PRMR	15,152	[P]=Higher of [M] or [O]

² <https://www.misoenergy.org/legal/tariff/>

³ Effective Date: November 1, 2018

Table 2-1: Example LRZ Calculation

2.1 Future Study Improvement Considerations

This year, MISO implemented a methodology change in the LOLE model to better capture the risk associated with planned outages. Under last year's Perfectly Optimized Planned Outage methodology used in the determination of LRRs, SERVM creates 30 unique outage schedules that are perfectly optimized for each of the 30 load shapes to avoid high load periods with perfect foresight. As a result, this approach significantly underestimates the level of planned outages during tight conditions. Conversely, under last year's Realistically Optimized Planned Outage methodology used in the determination of the PRM, SERVM creates a single outage schedule that is optimized around the average of the 30 load shapes. This allows the model to capture scenarios where planned outages are scheduled during unseasonably high load periods in shoulder seasons that was not previously captured due to the perfect optimization. Although the Realistically Optimized approach provided better alignment between modeled and actual planned outages compared to the Perfectly Optimized approach, it undervalued the ability for some volume of generation outages to reschedule around high load periods as needed. In light of this observation, MISO, in collaboration with stakeholders of the Resource Adequacy Subcommittee (RASC), implemented the Flexible Planned Outage methodology in the determination of both the PRM and the LRRs wherein SERVM schedules a percentage of planned outages by optimizing around high load periods, fixed across all 30 load shapes. The remaining planned outages are scheduled optimally for each of the 30 load shapes to reflect the flexibility to reschedule generation outages as needed. Going forward, MISO will continue to work with stakeholders to fine-tune and improve the new Flexible Planned Outage methodology for future LOLE studies and provide stakeholders ample awareness on expected changes to system-wide and zonal requirements.

3 Transfer Analysis

3.1 Calculation Methodology and Process Description

Transfer analyses determined preliminary CIL and CEL values for LRZs for the 2022-2023 Planning Year. Adjustments are made for Border External Resources (BERs) and Coordinating Owner Resources (COs) to determine the ZIA and ZEA. Further adjustments are made for exports to non-MISO Loads to arrive at the initial CIL and CEL values. The objective of transfer analysis is to determine constraints caused by the transfer of capacity between zones and the associated transfer capability. Multiple factors impacted the analysis when compared to previous studies, including:

- 8.9GW of Retirements / Suspensions
- New Intermittent Resources
- Base Model Dispatch in MISO and Seams

3.1.1 Generation pools

To determine an LRZ's import or export limit, a transfer is modeled by ramping generation up in a source subsystem and ramping generation down in a sink subsystem. The source and sink definitions depend on the limit being tested. The LRZ studied for import limits is the sink subsystem and the adjacent MISO LBA's are the source subsystem. The LRZ studied for export limits is the source subsystem and the rest of MISO is the sink subsystem.

Transfers can cause potential issues, which are addressed through the study assumptions. First, an abundantly large source pool spreads the impact of the transfer widely which can cause differences in studied zones transfer capabilities and constraints identified. Second, ramping up generation from remote

areas could cause electrically distant constraints for any given LRZ, which should not determine a zone's limit. For example, export constraints due to dispatch of LRZ 1 generation in the northwest portion of the footprint should not limit the import capability of LRZ 10, which covers the MISO portion of Mississippi.

To address these potential issues, the transfer studies limit the source pool for the import studies to the Tier 1 and Tier 2 adjacent LBA's to the study zone. Since the generation that is ramped up in export studies are contained in the study LRZ, these issues only apply to import studies. Generation within the zone studied for an export limit is ramped up and constraints are expected to be near or in the study zone.

3.1.2 Redispatch

Limited redispatch is applied after performing transfer analyses to mitigate constraints. Redispatch ensures constraints are not caused by the base dispatch and aligns with potential actions that can be implemented for the constraint in MISO operations. Redispatch scenarios can be designed to address multiple constraints as required and may be used for constraints that are electrically close to each other or to further optimize transfer limits for several constraints requiring only minor redispatch. The redispatch assumptions include:

- The use of no more than 10 conventional fuel plants or intermittent resources
- Redispatch limit at 2,000 MW total (1,000 MW up and 1,000 MW down)
- No adjustments to nuclear units
- No adjustments to the portions of pseudo-tied units committed to non-MISO load

3.1.3 Generation Limited Transfer for CIL/CEL and ZIA/ZE

When conducting transfer analysis to determine import or export limits, the source subsystem might run out of generation to dispatch before identifying a valid constraint caused by a transmission limit. MISO developed a Generation Limited Transfer (GLT) process to identify transmission constraints in these situations, when possible, for both imports and exports.

After running the First Contingency Incremental Transfer Capability (FCITC) analysis to determine limits for each LRZ, MISO will determine whether a zone is experiencing a GLT (e.g. whether the first constraint would only occur after all the generation is dispatched at its maximum amount). If the LRZ experiences a GLT, MISO will adjust the base model depending on whether it is an import or export analysis and re-run the transfer analysis.

For an export study, when a transmission constraint has not been identified after dispatching all generation within the exporting system (LRZ under study) MISO will decrease load and generation dispatch in the study zone. The adjustment creates additional capacity to export from the zone. After the adjustments are complete, MISO will rerun the transfer analysis. If a GLT reappears, MISO will make further adjustments to the load and generation of the study zone.

For an import study, when a transmission constraint has not been identified after dispatching all generation within the source subsystem, MISO will decrease load and generation in the source subsystem. This increases the export capacity of the adjacent LBA's for the study zone. After the adjustments are complete, MISO will run the transfer analysis again. If a GLT reappears, MISO will make further adjustments to the model's load and generation in the source subsystem.

FCITC could indicate the transmission system can support larger thermal transfers than would be available based on installed generation for some zones. However, large variations in load and generation for any zone may lead to unreliable limits and constraints. Therefore, MISO limits load scaling for both import and export studies to 50 percent of the zone's load. In a GLT, redispatch, or GLT plus redispatch scenario, the FCITC of the most limiting constraint might exceed Zonal Export/Import Capability. If the

GLT does not produce a limit for a zone(s), due to a valid constraint not being identified, or due to other considerations as listed in the prior paragraph, MISO shall report that LRZ as having no limit and ensure that the limit will not bind in the first iteration of the Simultaneous Feasibility Test (SFT).

3.1.4 Voltage Limited Transfer for CIL/CEL and ZIA/ZEA

Zonal imports may be limited by voltage constraints due to a decrease in the generation in the study zone. Voltage constraints might occur at lower transfer levels than thermal limits determined by linear FCITC. As such, LOLE studies may evaluate Power-Voltage curves for LRZs with known voltage-based transfer limitations identified through existing MISO or Transmission Owner studies. Such evaluation may also occur if an LRZ’s import reaches a level where the majority of the zone’s load would be served using imports from resources outside of the zone. MISO will coordinate with stakeholders as it encounters these scenarios. For the PY 2022-2023 only Zones 1, 4 and 7 import analysis included voltage screening and study. No voltage limits with lower transfer capability than thermal limits were identified for any zone in the 2022-2023 PY analysis.

3.2 Powerflow Models and Assumptions

3.2.1 Tools used

MISO used the Siemens PTI Power System Simulator for Engineering (PSS/E) and Transmission Adequacy and Reliability Assessment (TARA) for analysis tools.

3.2.2 Inputs required

Thermal transfer analysis requires powerflow models and input files. MISO used contingency files from MTEP⁴ reliability assessment studies. Single-element contingencies in MISO/seam areas were also evaluated.

MISO developed a subsystem file to monitor its footprint and seam areas. LRZ definitions were developed as sources and sinks in the study. See Appendix B for tables containing adjacent area definitions (Tiers 1 and 2) used for this study. The monitored file includes all facilities under MISO functional control and single elements in the seam areas of 100 kV and above.

3.2.3 Powerflow Modeling

The MTEP21 summer peak 2022 study model was built using MISO’s Model on Demand (MOD) model data repository, with the following base assumptions (Table 3-1).

Scenario	Effective Date	Projects Applied	External Modeling	Load and Generation Profile
2022	6/1/2022	MTEP Appendix A and Target A	2020 Series 2022 Summer ERAG MMWG	Summer Peak

Table 3-1: Model assumptions

MISO excluded several types of units from the transfer analysis dispatch—these units’ base dispatch remained fixed.

- Nuclear dispatch does not change for any transfer
- Wind and solar resources can be ramped down, but not up
- Pseudo-tied resources were modeled at their expected commitments to non-MISO load, although portions of these units committed to MISO could participate in transfer analyses

⁴ Refer to the Transmission Planning BPM (BPM-20) for more information regarding MTEP input files. <https://www.misoenergy.org/legal/business-practice-manuals/>

System conditions such as load, dispatch, topology, and interchange have an impact on transfer capability. The model was reviewed as part of the base model build for MTEP21 analyses, with study files made available on MISO ShareFile. MISO worked closely with transmission owners and stakeholders in order to model the transmission system accurately, as well as to validate constraints and redispatch. Like other planning studies, transmission outage schedules were not included in the analysis. This is driven partly by limited availability of outage information as well as current standard requirements. Although no outage schedules were evaluated, single element contingencies were evaluated. This includes BES lines, transformers, and generators. Contingency coverage covers most of category P1 and some of category P2.

3.2.4 General Assumptions

MISO uses TARA to process the powerflow model and associated input files to determine the import and export limits of each LRZ by determining the transfer capability. Transfer capability measures the ability of interconnected power systems to reliably transfer power from one area to another under specified system conditions. The incremental amount of power that can be transferred is determined through FCITC analysis. FCITC analysis and base power transfers provide the information required to calculate the First Contingency Total Transfer Capability (FCTTC), which indicates the total amount of transferrable power before a constraint is identified. FCTTC is the base power transfer plus the incremental transfer capability (Equation 3-1). All published limits are based on the zone's FCTTC and may be adjusted for capacity exports.

$$\text{First Contingency Total Transfer Capability (FCTTC)} = \text{FCITC} + \text{Base Power Transfer}$$

Equation 3-1: Total Transfer Capability

FCITC constraints are identified under base case situations or under P1 contingencies provided through the MTEP process. Linear FCITC analysis identifies the limiting constraints using a minimum transfer Distribution Factor (DF) cutoff of 3 percent, meaning the transfer must increase the loading on the overloaded element, under contingency conditions, by 3 percent or more.

A pro-rata dispatch is used, which ensures all available generators will reach their maximum dispatch level at the same time. The pro-rata dispatch is based on the MW reserve available for each unit and the cumulative MW reserve available in the subsystem. The MW reserve is found by subtracting a unit's base model generation dispatch from its maximum dispatch, which reflects the available capacity of the unit.

Table 3-2 and Equation 3-2 show an example of how one unit's dispatch is set, given all machine data for the source subsystem.

Machine	Base Model Unit Dispatch (MW)	Minimum Unit Dispatch (MW)	Maximum Unit Dispatch (MW)	Reserve MW (Unit Dispatch Max – Unit Dispatch Min)
1	20	20	100	80
2	50	10	150	100
3	20	20	100	80
4	450	0	500	50
5	500	100	500	0
Total Reserve				310

Table 3-2: Example subsystem

$$\text{Machine 1 Incremental Post Transfer Dispatch} = \frac{\text{Machine 1 Reserve MW}}{\text{Source Subsystem Reserve MW}} \times \text{Transfer Level MW}$$

$$\text{Machine 1 Incremental Post Transfer Dispatch} = \frac{80}{310} \times 100 = 25.8$$

$$\text{Machine 1 Incremental Post Transfer Dispatch} = 25.8$$

Equation 3-2: Machine 1 dispatch calculation for 100 MW transfer

3.3 Results for CIL/CEL and ZIA/ZEA

Study constraints and associated ZIA, ZEA, CIL, and CEL for each LRZ were presented and reviewed through the [LOLEWG](#) with results for the 2022-23 Planning Year presented at the October 5th, 2021 meeting. Table 3-3 below shows the Planning Year 2022-23 CIL and ZIA with corresponding constraint, GLT, and redispatch information. Last year's CIL and ZIA results are also included for comparison.

All zones had an identified ZIA this year. If there is no valid constraint identified the following equation will be used where the FCITC will be replaced by the Tier 1 & 2 capacity.

$$\text{ZIA} = \text{FCITC} + \text{AI} - \text{Border External Resources and Coordinating Owners}$$

Equation 3-3: Zonal Import Ability (ZIA) Calculation

LRZ	Tier	22-23 CIL (MW)	22-23 ZIA (MW)	Monitored Element	Contingent Element	GLT Applied	Generation Redispatch (MW)	21-22 CIL (MW)	21-22 ZIA (MW)
1	1&2	4,629	4,627	North Appleton – Werner 345kV	North Appleton – Morgan 345kV	Yes	66	5,061	5,059
2	1&2	1,923	1,923	Arpin – Sigel 138kV	Arpin – Rocky Run 345kV	No	458	3,599	3,599
3	1	5,626	5,561	Ottumwa 345/161 kV Transformer	Ottumwa Generation	Yes	302	4,669	4,556
4	1	10,224	9,332	Sioux – Mississippi Tap 138kV	Sioux – Roxford 345kV	Yes	384	No Limit Found ⁵	5,141
5	1&2	6,072	6,072	Sioux – Mississippi Tap 138kV	Sioux Generation	Yes	458	4,384	4,384
6	1&2	7,352	6,952	Monroe – Lulu 345kV	Monroe – Lallendorf 345kV	Yes	300	7,023	6,738
7	1&2	3,749	3,749	Argenta – Tompkins 345kV	Argenta – Battle Creek 345kV	Yes	440	4,888	4,888
8	1	4,037	3,989	Adams Creek – Angie 230kV	Sterlington – Log Town 230kV	No	327	5,203	5,155
9	1	4,201	3,389	Braswell – Franklin 500kV	Franklin – Grand Gulf 500kV	No	2,000	3,284	3,284
10	1	3,033	3,033	Perryville – Baxter Wilson 500kV	Grand Gulf Generation	No	1,856	3,283	3,283

Table 3-3: Planning Year 2022–2023 Import Limits

⁵ LRZ 4: “No Limit Found” reflects no valid constraint identified after GLT of 25%




Figure 3-1: Planning Year 2022-23 Import Constraint Map

Capacity Exports Limits are found by increasing generation in the study zone and decreasing generation in the rest of the MISO footprint to create a transfer. Table 3-4 below shows the Planning Year 2022-23 CEL and ZEA with corresponding constraint, GLT, and redispatch information. Last year's CEL and ZEA results are also included for comparison. LRZs 4 and 5 reported no limit found.

LRZ	22-23 CEL (MW)	22-23 ZEA (MW)	Monitored Element	Contingent Element	GLT Applied	Generation Redispatch (MW)	21-22 CEL (MW)	21-22 ZEA (MW)
1	3,273	3,275	Arpin – Sigel 138kV	Rocky Run – Arpin 345kV	Yes	60	2,474	2,476
2	2,246	2,246	Elm Road – Racine 345kV	Base Case	No	0	3,488	3,488
3	3,777	3,842	Sandburg 161/138kV Transformer	Sandburg – Oak Grove 345kV	Yes	0	No Limit Found ⁶	NLF
4	No Limit Found ¹⁰	NLF					4,886	5,804
5	No Limit Found ¹⁰	NLF					No Limit Found ⁷	NLF
6	7,231	7,631	Gibson – Albion 345kV	Gibson – Francisco 345kV	Yes	187	4,710	4,995
7	2,392	2,392	Monroe – Lulu 345kV	Monroe – Lallendorf 345kV	Yes	0	No Limit Found ⁸	NLF
8	4,705	4,705	El Dorado – Sterlington 500kV	Grand Gulf Generation	Yes	268	No Limit Found ⁹	NLF
9	2,790	1,501	Adams Creek – Angie 230kV	Sterlington – Log Town 230kV	No	0	2,790	2,790
10	842	842	Batesville – Tallahachie 161kV	Choctaw – Clay 500kV	No	0	1,369	1,369

Table 3-4: Planning Year 2022–2023 Export Limits

⁶ LRZ 3: “No Limit Found” reflects no valid constraint identified after GLT of 45%

⁷ LRZ 5: “No Limit Found” reflects no valid constraint identified after GLT of 20%

⁸ LRZ 7: “No Limit Found” reflects no valid constraint identified after GLT of 50%

⁹ LRZ 8: “No Limit Found” reflects no valid constraint identified after GLT of 50%

¹⁰ LRZ’s where “No Limit Found” reflects no valid constraints identified after GLT of 50%




Figure 3-2: Planning Year 2022-23 Export Constraint Map

3.3.1 Out-Year Analysis

In 2018, MISO and its stakeholders redesigned the out-year LOLE transfer analysis process through the LOLEWG and Resource Adequacy Subcommittee (RASC). The out-year analysis is now performed after the planning year analyses are complete. The out-year results will be documented outside of the LOLE report and recorded in LOLEWG meeting materials.

4 Loss of Load Expectation Analysis

4.1 LOLE Modeling Input Data and Assumptions

MISO uses a program managed by Astrapé Consulting called Strategic Energy & Risk Valuation Model (SERVM) to calculate the LOLE for the applicable planning year. SERVM uses a sequential Monte Carlo simulation to model a generation system and to assess the system's reliability based on any number of interconnected areas. SERVM calculates the annual LOLE for the MISO system and each LRZ by stepping through the year chronologically and taking into account generation, load, load modifying and energy efficiency resources, equipment forced outages, planned and maintenance outages, weather and economic uncertainty, and external support.

Building the SERVM model is the most time-consuming task of the PRM study. Many scenarios are built in order to determine how certain variables impact the results. The base case models determine the MISO PRM Installed Capacity (ICAP), PRM UCAP and the LRRs for each LRZ for future planning years one, four and six.

4.2 MISO Generation

4.2.1 Thermal Units

The 2022-2023 planning year LOLE study used the 2021 PRA converted capacity as a starting point for which resources to include in the study. This ensured that only resources eligible as a Planning Resources were included in the LOLE study. An exception was made for resources with a signed GIA with an anticipated in-service date for the 2022-2023 PY. These resources were also included. All internal Planning Resources were modeled in the LRZ in which they are physically located. Additionally, Coordinating Owners and Border External Resources were modeled as being internal to the LRZ in which they are committed to serving load.

Forced outage rates and planned maintenance factors were calculated over a five-year period (January 2016 to December 2020) and modeled as one value for each unit. Some units did not have five years of historical data in MISO's Generator Availability Data System (PowerGADS). However, if they had at least 12 consecutive months of data, unit-specific information was used to calculate their forced outage rates and maintenance factors. Units with fewer than 12 consecutive months of unit-specific data were assigned the corresponding MISO class average forced outage rate and planned maintenance factor based on their fuel type. Any MISO class with fewer than 30 units were assigned the overall MISO weighted class average forced outage rate of 9.04 percent. When the units are populated into the LOLE model, the weighted outage rate in SERVM may be different from the calculated MISO-wide weighted average because the MISO-wide weighted average excludes units with insufficient operating history. Therefore, the weighted outage rate is recalculated to include units that were assigned class average outage rates to gauge how SERVM views the MISO-wide weighted average. This value is for information only and is not assigned to any units.

Nuclear units have a fixed maintenance schedule, which was pulled from publicly available information and was modeled for each of the study years.

The historical class average outage rates as well as the MISO fleet-wide weighted average forced outage rate are in Table 4-1.

Pooled EFORD GADS Years	2016-2020 (%)	2015-2019 (%)	2014-2018 (%)	2013-2017 (%)	2012-2016 (%)	2011-2015 (%)
LOLE Study Planning Year	2022-2023 PY LOLE Study	2021-2022 PY LOLE Study	2020-2021 PY LOLE Study	2019-2020 PY LOLE Study	2018-2019 PY LOLE Study	2017-2018 PY LOLE Study
Combined Cycle	5.85	5.52	5.7	5.37	4.62	3.56
Combustion Turbine (0-20 MW)	35.20	36.38	40.39	23.18	29.02	24.2
Combustion Turbine (20-50 MW)	13.65	14.20	15.29	15.76	13.48	13.94
Combustion Turbine (50+ MW)	4.36	4.76	4.65	5.18	6.19	5.94
Diesel Engines	7.25	10.05	23.53	10.26	10.42	13.12
Fluidized Bed Combustion	*	*	*	*	*	*
Hydro (0-30MW)	*	*	*	*	*	*
Hydro (30+ MW)	*	*	*	*	*	*
Nuclear	*	*	*	*	*	*
Pumped Storage	*	*	*	*	*	*
Steam - Coal (0-100 MW)	*	*	5.33	4.60	5.14	5.99
Steam - Coal (100-200 MW)	*	*	*	*	*	*
Steam - Coal (200-400 MW)	*	10.47	10.16	9.82	9.77	8.64
Steam - Coal (400-600 MW)	*	*	*	*	*	*
Steam - Coal (600-800 MW)	*	*	*	8.22	7.90	7.42
Steam - Coal (800-1000 MW)	*	*	*	*	*	*
Steam - Gas	11.84	12.91	12.54	11.56	11.94	11.68
Steam - Oil	*	*	*	*	*	*
Steam - Waste Heat	*	*	*	*	*	*
Steam - Wood	*	*	*	*	*	*
MISO System Wide Weighted	9.04	9.36	9.24	9.28	9.16	8.21
MISO Weighted as seen in SERVIM	8.95	9.17	9.22	9.18	-	-

*MISO system-wide weighted forced outage rate used in place of class data for those with less than 30 units reporting 12 or more months of data

Table 4-1: Historical Class Average Forced Outage Rates

4.2.2 Behind-the-Meter Generation

Behind-the-Meter generation data came from the Module E Capacity Tracking (MECT) tool. These resources were explicitly modeled just as any other thermal generator with a monthly capacity and forced outage rate. Performance data was pulled from PowerGADS.

4.2.3 Sales

The LOLE analysis incorporates firm sales to neighboring capacity markets as well as firm transactions off system where information was available. For units with capacity sold off-system, the monthly capacities were reduced by the megawatt amount sold. This totaled 1,750 MW UCAP for Planning Year 2022-2023. See Section 4.4 for a more detailed breakdown. These values came from PJM's Reliability Pricing Model (RPM) as well as exports to other external areas taken from the Independent Market Monitor (IMM) exclusion list.

4.2.4 Attachment Y

For the 2022-2023 planning year, generating units with approved suspensions or retirements (as of June 1, 2021) through MISO's Attachment Y process were removed from the LOLE analysis. Any unit retiring, suspending, or coming back online at any point during the planning year was excluded from the year-one analysis. This same methodology is used for the four- and six-year analyses.

4.2.5 Future Generation

Future thermal generation and upgrades were added to the LOLE model based on unit information in the [MISO Generator Interconnection Queue](#). The LOLE model included units with a signed interconnection agreement (as of June 1, 2021). These new units were assigned class-average forced outage rates and planned maintenance factors based on their particular unit class. Units upgraded during the study period reflect the megawatt increase for each month, beginning the month the upgrade was finished. The LOLE analysis also included future wind generation at the MISO average monthly wind ELCC values and future solar at 50% capacity credit. Going forward, MISO will also include any future contracts for firm imports in the LOLE analysis.

4.2.6 Intermittent Resources

Intermittent resources such as run-of-river hydro, biomass, wind and solar were explicitly modeled as demand-side resources. Intermittent resources provide MISO with a minimum of 3 years and up to 15 years of historical summer output data for the hours ending 15:00 EST through 17:00 EST. This data is averaged and modeled in the LOLE analysis as UCAP for all months. Each individual unit is modeled and put in the corresponding LRZ.

Each wind resource Commercial Pricing Node (CPNode) received monthly capacity values based on its historical output during the peak hour of MISO's system-wide coincident monthly peak days. The megawatt value corresponding to each CPNode's calculated wind capacity value was unique for each month of the year. Units new to the commercial model without a wind capacity credit as part of the 2021 Wind Capacity Credit analysis received the MISO-wide monthly average ELCC values. The detailed methodology for establishing the MISO-wide and individual CPNode Wind Capacity Credits can be found in the [2021 Wind & Solar Capacity Credit Report](#). The monthly wind capacity values were allocated across each existing wind resource based on their unit-specific performance to develop individual monthly capacity values, following a similar deterministic process used in the annual Wind Capacity Credit study but at the monthly granularity. The results of the monthly wind ELCC simulations (expressed as percentages) are shown below (Figure 4-1).




Figure 4-1: Monthly Average Wind ELCC

4.2.7 Demand Response

Demand response data came from the MECT tool. These resources were explicitly modeled as dispatch-limited resources. Each demand response program was modeled individually with a monthly capacity, limited to the number of times each program can be called upon, and limited by duration.

New to this year’s study, as a result of FERC acceptance of DR accreditation changes, demand response capacity (reflected in the UCAP total) is based on its registered number of calls. At 5-9 calls, a demand response resource would be modeled at 80% capacity. At 10 or more calls, 100% of the demand response resource’s capacity would be modeled.

4.3 MISO Load Data

The 2022-2023 LOLE analysis used a load training process with neural net software to create a neural-net relationship between historical weather and load data. This relationship was then applied to 30 years of hourly historical weather data to create 30 different load shapes for each LRZ in order to capture both load diversity and seasonal variations. The average monthly loads of the predicted load shapes were adjusted to match each LRZ’s Module E 50/50 monthly zonal peak load forecasts for each study year. The results of this process are shown as the MISO System Peak Demand (Table 5-1) and LRZ Peak Demands (Table 6-1).

Direct Control Load Management and Interruptible Demand types of demand response were explicitly included in the LOLE model as resources. These demand resources are implemented in the LOLE simulation before accumulating LOLE or shedding of firm load.

4.3.1 Weather Uncertainty

MISO has adopted a six-step load training process in order to capture the weather uncertainty associated with the 50/50 load forecasts. The first step of this process requires the collection of five years of historical real-time load modifying resource (LMR) performance and load data, as well as the collection of 30 years of historical weather data. Both the LMR and load data are taken from the MISO market for each LBA, while the historical weather data is collected from the National Oceanic and Atmospheric Administration (NOAA) for each LRZ. After collecting the data, the hourly gross load for each LRZ is calculated using the five years of historical data.

The second step of the process is to normalize the five years of load data to consistent economics. With the load growth due to economics removed from 5 years of historical LRZ load, the third step of the process utilizes neural network software to establish functional relationships between the five years of historical weather and load data. In the fourth step of the process the neural network relationships are applied to the 30 years of historical weather data in order to predict/create 30 years' worth of load shapes for each LRZ.

In the fifth step of the load training process, MISO undertakes extreme temperature verification on the 30 years of load shapes to ensure that the hourly load data is accurate at extremely hot or cold temperatures. This is required since there are fewer data points available at the temperature extremes when determining the neural network functional relationships. This lack of data at the extremes can result in inaccurate predictions when creating load shapes, which will need to be corrected before moving forward.

The sixth and final step of the load training process is to average the monthly peak loads of the predicted load shapes and adjust them to match each LRZ's Module E 50/50 monthly zonal peak load forecasts for each study year. In order to calculate this adjustment, the ratio of the first year's non-coincident peak forecast to the zonal coincident peak forecast is applied to future year's non-coincident peak forecast.

By adopting this new methodology for capturing weather uncertainty MISO is able to model multiple load shapes based off a functional relationship with weather. This modeling approach provides a variance in load shapes, as well as the peak loads observed in each load shape. This approach also provides the ability to capture the frequency and duration of severe weather patterns.

4.3.2 Economic Load Uncertainty

To account for economic load uncertainty in the 2022-2023 planning year LOLE model, MISO utilized a normal distribution of electric utility forecast error accounting for projected and actual Gross Domestic Product (GDP), as well as electricity usage. The historic projections for GDP growth were taken from the Congressional Budget Office (CBO), the actual GDP growth was taken from the Bureau of Economic Analysis (BEA), and the electric use was taken from the U.S. Energy Information Administration (EIA). Due to lack of statewide projected GDP data MISO relied on United States aggregate level data when calculating the economic uncertainty.

In order to calculate the electric utility forecast error, MISO first calculated the forecast error of GDP between the projected and actual values. The resulting GDP forecast error was then translated into electric utility forecast error by multiplying by the rate at which electric load grows in comparison to the GDP. Finally, a standard deviation is calculated from the electric utility forecast error and used to create a normal distribution representing the probabilities of the load forecast errors (LFE) as shown in Table 4-2.

		LFE Levels				
		-2.0%	-1.0%	0.0%	1.0%	2.0%
Standard Deviation in LFE	0.91%	Probability assigned to each LFE				
		5.0%	24.2%	41.7%	24.2%	5.0%

Table 4-2: Economic Uncertainty

As a result of stakeholder feedback MISO is exploring possible alternative methods for determining economic uncertainty to be used in the LOLE process.

4.4 External System

Within the LOLE study, a 1 MW increase of non-firm support from external areas leads to a 1 MW decrease in the reserve margin calculation. It is important to account for the benefit of being part of the eastern interconnection while also providing a stable result. Historically, MISO modeled the external system, including non-firm imports, in the LOLE study which resulted in year-over-year volatility in the PRM. In order to provide a more stable result and remove the false sense of precision, the external non-firm support was set at an ICAP of 2,987 MW and a UCAP of 2,331 MW in the 2015 LOLE study and has since remained constant.

Firm imports from external areas to MISO are modeled at the individual unit level. The specific external units were modeled with their specific installed capacity amount and their corresponding Equivalent Forced Outage Rate demand (EFORd). This better captures the probabilistic reliability impact of firm external imports. These units are only modeled within the MISO PRM analysis and are not modeled when calculating the LRZ LRRs. Due to the locational Tariff filing, Border and Coordinating Owners External Resources are no longer considered firm imports. Instead, these resources are modeled as internal MISO units and are included in the PRM and LRR analysis. The external resources to include for firm imports were based on the amount offered into the 2021-22 planning year PRA. This is a historically accurate indicator of future imports. For the 2021-22 planning year, this amount was 1,748 MW ICAP.

Firm exports from MISO to external areas were modeled the same as previous years. As stated in Section 4.2.3, capacity ineligible as MISO capacity due to transactions with external areas is removed from the model. Table 4-3 shows the amount of firm imports and exports in this year's study.

Contracts	ICAP (MW)	UCAP (MW)
Imports (MW)	1,748	1,692
Exports (MW)	1,899	1,750
Net	-151	-59

Table 4-3: 2021-22 Planning Year Firm Imports and Exports

4.5 Loss of Load Expectation Analysis and Metric Calculations

Upon completion of the SERVM database, MISO determined the appropriate PRM ICAP and PRM UCAP for the 2022-2023 planning year as well as the appropriate Local Reliability Requirement for each of the 10 LRZs. These metrics were determined by a probabilistic LOLE analysis such that the LOLE for the planning year was 1 day in 10 years, or 0.1 day per year.

4.5.1 MISO-Wide LOLE Analysis and PRM Calculation

For the MISO-wide analysis, generating units were modeled as part of their appropriate LRZ as a subset of a larger MISO pool. The MISO system was modeled with no internal transmission limitations. In order to meet the reliability criteria of 0.1 day per year LOLE, capacity is either added or removed from the MISO pool. The minimum amount of capacity above the 50/50 net internal MISO Coincident Peak Demand required to meet the reliability criteria was used to establish the PRM values.

The minimum PRM requirement is determined using the LOLE analysis by either adding or removing capacity until the LOLE reaches 0.1 day per year. If the LOLE is less than 0.1 day per year, a perfect negative unit with zero forced outage rate is added until the LOLE reaches 0.1 day per year. The perfect negative unit adjustment is akin to adding load to the model. If the LOLE is greater than 0.1 day per year, proxy units based on a unit of typical size and forced outage rate will be added to the model until the LOLE reaches 0.1 day per year.

For the 2022-2023 planning year, the MISO PRM analysis removed capacity (9,300 MW) using the perfect unit adjustment and applies to both the PRM ICAP and PRM UCAP.

The formulas for the PRM values for the MISO system are:

$$\text{PRM ICAP} = ((\text{Installed Capacity} + \text{Firm External Support ICAP} + \text{ICAP Adjustment to meet a LOLE of 0.1 days per year}) - \text{MISO Coincident Peak Demand}) / \text{MISO Coincident Peak Demand}$$

$$\text{PRM UCAP} = (\text{Unforced Capacity} + \text{Firm External Support UCAP} + \text{UCAP Adjustment to meet a LOLE of 0.1 days per year}) - \text{MISO Coincident Peak Demand} / \text{MISO Coincident Peak Demand}$$

$$\text{Where Unforced Capacity (UCAP)} = \text{Installed Capacity (ICAP)} \times (1 - \text{XEFORd})$$

4.5.2 LRZ LOLE Analysis and Local Reliability Requirement Calculation

For the LRZ analysis, each LRZ included only the generating units within the LRZ (including Coordinating Owners and Border External Resources) and was modeled without consideration of the benefit of the LRZ's import capability. Much like the MISO analysis, unforced capacity is either added or removed in each LRZ such that a LOLE of 0.1 day per year is achieved. The minimum amount of unforced capacity above each LRZ's Peak Demand that was required to meet the reliability criteria was used to establish each LRZ's LRR.

The 2022-2023 LRR is determined using the LOLE analysis by either adding or removing capacity until the LOLE reaches 0.1 day per year for the LRZ. If the LOLE is less than 0.1 day per year, a perfect negative unit with zero forced outage rate will be added until the LOLE reaches 0.1 day per year. If the LOLE is greater than 0.1 day per year, proxy units based on a unit of typical size and forced outage rate will be added to the model until the LOLE reaches 0.1 day per year.

For the 2022-2023 planning year, only LRZ-1, LRZ-3, and LRZ-8 had sufficient capacity internal to the LRZ to achieve the LOLE of 0.1 day per year as an island. In the seven zones without sufficient capacity as an island, proxy units of typical size (160 MW) and class-average EFORD (4.36 percent) were added to the LRZ. When needed, a fraction of the final proxy unit was added to achieve the exact LOLE of 0.1 day per year for the LRZ.

$$\text{LRR UCAP} = (\text{Unforced Capacity} + \text{UCAP Adjustment to meet a LOLE of 0.1 days per year} - \text{Zonal Coincident Peak Demand}) / \text{Zonal Coincident Peak Demand}$$

5 MISO System Planning Reserve Margin Results

5.1 Planning Year 2022-2023 MISO Planning Reserve Margin Results

For the 2022-2023 planning year, the ratio of MISO capacity to forecasted MISO system peak demand yielded a planning ICAP reserve margin of 17.9 percent and a planning UCAP reserve margin of 8.7 percent. These PRM values assume 1,692 MW UCAP of firm and 2,331 MW UCAP of non-firm external support. Numerous values and calculations went into determining the MISO system PRM ICAP and PRM UCAP (Table 5-1).

MISO Planning Reserve Margin (PRM)	2022/2023 PY (June 2022 - May 2023)	Formula Key
MISO System Peak Demand (MW)	122,076	[A]
Installed Capacity (ICAP) (MW)	154,413	[B]
Unforced Capacity (UCAP) (MW)	142,680	[C]
Firm External Support (ICAP) (MW)	1,748	[D]
Firm External Support (UCAP) (MW)	1,692	[E]
Adjustment to ICAP {1d in 10yr} (MW)	-9,300	[F]
Adjustment to UCAP {1d in 10yr} (MW)	-9,300	[G]
Non-Firm External Support (ICAP) (MW)	2,987	[H]
Non-Firm External Support (UCAP) (MW)	2,331	[I]
ICAP PRM Requirement (PRMR) (MW)	143,873	[J]=[B]+[D]+[F]-[H]
UCAP PRM Requirement (PRMR) (MW)	132,741	[K]=[C]+[E]+[G]-[I]
MISO PRM ICAP	17.9%	[L]=([J]-[A])/[A]
MISO PRM UCAP	8.7%	[M]=([K]-[A])/[A]

Table 5-1: Planning Year 2022-2023 MISO System Planning Reserve Margins

5.1.1 LOLE Results Statistics

In addition to the LOLE results SERVM has the ability to calculate several other probabilistic metrics (Table 5-2). These values are given when MISO is at its PRM UCAP of 8.7 percent. The LOLE of 0.1 day/year is what the model is driven to and how the PRM is calculated. The loss of load hours is defined as the number of hours during a given time period where system demand will exceed the generating capacity. Expected Unserved Energy (EUE) is energy-centric and analyzes all hours of a particular planning year. Results are calculated in megawatt-hours (MWh). EUE is the summation of the expected number of MWh of load that will not be served in a given planning year as a result of demand exceeding the available capacity across all hours.

MISO LOLE Statistics	
Loss of Load Expectation - LOLE [Days/Yr]	0.100
Loss of Load Hours - LOLH [hrs/yr]	0.263
Expected Unserved Energy - EUE [MWh/yr]	537.0

Table 5-2: MISO Probabilistic Model Statistics

5.2 Comparison of PRM Targets Across 10 Years

Figure 5-1 compares the PRM UCAP values over the last 10 planning years. The last endpoint of the blue line shows the Planning Year 2022-2023 PRM value.




Figure 5-1: Comparison of PRM targets across ten years

5.3 Future Years 2022 through 2031 Planning Reserve Margins

Beyond the planning year 2022-2023 LOLE study analysis, an LOLE analysis was performed for the four-year-out planning year of 2025-2026, and the six-year-out planning year of 2027-2028. Table 5-3 shows all the values and calculations that went into determining the MISO system PRM ICAP and PRM UCAP values for those years. Those results are shown as the underlined values of Table 5-4. The values from the intervening years result from interpolating the 2022, 2025, and 2027 results. Note that the MISO system PRM results assume no limitations on transfers within MISO.

The 2025-2026 and 2027-2028 planning year PRM decreased slightly from the 2022-2023 planning year driven mainly by new unit additions and retirements.

MISO Planning Reserve Margin (PRM)	2025/2026 PY (June 2025 - May 2026)	2027/2028 PY (June 2027 - May 2028)	Formula Key
MISO System Peak Demand (MW)	125,750	124,038	[A]
Installed Capacity (ICAP) (MW)	159,463	162,630	[B]
Unforced Capacity (UCAP) (MW)	147,479	150,202	[C]
Firm External Support (ICAP) (MW)	1,748	1,748	[D]
Firm External Support (UCAP) (MW)	1,692	1,692	[E]
Adjustment to ICAP {1d in 10yr} (MW)	-11,750	-16,233	[F]
Adjustment to UCAP {1d in 10yr} (MW)	-11,750	-16,233	[G]
Non-Firm External Support (ICAP) (MW)	2,987	2,987	[H]
Non-Firm External Support (UCAP) (MW)	2,331	2,331	[I]
ICAP PRM Requirement (PRMR) (MW)	146,474	145,158	[J]=[B]+[D]+[F]-[H]
UCAP PRM Requirement (PRMR) (MW)	135,090	133,330	[K]=[C]+[E]+[G]-[I]
MISO PRM ICAP	16.5%	17.0%	[L]=([J]-[A])/[A]
MISO PRM UCAP	7.4%	7.5%	[M]=([K]-[A])/[A]

Table 5-3: Future Planning Year MISO System Planning Reserve Margins

Metric	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
ICAP (GW)	154.4	156.2	158.5	161.8	162.6	163.2	163.2	163.2	163.2	163.2
Demand (GW)	122.1	123.3	124.6	125.8	125.8	124.0	125.5	125.9	126.4	126.8
PRM _{ICAP}	<u>17.9%</u>	17.4%	17.0%	<u>16.5%</u>	16.8%	<u>17.0%</u>	16.5%	16.3%	16.1%	15.9%
PRM _{UCAP}	<u>8.7%</u>	8.3%	7.8%	<u>7.4%</u>	7.5%	<u>7.5%</u>	7.0%	6.8%	6.5%	6.3%

Table 5-4: MISO System Planning Reserve Margins 2022 through 2031
(Years without underlined results indicate PRM values that were calculated through interpolation)

6 Local Resource Zone Analysis – LRR Results

6.1 Planning Year 2022-2023 Local Resource Zone Analysis

MISO calculated the per-unit LRR of LRZ Peak Demand for years one, four and six (Table 6-1, Table 6-2, and Table 6-3). MISO applied the revised planning outage methodology to the LRR determination for the out-year analyses to inform stakeholders of potential LRR impacts of modeling planned outages more realistically for their awareness. The UCAP values in Table 6-1 reflect the UCAP within each LRZ, including Border External Resources and Coordinating Owners. The adjustment to UCAP values are the megawatt adjustments needed in each LRZ so that the reliability criterion of 0.1 days per year LOLE is met. The LRR is the summation of the UCAP and adjustment to UCAP megawatts. The LRR is then divided by each LRZ's Peak Demand to determine the per-unit LRR UCAP. The 2022-2023 per unit LRR UCAP values will be multiplied by the updated demand forecasts submitted for the 2022-2023 PRA to determine each LRZ's LRR. The zonal peak demand timestamps for all 30 weather years modeled in SERVM is shown in Table 6-4. These peak demand timestamps are the result of the SERVM load training process and are not necessarily the actual peaks for each year.

Local Resource Zone (LRZ)	LRZ-1 MN/ND	LRZ-2 WI	LRZ-3 IA	LRZ-4 IL	LRZ-5 MO	LRZ-6 IN	LRZ-7 MI	LRZ-8 AR	LRZ-9 LA/TX	LRZ-10 MS	Formula Key
2022-2023 Planning Reserve Margin (PRM) Study											
Installed Capacity (ICAP) (MW)	22,061	14,712	11,976	11,511	8,628	18,817	23,931	11,696	24,887	6,187	[A]
Unforced Capacity (UCAP) (MW)	20,781	13,789	11,472	10,272	7,794	17,113	22,206	10,961	23,091	5,194	[B]
Adjustment to UCAP {1d in 10yr} (MW)	-1,037	516	-10	1,999	2,692	3,080	1,908	-826	1,033	2,066	[C]
LRR (UCAP) (MW)	19,744	14,306	11,462	12,271	10,487	20,192	24,115	10,135	24,124	7,260	[D]=[B]+[C]
Peak Demand (MW)	17,609	12,552	9,847	9,213	7,684	17,185	20,204	7,509	20,469	4,553	[E]
LRR UCAP per-unit of LRZ Peak Demand	112.1%	114.0%	116.4%	133.2%	136.5%	117.5%	119.4%	135.0%	117.9%	159.5%	[F]=[D]/[E]

Table 6-1: Planning Year 2022-2023 LRZ Local Reliability Requirements

Local Resource Zone (LRZ)	LRZ-1 MN/ND	LRZ-2 WI	LRZ-3 IA	LRZ-4 IL	LRZ-5 MO	LRZ-6 IN	LRZ-7 MI	LRZ-8 AR	LRZ-9 LA/TX	LRZ-10 MS	Formula Key
2025-2026 Planning Reserve Margin (PRM) Study											
Installed Capacity (ICAP) (MW)	22,534	16,327	12,400	11,007	8,052	18,868	25,649	12,711	24,673	6,285	[A]
Unforced Capacity (UCAP) (MW)	21,237	15,322	11,883	9,932	7,363	17,223	23,579	11,946	22,840	5,292	[B]
Adjustment to UCAP {1d in 10yr} (MW)	-662	-772	-314	1,296	2,888	3,921	277	-1,352	1,927	2,154	[C]
LRR (UCAP) (MW)	20,575	14,550	11,569	11,228	10,251	21,144	23,857	10,594	24,767	7,446	[D]=[B]+[C]
Peak Demand (MW)	18,622	13,121	9,976	9,384	8,121	18,517	21,003	7,880	22,036	4,802	[E]
LRR UCAP per-unit of LRZ Peak Demand	110.5%	110.9%	116.0%	119.6%	126.2%	114.2%	113.6%	134.4%	112.4%	155.1%	[F]=[D]/[E]

Table 6-2: Planning Year 2025-2026 LRZ Local Reliability Requirements

Local Resource Zone (LRZ)	LRZ-1 MN/ND	LRZ-2 WI	LRZ-3 IA	LRZ-4 IL	LRZ-5 MO	LRZ-6 IN	LRZ-7 MI	LRZ-8 AR	LRZ-9 LA/TX	LRZ-10 MS	Formula Key
2027-2028 Planning Reserve Margin (PRM) Study											
Installed Capacity (ICAP) (MW)	22,534	16,327	12,400	12,272	8,746	19,590	26,135	12,711	24,673	6,285	[A]
Unforced Capacity (UCAP) (MW)	21,237	15,322	11,883	11,033	7,880	17,886	24,020	11,946	22,840	5,292	[B]
Adjustment to UCAP {1d in 10yr} (MW)	-1,100	-761	-131	217	2,276	2,726	-499	-1,510	1,310	2,066	[C]
LRR (UCAP) (MW)	20,137	14,561	11,752	11,250	10,157	20,612	23,521	10,436	24,150	7,358	[D]=[B]+[C]
Peak Demand (MW)	18,177	13,132	10,172	9,485	8,001	18,099	20,705	7,725	21,417	4,716	[E]
LRR UCAP per-unit of LRZ Peak Demand	110.8%	110.9%	115.5%	118.6%	126.9%	113.9%	113.6%	135.1%	112.8%	156.0%	[F]=[D]/[E]

Table 6-3: Planning Year 2027-2028 LRZ Local Reliability Requirements

Weather Year Time of Peak Demand (EST/HE)	MISO	LRZ-1 MN/ND	LRZ-2 WI	LRZ-3 IA	LRZ-4 IL	LRZ-5 MO	LRZ-6 IN	LRZ-7 MI	LRZ-8 AR	LRZ-9 LA/TX	LRZ-10 MS
1991	7/19/91 16:00	7/18/91 17:00	7/18/91 15:00	7/20/91 17:00	7/6/91 17:00	8/3/91 16:00	8/2/91 18:00	7/20/91 16:00	7/23/91 17:00	7/13/91 17:00	7/2/91 14:00
1992	7/9/92 16:00	8/9/92 17:00	8/10/92 18:00	7/8/92 17:00	7/2/92 15:00	7/2/92 17:00	1/16/92 8:00	7/2/92 16:00	7/16/92 17:00	7/11/92 18:00	7/12/92 17:00
1993	7/27/93 17:00	8/11/93 17:00	8/27/93 14:00	8/22/93 19:00	7/17/93 17:00	7/27/93 16:00	7/25/93 16:00	7/9/93 15:00	7/31/93 17:00	8/14/93 16:00	7/31/93 18:00
1994	7/6/94 15:00	6/14/94 17:00	6/15/94 17:00	7/19/94 17:00	7/5/94 17:00	7/19/94 18:00	1/19/94 6:00	6/18/94 17:00	6/29/94 18:00	8/14/94 17:00	7/5/94 17:00
1995	7/13/95 17:00	7/13/95 18:00	7/13/95 16:00	7/14/95 17:00	7/14/95 17:00	7/13/95 16:00	7/13/95 17:00	7/13/95 17:00	8/17/95 14:00	7/27/95 17:00	7/12/95 15:00
1996	6/29/96 17:00	8/6/96 17:00	6/29/96 17:00	7/18/96 17:00	7/18/96 18:00	7/18/96 17:00	7/19/96 17:00	8/7/96 15:00	7/20/96 15:00	2/5/96 7:00	7/3/96 18:00
1997	7/26/97 16:00	7/16/97 16:00	7/16/97 17:00	7/25/97 18:00	7/18/97 16:00	7/26/97 17:00	7/26/97 16:00	7/16/97 16:00	7/25/97 18:00	8/16/97 16:00	7/25/97 18:00
1998	7/20/98 16:00	7/13/98 16:00	6/25/98 18:00	7/20/98 18:00	7/20/98 18:00	7/19/98 16:00	7/19/98 17:00	6/25/98 18:00	7/6/98 17:00	8/28/98 18:00	8/27/98 15:00

1999	7/30/99 14:00	7/25/99 15:00	7/13/95 16:00	7/30/99 18:00	7/18/99 22:00	7/30/99 17:00	7/26/97 16:00	7/30/99 14:00	7/25/99 17:00	8/14/99 18:00	8/20/99 18:00
2000	8/31/00 16:00	6/8/00 19:00	9/1/00 17:00	8/31/00 16:00	9/1/00 15:00	8/17/00 16:00	9/1/00 15:00	9/1/00 14:00	7/19/00 17:00	8/30/00 16:00	8/30/00 17:00
2001	8/8/01 16:00	8/7/01 16:00	8/9/01 16:00	7/31/01 16:00	7/23/01 17:00	7/23/01 17:00	8/7/01 17:00	8/8/01 16:00	7/11/01 16:00	7/10/01 16:00	7/20/01 17:00
2002	7/3/02 16:00	7/6/02 18:00	8/1/02 15:00	7/20/02 18:00	7/5/02 17:00	8/1/02 16:00	8/3/02 16:00	7/3/02 16:00	7/9/02 17:00	8/2/02 19:00	10/4/02 15:00
2003	8/21/03 16:00	8/24/03 17:00	8/21/03 16:00	7/26/03 18:00	8/21/03 16:00	8/21/03 18:00	8/27/03 17:00	8/21/03 17:00	7/18/03 14:00	8/10/03 16:00	7/17/03 17:00
2004	7/22/04 16:00	6/7/04 17:00	7/22/04 16:00	7/20/04 17:00	7/13/04 17:00	7/13/04 16:00	1/31/04 9:00	7/22/04 16:00	7/14/04 17:00	7/24/04 17:00	7/25/04 15:00
2005	7/24/05 17:00	7/17/05 17:00	7/24/05 16:00	7/25/05 17:00	7/24/05 16:00	7/24/05 18:00	7/25/05 17:00	7/24/05 18:00	8/21/05 18:00	7/25/05 16:00	8/21/05 15:00
2006	7/31/06 17:00	7/31/06 17:00	8/1/06 17:00	7/19/06 18:00	7/31/06 18:00	7/31/06 16:00	7/31/06 16:00	7/31/06 16:00	7/31/93 17:00	8/15/06 18:00	7/16/06 15:00
2007	8/1/07 17:00	7/26/07 15:00	8/2/07 15:00	7/17/07 17:00	8/15/07 18:00	8/15/07 18:00	8/29/07 17:00	7/31/07 18:00	8/17/95 14:00	8/14/07 15:00	8/14/07 15:00
2008	7/16/08 17:00	7/11/08 18:00	7/17/08 17:00	8/3/08 17:00	7/20/08 17:00	7/20/08 16:00	8/23/08 16:00	8/24/08 12:00	8/17/95 14:00	7/20/08 17:00	7/27/08 16:00
2009	6/25/09 16:00	6/22/09 19:00	7/28/09 16:00	7/24/09 18:00	8/9/09 16:00	8/9/09 16:00	1/16/09 8:00	6/25/09 16:00	6/22/09 16:00	7/2/09 16:00	7/2/09 18:00
2010	8/10/10 17:00	8/8/10 18:00	8/20/10 14:00	7/17/10 19:00	7/15/10 15:00	8/3/10 16:00	8/2/91 18:00	9/1/10 17:00	8/17/95 14:00	8/1/10 17:00	8/2/10 17:00
2011	7/20/11 18:00	6/7/11 19:00	7/13/95 16:00	7/20/11 16:00	9/1/11 16:00	8/31/11 16:00	7/26/97 16:00	7/20/11 19:00	7/31/93 17:00	7/2/11 17:00	7/10/11 18:00
2012	7/6/12 17:00	7/6/12 18:00	7/13/95 16:00	7/7/12 16:00	7/7/12 17:00	7/25/12 18:00	7/26/97 16:00	7/6/12 17:00	7/30/12 17:00	6/26/12 16:00	7/3/12 15:00
2013	7/19/13 16:00	7/18/13 19:00	8/27/13 16:00	8/30/13 16:00	9/11/13 16:00	8/31/13 17:00	8/31/13 15:00	7/19/13 14:00	6/27/13 18:00	8/7/13 16:00	8/8/13 17:00
2014	7/22/14 16:00	7/22/14 17:00	7/22/14 16:00	7/22/14 16:00	9/5/14 16:00	7/26/14 15:00	2/7/14 9:00	7/22/14 17:00	7/27/14 17:00	8/23/14 16:00	7/26/14 17:00
2015	7/29/15 16:00	8/14/15 15:00	8/14/15 17:00	7/13/15 15:00	9/3/15 16:00	7/13/15 16:00	7/18/15 17:00	8/2/15 16:00	8/7/15 18:00	8/10/15 16:00	7/30/15 16:00
2016	7/20/16 15:00	7/21/16 17:00	8/10/16 17:00	7/22/16 16:00	9/22/16 17:00	7/23/16 17:00	6/11/16 14:00	8/10/16 14:00	7/20/16 13:00	9/1/16 16:00	7/20/16 15:00
2017	7/20/17 16:00	7/6/17 17:00	6/12/17 14:00	7/21/17 17:00	9/26/17 15:00	7/12/17 15:00	9/26/17 16:00	6/12/17 14:00	7/21/17 15:00	8/19/17 15:00	7/20/17 15:00

2018	6/29/18 15:00	6/29/18 15:00	6/29/18 15:00	5/28/18 14:00	9/5/18 15:00	8/6/18 16:00	9/5/18 16:00	9/5/18 15:00	1/17/18 6:00	1/17/18 6:00	9/19/18 16:00
2019	7/19/19 14:00	7/19/19 18:00	7/19/19 16:00	7/19/19 14:00	9/12/19 16:00	10/1/19 15:00	9/13/19 16:00	7/19/19 13:00	8/13/19 14:00	10/4/19 15:00	10/2/19 16:00
2020	7/9/20 15:00	7/2/20 17:00	8/27/20 14:00	7/8/20 14:00	7/8/20 15:00	7/11/20 15:00	8/25/20 15:00	7/9/20 15:00	7/12/20 15:00	7/11/20 15:00	9/4/20 16:00

Table 6-4: Time of Peak Demand for all 30 weather years

Appendix A: Comparison of Planning Year 2021 to 2022

Multiple study sensitivity analyses were performed to compute changes in the PRM target on an UCAP basis, from the 2021-2022 planning year to the 2022-2023 planning year. These sensitivities included one-off incremental changes of input parameters to quantify how each change affected the PRM result independently. Note the impact of the incremental PRM changes from 2021 to 2022 in the waterfall chart of Figure A-1—see Section A.1 Waterfall Chart Details for an explanation.




Figure A-1: Waterfall Chart of 2021 PRM UCAP to 2022 PRM UCAP

A.1 Waterfall Chart Details

A.1.1 Load

The MISO Coincident Peak Demand increased from the 2020-2021 planning year, which was driven by the updated actual load forecasts submitted by the LSEs. The reduction was mainly driven by reduction in anticipated load growth and changes in diversity. Overall, the magnitude of changes in the load profiles and economic uncertainty was minimal and resulted in a slight increase in the PRM.

A.1.2 Units

Changes from 2021-2022 planning year values are due to changes in Generation Verification Test Capacity (GVTC), EFORD or equivalent forced outage rate demand with adjustment to exclude events outside management control (XEFORD), new units, retirements, suspensions, and changes in the resource mix. The MISO fleet weighted average forced outage rate decreased from 9.36 percent to 9.04 percent from the previous study to this study. However, due to units which receive the MISO class average EFORD, which are not included in the calculation of the MISO weighted EFORD, the weighted EFORD seen by the LOLE model decreased from 9.17 percent to 8.95 percent. A general decrease in unit outage rates lead to a decrease in reserve margin. The flexible planned outage modeling option was used for the first time for the 2022-2023 planning year which resulted in a 0.45 percentage point decrease to the PRM. This was due to the model's increased ability to optimize planned outages by rescheduling a portion of them to outside of peak demand periods.

Appendix B: Capacity Import Limit Tier 1 & 2 Source Subsystem Definitions

MISO Local Resource Zone 1

LRZ Area Name / Area #	Tier-1 Area Name / Area #	Tier-2 Area Name / Area #
XEL / 600	ITCM / 627	WEC / 295
MP / 608	ALTE / 694	MIUP / 296
SMMPA / 613	WPS / 696	AMMO / 356
GRE / 615	MGE / 697	AMIL / 357
OTP / 620		MPW / 633
MDU / 661		MEC / 635
BEPC-MISO / 663		
DPC / 680		

MISO Local Resource Zone 2

LRZ Area Name / Area #	Tier-1 Area Name / Area #	Tier-2 Area Name / Area #
WEC / 295	METC / 218	NIPS / 217
MIUP / 296	XEL / 600	ITCT / 219
ALTE / 694	MP / 608	SMMPA / 613
WPS / 696	DPC / 680	GRE / 615
MGE / 697		OTP / 620
UPPC / 698		ITCM / 627

MISO Local Resource Zone 3

LRZ Area Name / Area #	Tier-1 Area Name / Area #	Tier-2 Area Name / Area #	
ITCM / 627	AMMO / 356	DEI / 208	GRE / 615
MPW / 633	AMIL / 357	NIPS / 217	OTP / 620
MEC / 635	XEL / 600	CWLP / 360	ALTE / 694
	SMMPA / 613	SIPC / 361	WPS / 696
	DPC / 680	GLHB / 362	MGE / 697
		MP / 608	

MISO Local Resource Zone 4

LRZ Area Name / Area #	Tier-1 Area Name / Area #	Tier-2 Area Name / Area #	
ITCM / 627	AMMO / 356	DEI / 208	GRE / 615
MPW / 633	AMIL / 357	NIPS / 217	OTP / 620
MEC / 635	XEL / 600	CWLP / 360	ALTE / 694
	SMMPA / 613	SIPC / 361	WPS / 696
	DPC / 680	GLHB / 362	MGE / 697
		MP / 608	

MISO Local Resource Zone 5

LRZ Area Name / Area #	Tier-1 Area Name / Area #	Tier-2 Area Name / Area #	
CWLD / 333	AMIL / 357	DEI / 208	XEL / 600
AMMO / 356	GLHB / 362	NIPS / 217	SMMPA / 613
	ITCM / 627	CWLP / 360	MPW / 633
	MEC / 635	SIPC / 361	DPC / 680

MISO Local Resource Zone 6

LRZ Area Name / Area #	Tier-1 Area Name / Area #	Tier-2 Area Name / Area #
HE / 207	METC / 218	ITCT / 219
DEI / 208	AMIL / 357	MIUP / 296
SIGE / 210	SIPC / 361	AMMO / 356
IPL / 216		CWLP / 360
NIPS / 217		GLHB / 362
BREC / 314		ITCM / 627
HMPL / 315		MEC / 635

MISO Local Resource Zone 7

LRZ Area Name / Area #	Tier-1 Area Name / Area #	Tier-2 Area Name / Area #
HE / 207	METC / 218	ITCT / 219
DEI / 208	AMIL / 357	MIUP / 296
SIGE / 210	SIPC / 361	AMMO / 356
IPL / 216		CWLP / 360
NIPS / 217		GLHB / 362
BREC / 314		ITCM / 627
HMPL / 315		MEC / 635

MISO Local Resource Zone 8

LRZ Area Name / Area #	Tier-1 Area Name / Area #	Tier-2 Area Name / Area #
HE / 207	METC / 218	ITCT / 219
DEI / 208	AMIL / 357	MIUP / 296
SIGE / 210	SIPC / 361	AMMO / 356
IPL / 216		CWLP / 360
NIPS / 217		GLHB / 362
BREC / 314		ITCM / 627
HMPL / 315		MEC / 635

MISO Local Resource Zone 9

LRZ Area Name / Area #	Tier-1 Area Name / Area #	Tier-2 Area Name / Area #
LAGN / 332	EES-EMI / 326	Cooperative Energy / 349
EES / 351	EES-EAI / 327	
CLEC / 502		
LAFA / 503		
LEPA / 504		

MISO Local Resource Zone 10

LRZ Area Name / Area #	Tier-1 Area Name / Area #	Tier-2 Area Name / Area #
EES-EMI / 326	EES-EAI / 327	LAGN / 332
Cooperative Energy / 349	EES / 351	CLEC / 502
		LAFA / 503

Appendix C: Compliance Conformance Table

Requirements under: Standard BAL-502-RF-03	Response
R1 The Planning Coordinator shall perform and document a Resource Adequacy analysis annually. The Resource Adequacy analysis shall:	The Planning Year 2022-23 LOLE Study Report is the annual Resource Adequacy Analysis for the peak season of June 2022 through May 2023 and beyond. Analysis of Planning Year 2022-23 is in Sections 5.1 and 6.1. Analysis of Future Years 2022-2031 is in Sections 5.3 and 6.1.
R1.1 Calculate a planning reserve margin that will result in the sum of the probabilities for loss of Load for the integrated peak hour for all days of each planning year ¹ analyzed (per R1.2) being equal to 0.1. (This is comparable to a “one day in 10 year” criterion).	Section 4.5 of this report outlines the utilization of LOLE in the reserve margin determination. “These metrics were determined by a probabilistic LOLE analysis such that the LOLE for the planning year was one day in 10 years, or 0.1 day per year.”
R1.1.1 The utilization of Direct Control Load Management or curtailment of Interruptible Demand shall not contribute to the loss of Load probability.	Section 4.3 of this report. “Direct Control Load Management and Interruptible Demand types of demand response were explicitly included in the LOLE model as resources. These demand resources are implemented in the LOLE simulation before accumulating LOLE or shedding of firm load.”
R1.1.2 The planning reserve margin developed from R1.1 shall be expressed as a percentage of the median forecast peak Net Internal Demand (planning reserve margin).	Section 4.5.1 of this report. “The minimum amount of capacity above the 50/50 net internal MISO Coincident Peak Demand required to meet the reliability criteria was used to establish the PRM values.”
R1.2 Be performed or verified separately for each of the following planning years.	Covered in the segmented R1.2 responses below.
R1.2.1 Perform an analysis for Year One.	In Sections 5.1 and 6.1, a full analysis was performed for planning year 2021.
R1.2.2 Perform an analysis or verification at a minimum for one year in the 2 through 5 year period and at a minimum one year in the 6 through 10 year period.	Sections 5.3 and 6.1 show a full analysis was performed for future planning years 2025 and 2027.
R1.2.2.1 If the analysis is verified, the verification must be supported by current or past studies for the same planning year.	Analysis was performed.
R1.3 Include the following subject matter and documentation of its use:	Covered in the segmented R1.3 responses below.

<p>R1.3.1 Load forecast characteristics:</p> <ul style="list-style-type: none"> • Median (50:50) forecast peak load • Load forecast uncertainty (reflects variability in the Load forecast due to weather and regional economic forecasts). • Load diversity. • Seasonal Load variations. • Daily demand modeling assumptions (firm, interruptible). • Contractual arrangements concerning curtailable/Interruptible Demand. 	<p>Median forecasted load – In Section 4.3 of this report: “The average monthly loads of the predicted load shapes were adjusted to match each LRZ’s Module E 50/50 monthly zonal peak load forecasts for each study year.”</p> <p>Load Forecast Uncertainty – A detailed explanation of the weather and economic uncertainties are given in Sections 4.3.1 and 4.3.2.</p> <p>Load Diversity/Seasonal Load Variations — In Section 4.3 of this report: “The 2022-2023 LOLE analysis used a load training process with neural net software to create a neural-net relationship between historical weather and load data. This relationship was then applied to 30 years of hourly historical weather data to create 30 different load shapes for each LRZ in order to capture both load diversity and seasonal variations.”</p> <p>Demand Modeling Assumptions/Curtailable and Interruptible Demand — All Load Modifying Resources must first meet registration requirements through Module E. As stated in Section 4.2.7: “Each demand response program was modeled individually with a monthly capacity and was limited to the number of times each program can be called upon as well as limited by duration.”</p>
<p>R1.3.2 Resource characteristics:</p> <ul style="list-style-type: none"> • Historic resource performance and any projected changes • Seasonal resource ratings • Modeling assumptions of firm capacity purchases from and sales to entities outside the Planning Coordinator area. • Resource planned outage schedules, deratings, and retirements. • Modeling assumptions of intermittent and energy limited resource such as wind and cogeneration. • Criteria for including planned resource additions in the analysis. 	<p>Section 4.2 details how historic performance data and seasonal ratings are gathered, and includes discussion of future units and the modeling assumptions for intermittent capacity resources.</p> <p>A more detailed explanation of firm capacity purchases and sales is in Section 4.4.</p>
<p>R1.3.3 Transmission limitations that prevent the delivery of generation reserves</p>	<p>Annual MTEP deliverability analysis identifies transmission limitations preventing delivery of generation reserves. Additionally, Section 3 of this report details the transfer analysis to capture transmission constraints limiting capacity transfers.</p>
<p>R1.3.3.1 Criteria for including planned Transmission Facility additions in the analysis</p>	<p>Inclusion of the planned transmission addition assumptions is detailed in Section 3.2.3.</p>
<p>R1.3.4 Assistance from other interconnected systems including multi-area assessment considering Transmission limitations into the study area.</p>	<p>Section 4.4 provides the analysis on the treatment of external support assistance and limitations.</p>

<p>R1.4 Consider the following resource availability characteristics and document how and why they were included in the analysis or why they were not included:</p> <ul style="list-style-type: none"> • Availability and deliverability of fuel. • Common mode outages that affect resource availability. • Environmental or regulatory restrictions of resource availability. • Any other demand (Load) response programs not included in R1.3.1. • Sensitivity to resource outage rates. • Impacts of extreme weather/drought conditions that affect unit availability. • Modeling assumptions for emergency operation procedures used to make reserves available. • Market resources not committed to serving Load (uncommitted resources) within the Planning Coordinator area. 	<p>Fuel availability, environmental restrictions, common mode outage and extreme weather conditions are all part of the historical availability performance data that goes into the unit's EFORd statistic. The use of the EFORd values is covered in Section 4.2.</p> <p>The use of demand response programs is mentioned in Section 4.2.</p> <p>The effects of resource outage characteristics on the reserve margin are outlined in Section 4.5.2 by examining the difference between PRM ICAP and PRM UCAP values.</p>
<p>R1.5 Consider Transmission maintenance outage schedules and document how and why they were included in the Resource Adequacy analysis or why they were not included</p>	<p>Transmission maintenance schedules were not included in the analysis of the transmission system due to the limited availability of reliable long-term maintenance schedules and minimal impact to the results of the analysis. However, Section 3 treats worst-case theoretical outages by Perform First Contingency Total Transfer Capability (FCTTC) analysis for each LRZ, by modeling NERC Category P0 (system intact) and Category P1 (N-1) contingencies.</p>
<p>R1.6 Document that capacity resources are appropriately accounted for in its Resource Adequacy analysis</p>	<p>MISO internal resources are among the quantities documented in the tables provided in Sections 5 and 6.</p>
<p>R1.7 Document that all Load in the Planning Coordinator area is accounted for in its Resource Adequacy analysis</p>	<p>MISO load is among the quantities documented in the tables provided in Sections 5 and 6.</p>
<p>R2 The Planning Coordinator shall annually document the projected Load and resource capability, for each area or Transmission constrained sub-area identified in the Resource Adequacy analysis.</p>	<p>In Sections 5 and 6, the peak load and estimated amount of resources for planning years 2022, 2025, and 2027 are shown. This includes the detail for each transmission constrained sub-area.</p>
<p>R2.1 This documentation shall cover each of the years in year one through ten.</p>	<p>Section 5.3 and Table 5-4 shows the three calculated years, and in-between years estimated by interpolation. Estimated transmission limitations may be determined through a review of the 2022-23 LOLE study transfer analysis shown in Section 3 of this report, along with the results from previous LOLE studies.</p>
<p>R2.2 This documentation shall include the Planning Reserve margin calculated per requirement R1.1 for each of the three years in the analysis.</p>	<p>Section 5.3 and Table 5-4 shows the three calculated years underlined.</p>
<p>R2.3 The documentation as specified per requirement R2.1 and R2.2 shall be publicly posted no later than 30 calendar days prior to the beginning of Year One.</p>	<p>The 2022-23 LOLE Study Report documentation is posted on November 1 prior to the planning year.</p>

R3 The Planning Coordinator shall identify any gaps between the needed amount of planning reserves defined in Requirement R1, Part 1.1 and the projected planning reserves documented in Requirement R2.

In Sections 5 and 6, the difference between the needed amount and the projected planning reserves for planning years 2022, 2025, and 2027 are shown the adjustments to ICAP and UCAP in Table 5-1, Table 5-3, Table 6-1, Table 6-2, and Table 6-3.

Appendix D: Acronyms List Table

CEL	Capacity Export Limit
CIL	Capacity Import Limit
CPNode	Commercial Pricing Node
DF	Distribution Factor
EFORd	Equivalent Forced Outage Rate demand
ELCC	Effective Load Carrying Capability
ERZ	External Resource Zone
EUE	Expected Unserved Energy
FERC	Federal Energy Regulatory Commission
FCITC	First Contingency Incremental Transfer Capability
FCTTC	First Contingency Total Transfer Capability
GADS	Generator Availability Data System
GLT	Generation Limited Transfer
GVTC	Generation Verification Test Capacity
ICAP	Installed Capacity
LBA	Local Balancing Authority
LCR	Local Clearing Requirement
LFE	Load Forecast Error
LFU	Load Forecast Uncertainty
LOLE	Loss of Load Expectation
LOLEWG	Loss of Load Expectation Working Group
LRR	Local Reliability Requirement
LRZ	Local Resource Zones
LSE	Load Serving Entity
MARS	Multi-Area Reliability Simulation
MECT	Module E Capacity Tracking
MISO	Midcontinent Independent System Operator
MOD	Model on Demand
MTEP	MISO Transmission Expansion Plan
MW	Megawatt
MWh	Megawatt hours
NERC	North American Electric Reliability Corp.
PRA	Planning Resource Auction
PRM	Planning Reserve Margin
PRM ICAP	PRM Installed Capacity

PRM UCAP	PRM Unforced Capacity
PRMR	Planning Reserve Margin Requirement
PSS E	Power System Simulator for Engineering
RCF	Reciprocal Coordinating Flowgate
RPM	Reliability Pricing Model
SERVM	Strategic Energy & Risk Valuation Model
SPS	Special Protection Scheme
TARA	Transmission Adequacy and Reliability Assessment
UCAP	Unforced Capacity
XEFORd	Equivalent forced outage rate demand with adjustment to exclude events outside management control
ZIA	Zonal Import Ability
ZEA	Zonal Export Ability