

EVERGY

2020 Analysis of System Losses

December 2021

Prepared by:



Management Applications Consulting, Inc.
1103 Rocky Drive – Suite 201
Reading, PA 19609
Phone: (610) 670-9199 / Fax: (610) 670-9190



MANAGEMENT APPLICATIONS CONSULTING, INC.

1103 Rocky Drive • Suite 201 • Reading, PA 19609-1157 • 610/670-9199 • fax 610/670-9190 • www.manapp.com

December 20, 2021

Ms. Linda Nunn
Manager, Regulatory Affairs
Eversource
818 South Kansas Avenue
Topeka, KS 66612

RE: 2020 LOSS ANALYSIS – EVERSOURCE

Dear Ms. Nunn:

Transmitted herewith are the results of the 2020 Analysis of System Losses for the Eversource power system consisting of Eversource Metro (MO and KS) and Missouri West. Our analysis develops cumulative expansion factors (loss factors) for both demand (peak/kW) and energy (average/kWh) losses by discrete voltage levels applicable to metered sales data. Our analysis considers only technical losses in arriving at our final recommendations.

On behalf of MAC, we appreciate the opportunity to assist you in performing the loss analysis contained herein. The level of detailed load and sales data by voltage level, coupled with the FERC-approved transmission loss factors, forms the foundation for determining reasonable and representative power losses on the Eversource system. Our review of these data and calculated loss results support the proposed loss factors as presented herein for your use in various cost of service, rate studies, and demand analyses.

Should you require any additional information, please let us know at your earliest convenience.

Sincerely,

A handwritten signature in black ink, appearing to read 'Paul M. Normand', written in a cursive style.

Paul M. Normand
Principal

Enclosure
PMN/tjp

Evergy 2020 Analysis of System Losses

TABLE OF CONTENTS

1.0	EXECUTIVE SUMMARY	1
2.0	INTRODUCTION	6
2.1	Conduct of Study	6
2.2	Description of Model	7
2.2	Description of Model	9
3.0	METHODOLOGY	10
3.1	Background.....	10
3.2	Analysis and Calculations.....	12
3.2.1	Bulk, Transmission and Subtransmission Lines	12
3.2.2	Transformers	12
3.2.3	Distribution System	12
4.0	DISCUSSION OF RESULTS.....	14

Appendix A – Results of 2020 Evergy Missouri and Metro

Appendix B – Results of 2020 Evergy Kansas and Metro

Appendix C – Results of 2020 Evergy Missouri West (MO West)

Appendix D – Discussion of Hoebel Coefficient



Evergy

2020 Analysis of System Losses

1.0 EXECUTIVE SUMMARY

This report presents Evergy’s 2020 Analysis of System Losses for the power systems as performed by Management Applications Consulting, Inc. (MAC). The study developed separate demand (kW) and energy (kWh) loss factors for each voltage level of service in the power system for Evergy consisting of Metro MO, Metro KS, Metro combined, and MO West. The cumulative loss factor results by voltage level, as presented herein, can be used to adjust metered kW and kWh sales data for losses in performing cost of service studies, determining voltage discounts, and other analyses which may require a loss adjustment.

The procedures used in the overall loss study emphasized the use of “in house” resources where possible. Extensive use was made of the Company’s transformer plant investments in the model. In addition, measured and estimated load data provided a means of calculating reasonable estimates of losses by using a “top-down” and “bottom-up” procedure. In the “top-down” approach, losses from the high voltage system, through and including distribution substations, were estimated along with transformer loss estimates and metered data.

At this point in the analysis, system loads and losses at the input into the distribution substation system are known with reasonable accuracy. However, it is the remaining loads and losses on the distribution substations, primary system, secondary circuits, and services which are generally difficult to estimate. Estimated Company load data provided the starting point for performing a “bottom-up” approach for calculating the remaining distribution losses. Basically, this “bottom-up” approach develops loadings by first determining loads and losses at each level beginning at a customer’s meter service entrance and then going through secondary lines, line transformers, primary lines, and finally distribution substation. These distribution system loads and associated losses are then compared to the initial calculated input into Distribution Substation loadings for reasonableness prior to finalizing the loss factors. An overview of the loss study is shown on Figure 1.

Table 1, below, provides the final results from Appendix A for the 2020 calendar year. Exhibits 8 and 9 of Appendix A present a more detailed analysis of the final calculated summary results of losses by voltage segments and delivery service level in the Company’s power system. These Table 1 cumulative loss expansion factors are applicable only to metered sales at the point of receipt for adjustment to the power system’s input level. A separate Metro combined loss factor was also calculated on Exhibit 10 (Appendices A and B) which combines the separate loss factors from the Evergy Metro MO and Metro KS loss results on a load weighted basis.



Eversgy

2020 Analysis of System Losses

TABLE 1
Loss Factors at Sales Level, Calendar Year 2020

<u>Voltage Level of Service</u>	<u>Metro-MO Total</u> (Appendix A)	<u>Metro-KS Total</u> (Appendix B)	<u>Metro Composite</u>	<u>MO West Total</u> (Appendix C)
<u>Demand (kW)</u>				
Transmission ¹	1.03000	1.03000	1.03000	1.03000
Substation	1.03709	1.03587	1.03694	1.03724
Primary Lines	1.05865	1.05695	1.05786	1.05618
Secondary	1.07994	1.07642	1.07822	1.08050
<u>Energy (kWh)</u>				
Transmission ¹	1.03000	1.03000	1.03000	1.03000
Substation	1.03776	1.03762	1.03775	1.03880
Primary Lines	1.04965	1.05008	1.04982	1.05026
Secondary	1.06899	1.07116	1.06997	1.07664
Losses – Net System Input ²	6.09% MWh 7.14% MW	6.51% MWh 7.01% MW		6.69% MWh 7.16% MW
Losses – Net System Output ³	6.49% MWh 7.69% MW	6.97% MWh 7.54% MW		7.17% MWh 7.71% MW

The net system input shown in Table 1 is the MWh losses of 6.09% for the total Eversgy MO load using calculated losses divided by the total input energy to the system. The 6.49% represents the same MWh losses using system output instead of input as a reference. The net system input reference shown in Table 1 represents MW losses of 7.14% and 7.69% represents these MW losses at output. These results use the appropriate total losses for each but are divided by system output or sales. These calculations are all based on the data and results shown on Exhibits 1, 7 and 9 of each study.

Variable losses are primarily a function of equipment loading levels for a peak load hour, the loss factor derivations for any voltage level must consider both the load at that level plus the loads from lower voltages and their associated losses. As a result, cumulative losses on losses equates to additional load at higher levels along with future changes (+ or –) in loads throughout the power system. It is important to recognize that losses are multiplicative in nature (future) and not additive (test year only) for all future years to ensure total recovery.

¹ Reflects results for 345 kV, 138 kV, and 69 kV.

² Net system input equals firm sales plus losses, Company use less non-requirement sales and related losses. See Appendix A, Exhibit 1, for their calculations.

³ Net system output uses losses divided by output or sales data as a reference.



Eergy

2020 Analysis of System Losses

The derivation of the cumulative loss factors shown in Table 1 have been detailed for all electrical facilities in Exhibit 9, page 1 for demand and page 2 for energy for all Appendices. Beginning on line 1 of page 1 (demand) under the secondary column, metered sales are adjusted for service losses on lines 3 and 4. This new total load (with losses) becomes the load amount for the next higher facilities of secondary conductors and their loss calculations. This process is repeated for all the installed facilities until the secondary sales are at the input level (line 45). The final loss factor for all delivery voltages using this same process is shown on line 46 and Table 1 for demand. This procedure is repeated in Exhibit 9, page 2, for the energy loss factors.


The loss factor calculation is simply the input required (line 45) divided by the metered sales (line 43).

An overview of the loss study is shown on Figure 1 on the next page. Figure 2 simply illustrates the major components that must be considered in a loss analysis.




Everg 2020 Analysis of System Losses

Figure 1



Energy 2020 Analysis of System Losses

**Figure 2
Major Energy and Loss Components**



Evergy

2020 Analysis of System Losses

2.0 INTRODUCTION

This report of the 2020 Analysis of System Losses for the Evergy power system provides a summary of results, conceptual background or methodology, description of the analyses, and input information related to the study.

2.1 Conduct of Study

Typically, between five to ten percent of the total peak hour MW and annual MWH requirements of an electric utility is lost or unaccounted for in the delivery of power to customers. Investments must be made in facilities which support the total load which includes losses or unaccounted for load. Revenue requirements associated with load losses are an important concern to utilities and regulators in that customers must equitably share in all of these cost responsibilities. Loss expansion factors by voltage level are the mechanism by which customers' metered demand and energy data are mathematically adjusted to the generation or input level (point of reference) when performing cost and revenue calculations.

An acceptable accounting of losses can be determined for any given time period using available engineering, system, and customer data along with empirical relationships. This loss analysis for the delivery of demand and energy utilizes such an approach. A microcomputer loss model⁴ is utilized as the vehicle to organize the available data, develop the relationships, calculate the losses, and provide an efficient and timely avenue for future updates and sensitivity analyses. Our procedures and calculations are similar with prior loss studies, and they rely on numerous databases that include customer statistics and power system investments at various voltage levels of service.

Company personnel performed most of the data gathering and data processing efforts and checked for reasonableness. MAC provided assistance as necessary to construct databases, transfer files, perform calculations, and check the reasonableness of results. Efforts in determining the data required to perform the loss analysis centered on information which was available from existing studies or reports within the Company. From an overall perspective, our efforts concentrated on five major areas:

1. System information concerning peak demand and annual energy requirements by voltage level,
2. High voltage power system analysis not required as using FERC-approved loss factors,
3. Distribution system primary and secondary loss calculations,
4. Derivation of fixed and variable losses by voltage level, and
5. Development of final cumulative expansion factors at each voltage for peak demand (kW) and annual energy (kWh) requirements at the point of delivery (meter).

⁴Copyright by Management Applications Consulting, Inc.



Eversource 2020 Analysis of System Losses

2.2 Electric Power Losses

Losses in power systems consist of primarily technical losses with a much smaller level of non-technical losses.

Technical Losses

Electrical losses result from the transmission of energy over various electrical equipment. The largest component of total losses during peaking conditions is power dissipation as a result of varying loading conditions and are oftentimes called load losses which are mostly related to the square of the current (I^2R). These peak hour losses can be very high percent of all technical losses during peak loading conditions. The remaining losses are called no-load and represent essentially fixed (constant) energy losses throughout the year. These no-load losses represent energy required to energize various electrical equipment regardless of their loading levels over the entire year. The major portion of these no-load losses consist of core or magnetizing energy related to installed transformers throughout the power system and generates the major component of annual losses on any distribution system.

The following Tables 2, 3, and 4 summarize the unadjusted fixed and variable losses by major functional categories from Exhibit 5 of Appendices A, B, and C:

TABLE 2 – METRO MO

	<u>DEMAND (PEAK HOUR – MW)</u>			<u>ENERGY (ANNUAL AVERAGE – MWH)</u>		
	FIXED	VARIABLE	TOTAL	FIXED	VARIABLE	TOTAL
TRANS (%)	6.05 12.00%	44.35 88.00%	50.40 100.00%	53,121 21.21%	197,364 78.79%	250,485 100.00%
SUBTRANS (%)	0.00 N/A	0.00 N/A	0.00 N/A	0.00 N/A	0.00 N/A	0.00 N/A
DIST SUBS (%)	5.13 58.76%	3.60 41.24%	8.73 100.00%	45,080 78.46%	12,373 21.54%	57,453 100.00%
PRIMARY (%)	2.54 10.00%	22.84 90.00%	25.38 100.00%	22,290 26.65%	61,348 73.35%	83,638 100.00%
SECONDARY (%)	10.62 46.48%	12.24 53.52%	22.86 100.00%	93,328 76.90%	28,028 23.10%	121,357 100.00%
TOTAL SYS (%)	24.34 22.67%	83.02 77.33%	107.37 100.00%	213,819 41.69%	299,114 58.31%	512,933 100.00%
TOTAL DIST (%)	18.29 32.11%	38.68 67.89%	56.97 100.00%	160,698 61.23%	101,749 38.77%	262,447 100.00%



Energy 2020 Analysis of System Losses

TABLE 3 – METRO KS

	<u>DEMAND (PEAK HOUR – MW)</u>			<u>ENERGY (ANNUAL AVERAGE – MWH)</u>		
	FIXED	VARIABLE	TOTAL	FIXED	VARIABLE	TOTAL
TRANS (%)	5.50 12.00%	40.37 88.00%	45.87 100.00%	48,355 25.15%	143,878 74.85%	192,233 100.00%
SUBTRANS (%)	0.00 N/A	0.00 N/A	0.00 N/A	0.00 N/A	0.00 N/A	0.00 N/A
DIST SUBS (%)	4.25 54.54%	3.55 45.46%	7.80 100.00%	37,362 79.83%	9,442 20.17%	46,804 100.00%
PRIMARY (%)	2.72 10.00%	24.48 90.00%	27.20 100.00%	23,888 31.97%	50,833 68.03%	74,721 100.00%
SECONDARY (%)	10.45 45.27%	12.63 54.73%	23.08 100.00%	91,770 80.00%	22,946 20.00%	114,716 100.00%
TOTAL SYS (%)	22.93 22.06%	81.02 77.94%	103.95 100.00%	201,374 47.00%	227,100 53.00%	428,475 100.00%
TOTAL DIST (%)	17.42 30.00%	40.65 70.00%	58.07 100.00%	153,020 64.77%	83,222 35.23%	236,242 100.00%

TABLE 4 – MO WEST

	<u>DEMAND (PEAK HOUR – MW)</u>			<u>ENERGY (ANNUAL AVERAGE – MWH)</u>		
	FIXED	VARIABLE	TOTAL	FIXED	VARIABLE	TOTAL
TRANS (%)	6.45 12.00%	47.28 88.00%	53.73 100.00%	56,635 22.65%	193,356 77.35%	249,991 100.00%
SUBTRANS (%)	0.00 N/A	0.00 N/A	0.00 N/A	0.00 N/A	0.00 N/A	0.00 N/A
DIST SUBS (%)	5.98 54.69%	4.95 45.31%	10.93 100.00%	52,490 77.92%	14,872 22.08%	67,363 100.00%
PRIMARY (%)	2.71 10.00%	24.37 90.00%	27.08 100.00%	23,786 28.78%	58,870 71.22%	82,656 100.00%
SECONDARY (%)	15.57 49.33%	16.00 50.67%	31.57 100.00%	136,802 81.00%	32,091 19.00%	168,893 100.00%
TOTAL SYS (%)	30.71 24.90%	92.60 75.10%	123.31 100.00%	269,713 47.41%	299,190 52.59%	568,903 100.00%
TOTAL DIST (%)	24.26 34.86%	45.32 65.14%	69.58 100.00%	213,078 66.81%	105,833 33.19%	318,911 100.00%



Energy

2020 Analysis of System Losses

Non-Technical Losses

These are unaccounted for energy losses that are related to energy theft, metering, non-payment by customers, and accounting errors. Losses related to these areas are generally very small and can be extremely difficult and subjective to quantify. Our efforts generally do not develop any meaningful level because we assume that improving technology and utility practices have minimized these amounts.

2.3 Loss Impacts from Distributed Generation (DG)

The impacts of losses on a power system from the installation of various DG facilities will depend somewhat on the penetration level, type of installations and location on a circuit. Based on the results presented in Tables 2, 3, and 4 of this loss study, the loss impacts are significantly different from looking at any single peak load hour versus the potential impacts over all hours of an entire year. Use of a typical uniform loss factor(s) for each voltage level may require additional consideration to recognize that a reduced consumption level could have little or no impact due to the recovery requirements for the high level of fixed losses over the entire hourly electric grid condition for any DG location.

2.4 Description of Model

The loss model is a customized applications model, constructed using the Excel software program. Documentation consists primarily of the model equations at each cell location. A significant advantage of such a model is that the actual formulas and their corresponding computed values at each cell of the model are immediately available to the analyst.

A brief description of the three (3) major categories of effort for the preparation of each loss model is as follows:

- Main tab which contains calculations for all primary and secondary losses, summaries of all conductor and transformer calculations from other tabs discussed below, output reports and supporting results.
- Transformer tab which contains data input and loss calculations for each distribution substation and high voltage transformer. Separate iron and winding losses are calculated for each transformer by identified type.
- Conductor tab containing summary data by major voltage level as to circuit miles, loading assumptions, and kW and kWh loss calculations. Separate loss calculations for each line segment were made using the Company's power flow data by line segment and summarized by voltage level in this model.



Evegy

2020 Analysis of System Losses

3.0 METHODOLOGY

3.1 Background

The objective of a Loss Study is to provide a reasonable set of energy (average) and demand (peak) loss expansion factors which account for system losses associated with the transmission and delivery of power to each voltage level over a designated period of time. The focus of this study is to identify the difference between total energy inputs and the associated sales with the difference being equitably allocated to all delivery levels. Several key elements are important in establishing the methodology for calculating and reporting the Company's losses. These elements are:

- Selection of voltage level of services,
- Recognition of losses associated with conductors, transformations, and other electrical equipment/components within voltage levels,
- Identification of customers and loads at various voltage levels of service,
- Review of generation or net power supply input at each level for the test period studied, and
- Analysis of kW and kWh sales by voltage levels within the test period.

The three major areas of data gathering and calculations in the loss analysis were as follows:

1. System Information (monthly and annual)
 - MWH generation and MWH sales.
 - Coincident peak estimates and net power supply input from all sources and voltage levels.
 - Customer load estimates, adjusted MWH sales, and number of customers in the customer groupings and voltage levels identified in the model.
 - System default values, such as power factor, loading factors, and load factors by voltage level.



Evergy

2020 Analysis of System Losses

2. High Voltage System

These calculations were prepared separately and their results incorporated through the use of approved FERC loss factors for each generation.

3. Distribution System

- Distribution Substations – Data was developed for modeling each substation as to its size and loading. Loss calculations were performed from this data to determine load and no load losses separately for each transformer.
- Primary lines – Line loading and loss characteristics for representative primary circuits were obtained from the Company. These loss results developed kW loss per MW of load and a composite average was calculated to derive the primary loss estimate.
- Secondary voltage transformers – Losses in line transformers were based on each customer service group’s size, as well as the number of customers per transformer. Accounting and load data provided the foundation with which to model the transformer loadings and to calculate load and no load losses.
- Secondary network – Typical secondary networks were estimated for conductor sizes, lengths, loadings, and customer penetration for residential and small general service customers.
- Services – Typical services were estimated for each secondary service class of customers identified in the study with respect to type, length, and loading.

The loss analysis was thus performed by constructing the model in segments and subsequently calculating the composite until the constraints of peak demand and energy were met:

- Information as to the physical characteristics and loading of each transformer and conductor segment was modeled.
- Conductors, transformers, and distribution were grouped by voltage level, and unadjusted losses were calculated.
- The loss factors calculated at each voltage level were determined by “compounding” the per-unit losses. Equivalent sales at the supply point



Evergy

2020 Analysis of System Losses

were obtained by dividing sales at a specific level by the compounded loss factor to determine losses by voltage level.

- The resulting demand and energy loss expansion factors were then used to adjust all sales to the generation or input level in order to estimate the difference.
- Reconciliation of kW and kWh sales by voltage level using the reported system kW and kWh was accomplished by adjusting the initial loss factor estimates until the mismatch or difference was eliminated.

3.2 Calculations and Analysis

This section provides a discussion of the input data, assumptions, and calculations performed in the loss analysis. Specific appendices have been included in order to provide documentation of the input data utilized in the model.

3.2.1 Bulk, Transmission and Subtransmission Lines

3.2.2 Transformers

Loss calculations for all high voltage were prepared separately and presented at FERC with the respective approved loss factors incorporated in each of these studies.

3.2.3 Distribution System

The load data at the substation and customer level, coupled with primary and secondary network information, was sufficient to model the distribution system in adequate detail to calculate losses.

Primary Lines

Primary line loadings take into consideration the available distribution load along with the actual customer loads including losses. Primary line loss estimates were prepared by the Company for use in this loss study. These estimates considered voltage levels, loadings, total circuit miles, and wire size. All of these factors were considered in calculating the actual demand (kW) and energy (kWh) for the primary system.

Secondary Voltage Transformers

Losses in line transformers were determined based on typical transformer sizes for each secondary customer service group and an estimated or calculated number



Eversgy

2020 Analysis of System Losses

of customers per transformer. Company records and estimates of load data provided the necessary database with which to model the loadings. These calculations also made it possible to determine separate winding and iron losses for distribution line transformers, based on a table of representative losses for various transformer sizes.

Secondary Conductor Circuits

A calculation of secondary conductor circuit losses was performed for loads served through these secondary line investments. Estimates of typical conductor sizes, lengths, loadings and customer class penetrations were made to obtain total circuit miles and losses for the secondary network. Customer loads which do not have secondary line requirements were estimated so that a reasonable estimate of losses and circuit miles of these investments could be made.

Service Drops and Meters

Service drops were estimated for each secondary customer reflecting conductor size, length and loadings to obtain demand losses. A separate calculation was also performed using customer maximum demands to obtain kWh losses. Meter loss estimates were also made for each customer and incorporated into the calculations of kW and kWh losses included in the Summary Results.



Eversgy

2020 Analysis of System Losses

4.0 DISCUSSION OF RESULTS

A brief description of each Exhibit provided in Appendix A follows:

Exhibit 1 - Summary of Company Data

This exhibit reflects system information used to determine percent losses and a detailed summary of kW and kWh losses by voltage level. The loss factors developed in Exhibit 7 are also summarized by voltage level.

Exhibit 2 - Summary of Conductor Information

A summary of MW and MWH load and no load losses for conductors by voltage levels is presented. The sum of all calculated losses by voltage level is based on input data information provided in Appendix A. Percent losses are based on equipment loadings.

Exhibit 3 - Summary of Transformer Information

This exhibit summarizes transformer losses by various types and voltage levels throughout the system. Load losses reflect the winding portion of transformer losses while iron losses reflect the no load or constant losses. MWH losses are estimated using a calculated loss factor for winding and the test year hours times no load losses.

Exhibit 4 - Summary of Losses Diagram (2 Pages)

This loss diagram represents the inputs and output of power at system peak conditions. Page 1 details information from all points of the power system and what is provided to the distribution system for primary loads. This portion of the summary can be viewed as a “top down” summary into the distribution system.

Page 2 represents a summary of the development of primary line loads and distribution substations based on a “bottom up” approach. Basically, loadings are developed from the customer meter through the Company’s physical investments based on load research and other metered information by voltage level to arrive at MW and MVA requirements during peak load conditions by voltage levels.

Exhibit 5 - Summary of Sales and Calculated Losses

Summary of Calculated Losses represents a tabular summary of MW and MWH load and no load losses by discrete areas of delivery within each voltage level. Losses have been identified and are derived based on summaries obtained from Exhibits 2 and 3 and losses associated with meters, capacitors and regulators.



Eversgy

2020 Analysis of System Losses

Exhibit 6 - Development of Loss Factors, Unadjusted

This exhibit calculates demand and energy losses and loss factors by specific voltage levels based on sales level requirements. The actual results reflect loads by level and summary totals of losses at that level, or up to that level, based on the results as shown in Exhibit 5. Finally, the estimated values at generation are developed and compared to actual generation to obtain any difference or mismatch.

Exhibit 7 - Development of Loss Factors, Adjusted

The adjusted loss factors are the results of adjusting Exhibit 6 for any difference. All differences between estimated and actual are prorated to each level based on the ratio of each level's total load plus losses to the system total. These new loss factors reflect an adjustment in losses due only to the kW and kWh mismatch.

Exhibit 8 – Adjusted Losses and Loss Factors by Facility

These calculations present an expanded summary detail of Exhibit 7 for each segment of the power system with respect to the flow of power and associated losses from the receipt of energy at the meter to the generation for the Eversgy power system.

Exhibit 9 – Summary of Losses by Delivery Voltage

These calculations present a reformatted summary of losses presented in Exhibits 7 and 8 by power system delivery segment as calculated by voltage level of service based on reported metered sales.

Exhibit 10 – Composite Summary of Losses for Eversgy Metro Only

These calculations are based on using the individual loss results from their respective Exhibit 7 for Metro MO and KS on a load weighted basis by voltage level of service to derive the loss factors.



Evergy
2020 Analysis of System Losses

Appendix A

**Results of 2020 Evergy
Missouri and Metro Combined**

(NOTE: All of the 0.000 high voltage values shown on Exhibits 2, 3, and 5 reflect results that have been included in the loss factor estimates of Exhibit 5, line 22, TOT TRANS LOSS FAC.)



METRO MO

SUMMARY OF COMPANY DATA

ANNUAL PEAK	1,730 MW
ANNUAL SYSTEM INPUT	8,600,000 MWH
ANNUAL SALES	8,075,854 MWH
SYSTEM LOSSES @ INPUT	524,146 or 6.09%
SYSTEM LOAD FACTOR	56.6%

SUMMARY OF LOSSES - OUTPUT RESULTS

SERVICE	KV	--- MW ---	% TOTAL	--- MWH ---	% TOTAL
		Input		Input	
TRANS	345,161,115 69,66,35	50.4	40.80%	250,485	47.79%
		2.91%		2.91%	
PRIM SUBS	33,12,1	11.2	9.08%	59,908	11.43%
		0.65%		0.70%	
PRIMARY	33,12,1	32.6	26.37%	87,211	16.64%
		1.88%		1.01%	
SECONDARY	120/240,to,477	29.3	23.76%	126,542	24.14%
		1.70%		1.47%	
TOTAL		123.5	100.00%	524,146	100.00%
		7.14%		6.09%	

SUMMARY OF LOSS FACTORS

SERVICE	KV	CUMMULATIVE SALES EXPANSION FACTORS			
		DEMAND (Peak)		ENERGY (Annual)	
		d	1/d	e	1/e
TOT TRANS	345,161,115 69,66,35	1.03000	0.97087	1.03000	0.97087
PRIM SUBS	33,12	1.03709	0.96424	1.03776	0.96361
PRIMARY	33,12,1	1.05865	0.94460	1.04965	0.95270
SECONDARY	120/240,to,477	1.07994	0.92597	1.06899	0.93547

SUMMARY OF CONDUCTOR INFORMATION

EXHIBIT 2

DESCRIPTION	CIRCUIT MILES	LOADING % RATING	---- MW LOSSES ----		
			LOAD	NO LOAD	TOTAL
--- BULK ----- 345 KV OR GREATER -----					
TIE LINES	0.0	0.00%	0.000	0.000	0.000
<u>BULK TRANS</u>	<u>0.0</u>	<u>0.00%</u>	<u>0.000</u>	<u>0.000</u>	<u>0.000</u>
SUBTOT	0.0		0.000	0.000	0.000
--- TRANS ----- 115 KV TO 345.00 KV -----					
TIE LINES	0	0.00%	0.000	0.000	0.000
TRANS1	161 KV	0.0	0.000	0.000	0.000
<u>TRANS2</u>	<u>115 KV</u>	<u>0.0</u>	<u>0.000</u>	<u>0.000</u>	<u>0.000</u>
SUBTOT	0.0		0.000	0.000	0.000
--- SUBTRANS ----- 35 KV TO 115 KV -----					
TIE LINES	0	0.00%	0.000	0.000	0.000
SUBTRANS1	69 KV	0.0	0.000	0.000	0.000
SUBTRANS2	66 KV	0.0	0.000	0.000	0.000
<u>SUBTRANS3</u>	<u>35 KV</u>	<u>0.0</u>	<u>0.000</u>	<u>0.000</u>	<u>0.000</u>
SUBTOT	0.0		0.000	0.000	0.000
PRIMARY LINES	5,601		22.756	2.538	25.293
SECONDARY LINES	3,386		2.413	0.000	2.413
SERVICES	4,133		2.759	0.618	3.377
TOTAL	13,120		27.927	3.156	31.083

---- MWH LOSSES ----		
LOAD	NO LOAD	TOTAL
0	0	0
<u>0</u>	<u>0</u>	<u>0</u>
0	0	0
0	0	0
0	0	0
<u>0</u>	<u>2</u>	<u>2</u>
0	2	2
61,103	22,290	83,393
4,184	0	4,184
6,708	5,431	12,139
71,995	27,723	99,718


SUMMARY OF TRANSFORMER INFORMATION

EXHIBIT 3


DESCRIPTION	KV CAPACITY		NUMBER TRANSFMR	AVERAGE SIZE	LOADING %	MVA LOAD	MW LOSSES			MWH LOSSES			
	VOLTAGE	MVA					LOAD	NO LOAD	TOTAL	LOAD	NO LOAD	TOTAL	
BULK STEP-UP	345	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
BULK - BULK		0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
BULK - TRANS1	161	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
BULK - TRANS2	115	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1 STEP-UP	161	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1 - TRANS2	115	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1-SUBTRANS1	69	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1-SUBTRANS2	66	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1-SUBTRANS3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS2 STEP-UP	115	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS2-SUBTRANS1	69	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS2-SUBTRANS2	66	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS2-SUBTRANS3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN1 STEP-UP	69	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN2 STEP-UP	66	0.0	0	0.0	0.00%	0	0.000	0.001	0.001	0	0	0	
SUBTRAN3 STEP-UP	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN1-SUBTRAN2	66	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN1-SUBTRAN3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN2-SUBTRAN3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
DISTRIBUTION SUBSTATIONS													
TRANS1 -	161	33	205.6	8	25.7	46.78%	96	0.224	0.289	0.513	763	2,540	3,303
TRANS1 -	161	12	3,684.8	92	40.1	41.87%	1,543	3.304	4.753	8.057	11,372	41,748	53,120
TRANS1 -	161	1	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
TRANS2 -	115	33	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
TRANS2 -	115	12	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
TRANS2 -	115	1	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN1-	69	33	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN1-	69	12	42.3	6	7.1	33.39%	14	0.055	0.070	0.126	178	618	796
SUBTRAN1-	69	1	9.3	3	3.1	48.34%	4	0.019	0.020	0.038	60	174	234
SUBTRAN2-	66	33	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN2-	66	12	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN2-	66	1	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN3-	35	33	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN3-	35	12	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN3-	35	1	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
PRIMARY - PRIMARY			116.0	21	5.5	29.80%	35	0.082	0.192	0.274	245	1,686	1,931
LINE TRANSFRMR			3,976.5	48,909	81.3	40.88%	1,626	7.065	10.007	17.071	17,136	87,897	105,034
TOTAL			8,034	49,039				10.750	15.332	26.081	29,754	134,663	164,417

SUMMARY OF LOSSES DIAGRAM - DEMAND MODEL - SYSTEM PEAK

1730.25 MW



FROM HIGH VOLTAGE SYSTEM



DISTRIBUTION SYSTEM LOAD

	PRIM1	PRIM2	PRIM3	PRIM1	PRIM2	PRIM3	PRIM1	PRIM2	PRIM3	PRIM1	PRIM2	PRIM3	PRIM1	PRIM2	PRIM3
VOLTAGE	33	12	1	33	12	1	33	12	1	33	12	1	33	12	1
LOAD MVA	96	1,543	0	0	0	0	0	14	4	0	0	0	0	0	0
% SYS TOT	5.80%	93.07%	0.00%	0.00%	0.00%	0.00%	0.00%	0.85%	0.27%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
NOLD LOSS	0.289	4.753	0.000	0.000	0.000	0.000	0.000	0.070	0.020	0.000	0.000	0.000	0.000	0.000	0.000
LOAD LOSS	0.224	3.304	0.000	0.000	0.000	0.000	0.000	0.055	0.019	0.000	0.000	0.000	0.000	0.000	0.000
AVG SIZE	25.7	40.1	0.0	0.0	0.0	0.0	0.0	7.1	3.1	0.0	0.0	0.0	0.0	0.0	0.0
NUMBER	8	92	0	0	0	0	0	6	3	0	0	0	0	0	0
DIVERSITY RATIO	1.000	1.000	0.000	0.000	0.000	0.000	0.000	1.000	1.000	0.000	0.000	0.000	0.000	0.000	0.000

PRIMARY LINES	
LOADING	1586.159 MW
@ SYS PF	1618.529 MVA
LOAD LOSS	22.756 MW
NOLD LOSS	2.538 MW
TOT LOSS	25.293 MW

PRIM/PRIM TRANSF	
LOADING	34.571 MW
NOLD LOSS	0.192 MW
LOAD LOSS	0.082 MW
AVG SIZE	5.52
NUMBER	21

PRIM CUST LOADS	
NO LINES	0.000 MW
CUST SUB	0.000 MVA
NO LINES	29.000 MW
CO. SUB	29.592 MVA
PRIM WITH	79.250 MW
LINES	86.141 MVA

LINE TRANSFORMERS		
LOADING	1481.341 MW	MVA 1642.776
NOLD LOSS	10.007	MW
LOAD LOSS	7.065	MW
AVG SIZE	81.3	KVA
NUMBER	48909	

SECONDARY LINES	
LOAD	395.887 MW
LOAD LOSS	2.413 MW
NOLD LOSS	0.000 MW
TOT LOSS	2.413 MW

NO SECONDARY LINES	
LOAD	1068.383 MW

SERVICES	
LOAD	1461.857 MW
LOAD LOSS	2.759 MW
NOLD LOSS	0.618 MW
TOT LOSS	3.377 MW

CUSTOMER SECONDARY LOAD	
	1458.480 MW

SUMMARY of SALES and CALCULATED LOSSES

EXHIBIT 5

LOSS # AND LEVEL	MW LOAD	NO LOAD	+	LOAD	=	TOT LOSS	EXP FACTOR	CUM EXP FAC	MWH LOAD	NO LOAD	+	LOAD	=	TOT LOSS	EXP FACTOR	CUM EXP FAC
1 BULK XFMMR	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0
2 BULK LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
3 TRANS1 XFMR	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
4 TRANS1 LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
5 TRANS2TR1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
6 TRANS2BLK SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
7 TRANS2 LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
TOTAL TRAN	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
8 STR1BLK SD																
9 STR1T1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
10 SRT1T2 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
11 SUBTRANS1 LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
12 STR2T1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
13 STR2T2 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
14 STR2S1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
15 SUBTRANS2 LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
16 STR3T1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
17 STR3T2 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
18 STR3S1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
19 STR3S2 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
20 SUBTRANS3 LINES	0.0	0.00		0.00		0.00	0.000000		0	2		0		2	0.000000	
21 SUBTRANS TOTAL	0.0	0.00		0.00		0.00	0.000000	FERC OATT	0	2		0		2	0.000000	FERC OATT
22 TOT TRANS LOSS FAC	1,730.3	6.05		44.35		50.40	1.030000	1.030000	8,600,000	53,121		197,364		250,485	1.030000	1.030000
DISTRIBUTION SUBST																
TRANS1	1,606.1	5.04		3.53		8.57	1.005365	0.000000	7,907,351	44,288		12,135		56,423	1.0071868	0.000000
TRANS2	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0.000000	0.000000
SUBTR1	18.3	0.09		0.07		0.16	1.009061	0.000000	89,863	792		238		1,030	1.0115941	0.000000
SUBTR2	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0.000000	0.000000
SUBTR3	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0.000000	0.000000
WEIGHTED AVERAGE	1,624.3	5.13		3.60		8.73	1.005406	1.035568	7,997,214	45,080		12,373		57,453	1.0072361	1.0374532
PRIMARY INTRCHNGE	0.0						0.000000		0						0.000000	
PRIMARY LINES	1,586.0	2.54		22.84		25.38	1.016260	1.052407	7,693,613	22,290		61,348		83,638	1.0109906	1.0488554
LINE TRANSF	1,481.3	10.01		7.06		17.07	1.011659	1.064677	6,989,913	87,897		17,136		105,034	1.0152557	1.0648564
SECONDARY SERVICES	1,464.3	0.00		2.41		2.41	1.001650	1.066434	6,884,879	0		4,184		4,184	1.0006081	1.0655039
	1,461.9	0.62		2.76		3.38	1.002315	1.068903	6,880,695	5,431		6,708		12,139	1.0017673	1.0673870
TOTAL SYSTEM		24.34		83.02		107.37				213,819		299,114		512,933		

DEVELOPMENT of LOSS FACTORS
UNADJUSTED
DEMAND

EXHIBIT 6

LOSS FACTOR LEVEL	CUSTOMER SALES MW	CALC LOSS TO LEVEL	SALES MW @ GEN	CUM PEAK EXPANSION FACTORS	
	a	b	c	d	1/d
BULK LINES	0.0	0.0	0.0	0.00000	0.00000
TRANS SUBS	0.0	0.0	0.0	0.00000	0.00000
TRANS LINES	0.0	0.0	0.0	0.00000	0.00000
SUBTRANS SUBS	0.0	0.0	0.0	0.00000	0.00000
TOTAL TRANS	40.0	1.2	41.2	1.03000	0.97087
PRIM SUBS	29.0	1.0	30.0	1.03557	0.96565
PRIM LINES	79.3	4.2	83.4	1.05241	0.95020
SECONDARY	<u>1,458.5</u>	<u>100.5</u>	<u>1,559.0</u>	1.06890	0.93554
TOTALS	1,606.7	106.9	1,713.6		

DEVELOPMENT of LOSS FACTORS
UNADJUSTED
ENERGY

LOSS FACTOR LEVEL	CUSTOMER SALES MWH	CALC LOSS TO LEVEL	SALES MWH @ GEN	CUM ANNUAL EXPANSION FACTORS	
	a	b	c	d	1/d
BULK LINES	0	0	0	0.00000	0.00000
TRANS SUBS	0	0	0	0.00000	0.00000
TRANS LINES	0	0	0	0.00000	0.00000
SUBTRANS SUBS	0	0	0	0.00000	0.00000
TOTAL TRANS	340,959	10,229	351,188	1.03000	0.97087
PRIM SUBS	246,276	9,224	255,500	1.03745	0.96390
PRIM LINES	620,063	30,293	650,356	1.04886	0.95342
SECONDARY	<u>6,868,556</u>	<u>462,851</u>	<u>7,331,407</u>	1.06739	0.93687
TOTALS	8,075,854	512,597	8,588,451		

ESTIMATED VALUES AT GENERATION

LOSS FACTOR AT VOLTAGE LEVEL	MW	MWH
BULK LINES	0.00	0
TRANS SUBS	0.00	0
TRANS LINES	0.00	0
SUBTRANS SUBS	0.00	0
SUBTRANS LINES	41.20	351,188
PRIM SUBS	30.03	255,500
PRIM LINES	83.40	650,356
SECONDARY	<u>1,558.97</u>	<u>7,331,407</u>
SUBTOTAL	1,713.61	8,588,451
ACTUAL ENERGY	1,730.25	8,600,000
MISMATCH	(16.64)	(11,549)
% MISMATCH	-0.96%	-0.13%

DEVELOPMENT of LOSS FACTORS

EXHIBIT 7

ADJUSTED
DEMAND

LOSS FACTOR LEVEL	CUSTOMER SALES MW a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MW @ GEN d	CUM PEAK EXPANSION FACTORS e	f=1/e
BULK LINES	0.0	0.0	0.0	0.0	0.00000	0.00000
TRANS SUBS	0.0	0.0	0.0	0.0	0.00000	0.00000
TRANS LINES	0.0	0.0	0.0	0.0	0.00000	0.00000
SUBTRANS SUBS	0.0	0.0	0.0	0.0	0.00000	0.00000
TOTAL TRANS	40.0	0.0	1.2	41.2	1.03000	0.97087
PRIM SUBS	29.0	0.0	1.1	30.1	1.03709	0.96424
PRIM LINES	79.3	0.0	4.6	83.9	1.05865	0.94460
SECONDARY	<u>1,458.5</u>	<u>0.0</u>	116.6	<u>1,575.1</u>	1.07994	0.92597
TOTALS	1,606.7	0.0	123.5	1,730.3		

DEVELOPMENT of LOSS FACTORS

ADJUSTED
ENERGY

LOSS FACTOR LEVEL	CUSTOMER SALES MWH a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MWH @ GEN d	CUM ANNUAL EXPANSION FACTORS e	f=1/e
BULK LINES	0	0	0	0	0.00000	0.00000
TRANS SUBS	0	0	0	0	0.00000	0.00000
TRANS LINES	0	0	0	0	0.00000	0.00000
SUBTRANS SUBS	0	0	0	0	0.00000	0.00000
TOTAL TRANS	340,959	0	10,229	351,188	1.03000	0.97087
PRIM SUBS	246,276	0	9,300	255,576	1.03776	0.96361
PRIM LINES	620,063	0	30,785	650,848	1.04965	0.95270
SECONDARY	<u>6,868,556</u>	<u>0</u>	473,832	<u>7,342,388</u>	1.06899	0.93547
TOTALS	8,075,854	0	524,146	8,600,000		

ESTIMATED VALUES AT GENERATION

LOSS FACTOR AT
VOLTAGE LEVEL

	MW	MWH
BULK LINES	0.00	0
TRANS SUBS	0.00	0
TRANS LINES	0.00	0
SUBTRANS SUBS	0.00	0
SUBTRANS LINES	41.20	351,188
PRIM SUBS	30.08	255,576
PRIM LINES	83.90	650,848
SECONDARY	1,575.08	7,342,388
	1,730.25	8,600,000
ACTUAL ENERGY	1,730.25	8,600,000
MISMATCH	0.00	0
% MISMATCH	0.00%	0.00%

Adjusted Losses and Loss Factors by Facility

EXHIBIT 8

Unadjusted Losses by Segment

	MW	Unadjusted	MWH	Unadjusted
Service Drop Losses	3.38	3.35	12,139	12,123
Secondary Losses	2.41	2.39	4,184	4,179
Line Transformer Losses	17.07	16.93	105,034	104,899
Primary Line Losses	25.38	25.16	83,638	83,531
Distribution Substation Losses	8.73	8.66	57,453	57,379
<u>Transmission System Losses</u>	<u>50.40</u>	<u>50.40</u>	<u>250,485</u>	<u>250,485</u>
Total	107.37	106.88	512,933	512,597

Mismatch Allocation by Segment

	MW	MWH
Service Drop Losses	-0.99	-534
Secondary Losses	-0.70	-184
Line Transformer Losses	-4.99	-4,622
Primary Line Losses	-7.41	-3,680
Distribution Substation Losses	-2.55	-2,528
<u>Transmission System Losses</u>	<u>0.00</u>	<u>0</u>
Total	-16.64	-11,549

Adjusted Losses by Segment

	MW	% of Total	MWH	% of Total
Service Drop Losses	4.33	3.5%	12,657	2.4%
Secondary Losses	3.10	2.5%	4,363	0.8%
Line Transformer Losses	21.91	17.7%	109,521	20.9%
Primary Line Losses	32.57	26.4%	87,211	16.6%
Distribution Substation Losses	11.21	9.1%	59,908	11.4%
<u>Transmission System Losses</u>	<u>50.40</u>	<u>40.8%</u>	<u>250,485</u>	<u>47.8%</u>
Total	123.52	100.0%	524,146	100.0%

Loss Factors by Segment

	MW	MWH	
Retail Sales from Service Drops	1,458.480	6,868,556	
<u>Adjusted Service Drop Losses</u>	<u>4.335</u>	<u>12,657</u>	
Input to Service Drops	1,462.815	6,881,213	
Service Drop Loss Factor	1.00297	1.00184	
Output from Secondary	1,462.815	6,881,213	
<u>Adjusted Secondary Losses</u>	<u>3.097</u>	<u>4,363</u>	
Input to Secondary	1,465.911	6,885,576	
Secondary Conductor Loss Factor	1.00212	1.00063	
Output from Line Transformers	1,465.911	6,885,576	
<u>Adjusted Line Transformer Losses</u>	<u>21.912</u>	<u>109,521</u>	
Input to Line Transformers	1,487.823	6,995,098	
Line Transformer Loss Factor	1.01495	1.01591	
Retail Sales from Primary	74.000	597,779	
Req. Whls Sales from Primary	5.250	22,284	
<u>Input to Line Transformers</u>	<u>1,487.823</u>	<u>6,995,098</u>	
Output from Primary Lines	1,567.073	7,615,161	
<u>Adjusted Primary Line Losses</u>	<u>32.570</u>	<u>87,211</u>	
Input to Primary Lines	1,599.644	7,702,372	
Primary Line Loss Factor	1.02078	1.01145	
Output PI from Distribution Substations	1,599.644	7,702,372	
Req. Whls Sales from Substations	0.000	0	
Retail Sales from Substations	29.000	246,276	
Total Output from Distribution Substations	1,628.644	7,948,648	
<u>Adjusted Distribution Substation Losses</u>	<u>11.211</u>	<u>59,908</u>	
Input to Distribution Substations	1,639.854	8,008,556	
Distribution Substation Loss Factor	1.00688	1.00754	
Retail Sales at from SubTransmission	40.000	340,959	
Req. Whls Sales from SubTransmission	0.000	0	
Non-Req. Whls Sales from SubTransmission	0.000	0	
Losses	0.000	0	4678
<u>Input to Distribution Substations</u>	<u>1,639.854</u>	<u>8,008,556</u>	
Output from SubTransmission	1,679.854	8,349,515	1,730.250
<u>SubTransmission System Losses</u>	<u>50.396</u>	<u>250,485</u>	50.396
Input to Transmission	1,730.250	8,600,000	50.396
TotTransmission System Loss Factor	1.03000	1.03000	50.396

DEMAND MW

SUMMARY OF LOSSES AND LOSS FACTORS BY DELIVERY VOLTAGE

EXHIBIT 9
PAGE 1 of 2

SERVICE LEVEL	SALES MW	LOSSES	SECONDARY	PRIMARY	SUBSTATION	SUBTRANS	TRANSMISSION
1 SERVICES							
2 SALES	1,458.5		1,458.5				
3 LOSSES		4.3	4.3				
4 INPUT			1,462.8				
5 EXPANSION FACTOR	1.00297						
6 SECONDARY							
7 SALES							
8 LOSSES		3.1	3.1				
9 INPUT			1,465.9				
10 EXPANSION FACTOR	1.00212						
11 LINE TRANSFORMER							
12 SALES							
13 LOSSES		21.9	21.9				
14 INPUT			1,487.8				
15 EXPANSION FACTOR	1.01495						
16 PRIMARY							
17 SECONDARY			1,487.8				
18 SALES	74.0			74.0			
19 LOSSES		32.6	30.9	1.5			
20 INPUT			1,518.7	75.5			
21 EXPANSION FACTOR	1.02078						
22 SUBSTATION							
23 PRIMARY			1,518.7	75.5			
24 SALES	29.0				29.0		
25 LOSSES		11.2	10.5	0.5	0.2		
26 INPUT			1,529.2	76.1	29.2		
27 EXPANSION FACTOR	1.00688						
28 SUB-TRANSMISSION							
29 DISTRIBUTION SUBS							
30 SALES							
31 LOSSES							
32 INPUT							
33 EXPANSION FACTOR							
34 TRANSMISSION							
35 SUBTRANSMISSION							
36 DISTRIBUTION SUBS			1,529.2	76.1	29.2		
37 SALES	40.0						40.0
38 LOSSES		50.2	45.9	2.3	0.9		1.2
39 INPUT			1,575.1	78.3	30.1		41.2
40 EXPANSION FACTOR	1.03000						
41 TOTALS							
42 LOSSES		123.4	116.6	4.3	1.1		1.2
42 % OF TOTAL		100%	94.52%	3.52%	0.87%		0.97%
43 SALES	1,601.5		1,458.5	74.0	29.0		40.0
44 % OF TOTAL	100.00%		91.07%	4.62%	1.81%		2.50%
45 INPUT	1,724.7		1,575.1	78.3	30.1		41.2
46 CUMMULATIVE EXPANSION LOSS FACTORS			1.07994	1.05865	1.03709		1.03000
	(from meter to system input)						

ENERGY MWH

SUMMARY OF LOSSES AND LOSS FACTORS BY DELIVERY VOLTAGE

EXHIBIT 9
PAGE 2 of 2

SERVICE LEVEL	SALES	LOSSES	SECONDARY	PRIMARY	SUBSTATION	SUBTRANS	TRANSMISSION
1 SERVICES							
2 SALES	6,868,556		6,868,556				
3 LOSSES		12,657	12,657				
4 INPUT			6,881,213				
5 EXPANSION FACTOR	1.00184						
6 SECONDARY							
7 SALES			4,363	4,363			
8 LOSSES		4,363	4,363				
9 INPUT			6,885,576				
10 EXPANSION FACTOR	1.00063						
11 LINE TRANSFORMER							
12 SALES			109,521	109,521			
13 LOSSES		109,521	109,521				
14 INPUT			6,995,098				
15 EXPANSION FACTOR	1.01591						
16 PRIMARY							
17 SECONDARY			6,995,098				
18 SALES	597,779,000		597,779	597,779			
19 LOSSES		87,211	80,110	6,846			
20 INPUT			7,075,208	604,625			
21 EXPANSION FACTOR	1.01145						
22 SUBSTATION							
23 PRIMARY			7,075,208	604,625			
24 SALES	246,276		246,276		246,276		
25 LOSSES		59,908	53,325	4,557	1,856		
26 INPUT			7,128,532	609,182	248,132		
27 EXPANSION FACTOR	1.00754						
28 SUB-TRANSMISSION							
29 DISTRIBUTION SUBS							
30 SALES							
31 LOSSES							
32 INPUT							
33 EXPANSION FACTOR							
34 TRANSMISSION							
35 SUBTRANSMISSION							
36 DISTRIBUTION SUBS			7,128,532	609,182	248,132		
37 SALES	340,959		340,959			340,959	
38 LOSSES		249,804	213,856	18,275	7,444	10,229	
39 INPUT			7,342,388	627,457	255,576	351,188	
40 EXPANSION FACTOR	1.03000						
41 TOTALS							
42 LOSSES		523,465	473,832	29,678	9,300	10,229	
42 % OF TOTAL		100%	90.52%	5.67%	1.78%	1.95%	
43 SALES	8,053,570		6,868,556	597,779	246,276	340,959	
44 % OF TOTAL	100.00%		85.29%	7.42%	3.06%	4.23%	
45 INPUT	8,576,610		7,342,388	627,457	255,576	351,188	
46 CUMMULATIVE EXPANSION LOSS FACTORS			1.06899	1.04965	1.03776	1.03000	
(from meter to system input)							

**KCPL KS & MO
COMPOSITE
LOSS FACTORS**

**DEVELOPMENT of LOSS FACTORS
ADJUSTED EXHIBIT 7
DEMAND**

LOSS FACTOR LEVEL	CUSTOMER SALES MW	SALES ADJUST	CALC LOSS TO LEVEL	SALES MW @ GEN	CUM PEAK FACTORS	EXPANTION	
	a	b	c	d	e	f=1/e	
BULK LINES		0.0	0.0	0.0	0.0	0.00000	0.00000
TRANS SUBS		0.0	0.0	0.0	0.0	0.00000	0.00000
TRANS LINES		0.0	0.0	0.0	0.0	0.00000	0.00000
TOTAL TRANS		0.0	0.0	0.0	0.0	0.00000	0.97824
SUBTRANS		40.0	0.0	1.2	41.2	1.03000	0.97824
PRIM SUBS		33.0	0.0	1.2	34.2	1.03694	0.96437
PRIM LINES		147.3	0.0	8.5	155.8	1.05786	0.94061
SECONDARY		2,851.0	0.0	223.0	3,074.1	1.07822	0.91849
TOTALS		3,071.3	0.0	234.0	3,305.3	1.07618	<COMPOSITE

**DEVELOPMENT of LOSS FACTORS
ADJUSTED
ENERGY**

LOSS FACTOR LEVEL	CUSTOMER SALES MWH	SALES ADJUST	CALC LOSS TO LEVEL	SALES MWH @ GEN	CUM ANNUAL FACTORS	EXPANTION	
	a	b	c	d	e	f=1/e	
BULK LINES		0	0	0	0	0.00000	0.00000
TRANS SUBS		0	0	0	0	0.00000	0.00000
TRANS LINES		0	0	0	0	0.00000	0.00000
TOTAL TRANS		0	0	0	0	0.00000	0.00000
SUBTRANS		340959	0	10229	351188	1.03000	0.97087
PRIM SUBS		269,877	0	10,188	280,065	1.03775	0.96362
PRIM LINES		1,017,249	0	50,676	1,067,925	1.04982	0.95255
SECONDARY		12,617,891	0	882,932	13,500,823	1.06997	0.93460
TOTAL		14,245,976	0	954,024	15,200,000	1.06697	<COMPOSITE

**DEVELOPMENT of LOSS FACTORS
ADJUSTED EXHIBIT 7
DEMAND**

LOSS FACTOR LEVEL	CUSTOMER SALES MW a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MW @ GEN d	CUM PEAK FACTORS e	EXPANTION f=1/e
BULK LINES	0.0	0	0	0	0.0	0.00000
TRANS SUBS	0.0	0	0	0	0.0	0.00000
TRANS LINES	0.0	0	0	0	0.0	0.00000
TOTAL TRANS	0.0	0.0	0.0	0.0	0.0	0.00000
SUBTRANS	0.0	0.0	0.0	0.0	0.0	0.00000
PRIM SUBS	4.0	0.0	0.1	4.1	1.03587	0.91849
PRIM LINES	68.0	0.0	3.9	71.9	1.05695	0.91849
SECONDARY	1,392.6	0.0	106.4	1,499.0	1.07642	0.91849
TOTALS	1,464.6	0.0	110.4	1,575.0	1.07541	<COMPOSITE

**DEVELOPMENT of LOSS FACTORS
ADJUSTED
ENERGY**

LOSS FACTOR LEVEL	CUSTOMER SALES MWH a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MWH @ GEN d	CUM ANNUAL FACTORS e	EXPANTION f=1/e
BULK LINES	0	0	0	0	0	0.00000
TRANS SUBS	0	0	0	0	0	0.00000
TRANS LINES	0	0	0	0	0	0.00000
TOTAL TRANS	0	0	0	0	0	0.00000
SUBTRANS	0	0	0	0	0	0.00000
PRIM SUBS	23,601	0	888	24,489	1.03762	0.96374
PRIM LINES	397,186	0	19,891	417,077	1.05008	0.95231
SECONDARY	5,749,335	0	409,099	6,158,434	1.07116	0.93357
TOTAL	6,170,122	0	429,878	6,600,000	1.06967	<COMPOSITE

**DEVELOPMENT of LOSS FACTORS
ADJUSTED EXHIBIT 7
DEMAND**

LOSS FACTOR LEVEL	CUSTOMER SALES MW a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MW @ GEN d	CUM PEAK FACTORS e	EXPANTION f=1/e
BULK LINES	0.0	0	0	0	0.0	0.00000
TRANS SUBS	0.0	0	0	0	0.0	0.00000
TRANS LINES	0.0	0	0	0	0.0	0.00000
TOTAL TRANS	0.0	0.0	0.0	0.0	0.0	0.00000
SUBTRANS	40.0	0.0	1.2	41.2	1.03000	0.97087
PRIM SUBS	29.0	0.0	1.1	30.1	1.03709	0.96424
PRIM LINES	79.3	0.0	4.6	83.9	1.05865	0.94460
SECONDARY	1458.5	0.0	116.6	1575.1	1.07994	0.92597
TOTALS	1,606.7	0.0	123.5	1,730.3	1.07688	<COMPOSITE

**DEVELOPMENT of LOSS FACTORS
ADJUSTED
ENERGY**

LOSS FACTOR LEVEL	CUSTOMER SALES MWH a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MWH @ GEN d	CUM ANNUAL FACTORS e	EXPANTION f=1/e
BULK LINES	0	0	0	0	0	0.00000
TRANS SUBS	0	0	0	0	0	0.00000
TRANS LINES	0	0	0	0	0	0.00000
TOTAL TRANS	0	0	0	0	0	0.00000
SUBTRANS	340,959	0	10,229	351,188	1.03000	0.97087
PRIM SUBS	246,276	0	9,300	255,576	1.03776	0.96361
PRIM LINES	620,063	0	30,785	650,848	1.04965	0.95270
SECONDARY	6,868,556	0	473,832	7,342,388	1.06899	0.93547
TOTAL	8,075,854	0	524,146	8,600,000	1.06490	<COMPOSITE

Evergy
2020 Analysis of System Losses

Appendix B

**Results of 2020 Evergy
Kansas and Metro Combined**

(NOTE: All of the 0.000 high voltage values shown on Exhibits 2, 3, and 5 reflect results that have been included in the loss factor estimates of Exhibit 5, line 22, TOT TRANS LOSS FAC.)



METRO KS

SUMMARY OF COMPANY DATA

ANNUAL PEAK	1,575 MW
ANNUAL SYSTEM INPUT	6,600,000 MWH
ANNUAL SALES	6,170,122 MWH
SYSTEM LOSSES @ INPUT	429,878 or 6.51%
SYSTEM LOAD FACTOR	47.7%

SUMMARY OF LOSSES - OUTPUT RESULTS

SERVICE	KV	--- MW ---	% TOTAL	--- MWH ---	% TOTAL
		Input		Input	
TRANS	345,161,115 69,66,35	45.9	41.54%	192,233	44.72%
		2.91%		2.91%	
PRIM SUBS	33,12,1	8.7	7.85%	47,082	10.95%
		0.55%		0.71%	
PRIMARY	33,12,1	30.2	27.38%	75,165	17.49%
		1.92%		1.14%	
SECONDARY	120/240,to,477	25.7	23.23%	115,398	26.84%
		1.63%		1.75%	
TOTAL		110.4	100.00%	429,878	100.00%
		7.01%		6.51%	

SUMMARY OF LOSS FACTORS

SERVICE	KV	CUMMULATIVE SALES EXPANSION FACTORS			
		DEMAND (Peak)		ENERGY (Annual)	
		d	1/d	e	1/e
TOT TRANS	345,161,115 69,66,35	1.03000	0.97087	1.03000	0.97087
PRIM SUBS	33,12	1.03587	0.96537	1.03762	0.96374
PRIMARY	33,12,1	1.05695	0.94612	1.05008	0.95231
SECONDARY	120/240,to,477	1.07642	0.92900	1.07116	0.93357

SUMMARY OF CONDUCTOR INFORMATION

EXHIBIT 2

DESCRIPTION	CIRCUIT MILES	LOADING % RATING	---- MW LOSSES ----		
			LOAD	NO LOAD	TOTAL
--- BULK ----- 345 KV OR GREATER -----					
TIE LINES	0.0	0.00%	0.000	0.000	0.000
<u>BULK TRANS</u>	<u>0.0</u>	<u>0.00%</u>	<u>0.000</u>	<u>0.000</u>	<u>0.000</u>
SUBTOT	0.0		0.000	0.000	0.000
--- TRANS ----- 115 KV TO 345.00 KV -----					
TIE LINES	0	0.00%	0.000	0.000	0.000
TRANS1	161 KV	0.0	0.000	0.000	0.000
<u>TRANS2</u>	<u>115 KV</u>	<u>0.0</u>	<u>0.000</u>	<u>0.000</u>	<u>0.000</u>
SUBTOT	0.0		0.000	0.000	0.000
--- SUBTRANS ----- 35 KV TO 115 KV -----					
TIE LINES	0	0.00%	0.000	0.000	0.000
SUBTRANS1	69 KV	0.0	0.000	0.000	0.000
SUBTRANS2	66 KV	0.0	0.000	0.000	0.000
<u>SUBTRANS3</u>	<u>35 KV</u>	<u>0.0</u>	<u>0.000</u>	<u>0.000</u>	<u>0.000</u>
SUBTOT	0.0		0.000	0.000	0.000
PRIMARY LINES	6,899		24.151	2.720	26.870
SECONDARY LINES	2,331		2.604	0.000	2.604
SERVICES	3,705		3.228	0.553	3.780
TOTAL	12,935		29.983	3.272	33.255

---- MWH LOSSES ----		
LOAD	NO LOAD	TOTAL
0	0	0
<u>0</u>	<u>0</u>	<u>0</u>
0	0	0
0	0	0
<u>0</u>	<u>0</u>	<u>0</u>
0	0	0
0	0	0
<u>0</u>	<u>0</u>	<u>0</u>
0	0	0
50,107	23,888	73,995
4,065	0	4,065
5,866	4,856	10,723
60,039	28,745	88,783


SUMMARY OF TRANSFORMER INFORMATION

EXHIBIT 3


DESCRIPTION	KV CAPACITY		NUMBER TRANSFMR	AVERAGE SIZE	LOADING %	MVA LOAD	MW LOSSES			MWH LOSSES			
	VOLTAGE	MVA					LOAD	NO LOAD	TOTAL	LOAD	NO LOAD	TOTAL	
BULK STEP-UP	345	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
BULK - BULK		0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
BULK - TRANS1	161	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
BULK - TRANS2	115	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1 STEP-UP	161	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1 - TRANS2	115	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1-SUBTRANS1	69	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1-SUBTRANS2	66	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1-SUBTRANS3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS2 STEP-UP	115	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS2-SUBTRANS1	69	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS2-SUBTRANS2	66	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS2-SUBTRANS3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN1 STEP-UP	69	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN2 STEP-UP	66	0.0	0	0.0	0.00%	0	0.000	0.001	0.001	0	0	0	
SUBTRAN3 STEP-UP	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN1-SUBTRAN2	66	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN1-SUBTRAN3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN2-SUBTRAN3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
DISTRIBUTION SUBSTATIONS													
TRANS1 -	161	33	287.2	10	28.7	42.85%	123	0.268	0.392	0.660	719	3,442	4,161
TRANS1 -	161	12	2,833.2	78	36.3	50.49%	1,431	3.278	3.862	7.139	8,724	33,920	42,644
TRANS1 -	161	1	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
TRANS2 -	115	33	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
TRANS2 -	115	12	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
TRANS2 -	115	1	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN1-	69	33	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN1-	69	12	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN1-	69	1	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN2-	66	33	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN2-	66	12	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN2-	66	1	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN3-	35	33	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN3-	35	12	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN3-	35	1	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
PRIMARY - PRIMARY			200.0	42	4.8	43.23%	86	0.325	0.340	0.665	726	2,985	3,711
LINE TRANSFRMR			3,919.4	58,416	67.1	39.63%	1,553	6.800	9.895	16.695	13,015	86,913	99,928
TOTAL			7,240	58,546				10.671	14.489	25.160	23,183	127,260	150,443

SUMMARY OF LOSSES DIAGRAM - DEMAND MODEL - SYSTEM PEAK

1575 MW



FROM HIGH VOLTAGE SYSTEM



SUMMARY of SALES and CALCULATED LOSSES

EXHIBIT 5

LOSS # AND LEVEL	MW LOAD	NO LOAD	+	LOAD	=	TOT LOSS	EXP FACTOR	CUM EXP FAC	MWH LOAD	NO LOAD	+	LOAD	=	TOT LOSS	EXP FACTOR	CUM EXP FAC
1 BULK XFMMR	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0
2 BULK LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
3 TRANS1 XFMR	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
4 TRANS1 LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
5 TRANS2TR1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
6 TRANS2BLK SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
7 TRANS2 LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
TOTAL TRAN	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
8 STR1BLK SD																
9 STR1T1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
10 SRT1T2 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
11 SUBTRANS1 LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
12 STR2T1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
13 STR2T2 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
14 STR2S1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
15 SUBTRANS2 LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
16 STR3T1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
17 STR3T2 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
18 STR3S1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
19 STR3S2 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
20 SUBTRANS3 LINES	0.0	0.00		0.00		0.00	0.000000		0	0		0		0	0	0.000000
21 SUBTRANS TOTAL	0.0	0.00		0.00		0.00	0.000000	FERC OATT	0	0		0		0	0	0.000000
22 TOT TRANS LOSS FAC	1,575.0	5.50		40.37		45.87	1.030000	1.030000	6,600,000	48,355		143,878		192,233	1.030000	1.030000
DISTRIBUTION SUBST																
TRANS1	1,522.5	4.25		3.55		7.80	1.005149	0.000000	6,405,928	37,362		9,442		46,804	1.0073602	0.000000
TRANS2	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0.000000	0.000000
SUBTR1	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0.000000	0.000000
SUBTR2	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0.000000	0.000000
SUBTR3	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0.000000	0.000000
WEIGHTED AVERAGE	1,522.5	4.25		3.55		7.80	1.005149	1.035303	6,405,928	37,362		9,442		46,804	1.0073602	1.0375810
PRIMARY INTRCHNGE	0.0						0.000000		0						0.000000	
PRIMARY LINES	1,510.8	2.72		24.48		27.20	1.018330	1.054280	6,335,958	23,888		50,833		74,721	1.0119339	1.0499634
LINE TRANSF	1,415.6	9.89		6.80		16.69	1.011934	1.066862	5,864,051	86,913		13,015		99,928	1.0173363	1.0681658
SECONDARY SERVICES	1,398.9	0.00		2.60		2.60	1.001865	1.068852	5,764,123	0		4,065		4,065	1.0007057	1.0689197
	1,396.3	0.55		3.23		3.78	1.002715	1.071754	5,760,058	4,856		5,866		10,723	1.0018651	1.0709133
TOTAL SYSTEM		22.93		81.02		103.95				201,374		227,100		428,475		

DEVELOPMENT of LOSS FACTORS
UNADJUSTED
DEMAND

EXHIBIT 6

LOSS FACTOR LEVEL	CUSTOMER SALES MW	CALC LOSS TO LEVEL	SALES MW @ GEN	CUM PEAK EXPANSION FACTORS	
	a	b	c	d	1/d
BULK LINES	0.0	0.0	0.0	0.00000	0.00000
TRANS SUBS	0.0	0.0	0.0	0.00000	0.00000
TRANS LINES	0.0	0.0	0.0	0.00000	0.00000
SUBTRANS SUBS	0.0	0.0	0.0	0.00000	0.00000
TOTAL TRANS	0.0	0.0	0.0	1.03000	0.97087
PRIM SUBS	4.0	0.1	4.1	1.03530	0.96590
PRIM LINES	68.0	3.7	71.7	1.05428	0.94851
SECONDARY	<u>1,392.6</u>	<u>99.9</u>	<u>1,492.5</u>	1.07175	0.93305
TOTALS	1,464.6	103.8	1,568.3		

DEVELOPMENT of LOSS FACTORS
UNADJUSTED
ENERGY

LOSS FACTOR LEVEL	CUSTOMER SALES MWH	CALC LOSS TO LEVEL	SALES MWH @ GEN	CUM ANNUAL EXPANSION FACTORS	
	a	b	c	d	1/d
BULK LINES	0	0	0	0.00000	0.00000
TRANS SUBS	0	0	0	0.00000	0.00000
TRANS LINES	0	0	0	0.00000	0.00000
SUBTRANS SUBS	0	0	0	0.00000	0.00000
TOTAL TRANS	0	0	0	1.03000	0.97087
PRIM SUBS	23,601	887	24,488	1.03758	0.96378
PRIM LINES	397,186	19,845	417,031	1.04996	0.95241
SECONDARY	<u>5,749,335</u>	<u>407,704</u>	<u>6,157,039</u>	1.07091	0.93378
TOTALS	6,170,122	428,436	6,598,558		

ESTIMATED VALUES AT GENERATION

LOSS FACTOR AT VOLTAGE LEVEL	MW	MWH
BULK LINES	0.00	0
TRANS SUBS	0.00	0
TRANS LINES	0.00	0
SUBTRANS SUBS	0.00	0
SUBTRANS LINES	0.00	0
PRIM SUBS	4.14	24,488
PRIM LINES	71.69	417,031
SECONDARY	1,492.48	6,157,039
SUBTOTAL	1,568.31	6,598,558
ACTUAL ENERGY	1,575.00	6,600,000
MISMATCH	(6.69)	(1,442)
% MISMATCH	-0.42%	-0.02%

DEVELOPMENT of LOSS FACTORS

EXHIBIT 7

ADJUSTED
DEMAND

LOSS FACTOR LEVEL	CUSTOMER SALES MW a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MW @ GEN d	CUM PEAK EXPANSION FACTORS e	f=1/e
BULK LINES	0.0	0.0	0.0	0.0	0.00000	0.00000
TRANS SUBS	0.0	0.0	0.0	0.0	0.00000	0.00000
TRANS LINES	0.0	0.0	0.0	0.0	0.00000	0.00000
SUBTRANS SUBS	0.0	0.0	0.0	0.0	0.00000	0.00000
TOTAL TRANS	0.0	0.0	0.0	0.0	1.03000	0.97087
PRIM SUBS	4.0	0.0	0.1	4.1	1.03587	0.96537
PRIM LINES	68.0	0.0	3.9	71.9	1.05695	0.94612
SECONDARY	<u>1,392.6</u>	<u>0.0</u>	106.4	<u>1,499.0</u>	1.07642	0.92900
			110.4			
TOTALS	1,464.6	0.0	110.4	1,575.0		

DEVELOPMENT of LOSS FACTORS

ADJUSTED
ENERGY

LOSS FACTOR LEVEL	CUSTOMER SALES MWH a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MWH @ GEN d	CUM ANNUAL EXPANSION FACTORS e	f=1/e
BULK LINES	0	0	0	0	0.00000	0.00000
TRANS SUBS	0	0	0	0	0.00000	0.00000
TRANS LINES	0	0	0	0	0.00000	0.00000
SUBTRANS SUBS	0	0	0	0	0.00000	0.00000
TOTAL TRANS	0	0	0	0	1.03000	0.97087
PRIM SUBS	23,601	0	888	24,489	1.03762	0.96374
PRIM LINES	397,186	0	19,891	417,077	1.05008	0.95231
SECONDARY	<u>5,749,335</u>	<u>0</u>	409,099	<u>6,158,434</u>	1.07116	0.93357
			429,878			
TOTALS	6,170,122	0	429,878	6,600,000		

ESTIMATED VALUES AT GENERATION

LOSS FACTOR AT
VOLTAGE LEVEL

	MW	MWH
BULK LINES	0.00	0
TRANS SUBS	0.00	0
TRANS LINES	0.00	0
SUBTRANS SUBS	0.00	0
SUBTRANS LINES	0.00	0
PRIM SUBS	4.14	24,489
PRIM LINES	71.87	417,077
SECONDARY	1,498.98	6,158,434
	1,575.00	6,600,000
ACTUAL ENERGY	1,575.00	6,600,000
MISMATCH	0.00	0
% MISMATCH	0.00%	0.00%

Adjusted Losses and Loss Factors by Facility

EXHIBIT 8

Unadjusted Losses by Segment

	MW	Unadjusted	MWH	Unadjusted
Service Drop Losses	3.78	3.77	10,723	10,721
Secondary Losses	2.60	2.60	4,065	4,064
Line Transformer Losses	16.69	16.64	99,928	99,912
Primary Line Losses	27.20	27.10	74,721	74,709
Distribution Substation Losses	7.80	7.77	46,804	46,797
<u>Transmission System Losses</u>	<u>45.87</u>	<u>45.87</u>	<u>192,233</u>	<u>192,233</u>
Total	103.95	103.75	428,475	428,436

Mismatch Allocation by Segment

	MW	MWH
Service Drop Losses	-0.44	-65
Secondary Losses	-0.30	-25
Line Transformer Losses	-1.92	-610
Primary Line Losses	-3.13	-456
Distribution Substation Losses	-0.90	-286
<u>Transmission System Losses</u>	<u>0.00</u>	<u>0</u>
Total	-6.69	-1,442

Adjusted Losses by Segment

	MW	% of Total	MWH	% of Total
Service Drop Losses	4.20	3.8%	10,787	2.5%
Secondary Losses	2.90	2.6%	4,089	1.0%
Line Transformer Losses	18.56	16.8%	100,522	23.4%
Primary Line Losses	30.24	27.4%	75,165	17.5%
Distribution Substation Losses	8.67	7.9%	47,082	11.0%
<u>Transmission System Losses</u>	<u>45.87</u>	<u>41.5%</u>	<u>192,233</u>	<u>44.7%</u>
Total	110.44	100.0%	429,878	100.0%

Loss Factors by Segment

	MW	MWH	
Retail Sales from Service Drops	1,392.560	5,749,335	
<u>Adjusted Service Drop Losses</u>	<u>4.203</u>	<u>10,787</u>	
Input to Service Drops	1,396.763	5,760,122	
Service Drop Loss Factor	1.00302	1.00188	
Output from Secondary	1,396.763	5,760,122	
<u>Adjusted Secondary Losses</u>	<u>2.896</u>	<u>4,089</u>	
Input to Secondary	1,399.659	5,764,211	
Secondary Conductor Loss Factor	1.00207	1.00071	
Output from Line Transformers	1,399.659	5,764,211	
<u>Adjusted Line Transformer Losses</u>	<u>18.561</u>	<u>100,522</u>	
Input to Line Transformers	1,418.220	5,864,733	
Line Transformer Loss Factor	1.01326	1.01744	
Retail Sales from Primary	68.000	397,186	
Req. Whls Sales from Primary	0.000	0	
<u>Input to Line Transformers</u>	<u>1,418.220</u>	<u>5,864,733</u>	
Output from Primary Lines	1,486.220	6,261,919	
<u>Adjusted Primary Line Losses</u>	<u>30.235</u>	<u>75,165</u>	
Input to Primary Lines	1,516.455	6,337,084	
Primary Line Loss Factor	1.02034	1.01200	
Output PI from Distribution Substations	1,516.455	6,337,084	
Req. Whls Sales from Substations	0.000	0	
Retail Sales from Substations	4.000	23,601	
Total Output from Distribution Substations	1,520.455	6,360,685	
<u>Adjusted Distribution Substation Losses</u>	<u>8.671</u>	<u>47,082</u>	
Input to Distribution Substations	1,529.126	6,407,767	
Distribution Substation Loss Factor	1.00570	1.00740	
Retail Sales at from SubTransmission	0.000	0	
Req. Whls Sales from SubTransmission	0.000	0	
Non-Req. Whls Sales from SubTransmission	0.000	0	
Losses	0.000	0	4678
<u>Input to Distribution Substations</u>	<u>1,529.126</u>	<u>6,407,767</u>	
Output from SubTransmission	1,529.126	6,407,767	1,575.000
<u>SubTransmission System Losses</u>	<u>45.874</u>	<u>192,233</u>	45.874
Input to Transmission	1,575.000	6,600,000	45.874
TotTransmission System Loss Factor	1.03000	1.03000	45.874

DEMAND MW

SUMMARY OF LOSSES AND LOSS FACTORS BY DELIVERY VOLTAGE

EXHIBIT 9
PAGE 1 of 2

	SERVICE LEVEL	SALES MW	LOSSES	SECONDARY	PRIMARY	SUBSTATION	SUBTRANS	TRANSMISSION
1	SERVICES							
2	SALES	1,392.6		1,392.6				
3	LOSSES		4.2	4.2				
4	INPUT			1,396.8				
5	EXPANSION FACTOR	1.00302						
6	SECONDARY							
7	SALES							
8	LOSSES		2.9	2.9				
9	INPUT			1,399.7				
10	EXPANSION FACTOR	1.00207						
11	LINE TRANSFORMER							
12	SALES							
13	LOSSES		18.6	18.6				
14	INPUT			1,418.2				
15	EXPANSION FACTOR	1.01326						
16	PRIMARY							
17	SECONDARY			1,418.2				
18	SALES	68.0			68.0			
19	LOSSES		30.2	28.9	1.4			
20	INPUT			1,447.1	69.4			
21	EXPANSION FACTOR	1.02034						
22	SUBSTATION							
23	PRIMARY			1,447.1	69.4			
24	SALES	4.0				4.0		
25	LOSSES		8.7	8.3	0.4	0.0		
26	INPUT			1,455.3	69.8	4.0		
27	EXPANSION FACTOR	1.00570						
28	SUB-TRANSMISSION							
29	DISTRIBUTION SUBS							
30	SALES							
31	LOSSES							
32	INPUT							
33	EXPANSION FACTOR							
34	TRANSMISSION							
35	SUBTRANSMISSION							
36	DISTRIBUTION SUBS			1,455.3	69.8	4.0		
37	SALES	0.0						0.0
38	LOSSES		45.9	43.7	2.1	0.1		0.0
39	INPUT			1,499.0	71.9	4.1		0.0
40	EXPANSION FACTOR	1.03000						
41	TOTALS		110.4	106.4	3.9	0.1		0.0
42	LOSSES							
42	% OF TOTAL		100%	96.36%	3.51%	0.13%		0.00%
43	SALES	1,464.6		1,392.6	68.0	4.0		0.0
44	% OF TOTAL	100.00%		95.08%	4.64%	0.27%		0.00%
45	INPUT	1,575.0		1,499.0	71.9	4.1		0.0
46	CUMMULATIVE EXPANSION LOSS FACTORS			1.07642	1.05695	1.03587		NA
	(from meter to system input)			1.09238				

ENERGY MWH

SUMMARY OF LOSSES AND LOSS FACTORS BY DELIVERY VOLTAGE

EXHIBIT 9
PAGE 2 of 2

SERVICE LEVEL	SALES	LOSSES	SECONDARY	PRIMARY	SUBSTATION	SUBTRANS	TRANSMISSION
1 SERVICES							
2 SALES	5,749,335		5,749,335				
3 LOSSES		10,787	10,787				
4 INPUT			5,760,122				
5 EXPANSION FACTOR	1.00188						
6 SECONDARY							
7 SALES							
8 LOSSES		4,089	4,089				
9 INPUT			5,764,211				
10 EXPANSION FACTOR	1.00071						
11 LINE TRANSFORMER							
12 SALES							
13 LOSSES		100,522	100,522				
14 INPUT			5,864,733				
15 EXPANSION FACTOR	1.01744						
16 PRIMARY							
17 SECONDARY			5,864,733				
18 SALES	397,186.000			397,186			
19 LOSSES		75,165	70,397	4,768			
20 INPUT			5,935,130	401,954			
21 EXPANSION FACTOR	1.01200						
22 SUBSTATION							
23 PRIMARY			5,935,130	401,954			
24 SALES	23,601				23,601		
25 LOSSES		47,082	43,932	2,975	175		
26 INPUT			5,979,062	404,929	23,776		
27 EXPANSION FACTOR	1.00740						
28 SUB-TRANSMISSION							
29 DISTRIBUTION SUBS							
30 SALES							
31 LOSSES							
32 INPUT							
33 EXPANSION FACTOR							
34 TRANSMISSION							
35 SUBTRANSMISSION							
36 DISTRIBUTION SUBS			5,979,062	404,929	23,776		
37 SALES	0						0
38 LOSSES		192,233	179,372	12,148	713		0
39 INPUT			6,158,434	417,077	24,489		0
40 EXPANSION FACTOR	1.03000						
41 TOTALS							
42 LOSSES		429,878	409,099	19,891	888		0
42 % OF TOTAL		100%	95.17%	4.63%	0.21%		0.00%
43 SALES	6,170,122		5,749,335	397,186	23,601		0
44 % OF TOTAL	100.00%		93.18%	6.44%	0.38%		0.00%
45 INPUT	6,600,000		6,158,434	417,077	24,489		0
46 CUMMULATIVE EXPANSION LOSS FACTORS			1.07116	1.05008	1.03762		NA
(from meter to system input)							

**KCPL KS & MO
COMPOSITE
LOSS FACTORS**

**DEVELOPMENT of LOSS FACTORS
ADJUSTED EXHIBIT 7
DEMAND**

LOSS FACTOR LEVEL	CUSTOMER SALES MW	SALES ADJUST	CALC LOSS TO LEVEL	SALES MW @ GEN	CUM PEAK FACTORS	EXPANTION	
	a	b	c	d	e	f=1/e	
BULK LINES		0.0	0.0	0.0	0.0	0.00000	0.00000
TRANS SUBS		0.0	0.0	0.0	0.0	0.00000	0.00000
TRANS LINES		0.0	0.0	0.0	0.0	0.00000	0.00000
TOTAL TRANS		0.0	0.0	0.0	0.0	0.00000	0.97824
SUBTRANS		40.0	0.0	1.2	41.2	1.03000	0.97824
PRIM SUBS		33.0	0.0	1.2	34.2	1.03694	0.96437
PRIM LINES		147.3	0.0	8.5	155.8	1.05786	0.94061
SECONDARY		2,851.0	0.0	223.0	3,074.1	1.07822	0.91849
TOTALS		3,071.3	0.0	234.0	3,305.3	1.07618	<COMPOSITE

**DEVELOPMENT of LOSS FACTORS
ADJUSTED
ENERGY**

LOSS FACTOR LEVEL	CUSTOMER SALES MWH	SALES ADJUST	CALC LOSS TO LEVEL	SALES MWH @ GEN	CUM ANNUAL FACTORS	EXPANTION	
	a	b	c	d	e	f=1/e	
BULK LINES		0	0	0	0	0.00000	0.00000
TRANS SUBS		0	0	0	0	0.00000	0.00000
TRANS LINES		0	0	0	0	0.00000	0.00000
TOTAL TRANS		0	0	0	0	0.00000	0.00000
SUBTRANS		340959	0	10229	351188	1.03000	0.97087
PRIM SUBS		269,877	0	10,188	280,065	1.03775	0.96362
PRIM LINES		1,017,249	0	50,676	1,067,925	1.04982	0.95255
SECONDARY		12,617,891	0	882,932	13,500,823	1.06997	0.93460
TOTAL		14,245,976	0	954,024	15,200,000	1.06697	<COMPOSITE

**DEVELOPMENT of LOSS FACTORS
ADJUSTED EXHIBIT 7
DEMAND**

LOSS FACTOR LEVEL	CUSTOMER SALES MW a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MW @ GEN d	CUM PEAK FACTORS e	EXPANTION f=1/e
BULK LINES	0.0	0	0	0	0.0	0.00000
TRANS SUBS	0.0	0	0	0	0.0	0.00000
TRANS LINES	0.0	0	0	0	0.0	0.00000
TOTAL TRANS	0.0	0.0	0.0	0.0	0.0	0.91849
SUBTRANS	0.0	0.0	0.0	0.0	0.0	0.91849
PRIM SUBS	4.0	0.0	0.1	4.1	1.03587	0.91849
PRIM LINES	68.0	0.0	3.9	71.9	1.05695	0.91849
SECONDARY	1,392.6	0.0	106.4	1,499.0	1.07642	0.91849
TOTALS	1,464.6	0.0	110.4	1,575.0	1.07541	<COMPOSITE

**DEVELOPMENT of LOSS FACTORS
ADJUSTED
ENERGY**

LOSS FACTOR LEVEL	CUSTOMER SALES MWH a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MWH @ GEN d	CUM ANNUAL FACTORS e	EXPANTION f=1/e
BULK LINES	0	0	0	0	0	0.00000
TRANS SUBS	0	0	0	0	0	0.00000
TRANS LINES	0	0	0	0	0	0.00000
TOTAL TRANS	0	0	0	0	0	0.00000
SUBTRANS	0	0	0	0	0	0.00000
PRIM SUBS	23,601	0	888	24,489	1.03762	0.96374
PRIM LINES	397,186	0	19,891	417,077	1.05008	0.95231
SECONDARY	5,749,335	0	409,099	6,158,434	1.07116	0.93357
TOTAL	6,170,122	0	429,878	6,600,000	1.06967	<COMPOSITE

**DEVELOPMENT of LOSS FACTORS
ADJUSTED EXHIBIT 7
DEMAND**

LOSS FACTOR LEVEL	CUSTOMER SALES MW a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MW @ GEN d	CUM PEAK FACTORS e	EXPANTION f=1/e
BULK LINES	0.0	0	0	0	0.0	0.00000
TRANS SUBS	0.0	0	0	0	0.0	0.00000
TRANS LINES	0.0	0	0	0	0.0	0.00000
TOTAL TRANS	0.0	0.0	0.0	0.0	0.00000	0.00000
SUBTRANS	40.0	0.0	1.2	41.2	1.03000	0.97087
PRIM SUBS	29.0	0.0	1.1	30.1	1.03709	0.96424
PRIM LINES	79.3	0.0	4.6	83.9	1.05865	0.94460
SECONDARY	1458.5	0.0	116.6	1575.1	1.07994	0.92597
TOTALS	1,606.7	0.0	123.5	1,730.3	1.07688	<COMPOSITE

**DEVELOPMENT of LOSS FACTORS
ADJUSTED
ENERGY**

LOSS FACTOR LEVEL	CUSTOMER SALES MWH a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MWH @ GEN d	CUM ANNUAL FACTORS e	EXPANTION f=1/e
BULK LINES	0	0	0	0	0	0.00000
TRANS SUBS	0	0	0	0	0	0.00000
TRANS LINES	0	0	0	0	0	0.00000
TOTAL TRANS	0	0	0	0	0	0.00000
SUBTRANS	340,959	0	10,229	351,188	1.03000	0.97087
PRIM SUBS	246,276	0	9,300	255,576	1.03776	0.96361
PRIM LINES	620,063	0	30,785	650,848	1.04965	0.95270
SECONDARY	6,868,556	0	473,832	7,342,388	1.06899	0.93547
TOTAL	8,075,854	0	524,146	8,600,000	1.06490	<COMPOSITE

Evergy
2020 Analysis of System Losses

Appendix C

**Results of 2020 Evergy
Missouri West (MO West)**

(NOTE: All of the 0.000 high voltage values shown on Exhibits 2, 3, and 5 reflect results that have been included in the loss factor estimates of Exhibit 5, line 22, TOT TRANS LOSS FAC.)



MO WEST

EXHIBIT 1

SUMMARY OF COMPANY DATA

ANNUAL PEAK	1,845 MW
ANNUAL SYSTEM INPUT	8,583,034 MWH
ANNUAL SALES	8,008,468 MWH
SYSTEM LOSSES @ INPUT	574,566 or 6.69%
SYSTEM LOAD FACTOR	53.0%

SUMMARY OF LOSSES - OUTPUT RESULTS

SERVICE	KV	--- MW ---	% TOTAL	--- MWH ---	% TOTAL
		Input		Input	
TRANS	345,161,115 69,66,35	53.7	40.69%	249,991	43.51%
		2.91%		2.91%	
PRIM SUBS	33,12,1	12.3	9.31%	68,559	11.93%
		0.67%		0.80%	
PRIMARY	33,12,1	30.5	23.08%	84,124	14.64%
		1.65%		0.98%	
SECONDARY	120/240,to,477	35.5	26.91%	171,892	29.92%
		1.93%		2.00%	
TOTAL		132.0	100.00%	574,566	100.00%
		7.16%		6.69%	

SUMMARY OF LOSS FACTORS

SERVICE	KV	CUMMULATIVE SALES EXPANSION FACTORS			
		DEMAND (Peak)		ENERGY (Annual)	
		d	1/d	e	1/e
TOT TRANS	345,161,115 69,66,35	1.03000	0.97087	1.03000	0.97087
PRIM SUBS	33,12	1.03724	0.96410	1.03880	0.96265
PRIMARY	33,12,1	1.05618	0.94681	1.05026	0.95215
SECONDARY	120/240,to,477	1.08050	0.92550	1.07664	0.92881

SUMMARY OF CONDUCTOR INFORMATION

EXHIBIT 2

DESCRIPTION	CIRCUIT MILES	LOADING % RATING	---- MW LOSSES ----		
			LOAD	NO LOAD	TOTAL
--- BULK ----- 345 KV OR GREATER -----					
TIE LINES	0.0	0.00%	0.000	0.000	0.000
<u>BULK TRANS</u>	<u>0.0</u>	<u>0.00%</u>	<u>0.000</u>	<u>0.000</u>	<u>0.000</u>
SUBTOT	0.0		0.000	0.000	0.000
--- TRANS ----- 115 KV TO 345.00 KV -----					
TIE LINES	0	0.00%	0.000	0.000	0.000
TRANS1	161 KV	0.0	0.000	0.000	0.000
<u>TRANS2</u>	<u>115 KV</u>	<u>0.0</u>	<u>0.000</u>	<u>0.000</u>	<u>0.000</u>
SUBTOT	0.0		0.000	0.000	0.000
--- SUBTRANS ----- 35 KV TO 115 KV -----					
TIE LINES	0	0.00%	0.000	0.000	0.000
SUBTRANS1	69 KV	0.0	0.000	0.000	0.000
SUBTRANS2	66 KV	0.0	0.000	0.000	0.000
<u>SUBTRANS3</u>	<u>35 KV</u>	<u>0.0</u>	<u>0.000</u>	<u>0.000</u>	<u>0.000</u>
SUBTOT	0.0		0.000	0.000	0.000
PRIMARY LINES	11,011		23.725	2.708	26.433
SECONDARY LINES	4,305		4.024	0.000	4.024
SERVICES	4,795		4.469	0.716	5.185
TOTAL	20,112		32.218	3.425	35.643

---- MWH LOSSES ----		
LOAD	NO LOAD	TOTAL
0	0	0
<u>0</u>	<u>0</u>	<u>0</u>
0	0	0
0	0	0
0	0	0
<u>0</u>	<u>3</u>	<u>3</u>
0	3	3
57,165	23,786	80,951
7,528	0	7,528
11,960	6,293	18,254
76,654	30,082	106,736


SUMMARY OF TRANSFORMER INFORMATION

EXHIBIT 3


DESCRIPTION	KV CAPACITY		NUMBER TRANSFMR	AVERAGE SIZE	LOADING %	MVA LOAD	MW LOSSES			MWH LOSSES			
	VOLTAGE	MVA					LOAD	NO LOAD	TOTAL	LOAD	NO LOAD	TOTAL	
BULK STEP-UP	345	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
BULK - BULK		0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
BULK - TRANS1	161	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
BULK - TRANS2	115	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1 STEP-UP	161	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1 - TRANS2	115	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1-SUBTRANS1	69	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1-SUBTRANS2	66	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS1-SUBTRANS3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS2 STEP-UP	115	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS2-SUBTRANS1	69	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS2-SUBTRANS2	66	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
TRANS2-SUBTRANS3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN1 STEP-UP	69	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN2 STEP-UP	66	0.0	0	0.0	0.00%	0	0.000	0.001	0.001	0	0	0	
SUBTRAN3 STEP-UP	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN1-SUBTRAN2	66	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN1-SUBTRAN3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
SUBTRAN2-SUBTRAN3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0	
DISTRIBUTION SUBSTATIONS													
TRANS1 -	161	33	495.7	8	62.0	40.16%	199	0.388	0.614	1.002	1,226	5,391	6,617
TRANS1 -	161	12	2,684.9	94	28.6	40.38%	1,084	2.448	3.597	6.045	7,553	31,597	39,150
TRANS1 -	161	1	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
TRANS2 -	115	33	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
TRANS2 -	115	12	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
TRANS2 -	115	1	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN1-	69	33	156.2	14	11.2	28.48%	44	0.099	0.236	0.335	305	2,077	2,382
SUBTRAN1-	69	12	850.7	61	13.9	46.99%	400	1.777	1.290	3.067	5,095	11,331	16,425
SUBTRAN1-	69	1	139.9	17	8.2	44.08%	62	0.239	0.238	0.478	694	2,094	2,787
SUBTRAN2-	66	33	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN2-	66	12	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN2-	66	1	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN3-	35	33	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN3-	35	12	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
SUBTRAN3-	35	1	0.0	0	0.0	0.00%	0	0.000	0.000	0.000	0	0	0
PRIMARY - PRIMARY			371.6	84	4.4	44.90%	167	0.646	0.621	1.267	1,705	5,453	7,158
LINE TRANSFMR			5,415.2	101,346	53.4	31.82%	1,723	7.506	14.858	22.364	12,602	130,509	143,111
=====													
TOTAL			10,114	101,624				13.103	21.455	34.558	29,180	188,452	217,632

SUMMARY OF LOSSES DIAGRAM - DEMAND MODEL - SYSTEM PEAK

1844.7 MW



FROM HIGH VOLTAGE SYSTEM



DISTRIBUTION SYSTEM LOAD

	PRIM1	PRIM2	PRIM3	PRIM1	PRIM2	PRIM3	PRIM1	PRIM2	PRIM3	PRIM1	PRIM2	PRIM3	PRIM1	PRIM2	PRIM3
VOLTAGE	33	12	1	33	12	1	33	12	1	33	12	1	33	12	1
LOAD MVA	199	1,084	0	0	0	0	44	400	62	0	0	0	0	0	0
% SYS TOT	11.13%	60.60%	0.00%	0.00%	0.00%	0.00%	2.49%	22.34%	3.45%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
NOLD LOSS	0.614	3.597	0.000	0.000	0.000	0.000	0.236	1.290	0.238	0.000	0.000	0.000	0.000	0.000	0.000
LOAD LOSS	0.388	2.448	0.000	0.000	0.000	0.000	0.099	1.777	0.239	0.000	0.000	0.000	0.000	0.000	0.000
AVG SIZE	62.0	28.6	0.0	0.0	0.0	0.0	11.2	13.9	8.2	0.0	0.0	0.0	0.0	0.0	0.0
NUMBER	8	94	0	0	0	0	14	61	17	0	0	0	0	0	0
DIVERSITY RATIO	1.000	1.000	0.000	0.000	0.000	0.000	1.000	1.000	1.000	0.000	0.000	0.000	0.000	0.000	0.000

PRIMARY LINES	
LOADING	1693.036 MW
@ SYS PF	1727.588 MVA
LOAD LOSS	23.725 MW
NOLD LOSS	2.708 MW
TOT LOSS	26.433 MW

PRIM/PRIM TRANSF	
LOADING	166.842 MW
NOLD LOSS	0.621 MW
LOAD LOSS	0.646 MW
AVG SIZE	4.42
NUMBER	84

PRIM CUST LOADS	
NO LINES	0.000 MW
CUST SUB	0.000 MVA
NO LINES	49.400 MW
CO. SUB	50.408 MVA
PRIM WITH	90.700 MW
LINES	98.587 MVA

LINE TRANSFORMERS		
LOADING	1574.637 MW	MVA 1745.372
NOLD LOSS	14.858	MW
LOAD LOSS	7.506	MW
AVG SIZE	53.4	KVA
NUMBER	101346	

SECONDARY LINES	
LOAD	586.407 MW
LOAD LOSS	4.024 MW
NOLD LOSS	0.000 MW
TOT LOSS	4.024 MW

NO SECONDARY LINES	
LOAD	965.866 MW

SERVICES	
LOAD	1548.249 MW
LOAD LOSS	4.469 MW
NOLD LOSS	0.716 MW
TOT LOSS	5.185 MW

CUSTOMER SECONDARY LOAD	
	1543.064 MW

SUMMARY of SALES and CALCULATED LOSSES

EXHIBIT 5

LOSS # AND LEVEL	MW LOAD	NO LOAD	+	LOAD	=	TOT LOSS	EXP FACTOR	CUM EXP FAC	MWH LOAD	NO LOAD	+	LOAD	=	TOT LOSS	EXP FACTOR	CUM EXP FAC
1 BULK XFMMR	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0
2 BULK LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
3 TRANS1 XFMR	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
4 TRANS1 LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
5 TRANS2TR1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
6 TRANS2BLK SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
7 TRANS2 LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
TOTAL TRAN	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
8 STR1BLK SD																
9 STR1T1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
10 SRT1T2 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
11 SUBTRANS1 LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
12 STR2T1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
13 STR2T2 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
14 STR2S1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
15 SUBTRANS2 LINES	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
16 STR3T1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
17 STR3T2 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
18 STR3S1 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
19 STR3S2 SD	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0	0.000000
20 SUBTRANS3 LINES	0.0	0.00		0.00		0.00	0.000000		0	3		0		3	0.000000	
21 SUBTRANS TOTAL	0.0	0.00		0.00		0.00	0.000000	FERC OATT	0	3		0		3	0.000000	FERC OATT
22 TOT TRANS LOSS FAC	1,844.7	6.45		47.28		53.73	1.030000	1.030000	8,583,034	56,635		193,356		249,991	1.030000	1.030000
DISTRIBUTION SUBST																
TRANS1	1,257.6	4.21		2.84		7.05	1.005635	0.000000	5,799,363	36,989		8,779		45,767	1.0079546	0.000000
TRANS2	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0.000000	0.000000
SUBTR1	495.7	1.76		2.12		3.88	1.007889	0.000000	2,286,014	15,502		6,093		21,595	1.0095368	0.000000
SUBTR2	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0.000000	0.000000
SUBTR3	0.0	0.00		0.00		0.00	0.000000	0.000000	0	0		0		0	0.000000	0.000000
WEIGHTED AVERAGE	1,753.3	5.98		4.95		10.93	1.006271	1.036460	8,085,377	52,490		14,872		67,363	1.0084014	1.0386535
PRIMARY INTRCHNGE	0.0						0.000000		0						0.000000	
PRIMARY LINES	1,692.4	2.71		24.37		27.08	1.016260	1.053313	7,706,716	23,786		58,870		82,656	1.0108415	1.0499140
LINE TRANSF	1,574.6	14.86		7.51		22.36	1.014407	1.068488	7,012,018	130,509		12,602		143,111	1.0208346	1.0717885
SECONDARY SERVICES	1,552.3	0.00		4.02		4.02	1.002599	1.071265	6,868,907	0		7,528		7,528	1.0010972	1.0729645
	1,548.2	0.72		4.47		5.19	1.003360	1.074865	6,861,379	6,293		11,960		18,254	1.0026674	1.0758266
TOTAL SYSTEM		30.71		92.60		123.31				269,713		299,190		568,903		

DEVELOPMENT of LOSS FACTORS
UNADJUSTED
DEMAND

EXHIBIT 6

LOSS FACTOR LEVEL	CUSTOMER SALES MW	CALC LOSS TO LEVEL	SALES MW @ GEN	CUM PEAK EXPANSION FACTORS	
	a	b	c	d	1/d
BULK LINES	0.0	0.0	0.0	0.00000	0.00000
TRANS SUBS	0.0	0.0	0.0	0.00000	0.00000
TRANS LINES	0.0	0.0	0.0	0.00000	0.00000
SUBTRANS SUBS	0.0	0.0	0.0	0.00000	0.00000
TOTAL TRANS	29.5	0.9	30.4	1.03000	0.97087
PRIM SUBS	49.4	1.8	51.2	1.03646	0.96482
PRIM LINES	90.7	4.8	95.5	1.05331	0.94939
SECONDARY	<u>1,543.1</u>	<u>115.5</u>	<u>1,658.6</u>	1.07486	0.93035
TOTALS	1,712.7	123.0	1,835.7		

DEVELOPMENT of LOSS FACTORS
UNADJUSTED
ENERGY

LOSS FACTOR LEVEL	CUSTOMER SALES MWH	CALC LOSS TO LEVEL	SALES MWH @ GEN	CUM ANNUAL EXPANSION FACTORS	
	a	b	c	d	1/d
BULK LINES	0	0	0	0.00000	0.00000
TRANS SUBS	0	0	0	0.00000	0.00000
TRANS LINES	0	0	0	0.00000	0.00000
SUBTRANS SUBS	0	0	0	0.00000	0.00000
TOTAL TRANS	241,668	7,250	248,918	1.03000	0.97087
PRIM SUBS	311,633	12,046	323,679	1.03865	0.96279
PRIM LINES	612,042	30,549	642,591	1.04991	0.95246
SECONDARY	<u>6,843,125</u>	<u>518,891</u>	<u>7,362,016</u>	1.07583	0.92952
TOTALS	8,008,468	568,736	8,577,204		

ESTIMATED VALUES AT GENERATION

LOSS FACTOR AT VOLTAGE LEVEL	MW	MWH
BULK LINES	0.00	0
TRANS SUBS	0.00	0
TRANS LINES	0.00	0
SUBTRANS SUBS	0.00	0
SUBTRANS LINES	30.39	248,918
PRIM SUBS	51.20	323,679
PRIM LINES	95.54	642,591
SECONDARY	<u>1,658.58</u>	<u>7,362,016</u>
SUBTOTAL	1,835.71	8,577,204
ACTUAL ENERGY	1,844.70	8,583,034
MISMATCH	(8.99)	(5,830)
% MISMATCH	-0.49%	-0.07%

DEVELOPMENT of LOSS FACTORS

EXHIBIT 7

ADJUSTED
DEMAND

LOSS FACTOR LEVEL	CUSTOMER SALES MW a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MW @ GEN d	CUM PEAK EXPANSION FACTORS e	f=1/e
BULK LINES	0.0	0.0	0.0	0.0	0.00000	0.00000
TRANS SUBS	0.0	0.0	0.0	0.0	0.00000	0.00000
TRANS LINES	0.0	0.0	0.0	0.0	0.00000	0.00000
SUBTRANS SUBS	0.0	0.0	0.0	0.0	0.00000	0.00000
TOTAL TRANS	29.5	0.0	0.9	30.4	1.03000	0.97087
PRIM SUBS	49.4	0.0	1.8	51.2	1.03724	0.96410
PRIM LINES	90.7	0.0	5.1	95.8	1.05618	0.94681
SECONDARY	<u>1,543.1</u>	<u>0.0</u>	124.2	<u>1,667.3</u>	1.08050	0.92550
TOTALS	1,712.7	0.0	132.0	1,844.7		

DEVELOPMENT of LOSS FACTORS

ADJUSTED
ENERGY

LOSS FACTOR LEVEL	CUSTOMER SALES MWH a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MWH @ GEN d	CUM ANNUAL EXPANSION FACTORS e	f=1/e
BULK LINES	0	0	0	0	0.00000	0.00000
TRANS SUBS	0	0	0	0	0.00000	0.00000
TRANS LINES	0	0	0	0	0.00000	0.00000
SUBTRANS SUBS	0	0	0	0	0.00000	0.00000
TOTAL TRANS	241,668	0	7,250	248,918	1.03000	0.97087
PRIM SUBS	311,633	0	12,092	323,725	1.03880	0.96265
PRIM LINES	612,042	0	30,761	642,803	1.05026	0.95215
SECONDARY	<u>6,843,125</u>	<u>0</u>	524,463	<u>7,367,588</u>	1.07664	0.92881
TOTALS	8,008,468	0	574,566	8,583,034		

ESTIMATED VALUES AT GENERATION

LOSS FACTOR AT
VOLTAGE LEVEL

MW

MWH

BULK LINES	0.00	0
TRANS SUBS	0.00	0
TRANS LINES	0.00	0
SUBTRANS SUBS	0.00	0
SUBTRANS LINES	30.39	248,918
PRIM SUBS	51.24	323,725
PRIM LINES	95.80	642,803
SECONDARY	1,667.28	7,367,588
	1,844.70	8,583,034
ACTUAL ENERGY	1,844.70	8,583,034
MISMATCH	0.00	0
% MISMATCH	0.00%	0.00%

Adjusted Losses and Loss Factors by Facility

EXHIBIT 8

Unadjusted Losses by Segment

	MW	Unadjusted	MWH	Unadjusted
Service Drop Losses	5.19	5.17	18,254	18,244
Secondary Losses	4.02	4.01	7,528	7,524
Line Transformer Losses	22.36	22.28	143,111	143,036
Primary Line Losses	27.08	26.98	82,656	82,613
Distribution Substation Losses	10.93	10.89	67,363	67,327
<u>Transmission System Losses</u>	<u>53.73</u>	<u>53.73</u>	<u>249,991</u>	<u>249,991</u>
Total	123.31	123.04	568,903	568,736

Mismatch Allocation by Segment

	MW	MWH
Service Drop Losses	-0.67	-334
Secondary Losses	-0.52	-138
Line Transformer Losses	-2.89	-2,616
Primary Line Losses	-3.50	-1,511
Distribution Substation Losses	-1.41	-1,232
<u>Transmission System Losses</u>	<u>0.00</u>	<u>0</u>
Total	-8.99	-5,830

Adjusted Losses by Segment

	MW	% of Total	MWH	% of Total
Service Drop Losses	5.84	4.4%	18,578	3.2%
Secondary Losses	4.53	3.4%	7,662	1.3%
Line Transformer Losses	25.17	19.1%	145,652	25.3%
Primary Line Losses	30.48	23.1%	84,124	14.6%
Distribution Substation Losses	12.30	9.3%	68,559	11.9%
<u>Transmission System Losses</u>	<u>53.73</u>	<u>40.7%</u>	<u>249,991</u>	<u>43.5%</u>
Total	132.04	100.0%	574,566	100.0%

Loss Factors by Segment

	MW	MWH	
Retail Sales from Service Drops	1,543.064	6,843,125	
<u>Adjusted Service Drop Losses</u>	<u>5.836</u>	<u>18,578</u>	
Input to Service Drops	1,548.899	6,861,703	
Service Drop Loss Factor	1.00378	1.00271	
Output from Secondary	1,548.899	6,861,703	
<u>Adjusted Secondary Losses</u>	<u>4.529</u>	<u>7,662</u>	
Input to Secondary	1,553.429	6,869,365	
Secondary Conductor Loss Factor	1.00292	1.00112	
Output from Line Transformers	1,553.429	6,869,365	
<u>Adjusted Line Transformer Losses</u>	<u>25.169</u>	<u>145,652</u>	
Input to Line Transformers	1,578.598	7,015,017	
Line Transformer Loss Factor	1.01620	1.02120	
Retail Sales from Primary	84.000	583,501	
Req. Whls Sales from Primary	6.700	28,541	
<u>Input to Line Transformers</u>	<u>1,578.598</u>	<u>7,015,017</u>	
Output from Primary Lines	1,669.298	7,627,059	
<u>Adjusted Primary Line Losses</u>	<u>30.476</u>	<u>84,124</u>	
Input to Primary Lines	1,699.773	7,711,183	
Primary Line Loss Factor	1.01826	1.01103	
Output PI from Distribution Substations	1,699.773	7,711,183	
Req. Whls Sales from Substations	0.000	0	
Retail Sales from Substations	49.400	311,633	
Total Output from Distribution Substations	1,749.173	8,022,816	
<u>Adjusted Distribution Substation Losses</u>	<u>12.298</u>	<u>68,559</u>	
Input to Distribution Substations	1,761.471	8,091,375	
Distribution Substation Loss Factor	1.00703	1.00855	
Retail Sales at from SubTransmission	29.500	241,668	
Req. Whls Sales from SubTransmission	0.000	0	
Non-Req. Whls Sales from SubTransmission	0.000	0	
Losses	0.000	0	4678
<u>Input to Distribution Substations</u>	<u>1,761.471</u>	<u>8,091,375</u>	
Output from SubTransmission	1,790.971	8,333,043	1,844.700
<u>SubTransmission System Losses</u>	<u>53.729</u>	<u>249,991</u>	53.729
Input to Transmission	1,844.700	8,583,034	53.729
TotTransmission System Loss Factor	1.03000	1.03000	53.729

DEMAND MW

SUMMARY OF LOSSES AND LOSS FACTORS BY DELIVERY VOLTAGE

EXHIBIT 9
PAGE 1 of 2

	SERVICE LEVEL	SALES MW	LOSSES	SECONDARY	PRIMARY	SUBSTATION	SUBTRANS	TRANSMISSION
1	SERVICES							
2	SALES	1,543.1		1,543.1				
3	LOSSES		5.8	5.8				
4	INPUT			1,548.9				
5	EXPANSION FACTOR	1.00378						
6	SECONDARY							
7	SALES							
8	LOSSES		4.5	4.5				
9	INPUT			1,553.4				
10	EXPANSION FACTOR	1.00292						
11	LINE TRANSFORMER							
12	SALES							
13	LOSSES		25.2	25.2				
14	INPUT			1,578.6				
15	EXPANSION FACTOR	1.01620						
16	PRIMARY							
17	SECONDARY			1,578.6				
18	SALES	84.0			84.0			
19	LOSSES		30.5	28.8	1.5			
20	INPUT			1,607.4	85.5			
21	EXPANSION FACTOR	1.01826						
22	SUBSTATION							
23	PRIMARY			1,607.4	85.5			
24	SALES	49.4				49.4		
25	LOSSES		12.3	11.3	0.6	0.3		
26	INPUT			1,618.7	86.1	49.7		
27	EXPANSION FACTOR	1.00703						
28	SUB-TRANSMISSION							
29	DISTRIBUTION SUBS							
30	SALES							
31	LOSSES							
32	INPUT							
33	EXPANSION FACTOR							
34	TRANSMISSION							
35	SUBTRANSMISSION							
36	DISTRIBUTION SUBS			1,618.7	86.1	49.7		
37	SALES	29.5						29.5
38	LOSSES		53.5	48.6	2.6	1.5		0.9
39	INPUT			1,667.3	88.7	51.2		30.4
40	EXPANSION FACTOR	1.03000						
41	TOTALS		131.8	124.2	4.7	1.8		0.9
42	% OF TOTAL		100%	94.22%	3.58%	1.40%		0.67%
43	SALES	1,706.0		1,543.1	84.0	49.4		29.5
44	% OF TOTAL	100.00%		90.45%	4.92%	2.90%		1.73%
45	INPUT	1,837.6		1,667.3	88.7	51.2		30.4
46	CUMMULATIVE EXPANSION LOSS FACTORS (from meter to system input)			1.08050	1.05618	1.03724		1.03000

ENERGY MWH

SUMMARY OF LOSSES AND LOSS FACTORS BY DELIVERY VOLTAGE

EXHIBIT 9
PAGE 2 of 2

SERVICE LEVEL	SALES	LOSSES	SECONDARY	PRIMARY	SUBSTATION	SUBTRANS	TRANSMISSION
1 SERVICES							
2 SALES	6,843,125		6,843,125				
3 LOSSES		18,578	18,578				
4 INPUT			6,861,703				
5 EXPANSION FACTOR	1.00271						
6 SECONDARY							
7 SALES							
8 LOSSES		7,662	7,662				
9 INPUT			6,869,365				
10 EXPANSION FACTOR	1.00112						
11 LINE TRANSFORMER							
12 SALES							
13 LOSSES		145,652	145,652				
14 INPUT			7,015,017				
15 EXPANSION FACTOR	1.02120						
16 PRIMARY							
17 SECONDARY			7,015,017				
18 SALES	583,501.000			583,501			
19 LOSSES		84,124	77,373	6,436			
20 INPUT			7,092,390	589,937			
21 EXPANSION FACTOR	1.01103						
22 SUBSTATION							
23 PRIMARY			7,092,390	589,937			
24 SALES	311,633				311,633		
25 LOSSES		68,559	60,608	5,041	2,663		
26 INPUT			7,152,998	594,978	314,296		
27 EXPANSION FACTOR	1.00855						
28 SUB-TRANSMISSION							
29 DISTRIBUTION SUBS							
30 SALES							
31 LOSSES							
32 INPUT							
33 EXPANSION FACTOR							
34 TRANSMISSION							
35 SUBTRANSMISSION							
36 DISTRIBUTION SUBS			7,152,998	594,978	314,296		
37 SALES	241,668					241,668	
38 LOSSES		249,118	214,590	17,849	9,429	7,250	
39 INPUT			7,367,588	612,827	323,725	248,918	
40 EXPANSION FACTOR	1.03000						
41 TOTALS							
42 LOSSES		573,693	524,463	29,326	12,092	7,250	
42 % OF TOTAL		100%	91.42%	5.11%	2.11%	1.26%	
43 SALES	7,979,927		6,843,125	583,501	311,633	241,668	
44 % OF TOTAL	100.00%		85.75%	7.31%	3.91%	3.03%	
45 INPUT	8,553,059		7,367,588	612,827	323,725	248,918	
46 CUMMULATIVE EXPANSION LOSS FACTORS			1.07664	1.05026	1.03880	1.03000	
			(from meter to system input)				

Appendix D

Discussion of Hoebel Coefficient



Energy

2020 Analysis of System Losses

COMMENTS ON THE HOEBEL COEFFICIENT

The Hoebel coefficient represents an established industry standard relationship between peak losses and average losses and is used in a loss study to estimate energy losses from peak demand losses. H. F. Hoebel described this relationship in his article, "Cost of Electric Distribution Losses," Electric Light and Power, March 15, 1959. A copy of this article is attached.

Within any loss evaluation study, peak demand losses can readily be calculated given equipment resistance and approximate loading. Energy losses, however, are much more difficult to determine given their time-varying nature. This difficulty can be reduced by the use of an equation which relates peak load losses (demand) to average losses (energy). Once the relationship between peak and average losses is known, average losses can be estimated from the known peak load losses.

Within the electric utility industry, the relationship between peak and average losses is known as the loss factor. For definitional purposes, loss factor is the ratio of the average power loss to the peak load power loss, during a specified period of time. This relationship is expressed mathematically as follows:

$$\underline{(1) F_{LS} \cong A_{LS} \div P_{LS}} \qquad \text{where: } \begin{array}{l} F_{LS} = \text{Loss Factor} \\ A_{LS} = \text{Average Losses} \\ P_{LS} = \text{Peak Losses} \end{array}$$

The loss factor provides an estimate of the degree to which the load loss is maintained throughout the period in which the loss is being considered. In other words, loss factor is the ratio of the actual kWh losses incurred to the kWh losses which would have occurred if full load had continued throughout the period under study.

Examining the loss factor expression in light of a similar expression for load factor indicates a high degree of similarity. The mathematical expression for load factor is as follows:

$$\underline{(2) F_{LD} \cong A_{LD} \div P_{LD}} \qquad \text{where: } \begin{array}{l} F_{LD} = \text{Load Factor} \\ A_{LD} = \text{Average Load} \\ P_{LD} = \text{Peak Load} \end{array}$$

This load factor result provides an estimate of the degree to which the load loss is maintained throughout the period in which the load is being considered. Because of the similarities in definition, the loss factor is sometimes called the "load factor of losses." While the definitions are similar, a strict equating of the two factors cannot be made. There does exist, however, a relationship between these two factors which is dependent upon the shape of the load duration curve. Since resistive losses vary as the square of the load, it can be shown mathematically that the loss factor can vary between the extreme limits of load factor and load factor squared. The

Energy 2020 Analysis of System Losses

relationship between load factor and loss factor has become an industry standard and is as follows:

$$(3) \ F_{LS} \cong H * F_{LD}^2 + (1-H) * F_{LD}$$

where: F_{LS} = Loss Factor
 F_{LD} = Load Factor
 H = Hoebel Coefficient

As noted in the attached article, the suggested value for H (the Hoebel coefficient) is 0.7. The exact value of H will vary as a function of the shape of the utility's load duration curve. In recent years, values of H have been computed directly for a number of utilities based on EEI load data. It appears on this basis, the suggested value of 0.7 should be considered a lower bound and that values approaching unity may be considered a reasonable upper bound. Based on experience, values of H have ranged from approximately 0.85 to 0.95. The standard default value of 0.9 is generally used.

Inserting the Hoebel coefficient estimate gives the following loss factor relationship using Equation (3):

$$(4) \ F_{LS} \cong 0.90 * F_{LD}^2 + 0.10 * F_{LD}$$

Once the Hoebel constant has been estimated and the load factor and peak losses associated with a piece of equipment have been estimated, one can calculate the average, or energy losses as follows:

$$(5) \ A_{LS} \cong P_{LS} * [H * F_{LD}^2 + (1-H) * F_{LD}]$$

where: A_{LS} = Average Losses
 P_{LS} = Peak Losses
 H = Hoebel Coefficient
 F_{LD} = Load Factor

Loss studies use this equation to calculate energy losses at each major voltage level in the analysis.