

White River's Estimated Costs to Serve -- DR 6.1

REQ: In White River's Response to Staff Data Request No. 6, it indicated that its current, most probabilistic plan was to extend its existing underground circuit north to the Property. Please provide an itemized estimate detailing the anticipated charges associated with this proposed extension, and include the intended amount to be the responsibility of Southwest Storage. If White River's plans have changed in regard to extending service to the Property, then please provide that information along with similar detail.

Resp. White River estimates this 700-foot, 3-phase extension at ~\$22,500 (labor and materials). Standard underground materials will be used, e.g., conduit, underground cable, junction cabinet, etc. This cost will be covered at 100% by White River. It has been communicated with Southway Storage that they are responsible for: 1) Clearing vegetation on the 10-foot right-of-way. Easement for this has already been obtained; 2) Providing a 40-inch-deep trench for White River's underground cable. It is understood that Southway Storage will complete this work during construction of their facilities given the heavy equipment will be on site for their build at that time.