

**BEFORE THE PUBLIC SERVICE COMMISSION  
OF THE STATE OF MISSOURI**

In the Matter of the Application of Confluence                    )  
Rivers Utility Operating Company, Inc., for                    )  
Authority to Acquire Certain Sewer Assets in an                ) File No. SM-2024-0130  
Area of Warren County, Missouri (North Oak Sewer         )  
District, Inc.)    )

**NOTICE OF COMPLETION**

**COMES NOW** Confluence Rivers Utility Operating Company, Inc., (“Confluence Rivers”) and for its *Notice of Completion* states as follows to the Missouri Public Service Commission ("Commission"):

1. On January 31, 2024 (effective February 10, 2024), the Commission issued its *Order Approving Acquisition of Assets and Granting Certificate of Convenience and Necessity* (“Order”) in this case. The Order approved the acquisition of, and grants a Certificate of Convenience and Necessity for, the sewer assets of North Oak Sewer District, Inc. (“North Oak”). On August 1, 2024, Confluence Rivers closed on the sewer utility assets of North Oak.

2. Among other things, the Order requires Confluence Rivers ‘to complete cleaning, vegetation removal, solid waste disposal, and address other deferred maintenance within 60 days of closing.’”


3. Confluence Rivers hereby provides notice to the Commission that it has completed the above tasks as of the dates reflected below:

	<b>Action</b>	<b>Completion Date</b>
<b>Plant Clean-Up</b>	Trash has been removed from the site.	9/20/24
	The plant walls were power washed while the water levels were low.	

	The gravel around the site has been regraded to direct water away from the plant, and the gravel around the plant itself has been lowered as well.	
<b>Removed Vegetation and Overgrowth</b>	Vegetation around the plant has been trimmed or removed.	9/19/24
	Vegetation within the plant has been cleared.	
<b>Solid Waste Disposal</b>	Both the digester and aeration chamber were pumped out to remove accumulated sludge that had settled at the bottom of the plant, resulting in approximately 40 truckloads being removed.	9/18/24
<b>Deferred Maintenance</b>	A new blower and motor have been installed, along with a new duplex panel that includes all the necessary components.	9/26/24
	The handrails have been painted.	
	Air drops and diffusers were inspected to verify their performance and replaced as necessary.	
	The area around the outfall weir has been cleaned, along with the ditchline that flows to the creek.	

**WHEREFORE**, Confluence Rivers respectfully submits this *Notice of Completion* to the Commission.

Respectfully submitted,



Dean L. Cooper, Mo. Bar #36592

**BRYDON, SWEARENGEN & ENGLAND P.C.**

312 East Capitol Avenue

P.O. Box 456

Jefferson City, MO 65102-0456

Telephone: (573) 635-7166

[dcooper@brydonlaw.com](mailto:dcooper@brydonlaw.com)

David L. Woodsmall, Mo. Bar #40747

**CENTRAL STATES WATER RESOURCES**

1630 Des Peres Rd., Suite 140


Des Peres, MO 63131

[dwoodsmall@cswrgroup.com](mailto:dwoodsmall@cswrgroup.com)

**ATTORNEYS FOR CONFLUENCE RIVERS  
UTILITY OPERATING COMPANY, INC.**

**CERTIFICATE OF SERVICE**

I do hereby certify that a true and correct copy of the foregoing document has been sent by electronic mail this 27<sup>th</sup> day of September 2024 to all counsel of record.

  
\_\_\_\_\_