

by **September 9, 2019**, stating what actions are being taken to address the Referral Notice of Violation #s 1 through 5 and prevent reoccurrences in the future. The written response shall be submitted to the Water Pollution Control Branch (WPCB) Compliance & Enforcement Section by mail at the Missouri Department of Natural Resources, Water Protection Program, ATTN: WPCB Compliance and Enforcement Section, P.O. Box 176, Jefferson City, Missouri 65102. Copy Mr. Oscar Vazquez on the written response by mail at the Missouri Department of Natural Resources, 7545 S. Lindbergh Blvd Suite 210, Saint Louis, Missouri 63125.

Recommendations

1. **Sludge Management Plant:** The City should prioritize the development and submission to the Department for review of a sludge management plan that details removal and disposal plans when sludge is to be removed from the lagoon, to ensure that an approved plan is in place in time.
2. **Three-Cell Aerated Lagoon:** More frequent removal and/or control of floating plants in the lagoon is recommended.
3. **Aeration System:** At the time of the inspection, excessive bubbling, indicative of air leaks, was observed in some areas in the lagoon. Timely checks and repairs of the air distribution lines is recommended.
4. **Sampling Procedures:** It is recommended that the facility develops a cheat sheet that lists the parameters sampled and monitored under the permit along with the pertinent test methods, maximum hold times, and any preservatives to be used.

Additional Comments/Conclusion

1. Continue to submit monthly, quarterly, and annual reports through the Department's eDMR system by established reporting deadlines.
2. Register for the Department's MoGEM system and report SSO and bypass events online. You can visit our MoGEM splash page for more information: <https://dnr.mo.gov/mogem/>.
3. Develop and submit a sludge management plan for approval as per the provisions under the permit's fact sheet.


Signatures

SUBMITTED BY:



Oscar Vazquez, P.E.
Environmental Engineer
St. Louis Regional Office

REVIEWED BY:



Eric Gilstrap, P.E.
Engineering and Compliance Assistance Unit Chief
St. Louis Regional Office

EJG/OVM/deb

Attachments

Attachment #1 – DMR Data Summary

Attachment #2 – Aerial & Other Maps


Attachment #3 – Photos #1 through #24

Attachment #4 – ESP Report and Sample Results


Attachment #5 – Graphs of Reported Flow vs. Percent Removal

Attachment #6 - Department Annual Inflow and Infiltration Report form [780-2690 (02-17)]


Monthly Average Flow




Daily Max Flow




Monthly Average BOD




Weekly Average BOD




Monthly Average TSS




Weekly Average TSS




E. Coli 30 Day Geometric Mean




E. Coli 7 Day Geometric Mean




Monthly Average Ammonia Total (as N)




Daily Max Ammonia Total (as N)





Monthly Average Oil & Grease




Daily Max Oil & Grease









1 - Eureka WWTF

2 - Outfall #004

12-digit-Watershed-Boundaries

DISCLAIMER: Although this map has been compiled by the Missouri Department of Natural Resources, no warranty, expressed or implied, is made by the department as to the data and related materials. The act of distribution shall not constitute any such warranty, and no responsibility is assumed by the department in the use of these data or related materials.



Map Key Number	WWTF Building/Area
1	Influent Lift Station Area (Photo #s 1-4)
2	Fine Screen Building (Photo #s 5-6)
3	Aerated Lagoon (Photo #s 7-9)
4	Recirculation Pump (Photo # 10)
5	Blowers Building (Photo #s 11-14)
6	Effluent Structure (Photo #s 15-16)
7	UV Disinfection System Building (Photo #s 17-21)
8	Effluent Lift Station Pumps (Photo # 22)
9	WWTF Office/Lab Building (Photo #s 23-24)

DISCLAIMER: The Department makes no warranty, expressed or implied as to the information shown in this figure. The act or distribution shall not constitute any such warranty, and no responsibility is assumed by the Department in the use of this information.




Photograph: # 1.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Influent Lift Station
Description: Wet well and pump control panel.




Photograph: # 2.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Influent Lift Station
Description: Wet well with four pump discharge lines.



Photograph: # 3.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Influent Lift Station
Description: LS control panel features include pump run indicator lights, hand-off-auto selector switches, and elapse time meters.



Photograph: # 4.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Influent Lift Station
Description: Rain gauge attached to LS control panel is integrated into a SCADA system.



Photograph: # 5.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Fine Screen Building
Description: Fine Screen.



Photograph: # 6.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Fine Screen Building
Description: Compacted and dewatered screenings are dumped into 300-pound trash containers.



Photograph: # 7.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Three-Cell Aerated Lagoon
Description: Looking northeast from the southern shore of lagoon cell #1, near the bar screen building.



Photograph: # 8.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Three-Cell Aerated Lagoon
Description: Looking south from the northern shore of lagoon. A line of Aquamats® is shown here.



Photograph: # 9.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Three-Cell Aerated Lagoon
Description: Looking north from the southern shore of lagoon cell #2. The photo shows the valve operated to control the discharge of return wastewater into cell #2.



Photograph: # 10.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Recirculation Pump Shed
Description: The recirculation pump shown here is operated manually to recirculate approximately 6.5 MGD of wastewater from lagoon cell #3 back to lagoon cell #s 1 and 2.




Photograph: # 11.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Blowers Building
Description: Old aeration pump used as backup.



Photograph: # 12.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Blowers Building
Description: Aeration pump panels.




Photograph: # 13.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Blowers Building
Description: Turbo blowers.



Photograph: # 14.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Blowers Building
Description: Turbo blower ducts system.




Photograph: # 15.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Effluent Structure
Description: The three valves are manually operated to draw and control lagoon cell #3 outflows at three different depths. To some extent, the effluent structure design allows the operator to control the lagoon effluent blend.



Photograph: # 16.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Effluent Structure
Description: The effluent blend overflows and is conveyed by gravity to the UV disinfection unit.



Photograph: # 17.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: UV Disinfection System Building
Description: Looking downstream: Parshall channel with mounted ultrasonic flow meter.



Photograph: # 18.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: UV Disinfection System Building
Description: UV Disinfection Unit Control Panels are raised to the 100-year floodplain.



Photograph: # 19.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: UV Disinfection System Building
Description: Looking upstream, after the Parshall channel, it can be observed that one of the UV disinfection banks and some modules were out of service at the time of inspection.



Photograph: # 20.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: UV Disinfection System Building
Description: Out-of-service bulb module is shown in the photo.




Photograph: # 21.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: UV Disinfection System Building
Description: Flow meter controller.



Photograph: # 22.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: Effluent Lift Station (LS)
Description: In the foreground, the effluent LS and LS control panel. In the background, effluent check valves vault.



Photograph: # 23.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit

Entity: Eureka WWTF
Permit: MO-0039569
Location: WWTF Office/Lab Building
Description: Backflow preventer.



Photograph: # 24.
Taken By: Oscar Vazquez
Date Taken: July 29, 2019
Program: ECA Unit


Entity: Eureka WWTF
Permit: MO-0039569
Location: WWTF Office/Lab Building
Description: Backflow preventer.

Attachment #4 – ESP Report and Sample Results
 Eureka WWTF
 August 20, 2019
 Page 1 of 1

DNR ESP Report dated July 3, 2017 (Collect Date June 14, 2017)					
Parameter	Units	2017 ESP Report Results	Permitted Interim Effluent Limitations (Daily Maximum)	Permitted Interim Effluent Limitations (Weekly Average)	Permitted Interim Effluent Limitations (Monthly Average)
BOD	mg/L	3.96*	--	45	30
TSS	mg/L	<5*	--	45	30
E. Coli	mpn/100 ml	103.9	--	630	126
Oil & Grease	mg/L	<2	15	--	10
Field pH	SU	7.72**	--	--	--
Field Temperature	°C	27.8	--	--	--

*Sample collected before UV disinfection

**Permit requires a minimum pH of 6 and a maximum pH of 9



Missouri Department of Natural Resources
 Environmental Services Program
 PO Box 176 Jefferson City MO 65102-0176

RESULTS OF SAMPLE ANALYSES

LDPR/Job Code: **FECMP** Program, Contact: **WPC Chelsey Bodenstab**

Chelsey Bodenstab
 Water Pollution Control Branch

Order ID:
 170615001



Report Date:
 7/3/2017

Sample: AC99652		Facility ID: MO0039659	Customer #: 172004	
		Site: Eureka Wastewater Treatment Facility	County: St. Louis	
Collect Date: 6/14/2017 9:08:00 AM	Collector: CHRIS RADCLIFFE	Affiliation: ESP		
Comments: Outfall #004. Automated sampler collected ~ 22 hrs of 24-hr composite. Collected before UV disinfection.				
Test	Parameter/Method	Result	Units	Qualifier(s)
Biochemical Oxygen Demand	Biochemical Oxygen Demand/SM 5210-B	3.96	mg/L	
Total Suspended Solids (TSS) / NFR Total Suspended Solids (TSS) / NFR/SM 2540-D		<5	mg/L	06, ND
Sample: AC99653		Facility ID: MO0039659	Customer #: 172005	
		Site: Eureka Wastewater Treatment Facility	County: St. Louis	
Collect Date: 6/14/2017 11:50:00 AM	Collector: CHRIS RADCLIFFE	Affiliation: ESP		
Comments: Grab: Outfall #004.				
Test	Parameter/Method	Result	Units	Qualifier(s)
E. coli - IDEXX	E. coli - IDEXX/SM 9223B	103.9	mpn/100ml	
Field pH	Field pH/EPA 150.1	7.72	pH Units	
Field Temperature	Field Temperature/EPA 170.1	27.8 C		
Oil And Grease	Oil And Grease/1664B	<2	mg/L	ND

The analysis of this sample was performed in accordance with procedures approved or recognized by the U. S. Environmental Protection Agency.

	Data Qualifier(s)		
	06	Estimated value, QC data outside limits	ND Not detected at reported value


Kevin Thoenen,
 Laboratory Manager
 Environmental Services Program
 Division of Environmental Quality

Monitoring Period	BOD, 5-day, 20 deg. C			Total Suspended Solids (TSS)		
	Influent (mg/L)	Effluent (mg/L)	Percent Removal (%)	Influent (mg/L)	Effluent (mg/L)	Percent Removal (%)
5/31/2019	--	21.8	84.7	--	22	79.7
4/30/2019	--	24	84.3	--	13.25	87.0
3/31/2019	--	13.75	87.0	--	7.5	88.0
2/28/2019	--	16.25	84.7	--	11	90.9
1/31/2019	--	23.6	84.4	--	17.4	7.9
12/31/2018	--	23.5	81.0	--	11.75	91.0
11/30/2018	--	21.5	85.0	--	11	87.0
10/31/2018	--	23.4	83.5	--	20.8	87.4
9/30/2018	--	26.5	81.7	--	13.5	91.8
8/31/2018	--	22	65.0	--	22	80.0
7/31/2018	--	15.75	82.5	--	12	91.7
6/30/2018	--	18.75	83.0	--	13.5	92.5
5/31/2018	128.4	23.8	81.5	116.6	19.6	83.2
4/30/2018	132.5	18	86.4	161	6.5	96.0
3/31/2018	106	13	87.7	47	7.75	83.5
2/28/2018	79.25	15.25	80.8	246.5	9.75	96.0
1/31/2018	110.4	13.4	87.9	185.8	8.8	95.3
12/31/2017	163.5	13.5	91.7	92.75	11.75	87.3
11/30/2017	126.46	11.8	90.7	116.72	14.4	87.7
10/31/2017	140.5	10	92.9	62.25	10.75	82.7
9/30/2017	98.5	12.75	87.1	58.25	12.75	78.1
8/31/2017	89.8	11.6	87.1	67.8	11.6	82.9
7/31/2017	109.5	9	91.8	108	11	89.8
6/30/2017	101.75	9.25	90.9	75.25	8	89.4
5/31/2017	77	13.6	82.3	84.2	8	90.5
4/30/2017	106.25	5.25	95.1	103.75	5.25	94.9
3/31/2017	136.25	13	90.5	65.5	8.5	87.0
2/28/2017	156.2	15	90.4	136.2	11.6	91.5
1/31/2017	98.75	18.25	81.5	77.25	11	85.8
12/31/2016	136.25	13	90.5	65.5	8.5	87.0
11/30/2016	121	15.2	87.4	100.8	10.6	89.5
10/31/2016	113.5	9.75	91.4	139.5	9.75	93.0


In red, the values imported directly from the eDMR system

In bold/bold, removal efficiencies below the required 85%


Daily Max Flow vs BOD % Removal




BOD % Removal




Daily Max Flow vs TSS % Removal



TSS % Removal





MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
ANNUAL INFLOW AND INFILTRATION REPORT

This report covers the period of:
January 1, 20__ to December 31, 20__
Page 1 of 2

GENERAL INFORMATION

FACILITY NAME		
PERMIT NUMBER	COUNTY	
MILES OF COLLECTION SYSTEM (INCLUDING FORCEMAINS)	PEAK EFFLUENT FLOW RATE (MGD)	AVERAGE EFFLUENT FLOW RATE (MGD)

MANHOLE OBSERVATION

Number of manholes observed:

Dates observed:

RESULTS – MANHOLES REPLACED

Number of manholes replaced:

Types of manholes replaced:

Dates of replacement:

RESULTS – MANHOLES REHABBED

Number of number of manholes rehabbed:

Types of manholes rehabbed:

Dates of rehabilitation:

SMOKE TESTING

Linear feet of lines tested:

Dates observed:

SMOKE TESTING RESULTS – LINES CLEANED

Linear feet of lines cleaned:

Date and method used to clean lines (jet, pig, auger):



MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
ANNUAL INFLOW AND INFILTRATION REPORT

This report covers the period of:
January 1, 20____ to December 31, 20____
Page 2 of 2

SMOKE TESTING RESULTS – LINES REPLACED

Linear feet of lines replaced:

Date, type of line replaced, and type of new line:

SMOKE TESTING RESULTS – LINES REHABBED

Linear feet of lines rehabbed:

Date, type of line rehabbed, and rehab material:

CCTV (CLOSED-CIRCUIT TELEVISION)

Linear feet viewed:

Dated observed:

LAMPHOLE OBSERVATION

Number observed:

Dates observed:

RESULTS – LAMPHOLES REPLACED

Number replaced:

Dates replaced:

SANITARY SEWER OVERFLOWS (SSOs)

Number of dry weather SSOs:

Number of wet weather SSOs:

BASEMENT/BUILDING BACKUPS

Number of dry weather basement/building backups:

Number of wet weather basement/building backups:

Mail completed copy to: MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
OPERATING PERMITS SECTION
P.O. BOX 176
JEFFERSON CITY, MO 65102-0176